

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/May/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	65.615	130.269	1) Gujrat	7.245	13.502
2) Hydro	23.435	31.389	2) Madhya Pradesh	13.011	24.642
3) Gas	6.739	13.456	3) Chattisgarh	8.230	16.530
Total MSPGCL	95.789	175.114	4) Maharashtra	140.011	284.559
B) 1) APMIL	68.327	136.225	5) Goa (Amona)	0.000	0.000
2) JSWEL	15.874	32.107	Total	168.497	339.233
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.339	45.516
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	24.694	49.030
5) WPCL	2.683	5.383	c) MSEDCL Bilateral *	58.739	122.987
6) Other IPP	7.041	14.132	Include PX	35.433	75.538
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.339	45.516
C) 1) TPCL Thermal	6.403	12.892	Include PX	16.953	32.676
2) TPCL Hydro	4.743	9.091	Standby	0.000	0.000
3) TPCL Gas	4.381	8.758	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.982	17.948	1) MSEDCL	360.789	712.548
D) STATE			2) Mumbai Discoms	49.201	97.717
1) Thermal	174.925	348.956	TOTAL STATE	409.990	810.265
(A1+C1+C4+(B1-B6))					
2) Hydro	28.178	40.480			
(A2+C2)					
3) Gas	11.120	22.214			
(A3+B7+C3)					
4) Wind	19.744	44.523			
6) SOLAR	7.528	14.861			
TOTAL STATE	241.495	471.034			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	2312	2633	2852	2909
MSPGCL Hydro	174	1494	1164	997
MSPGCL Gas	278	267	283	276
MSPGCL Total Generation	2764	4394	4299	4182
Central Sector Receipt	8357	8235	5650	6339
WIND	804	668	1180	876
CPP / IPP Thermal	3516	3366	4166	4029
CPP / IPP Gas	0	0	0	0
SOLAR	1034	672	0	0
Exchange with Mumbai	-1086	-1154	-986	-948
MSEDCL DEMAND MET	15389	16181	14309	14478
Load Shedding	0	0	0	0
MSEDCL DEMAND	15389	16181	14309	14478
TPCL GENERATION	524	529	906	778
AEML GENERATION	375	374	373	375
MUMBAI DEMAND	1985	2057	2265	2101
STATE DEMAND MET	17374	18238	16574	16579
STATE DEMAND	17374	18238	16574	16579
Frequency (Hz)	50.02	49.99	50.01	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 08:04 Hrs	49.83 Hz at 13:42 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 02/May/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	0.00	0.00	0	0
Total	0.00	0.00		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	10.74	20.68	475	360
Unit 7	0.00	0.00	0	0
Unit 8	11.24	22.55	485	370
Unit 9	10.32	20.72	460	360
Total	32.29	63.95		
Paras				
Unit 3	5.37	10.18	240	199
Unit 4	4.45	10.47	257	152
Total	9.82	20.65		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	4.23	8.38	185	160
Unit 3	4.39	8.23	195	160
Unit 4	4.31	8.49	190	160
Unit 5	10.57	20.57	500	365
Total	23.50	45.67		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.74	13.46	298	267
Total	6.74	13.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	0.38	45	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.15	0.38		
Koyna				
Stage 1-2	5.02	8.59	550	40
Stage 4	12.19	12.42	1000	0
Stage 3	3.40	4.64	320	0
Total	20.60	25.65		
Hydro				
KDPH	0.82	1.63	34	34
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.32	0.53	80	0
RNGR+BHTSA	0.29	0.58	12	11
BHANDARDRA	0.47	0.94	36	12
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.94	2.07	47	35
GHATGHAR	0.00	0.00	0	0
Total	2.83	5.74		
Wind				
Total	19.74	44.52	0	0
Total	19.74	44.52		
CPP				
APML(Mus)	68.33	136.22	0	0
JSWEL(Mus)	15.87	32.11	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.68	5.38	0	0
Other(Mus)	7.04	14.13	0	0
Total	93.92	187.85		
SOLAR				
Total	7.53	14.86	0	0
Total	7.53	14.86		
Tata				
Trombay 5	6.40	12.89	268	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.80	5.60	117	116
Trombay 7B	1.58	3.15	66	65
Trombay 8	0.00	0.00	0	0
TATA Hydro	4.74	9.09	457	49
Total	15.53	30.74		
AEML				
DTPS U-1&2	8.98	17.95	376	372
Total	8.98	17.95		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	65.62	130.27	MSPGCL Total	95.79	175.11
			MSPGCL Thml+Gas	72.35	143.72	Koyna 1,2 & 4 Total	17.21	21.01
			MSPGCL Hydro	23.44	31.39	State Total	241.50	471.03

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 02/May/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2946	718	285	3949	1100	4185	0	0	6644	6567	-1163	14638	0	14638	2358	16996	50.02
2	2946	778	284	4008	1002	4177	0	0	6427	6589	-1048	14728	0	14728	2218	16946	49.99
3	2909	997	276	4182	876	4029	0	0	6109	6339	-948	14478	0	14478	2101	16579	50.00
4	2822	1384	297	4503	819	4069	0	0	6060	6206	-904	14693	0	14693	2006	16699	49.99
5	2839	1291	287	4417	894	4053	0	0	6307	6313	-884	14793	0	14793	1954	16747	50.01
6	2848	1240	279	4367	833	4083	0	0	7135	7237	-890	15630	0	15630	1980	17610	50.00
7	2859	1398	298	4555	675	4063	0	39	7810	7605	-847	16090	0	16090	1883	17973	50.02
8	2856	907	287	4050	557	4099	0	234	7599	7658	-901	15697	0	15697	1837	17534	50.00
9	2855	706	277	3838	415	4104	0	512	7333	7187	-1011	15045	0	15045	1883	16928	50.08
10	2838	454	291	3583	487	4069	0	732	7451	7289	-1056	15104	0	15104	1930	17034	50.02
11	2532	320	273	3125	736	3727	0	954	7844	7361	-1069	14834	0	14834	1961	16795	50.06
12	2312	174	278	2764	804	3516	0	1034	8332	8357	-1086	15389	0	15389	1985	17374	50.02
13	2405	243	267	2915	742	3636	0	997	8311	8498	-1099	15689	0	15689	1997	17686	49.98
14	2523	244	286	3053	583	3861	0	939	8489	8357	-1115	15678	0	15678	2016	17694	49.97
15	2609	985	267	3861	665	3357	0	786	8526	8361	-1158	15872	0	15872	2063	17935	49.99
16	2633	1494	267	4394	668	3366	0	672	8176	8235	-1154	16181	0	16181	2057	18238	49.99
17	2451	1629	278	4358	757	3397	0	413	7882	7759	-1089	15595	0	15595	1988	17583	49.98
18	2547	1653	269	4469	869	3404	0	178	6855	7113	-1019	15014	0	15014	1899	16913	50.03
19	2787	1207	291	4285	874	4007	0	38	5886	5927	-981	14150	0	14150	1865	16015	50.00
20	2789	1214	272	4275	787	4126	0	0	5688	5644	-1044	13788	0	13788	2029	15817	49.98
21	2780	1225	281	4286	1078	4136	0	0	5564	5521	-990	14031	0	14031	2170	16201	49.99
22	2852	1164	283	4299	1180	4166	0	0	5500	5650	-986	14309	0	14309	2265	16574	50.01
23	2837	1033	283	4153	1134	4128	0	0	6244	6187	-1078	14524	0	14524	2349	16873	50.02
24	2840	977	283	4100	1209	4167	0	0	6592	6537	-1174	14839	0	14839	2409	17248	50.04
MUs	65.61	23.43	6.74	95.79	19.74	93.92	0.00	7.53	168.76	168.50	-24.69	360.79	0.00	360.79	49.20	409.99	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/May/2020

Position as on 6.30 Hrs of 03/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00	03/05/2020	07.50	Zero Schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56	03/05/2020	13.58	Zero Schedule.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/May/2020

Position as on 6.30 Hrs of 03/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	22/04/2020	20.45		Continued.	Zero Schedule By MSEDCL	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Khaparkheda Unit 2	210	03/05/2020	08.04		Continued.	Zero schedule Given by MSEDCL.	
MSPGCL	Khaparkheda Unit 3	210	03/05/2020	09.34		Continued.	Zero schedule Given by MSEDCL.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/May/2020

Statement-VII

Position as on 6.30 Hrs of 03/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/04/2020	17.40		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58		Continued.	EO	To attend Hot Spot
Chandrapur - Parli	IntraState	19/04/2020	02.20		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21		Continued.	T	Distance Protection(Tower collapsed at Loc.No.59.60.61)
Babhaleshtar - Padghe-II	IntraState	20/04/2020	09.25		Continued.	PO	Quarterly Maintenance work & Relay Testing, for CVT replacement work (RFC at 21.22 Hrs).
Girwali - Lonikand 1	IntraState	20/04/2020	14.27	03/05/2020	15.48	HT	Controllin loading of Parli-Parli(PG D/C) Line.
Taptitanda Waluj	IntraState	22/04/2020	17.18		Continued.	T	Distance Protection (RFC at 14.08Hrs DT.24-4-20)
Jaigad-Karad Ckt-I	IntraState	28/04/2020	19.03	02/05/2020	09.11	HT	Over Voltage
Bus B @ Kharghar	IntraState	02/05/2020	10.06	02/05/2020	17.21	EO	400KV Talegaon feeder B Bus Y Phase PG Isolator replacement work
Jejuri- Koynastage-IV	IntraState	02/05/2020	11.26	02/05/2020	12.03	T	Distance Protection
Parly(MS)- Nanded ckt I	IntraState	02/05/2020	13.08	02/05/2020	17.46	T	Fault SOTF Air Lock Out
Chandrapur-II - Nanded ckt I	IntraState	02/05/2020	13.08	02/05/2020	17.46	T	Distance Protection
Karad - Jaigad - II	IntraState	02/05/2020	19.23		Continued.	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	02/05/2020	20.21	02/05/2020	21.45	PO	Outage by Powergrid
Girwali- Lonikand 2	IntraState	03/05/2020	17.48		Continued.	HT	Controlling loading of Parli Parli (PG) D/C.
Khadka-Aurangabad (Waluj)	IntraState	03/05/2020	18.09		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07		Continued.	HT	Over Voltage
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19		Continued.	PO	Attending Hot Spot
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	19/04/2020	11.55		Continued.	HT	Over Voltage
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	29/04/2020	18.38		Continued.	T	tripped on NDR (charge from HV side 29/Apr/2020 23.12).
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	02/05/2020	09.50	02/05/2020	18.06	PO	To avail outage on B Bus
400/220/33 Kv 600 MVA ICT 4 @Padghe	IntraState	03/05/2020	10.43	03/05/2020	22.18	PO	220 KV Partial BUS-B outage at PADGHE Maintenance of ICT BUS side.Line side isolator.
400/220KV 500MVA ICT 2@koradi 2	IntraState	03/05/2020	21.42		Continued.	T	NDR Operated
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Bus B at Padgha	InterState	03/05/2020	10.52	03/05/2020	20.06	PO	Repairing servicing of B-BUS Isolator in lower side.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand &

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 02/May/2020

Statement-VII

Position as on 6.30 Hrs of 03/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Sawantwadi-Bidri	IntraState	01/05/2020	19.25	02/05/2020	12.17	HT	Over Voltage
Amalner-Bambhori	IntraState	01/05/2020	23.45	02/05/2020	06.00	T	Distance Protection
Theur-Phursungi	IntraState	02/05/2020	08.41	02/05/2020	11.19	PO	Half yearly maintenance work
Theur-Phursungi ckt-2	IntraState	02/05/2020	11.43	02/05/2020	13.23	PO	Half yearly maintenance work
Satana-Gangapur	IntraState	02/05/2020	20.15	02/05/2020	21.41	EO	To attend Hot Spot
Eklahara(Gcr)(Nasik)- Bableswhar 2	IntraState	03/05/2020	10.08	03/05/2020	13.42	PO	Repalcement Of R-PH coupling Due To high Tan Delta value.
Padghe - Nalasopara	IntraState	03/05/2020	10.10	03/05/2020	13.10	PO	220KV Partial BUS Outage At Padgha.
Padghe-Kamba II	IntraState	03/05/2020	14.17	03/05/2020	18.13	PO	Isolator Maintenace.
Amalner - Bambhori	IntraState	03/05/2020	16.30	03/05/2020	23.02	T	Distance Protection
220 KV ICT Outages/Trippings							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	27/04/2020	17.15		Continued.	HT	Over Voltage
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/132 Kv 200 Mva Cgl Ict 3 @Babhleshwar	IntraState	02/05/2020	10.55	02/05/2020	13.00	PO	Quarterly Maintenance Work
220/132 Kv 100 Mva Ict 2 @Tuljapur	IntraState	02/05/2020	13.43	02/05/2020	16.04	PO	Quarterly Maintenance Work
220/132 kV 200 Mva ICT-II @Boisar -Ii	IntraState	03/05/2020	19.47	03/05/2020	20.20	PO	Y-PH LV CT Bird nest Remove.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage