

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 02/May/2021 SUNDAY**

| I GENERATION (MUs)  |                |                | II EXCHANGES (MUs)             |                |                |
|---------------------|----------------|----------------|--------------------------------|----------------|----------------|
| A) MSPGCL           | Daily          | Monthly        | E) InterState Exchanges        | Daily          | Monthly        |
| 1) Thermal          | 133.665        | 264.477        | 1) Gujrat                      | -3.578         | -6.223         |
| 2) Hydro            | 9.977          | 22.271         | 2) Madhya Pradesh              | 10.689         | 21.029         |
| 3) Gas              | 10.023         | 19.939         | 3) Chattisgarh                 | 5.420          | 11.250         |
| <b>Total MSPGCL</b> | <b>153.665</b> | <b>306.687</b> | 4) Maharashtra                 | 135.623        | 271.086        |
| B) 1) APLM          | 67.266         | 133.463        | 5) Goa (Amona)                 | -1.482         | -3.350         |
| 2) JSWEL            | 12.047         | 24.871         | <b>Total</b>                   | <b>146.672</b> | <b>293.792</b> |
| 3) VIPL             | 0.000          | 0.000          | a) Mumbai Schedule             | 20.282         | 40.389         |
| 4) RPL(AMT)         | 28.696         | 56.962         | b) Mumbai Drawl                | 24.186         | 52.627         |
| 5) SWPGPL           | 6.802          | 12.402         | c) MSEDCL Bilateral *          | 32.565         | 65.158         |
| 6) Other IPP        | 14.020         | 28.954         | Include PX                     | 5.388          | 7.995          |
| 7) PGPL             | 0.000          | 0.000          | d) Mumbai Bilateral *          | 20.282         | 40.389         |
| C) 1) TPCL Thermal  | 12.580         | 22.958         | Include PX                     | 5.260          | 8.688          |
| 2) TPCL Hydro       | 1.662          | 3.770          | Standby                        | 0.000          | 0.000          |
| 3) TPCL Gas         | 4.367          | 8.739          | <b>H) ENERGY CATERED (MUs)</b> |                |                |
| 4) AEML Thermal     | 9.370          | 16.841         | 1) MSEDCL                      | 420.133        | 838.169        |
| <b>D) STATE</b>     |                |                | 2) Mumbai Discoms              | 52.165         | 104.935        |
| 1) Thermal          | 284.446        | 560.928        | <b>TOTAL STATE</b>             | <b>472.298</b> | <b>943.104</b> |
| (A1+C1+C4+(B1-B6))  |                |                |                                |                |                |
| 2) Hydro            | 11.639         | 26.041         |                                |                |                |
| (A2+C2)             |                |                |                                |                |                |
| 3) Gas              | 14.390         | 28.678         |                                |                |                |
| (A3+B7+C3)          |                |                |                                |                |                |
| 4) Wind             | 9.169          | 21.454         |                                |                |                |
| 6) SOLAR            | 5.982          | 12.211         |                                |                |                |
| <b>TOTAL STATE</b>  | <b>325.626</b> | <b>649.312</b> |                                |                |                |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 22 Hrs | D. Night Minimum at 23 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal           | 5749                      | 5723                  | 5344                      | 5286                       |
| MSPGCL Hydro             | 748                       | 436                   | 326                       | 316                        |
| MSPGCL Gas               | 411                       | 407                   | 423                       | 414                        |
| MSPGCL Total Generation  | 6908                      | 6566                  | 6094                      | 6016                       |
| Central Sector Receipt   | 6769                      | 6778                  | 5490                      | 6065                       |
| WIND                     | 173                       | 399                   | 735                       | 544                        |
| CPP / IPP Thermal        | 5190                      | 5960                  | 4666                      | 4673                       |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                          |
| SOLAR                    | 828                       | 498                   | 0                         | 0                          |
| Exchange with Mumbai     | -743                      | -779                  | -1250                     | -1317                      |
| <b>MSEDCL DEMAND MET</b> | <b>19125</b>              | <b>19423</b>          | <b>15734</b>              | <b>15982</b>               |
| Load Shedding            | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND            | 19125                     | 19423                 | 15734                     | 15982                      |
| TPCL GENERATION          | 930                       | 926                   | 742                       | 751                        |
| AEML GENERATION          | 500                       | 494                   | 285                       | 285                        |
| <b>MUMBAI DEMAND</b>     | <b>2173</b>               | <b>2199</b>           | <b>2277</b>               | <b>2353</b>                |
| STATE DEMAND MET         | 21298                     | 21622                 | 18011                     | 18334                      |
| <b>STATE DEMAND</b>      | <b>21298</b>              | <b>21622</b>          | <b>18011</b>              | <b>18334</b>               |
| Frequency (Hz)           | 49.96                     | 50.07                 | 50.00                     | 50.04                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.15 Hz at 14.02 Hrs | 49.84 Hz at 00.03 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 02/May/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.86        | 25.13         | 561      | 400      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| Unit 10            | 11.04        | 22.44         | 560      | 280      |
| <b>Total</b>       | <b>22.90</b> | <b>47.56</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.36         | 6.89          | 180      | 120      |
| Unit 4             | 11.55        | 22.88         | 500      | 380      |
| Unit 5             | 11.62        | 23.11         | 500      | 405      |
| <b>Total</b>       | <b>26.54</b> | <b>52.88</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.91         | 8.74          | 225      | 189      |
| Unit 7             | 4.77         | 9.76          | 220      | 176      |
| Unit 8             | 4.62         | 9.27          | 203      | 181      |
| <b>Total</b>       | <b>14.29</b> | <b>27.77</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.63         | 2.74          | 143      | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 9.40         | 18.74         | 410      | 329      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.48        | 23.22         | 495      | 340      |
| Unit 9             | 10.58        | 21.25         | 470      | 333      |
| <b>Total</b>       | <b>34.08</b> | <b>65.94</b>  |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.78         | 10.21         | 255      | 190      |
| Unit 4             | 5.11         | 10.81         | 253      | 132      |
| <b>Total</b>       | <b>10.89</b> | <b>21.01</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.66         | 5.02          | 140      | 100      |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.20         | 8.40          | 184      | 160      |
| Unit 4             | 0.00         | 0.93          | 0        | 0        |
| Unit 5             | 10.78        | 21.15         | 460      | 425      |
| <b>Total</b>       | <b>17.64</b> | <b>35.49</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.66         | 6.89          | 199      | 128      |
| Unit 5             | 3.67         | 6.93          | 197      | 127      |
| <b>Total</b>       | <b>7.33</b>  | <b>13.82</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.02        | 19.94         | 436      | 398      |
| <b>Total</b>       | <b>10.02</b> | <b>19.94</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.16         | 0.30          | 25       | 0        |
| <b>Total</b>       | <b>0.16</b>  | <b>0.30</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.32          | 5.08          | 335      | 35       |
| Stage 4         | 0.42          | 1.85          | 208      | 0        |
| Stage 3         | 0.44          | 1.27          | 80       | 0        |
| <b>Total</b>    | <b>3.18</b>   | <b>8.21</b>   |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.80          | 1.61          | 34       | 34       |
| VTRNA           | 0.89          | 1.89          | 60       | 0        |
| TILLARI         | 0.46          | 0.93          | 58       | 0        |
| BHIRA T.R.      | 0.14          | 0.36          | 80       | 0        |
| SMLHY_PTN       | 4.50          | 9.27          | 198      | 173      |
| GHATGHAR        | 0.00          | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>6.80</b>   | <b>14.06</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 9.17          | 21.45         | 0        | 0        |
| <b>Total</b>    | <b>9.17</b>   | <b>21.45</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 67.27         | 133.46        | 0        | 0        |
| JSWEL(Mus)      | 12.05         | 24.87         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 28.70         | 56.96         | 0        | 0        |
| SWPGPL-Mus      | 6.80          | 12.40         | 0        | 0        |
| Other(Mus)      | 14.02         | 28.95         | 0        | 0        |
| <b>Total</b>    | <b>128.83</b> | <b>256.65</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 5.98          | 12.21         | 0        | 0        |
| <b>Total</b>    | <b>5.98</b>   | <b>12.21</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 8.49          | 15.40         | 482      | 279      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 2.79          | 5.58          | 117      | 115      |
| Trombay 7B      | 1.58          | 3.16          | 66       | 65       |
| Trombay 8       | 4.09          | 7.56          | 230      | 135      |
| TATA Hydro      | 1.66          | 3.77          | 178      | 0        |
| <b>Total</b>    | <b>18.61</b>  | <b>35.47</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 9.37          | 16.84         | 502      | 285      |
| <b>Total</b>    | <b>9.37</b>   | <b>16.84</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 133.66      | 264.48        | MSPGCL Total        | 153.66      | 306.69        |
|                |             |         | MSPGCL Thml+Gas | 143.69      | 284.42        | Koyna 1,2 & 4 Total | 2.74        | 6.94          |
|                |             |         | MSPGCL Hydro    | 9.98        | 22.27         | State Total         | 325.63      | 649.31        |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 02/May/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |       | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|-------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS   |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5519        | 584  | 424   | 6526   | 371  | 5750      | 0    | 0     | 6119        | 6100        | -1344                | 17403                 | 0                    | 17403                     | 2527             | 19930           | 49.97         |
| 2                  | 5495        | 542  | 425   | 6462   | 368  | 5803      | 0    | 0     | 5896        | 5642        | -1235                | 17040                 | 0                    | 17040                     | 2349             | 19390           | 49.98         |
| 3                  | 5573        | 390  | 424   | 6386   | 421  | 5780      | 0    | 0     | 5737        | 5681        | -1102                | 17166                 | 0                    | 17166                     | 2203             | 19370           | 50.01         |
| 4                  | 5622        | 280  | 426   | 6328   | 457  | 5752      | 0    | 0     | 5705        | 5614        | -1084                | 17066                 | 0                    | 17066                     | 2083             | 19150           | 50.02         |
| 5                  | 5755        | 266  | 415   | 6436   | 433  | 5782      | 0    | 0     | 5779        | 5838        | -1137                | 17352                 | 0                    | 17352                     | 2024             | 19376           | 50.01         |
| 6                  | 5917        | 282  | 426   | 6624   | 362  | 5889      | 0    | 0     | 6032        | 5899        | -1025                | 17750                 | 0                    | 17750                     | 2071             | 19820           | 50.01         |
| 7                  | 5973        | 400  | 436   | 6810   | 318  | 5960      | 0    | 44    | 6219        | 6222        | -639                 | 18714                 | 0                    | 18714                     | 2015             | 20729           | 50.00         |
| 8                  | 5727        | 262  | 425   | 6414   | 341  | 5902      | 0    | 230   | 6513        | 6275        | -846                 | 18316                 | 0                    | 18316                     | 1973             | 20290           | 49.94         |
| 9                  | 5776        | 320  | 414   | 6510   | 133  | 5800      | 0    | 485   | 6726        | 6069        | -917                 | 18079                 | 0                    | 18079                     | 2053             | 20132           | 50.02         |
| 10                 | 5836        | 376  | 422   | 6634   | 112  | 5586      | 0    | 711   | 6626        | 6274        | -702                 | 18614                 | 0                    | 18614                     | 2131             | 20745           | 50.06         |
| 11                 | 5826        | 472  | 421   | 6718   | 95   | 5546      | 0    | 868   | 6868        | 6351        | -726                 | 18852                 | 0                    | 18852                     | 2154             | 21006           | 50.00         |
| 12                 | 5749        | 748  | 411   | 6908   | 173  | 5190      | 0    | 828   | 7041        | 6769        | -743                 | 19125                 | 0                    | 19125                     | 2173             | 21298           | 49.96         |
| 13                 | 5855        | 806  | 407   | 7068   | 134  | 5253      | 0    | 856   | 6935        | 6767        | -726                 | 19352                 | 0                    | 19352                     | 2164             | 21516           | 49.97         |
| 14                 | 5825        | 480  | 398   | 6702   | 278  | 5864      | 0    | 678   | 6735        | 6520        | -733                 | 19310                 | 0                    | 19310                     | 2162             | 21472           | 50.04         |
| 15                 | 5723        | 436  | 407   | 6566   | 399  | 5960      | 0    | 498   | 7115        | 6778        | -779                 | 19423                 | 0                    | 19423                     | 2199             | 21622           | 50.07         |
| 16                 | 5431        | 374  | 407   | 6212   | 412  | 5622      | 0    | 424   | 7440        | 6930        | -1028                | 18571                 | 0                    | 18571                     | 2183             | 20754           | 50.02         |
| 17                 | 5229        | 484  | 409   | 6122   | 471  | 4632      | 0    | 231   | 6705        | 6823        | -1081                | 17198                 | 0                    | 17198                     | 2110             | 19308           | 50.03         |
| 18                 | 5087        | 582  | 409   | 6078   | 485  | 4446      | 0    | 115   | 5851        | 5909        | -969                 | 16064                 | 0                    | 16064                     | 2029             | 18093           | 50.02         |
| 19                 | 5346        | 320  | 422   | 6088   | 526  | 4559      | 0    | 14    | 5402        | 5414        | -988                 | 15613                 | 0                    | 15613                     | 2028             | 17641           | 49.99         |
| 20                 | 5320        | 320  | 422   | 6062   | 645  | 4658      | 0    | 0     | 5573        | 5399        | -1141                | 15622                 | 0                    | 15622                     | 2192             | 17814           | 49.97         |
| 21                 | 5308        | 312  | 412   | 6032   | 518  | 4688      | 0    | 0     | 5566        | 5249        | -1224                | 15262                 | 0                    | 15262                     | 2253             | 17516           | 50.01         |
| 22                 | 5344        | 326  | 423   | 6094   | 735  | 4666      | 0    | 0     | 5851        | 5490        | -1250                | 15734                 | 0                    | 15734                     | 2277             | 18011           | 50.00         |
| 23                 | 5286        | 316  | 414   | 6016   | 544  | 4673      | 0    | 0     | 6266        | 6065        | -1317                | 15982                 | 0                    | 15982                     | 2353             | 18334           | 50.04         |
| 24                 | 5143        | 302  | 424   | 5868   | 438  | 5072      | 0    | 0     | 6405        | 6594        | -1450                | 16523                 | 0                    | 16523                     | 2459             | 18982           | 50.02         |
| MUs                | 133.67      | 9.98 | 10.02 | 153.66 | 9.17 | 128.83    | 0.00 | 5.98  | 151.11      | 146.67      | -24.19               | 420.13                | 0.00                 | 420.13                    | 52.17            | 472.30          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center, Airoli (MSETCL) Statement-VI

## Details of Generating Unit Outages/Trippings for 02/May/2021

Position as on 6.30 Hrs of 03/May/2021

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                  | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                   |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 16/03/2021   | 08.08        |            | Continued. | Boiler Tube Leakage(converted to Capital overhaul)                                |               |
| MSPGCL                | Koyna Unit 6            | 80       | 22/04/2021   | 12.00        |            | Continued. | UGC Oil Cooler Leakage.(Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                   |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                           |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                              |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                              |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                            |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                           |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                            |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                             |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).               |               |
| MSPGCL                | Koyna Unit 11           | 80       | 19/01/2021   | 10.05        |            | Continued. | Tripped on stator earth fault (will not be available till dt.12.05.21)            |               |
| IPP                   | JSW (J) U1              | 300      | 01/02/2021   | 18.00        |            | Continued. | Due to turbine vibration high                                                     |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 20/02/2021   | 23.43        |            | Continued. | Generator Earth Fault.                                                            |               |
| IPP                   | JSW (J) U4              | 300      | 11/04/2021   | 03.02        |            | Continued. | NO SCHEDULE.                                                                      |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 15/04/2021   | 16.54        |            | Continued. | Critical coal stock position                                                      |               |
| MSPGCL                | Koradi Unit 9           | 660      | 24/04/2021   | 14.59        |            | Continued. | Boiler Tube Leakage                                                               |               |
| MSPGCL                | Koradi Unit 6           | 210      | 27/04/2021   | 19.59        |            | Continued. | Zero Schedule.                                                                    |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Zero Schedule.                                                                    |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 28/04/2021   | 13.01        | 03/05/2021 | 14.17      | Boiler Tube Leakage                                                               |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 01/05/2021   | 00.40        | 02/05/2021 | 03.00      | Low Vacuum                                                                        |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 01/05/2021   | 06.02        |            | Continued. | Boiler Tube Leakage                                                               |               |
| MSPGCL                | Uran Unit B0            | 120      | 03/05/2021   | 15.44        | 03/05/2021 | 22.42      | Bus Fault R-Phase string broken.                                                  |               |
| MSPGCL                | Uran Unit 5             | 108      | 03/05/2021   | 15.44        |            | Continued. | Bus Fault R-Phase string broken.                                                  |               |
| MSPGCL                | Uran Unit 8             | 108      | 03/05/2021   | 15.44        | 03/05/2021 | 18.34      | Bus Fault R-Phase string broken.                                                  |               |
| MSPGCL                | Uran Unit A0            | 120      | 03/05/2021   | 16.12        | 03/05/2021 | 23.33      | Bus Fault R-Phase string broken.                                                  |               |
| MSPGCL                | Uran Unit 6             | 108      | 03/05/2021   | 16.12        | 03/05/2021 | 19.53      | Bus Fault R-Phase string broken.                                                  |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 03/05/2021   | 20.26        |            | Continued. | ID fan tripped                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 02/May/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 03/May/2021**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                            |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                                             |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                                                                    |
| Akola Wardha I                                    | InterState                | 21/04/2021   | 09.19        |            | Continued. | PO          | Line diversion works under consultancy due to upcoming Nagpur Mumbai super communication expressway (Samruddhi highway).                                                                    |
| Akola Wardha li                                   | InterState                | 21/04/2021   | 09.19        |            | Continued. | PO          | Line diversion works under consultancy due to upcoming Nagpur Mumbai super communication expressway (Samruddhi highway)                                                                     |
| Dhule Sar'Sarovar II                              | InterState                | 30/04/2021   | 18.28        | 02/05/2021 | 08.51      | HT          | Over Voltage                                                                                                                                                                                |
| Dhule Sar'Sarovar I                               | InterState                | 02/05/2021   | 18.31        | 03/05/2021 | 08.30      | HT          | Over Voltage                                                                                                                                                                                |
| Dabhol Nagothane II                               | InterState                | 03/05/2021   | 10.50        | 03/05/2021 | 20.20      | PO          | Cold washing,E/W replacement Work & Faulty string replacement Work.                                                                                                                         |
| Babhleshwar - RIPL(Nashik)                        | IntraState                | 18/03/2021   | 15.48        |            | Continued. | PO          | Hot spot attending.                                                                                                                                                                         |
| Girwali-Solapur (Lamboti)                         | IntraState                | 30/04/2021   | 16.20        | 02/05/2021 | 01.35      | EO          | To attend Flashover                                                                                                                                                                         |
| Deepnagar Waluj 1                                 | IntraState                | 01/05/2021   | 18.19        | 02/05/2021 | 15.09      | T           | Distance Protection                                                                                                                                                                         |
| Babhaleshwar - Padghe-II                          | IntraState                | 02/05/2021   | 10.45        | 02/05/2021 | 14.10      | EO          | To attend Hot Spot                                                                                                                                                                          |
| Babhaleshwar - Padghe-I                           | IntraState                | 02/05/2021   | 14.19        | 02/05/2021 | 18.11      | PO          | Replacement of broken Disc Insulators                                                                                                                                                       |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 02/05/2021   | 20.03        | 03/05/2021 | 08.30      | HT          | Over Voltage                                                                                                                                                                                |
| Akola-Nandgaonpeth (RPL)                          | IntraState                | 03/05/2021   | 07.14        | 03/05/2021 | 17.17      | PO          | Work of strings replacement detected faulty in PID testing are to be replaced by availing outage on 400 kV Akola-Nandgaonpeth line.                                                         |
| Babhaleshwar - Padghe-I                           | IntraState                | 03/05/2021   | 12.15        | 03/05/2021 | 20.01      | PO          | To attend broken disc insulator replacement wrok.                                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                                                             |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                                                                                                       |
| 400/220kv 315 Mva ICT I @Karad                    | IntraState                | 03/05/2021   | 07.16        |            | Continued. | PO          | For RRS REF stability work, RRS PG isolator trials, diagnostic testing work, routine & premonsoon maintenance work.                                                                         |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                                                                             |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                                                                 |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                                                                      |
| Chalisgaon -Babhaleshwar                          | IntraState                | 24/04/2021   | 09.52        |            | Continued. | PO          | For Shifting/Erection Work of monopole Tower Work For samruddhi express Highway work 4 nos of monopole erection & 2nos of tower erection work. Dismantling of 2nos of tower loc no.220-223. |
| Chikhli-Jalna-I                                   | IntraState                | 26/04/2021   | 12.14        |            | Continued. | PO          | Tower height raising of 220KV Jalna Chikhali line for Mumbai Nagpur samruddhi highway crossing.                                                                                             |
| Chikhli-Jalna-II                                  | IntraState                | 26/04/2021   | 12.16        |            | Continued. | PO          | Tower height raising of 220KV Jalna Chikhali line for Mumbai Nagpur samruddhi highway crossing.                                                                                             |
| Dahanu Ghodbunder Line 1                          | IntraState                | 02/05/2021   | 06.32        | 02/05/2021 | 14.21      | PO          | Shifting of LS Line from existing                                                                                                                                                           |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 02/May/2021**

**Statement-VII**

Position as on 6.30 Hrs of 03/May/2021

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                 |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                                              |                           |              |              |            |            |             | position                                                                                                                                                                         |
| REL Borivali TPC Borivali line               | IntraState                | 02/05/2021   | 10.32        | 02/05/2021 | 18.08      | PO          | Testing Work                                                                                                                                                                     |
| Dahanu Ghodbunder Line 2                     | IntraState                | 03/05/2021   | 06.30        | 03/05/2021 | 16.02      | PO          | Shifting of LS line from its existing position (Temporary diversion) to newly constructed Permanent towers under DFCCIL Modification / Diversion works. Location - LS-12A-13-14. |
| Kandalgaon - Koyna (Pophali)                 | IntraState                | 03/05/2021   | 09.50        | 03/05/2021 | 18.15      | PO          | Jumper nut bolt tightening.                                                                                                                                                      |
| 220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 2 | IntraState                | 03/05/2021   | 14.53        | 03/05/2021 | 16.12      | HT          | 220V DC charger replacement at 220KV Jalkot S/ST.                                                                                                                                |
| 220 KV JALKOT - NANDED (KUMBHARGAON) CKT - 1 | IntraState                | 03/05/2021   | 14.53        | 03/05/2021 | 16.12      | HT          | 220V DC charger replacement at 220KV Jalkot S/ST.                                                                                                                                |
| Uran - Kharghar I                            | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.20      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| Uran - Apta IV                               | IntraState                | 03/05/2021   | 15.44        |            | Continued. | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| Uran - Apta II                               | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.15      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| Uran - Ongc Uran                             | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.22      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| Uran - Jnpt                                  | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.14      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| Uran - Apta III                              | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.20      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                  |
| Dharavi : 220 / 110 / 33 250 MVA ICT 8       | IntraState                | 02/05/2021   | 09.32        | 02/05/2021 | 16.20      | PO          | Routine Maintenance Work                                                                                                                                                         |
| 220/22 Kv 50 Mva Vijai Make Ptr 1 @Uran      | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.23      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |
| 220/22 Kv 50 Mva Bb Ptr 2 @Uran              | IntraState                | 03/05/2021   | 15.44        | 03/05/2021 | 16.23      | T           | Bus fault at Uran due to 220KV Uran Apta ckt 4String fell.                                                                                                                       |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage