

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Jun/2021 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	104.139	217.660	1) Gujrat	1.648	5.212
2) Hydro	19.162	30.185	2) Madhya Pradesh	12.585	25.173
3) Gas	6.662	13.282	3) Chattisgarh	6.790	12.830
Total MSPGCL	129.963	261.127	4) Maharashtra	159.794	321.119
B) 1) APML	30.118	60.775	5) Goa (Amona)	-1.265	-2.526
2) JSWEL	21.238	41.945	Total	179.552	361.808
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.633	61.162
4) RPL(AMT)	29.033	60.376	b) Mumbai Drawl	25.768	53.976
5) SWPGPL	8.990	17.429	c) MSEDCL Bilateral *	55.351	113.514
6) Other IPP	9.417	18.734	Include PX	19.460	30.766
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.614	61.123
C) 1) TPCL Thermal	15.207	29.492	Include PX	18.908	37.153
2) TPCL Hydro	5.393	10.679	Standby	0.019	0.039
3) TPCL Gas	4.023	8.064	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.009	11.952	1) MSEDCL	396.681	804.780
D) STATE			2) Mumbai Discoms	56.400	114.163
1) Thermal	224.151	458.363	TOTAL STATE	453.081	918.943
(A1+C1+C4+(B1-B6))					
2) Hydro	24.555	40.864			
(A2+C2)					
3) Gas	10.685	21.346			
(A3+B7+C3)					
4) Wind	7.601	23.550			
6) SOLAR	6.537	13.012			
TOTAL STATE	273.529	557.135			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4433	4405	4378	4231
MSPGCL Hydro	499	1189	973	660
MSPGCL Gas	269	268	277	287
MSPGCL Total Generation	5201	5862	5628	5178
Central Sector Receipt	8484	8691	6547	6893
WIND	46	278	836	82
CPP / IPP Thermal	4174	3961	3951	4216
CPP / IPP Gas	0	0	0	0
SOLAR	966	650	0	0
Exchange with Mumbai	-1384	-1393	-963	-894
MSEDCL DEMAND MET	17487	18049	15999	15475
Load Shedding	0	0	0	0
MSEDCL DEMAND	17487	18049	15999	15475
TPCL GENERATION	1024	1019	1132	808
AEML GENERATION	250	250	250	250
MUMBAI DEMAND	2658	2662	2345	1952
STATE DEMAND MET	20145	20711	18344	17427
STATE DEMAND	20145	20711	18344	17427
Frequency (Hz)	49.94	49.99	49.99	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 08:01 Hrs	49.8 Hz at 05:49 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 02/Jun/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	11.78	23.08	560	400
Total	11.78	23.08		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.57	23.28	500	430
Unit 5	0.00	2.28	0	0
Total	11.57	25.57		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.36	6.74	149	118
Unit 4	4.17	8.16	181	164
Unit 5	9.29	18.61	420	330
Unit 6	9.39	18.65	410	360
Unit 7	0.00	0.00	0	0
Unit 8	11.78	23.50	495	487
Unit 9	0.00	10.05	0	0
Total	37.98	85.71		
Paras				
Unit 3	5.42	10.75	245	205
Unit 4	5.86	11.57	253	230
Total	11.29	22.32		
Khaparkheda				
Unit 1	2.66	5.20	120	95
Unit 2	4.04	8.08	180	155
Unit 3	4.37	8.44	195	170
Unit 4	4.36	8.13	200	160
Unit 5	11.57	22.76	500	440
Total	27.01	52.60		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.51	8.37	198	130
Unit 5	0.00	0.00	0	0
Total	4.51	8.37		
Uran				
All Units	6.66	13.28	298	267
Total	6.66	13.28		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.43	0.74	25	0
Total	0.43	0.74		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.30	7.18	435	35
Stage 4	5.71	6.84	905	0
Stage 3	2.56	3.40	160	0
Total	12.58	17.42		
Hydro				
KDPH	0.34	0.67	14	14
VTRNA	0.56	1.42	59	0
TILLARI	0.58	1.16	58	0
BHIRA T.R.	0.30	0.52	80	0
SMLHY_PTN	4.65	8.84	213	178
GHATGHAR	0.16	0.16	100	0
Total	6.59	12.76		
Wind				
Total	7.60	23.55	0	0
Total	7.60	23.55		
CPP				
APML(Mus)	30.12	60.78	0	0
JSWEL(Mus)	21.24	41.94	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	29.03	60.38	0	0
SWPGPL-Mus	8.99	17.43	0	0
Other(Mus)	9.42	18.73	0	0
Total	98.80	199.26		
SOLAR				
Total	6.54	13.01	0	0
Total	6.54	13.01		
Tata				
Trombay 5	9.78	18.93	427	375
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.51	5.03	116	102
Trombay 7B	1.52	3.04	67	62
Trombay 8	5.42	10.57	231	220
TATA Hydro	5.39	10.68	441	0
Total	24.62	48.24		
AEML				
DTPS U-1&2	6.01	11.95	252	250
Total	6.01	11.95		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	104.14	217.66	MSPGCL Total	129.96	261.13
			MSPGCL Thml+Gas	110.80	230.94	Koyna 1,2 & 4 Total	10.01	14.02
			MSPGCL Hydro	19.16	30.18	State Total	273.53	557.14

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 02/Jun/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4107	1240	277	5624	321	4224	0	0	6739	6860	-1091	15938	0	15938	2363	18301	50.03
2	4129	1201	278	5608	177	4221	0	0	6855	6738	-936	15808	0	15808	2214	18022	50.04
3	4126	823	286	5235	114	4233	0	0	6945	7064	-857	15789	0	15789	2080	17869	50.01
4	4168	656	276	5100	34	4226	0	0	6991	7066	-944	15482	0	15482	1979	17461	49.97
5	4231	660	287	5178	82	4216	0	0	6974	6893	-894	15475	0	15475	1952	17427	50.03
6	4284	685	286	5255	35	4217	0	0	7842	7915	-884	16538	0	16538	1942	18480	49.97
7	4298	760	277	5335	72	4211	0	52	8303	8327	-896	17101	0	17101	1918	19019	50.01
8	4327	724	276	5327	109	4210	0	221	8335	8171	-952	17086	0	17086	2006	19092	50.02
9	4418	407	274	5099	130	4225	0	535	8120	8153	-1102	17040	0	17040	2209	19249	50.02
10	4385	721	283	5389	71	4236	0	732	8321	8304	-1252	17480	0	17480	2453	19933	49.99
11	4434	510	271	5215	91	4184	0	846	8730	8496	-1344	17488	0	17488	2614	20102	49.98
12	4433	499	269	5201	46	4174	0	966	8739	8484	-1384	17487	0	17487	2658	20145	49.94
13	4404	593	267	5264	79	4162	0	903	8645	8645	-1356	17697	0	17697	2675	20372	49.91
14	4396	644	288	5328	150	4203	0	845	8548	8580	-1328	17778	0	17778	2635	20413	49.97
15	4405	1189	268	5862	278	3961	0	650	8441	8691	-1393	18049	0	18049	2662	20711	49.99
16	4389	1443	269	6101	394	3989	0	476	8045	7845	-1347	17458	0	17458	2687	20145	50.05
17	4425	972	268	5665	640	3977	0	214	7838	7724	-1268	16952	0	16952	2641	19593	50.01
18	4403	559	269	5231	782	3948	0	72	7184	6871	-1010	15894	0	15894	2520	18414	49.98
19	4361	612	286	5259	935	3879	0	25	6519	6494	-917	15675	0	15675	2364	18039	50.02
20	4378	973	277	5628	836	3951	0	0	6232	6547	-963	15999	0	15999	2345	18344	49.99
21	4421	738	277	5436	970	3962	0	0	6297	6236	-925	15679	0	15679	2337	18016	49.99
22	4430	540	298	5268	536	4057	0	0	6267	6350	-836	15375	0	15375	2325	17700	49.96
23	4394	892	277	5563	396	4057	0	0	6288	7009	-899	16126	0	16126	2368	18494	49.94
24	4393	1121	278	5792	323	4073	0	0	6424	6089	-990	15287	0	15287	2453	17740	49.96
MUs	104.14	19.16	6.66	129.96	7.60	98.80	0.00	6.54	179.62	179.55	-25.77	396.68	0.00	396.68	56.40	453.08	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Jun/2021

Position as on 6.30 Hrs of 03/Jun/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 6	80	22/04/2021	12.00		Continued.	UGC Oil Cooler Leakage.(Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021)	25/06/2021
AEML	AEML Unit 1	250	19/05/2021	09.52		Continued.	HP turbine replacement.	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	
MSPGCL	Chandrapur Unit 7	500	20/02/2021	23.43		Continued.	Generator Earth Fault.	
MSPGCL	Koradi Unit 6	210	27/04/2021	19.59		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Bhusawal Unit 3	210	04/05/2021	20.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	04/05/2021	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	05/05/2021	19.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	06/05/2021	19.45		Continued.	Zero Schedule	
IPP	Adani U-4	660	16/05/2021	10.01		Continued.	Zero Schedule.	
IPP	Adani U-1	660	16/05/2021	17.57		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-5	660	17/05/2021	12.05		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 5	210	17/05/2021	12.50		Continued.	Zero schedule.	
MSPGCL	Uran Unit 6	108	17/05/2021	22.59		Continued.	Gas shortage.	
MSPGCL	Koradi Unit-8	660	25/05/2021	03.52		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	31/05/2021	21.59		Continued.	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 5	500	01/06/2021	05.21	03/06/2021	13.42	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	01/06/2021	23.57		Continued.	Boiler Validity Renevoation	
IPP	RPL(AMT) U-5	270	02/06/2021	14.29		Continued.	Bottom ash problem	
MSPGCL	Chandrapur Unit 4	210	03/06/2021	23.20		Continued.	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jun/2021

Statement-VII

Position as on 6.30 Hrs of 03/Jun/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Lamboti - Solapur (PG)	InterState	02/06/2021	21.50	03/06/2021	13.16	T	Distance Protection
Babhleshwar - RIPL(Nashik)	IntraState	18/03/2021	15.48		Continued.	PO	Hot spot attending.
Khadka-Aurangabad (Waluj)	IntraState	01/06/2021	20.01	02/06/2021	09.45	HT	Over Voltage
Parly(MS)- Nanded ckt I	IntraState	02/06/2021	00.11	02/06/2021	01.32	T	Distance Protection
New Koyna - Koyna Stage IV-II	IntraState	02/06/2021	10.11	02/06/2021	21.44	PO	Routine Maintenance Work
Ektuni-Taptitanda II	IntraState	02/06/2021	15.58	02/06/2021	18.11	EO	Attending Hot spot of stub bus Y phase jumper.
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	02/06/2021	16.15	02/06/2021	16.31	EO	To take line reactor in service
Karad - Jaigad - II	IntraState	02/06/2021	22.13	03/06/2021	10.32	T	Distance Protection
Karad-Jaigad - I	IntraState	02/06/2021	22.13	03/06/2021	10.23	T	Distance Protection
Girwali - Lonikand 1	IntraState	03/06/2021	11.29	03/06/2021	18.03	PO	Half yearly maintenance work
karad -kolhapur-I	IntraState	03/06/2021	11.51	03/06/2021	13.42	PO	Problem with the Isolator Jaws
Koradi-Bhusawal	IntraState	03/06/2021	12.35	03/06/2021	13.47	T	Distance Protection
karad -kolhapur-II	IntraState	03/06/2021	21.03		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.(FTC DT 16/08/2021 At 14.42)
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	02/06/2021	07.07	02/06/2021	10.06	T	Y-Phase oil temperature tripped.
167 Mva Spare Ict @Lamboti	IntraState	02/06/2021	10.16	02/06/2021	16.32	PO	Diagnostic testing work
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	02/06/2021	21.08	02/06/2021	23.54	PO	Premonsoon maintenance work.
400/220kv 315MVA ICT 2 @ Chandrapur GCR	IntraState	03/06/2021	09.30		Continued.	PO	Testing Work
400/220/33 Kv 315 MVA ICT-3 @Padghe	IntraState	03/06/2021	10.29	03/06/2021	15.18	PO	Pre Monsoon Maintenance work
400/220/33 Kv 315 Mva Ict 1 @Parali (Girwali)	IntraState	03/06/2021	10.57	03/06/2021	15.36	PO	Pre Monsoon Maintenance work
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	03/06/2021	18.12	03/06/2021	21.55	PO	DC Leakage
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Solapur (Pg) South Solapur I	InterState	02/06/2021	11.33	02/06/2021	17.52	PO	Outage is required for stringing at Loc no. 238 to 239 of proposed 220KV Narangwadi solapur (PGCIL) DCDC line.
Solapur (Pg) South Solapur li	InterState	02/06/2021	11.33	02/06/2021	17.54	PO	Outage is required for stringing at Loc no. 238 to 239 of proposed 220KV Narangwadi solapur (PGCIL) DCDC line.
Khaparkheda-Ambazari-I	IntraState	02/06/2021	09.47	02/06/2021	17.09	PO	Replacement of flashover string at various locations.
Boisar Versova Line	IntraState	02/06/2021	14.21	02/06/2021	15.13	PO	Premonsoon maintenance work.
Sadawaghapur Karad Ckt 2	IntraState	02/06/2021	15.31	02/06/2021	17.31	EO	Removal of R ph LA jump.
Karad -Mudshingi Ckt- IV	IntraState	02/06/2021	23.04	03/06/2021	00.48	EO	Sparking at Loc no.174 R-ph string replacement work.
Eklahare (Gcr)(Nashik)- Ghatghar	IntraState	03/06/2021	10.30	03/06/2021	11.59	EO	For removing Metal sheet stuck
Dondaicha(220)-Amalner(220)	IntraState	03/06/2021	12.44	03/06/2021	19.44	T	Distance Protection
Sawantwadi-Bidri	IntraState	03/06/2021	15.56	03/06/2021	16.23	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jun/2021

Statement-VII

Position as on 6.30 Hrs of 03/Jun/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Talandage - Sawantwadi I	IntraState	03/06/2021	16.10	03/06/2021	17.08	T	Distance Protection
Satana-Gangapur	IntraState	03/06/2021	16.50	03/06/2021	18.38	T	Distance Protection
Satana-Gangapur	IntraState	03/06/2021	16.52	03/06/2021	18.35	T	Distance Protection
Gangapur-Valve	IntraState	03/06/2021	18.11	03/06/2021	19.02	T	Distance Protection
Valve-Jamde	IntraState	03/06/2021	18.11	03/06/2021	18.36	T	Distance Protection
Ghatghar - Jindal	IntraState	03/06/2021	18.35	03/06/2021	19.55	T	Distance Protection
Eklahare (Gcr)(Nashik)- Ghatghar	IntraState	03/06/2021	18.45	03/06/2021	20.48	T	Distance Protection
220 KV ICT Outages/Trippings							
220/132 KV 150MVA ICT I @ Boisar	IntraState	17/05/2021	11.19		Continued.	T	ICT Failed due to internal fault.
200/132KV 100MVA ICT-1@Butibori	IntraState	02/06/2021	08..28	02/06/2021	09.18	PO	Pre-monsoon maintenance work.
220/132 kv 100 MVA ICT II @ Butibori	IntraState	02/06/2021	09.21	02/06/2021	10.03	PO	Pre-monsoon maintenance work.
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	02/06/2021	10.10	02/06/2021	13.03	PO	Pre-monsoon maintenance work.
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	02/06/2021	10.14	02/06/2021	20.00	PO	1)Premonsoon maintenance work 2)Routine maintenance work 3)100kv isolator work.
220/132 KV 200MVA ICT I @ Kanhan	IntraState	02/06/2021	10.16	02/06/2021	11.04	PO	Pre-monsoon maintenance work.
220/132kv 100 Mva Cgl Ict 1 @Bhugaon	IntraState	02/06/2021	10.39	02/06/2021	12.22	PO	Pre-monsoon maintenance work.
220/132 Kv 150 Mva Cgl Ptr No 7 @Chinchwad	IntraState	02/06/2021	10.58	02/06/2021	12.38	PO	Premonsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 1 @Beed	IntraState	02/06/2021	11.01	02/06/2021	12.05	PO	Pre-monsoon maintenance work.
220/132kv 200 Mva Aditya Vidyut Ict 2 @Kanhan	IntraState	02/06/2021	11.10	02/06/2021	11.54	PO	Pre-monsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 2 @Beed	IntraState	02/06/2021	12.11	02/06/2021	12.56	PO	Pre-monsoon maintenance work.
220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	IntraState	02/06/2021	12.54	02/06/2021	14.14	PO	Premonsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 1 @Kalmeshwar	IntraState	02/06/2021	13.45	02/06/2021	15.25	PO	Pre-monsoon maintenance work.
220/132 Kv 200 MVA ICT II @Kalmeshwar	IntraState	02/06/2021	15.53	02/06/2021	17.08	PO	Pre-monsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded	IntraState	02/06/2021	16.25	02/06/2021	17.52	PO	Pre-monsoon maintenance work.
220/132 Kv 100 Mva Ict 1 @Bhokardan	IntraState	02/06/2021	17.01	02/06/2021	18.46	PO	Pre-monsoon maintenance work.
220/132 Kv 100 Mva Emco Ict @Shahada	IntraState	03/06/2021	07.05	03/06/2021	09.15	PO	Gantry String replacement work
Salsette : 220 / 110 / 22 250 MVA ICT 2	IntraState	03/06/2021	08.48	03/06/2021	12.16	PO	work in vicinity of cable sealing
220/132 KV 100MVA ICT-I @ Bhokar	IntraState	03/06/2021	14.00	03/06/2021	15.48	PO	Pre Monsoon Maintenance work
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	03/06/2021	18.13	03/06/2021	20.05	PO	Attending Oil Leakage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage