

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Jun/2024 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.367	327.508	1) Gujrat	-0.517	3.350
2) Hydro	16.798	32.709	2) Madhya Pradesh	3.931	7.978
3) Gas	6.981	14.069	3) Chattisgarh	3.410	5.840
Total MSPGCL	183.146	374.286	4) Maharashtra	206.749	410.009
B) 1) APLM	70.185	139.201	5) Goa (Amona)	-2.407	-4.691
2) JSWEL	27.676	55.230	Total	211.166	422.486
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.002	84.186
4) RPL(AMT)	25.449	51.132	b) Mumbai Drawl	43.134	87.598
5) SWPGPL	11.723	23.565	c) MSEDCL Bilateral *	96.700	195.807
6) Other IPP	15.857	31.841	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.002	84.186
C) 1) TPCL Thermal	11.130	25.827	Include PX	0.000	0.000
2) TPCL Hydro	3.647	9.096	Standby	0.000	0.000
3) TPCL Gas	4.128	8.256	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.874	22.344	1) MSEDCL	528.630	1069.362
D) STATE			2) Mumbai Discoms	72.913	153.121
1) Thermal	332.261	676.648	3) Other Discoms	10.774	21.959
(A1+C1+C4+(B1-B6))			TOTAL STATE	612.317	1244.442
2) Hydro	20.445	41.805			
3) Gas	11.109	22.325			
4) Wind	20.953	47.686			
6) SOLAR	16.383	33.492			
TOTAL STATE	401.151	821.956			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6411	6744	6738	6602
MSPGCL Hydro	128	777	675	286
MSPGCL Gas	279	278	285	284
MSPGCL Total Generation	6818	7799	7698	7172
Central Sector Receipt	9651	9402	8341	8663
WIND	526	417	1139	736
CPP / IPP Thermal	5261	6494	6632	6281
CPP / IPP Gas	0	0	0	0
SOLAR	2211	1231	0	515
Exchange with Mumbai	-1840	-2042	-1747	-1577
MSEDCL DEMAND MET	22173	22820	21577	21352
Load Shedding	0	0	0	0
MSEDCL DEMAND	22173	22820	21577	21352
TPCL GENERATION	688	770	906	642
AEML GENERATION	444	456	492	390
MUMBAI DEMAND	2972	3268	3145	2609
OTHER DISCOM DEMAND	454	481	486	438
STATE DEMAND MET	25599	26569	25208	24399
STATE DEMAND	25599	26569	25208	24399
Frequency (Hz)	49.93	50.03	49.99	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.13 Hz at 19.02 Hrs	49.68 Hz at 22.55 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 02/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.26	8.15	190	159
Unit 8	13.32	27.40	592	525
Unit 9	3.97	3.97	520	0
Unit 10	13.37	26.94	590	501
Total	34.92	66.47		
Bhusawal				
Unit 3	2.28	2.28	160	0
Unit 4	10.37	21.36	480	350
Unit 5	9.98	20.70	490	325
Total	22.63	44.34		
Parli				
Unit 6	4.95	10.00	247	142
Unit 7	4.88	9.91	241	147
Unit 8	4.69	9.28	233	147
Total	14.52	29.19		
Chandrapur				
Unit 3	3.79	7.55	162	150
Unit 4	3.83	7.66	166	145
Unit 5	5.77	15.27	420	175
Unit 6	7.91	17.11	405	190
Unit 7	9.45	18.79	405	355
Unit 8	10.59	21.26	453	415
Unit 9	10.25	21.70	500	0
Total	51.59	109.33		
Paras				
Unit 3	1.27	6.48	223	0
Unit 4	0.00	0.58	0	0
Total	1.27	7.06		
Khaparkheda				
Unit 1	3.76	7.48	160	145
Unit 2	4.76	8.92	208	187
Unit 3	0.43	4.10	147	0
Unit 4	4.48	8.62	192	176
Unit 5	10.95	22.26	470	399
Total	24.38	51.37		
Nasik				
Unit 3	3.50	6.37	162	121
Unit 4	3.26	6.57	143	123
Unit 5	3.30	6.82	159	119
Total	10.06	19.76		
Uran				
All Units	6.98	14.07	376	276
Total	6.98	14.07		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	4.86	9.62	495	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.90	13.19	1008	0
Stage 3	2.38	4.91	320	0
Total	14.14	27.71		
Hydro				
KDPH	0.48	0.98	20	20
VTRNA	0.42	0.83	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.53	2.94	69	58
GHATGHAR	0.24	0.24	125	0
Total	2.66	5.00		
Wind				
Total	20.95	47.69	0	0
Total	20.95	47.69		
CPP				
APML(Mus)	70.18	139.20	0	0
JSWEL(Mus)	27.68	55.23	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.45	51.13	0	0
SWPGPL-Mus	11.72	23.56	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.05	12.12	269	233
Other(Mus)	5.38	10.84	0	0
JPL	4.43	8.88	270	128
Total	150.89	300.97		
SOLAR				
Total	16.38	33.49	0	0
Total	16.38	33.49		
Tata				
Trombay 5	7.37	17.02	455	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	5.18	108	108
Trombay 7B	1.54	3.07	64	64
TATA Hydro	3.65	9.10	414	42
Trombay 8	3.76	8.80	223	129
Total	18.90	43.18		
AEML				
DTPS U-1&2	10.87	22.34	503	357
Total	10.87	22.34		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.37	327.51	MSPGCL Total	183.15	374.29
			MSPGCL Thml+Gas	166.35	341.58	Koyna 1,2 & 4 Total	11.76	22.80
			MSPGCL Hydro	16.80	32.71	State Total	401.15	821.96

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 02/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7096	1758	376	9230	1406	6744	0	0	8703	8258	-1839	23386	0	0	23386	3444	412	27243	50.00
2	7041	1198	364	8603	1352	6736	0	0	8839	8599	-1824	23080	0	0	23080	3364	386	26830	50.00
3	6963	787	288	8038	1485	6763	0	0	9292	8919	-1724	23127	0	0	23127	3069	355	26550	50.01
4	6894	364	289	7547	1434	6717	0	0	9500	9219	-1830	22706	0	0	22706	2928	381	26015	50.01
5	6935	365	289	7589	1206	6708	0	0	9202	8938	-1693	22371	0	0	22371	2829	377	25577	49.99
6	6808	1162	290	8260	962	6702	0	0	9112	8951	-1597	22865	0	0	22865	2791	413	26069	50.00
7	6606	1057	287	7950	742	6474	0	129	9406	8862	-1567	22157	0	6	22157	2671	432	25261	49.99
8	6602	286	284	7172	736	6281	0	515	8926	8663	-1577	21352	0	22	21352	2609	438	24399	49.97
9	6448	209	289	6946	699	5606	0	1162	8902	8762	-1597	21128	0	11	21128	2650	450	24228	49.97
10	6502	124	281	6907	551	5401	0	1730	8839	8815	-1632	21293	0	16	21293	2763	480	24535	49.97
11	6469	132	281	6882	481	5530	0	2154	9322	8875	-1766	21684	0	26	21684	2875	472	25031	49.95
12	6411	128	279	6818	526	5261	0	2211	9677	9651	-1840	22173	0	66	22173	2972	454	25599	49.93
13	6464	171	278	6913	319	5511	0	2238	9471	9330	-1924	21935	0	64	21935	3016	452	25403	49.99
14	6250	421	276	6947	263	5803	0	2020	9277	9099	-1984	21688	0	28	21688	3062	460	25210	49.94
15	6559	423	276	7258	340	6346	0	1715	9615	9579	-2052	22714	0	42	22714	3179	472	26365	50.00
16	6744	777	278	7799	417	6494	0	1231	9755	9402	-2042	22820	0	44	22820	3268	481	26569	50.03
17	6775	265	280	7320	790	6354	0	834	10280	9254	-1999	22076	0	34	22076	3190	477	25743	50.20
18	6332	274	281	6887	1141	5982	0	399	9852	9272	-2019	21179	0	21	21179	3018	483	24680	49.98
19	6386	365	283	7034	805	6124	0	45	9191	8697	-1956	20243	0	0	20243	2926	506	23675	50.01
20	6701	692	285	7678	924	6485	0	0	9260	8939	-1940	21590	0	0	21590	3043	495	25129	50.02
21	6738	675	285	7698	1139	6632	0	0	8849	8341	-1747	21577	0	0	21577	3145	486	25208	49.99
22	6673	1162	286	8121	1126	6692	0	0	7714	7572	-1611	21429	0	0	21429	3229	471	25129	49.93
23	6594	1969	287	8850	1086	6759	0	0	7627	7421	-1636	22013	57	0	22070	3367	468	25904	49.88
24	6376	2034	289	8699	1023	6786	0	0	7895	7748	-1738	22044	763	0	22807	3505	474	26786	49.97
MUs	159.37	16.80	6.98	183.15	20.95	150.89	0.00	16.38	218.51	211.17	-43.13	528.63	0.82	0.38	529.45	72.91	10.77	613.14	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) 132 KV BBLR TO Rahuri line over Load Alarm 488 AMP/102.10 MW.2)Due to higher loading DLS carried out at solapur circle.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 02/Jun/2024

Position as on 6.30 Hrs of 03/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Koradi Unit 9	660	28/05/2024	22:12	02/06/2024	14:25	Boiler Tube Leakage	02/06/2024
MSPGCL	Bhusawal Unit 3	210	29/05/2024	02:31	02/06/2024	06:24	Boiler Tube Leakage	02/06/2024
MSPGCL	Paras Unit 4	250	01/06/2024	02:27		Continued.	Drum level low	04/06/2024
MSPGCL	Khaparkheda Unit 3	210	02/06/2024	03:05		Continued.	Boiler Tube Leakage	04/06/2024
MSPGCL	Paras Unit 3	250	02/06/2024	06:16	03/06/2024	02:23	Valve malfunction operate.	
MSPGCL	Bhusawal Unit 3	210	02/06/2024	06:37	02/06/2024	06:56	Low Vaccum	02/06/2024
MSPGCL	Chandrapur Unit 9	500	02/06/2024	22:52		Continued.	Condenser Vacuum low	03/06/2024
MSPGCL	Bhusawal Unit 3	210	03/06/2024	00:30		Continued.	Boiler Tube Leakage	
Total Capacity MSPGCL		2745						
IPP								
IPP	RPL(AMT) U-4	270	28/05/2024	18:57		Continued.	Due to ID Fan tripped on high vibration..	28/06/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3335						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	02/06/2024	02:00		Continued.	Due to Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Jun/2024

Position as on 6.30 Hrs of 03/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
220 KV PARLI (400 KV)- GIRWALI I/C -2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	02/06/2024	07:15	02/06/2024	10:20	PO	Pre-monsoon maintenance activity
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34			PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay
132 kv GHATODI ARNI	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104) .
132 KV GHATODI (220 KV) - DIGRAS CKT	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104).
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
GORAI -MSETCL BORIVALI CKT -1	IntraState	28/05/2024	17:59			T	Bus fault
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
GORAI -MSETCL BORIVALI CKT -2	IntraState	28/05/2024	17:59	02/06/2024	20:00	T	Bus fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
MHAISAL - ALKUD	IntraState	01/06/2024	17:48	02/06/2024	02:24	PO	Wedge connector work
BUTIBORI 3-PURTI	IntraState	01/06/2024	19:28	02/06/2024	02:57	T	Distance protection
KALWA - SIEMENS	IntraState	01/06/2024	22:26	02/06/2024	06:33	PO	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48 (Total 18 sets out of 18 sets are to be installed)
KHARGHAR - BORIVALI CKT - 2	IntraState	01/06/2024	22:27	02/06/2024	06:39	PO	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48, 27/3 & 28 (Total 24 sets out of 66 sets are to be installed, total completed - 6 sets

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	01/06/2024	22:53	02/06/2024	03:44	PO	Replacement of old disc insulator with porcelain long rod insulator strings,
KAMBA - VASAI	IntraState	02/06/2024	04:39	03/06/2024	01:17	PO	work 1) Cut point formation over newly erected Monopole work will be carry out at loc.no.48,49 and amp;49A on 220kV Kamba-Vasai line and also related tower 65533;s conductor destringing & stringing work will be carry out of above said ckt. 2) Dismantling work of old existing tower at Loc.No.48 &49
KAMBA - VASAI	IntraState	02/06/2024	04:39	03/06/2024	01:17		1) Cut point formation over newly erected monopole & work will be carried out at loc no 4 9 and also related de-stringing & stringing work will be carried out. 2) Dismantling of old existing tower no. 53 & 54. 3) After cut point formation & conductor stringing work kamba-Vasai line will be charged at 22:00 Hrs of 02.06.2024.
KAMBA - VASAI	IntraState	02/06/2024	04:39	03/06/2024	01:17		Work of replacement of old C&R panel by new and diagnostic testing work
WAGHIVALI - DHARAVI 8	IntraState	02/06/2024	05:59	02/06/2024	15:57	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	IntraState	02/06/2024	06:03	02/06/2024	16:00	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site
GADCHANDUR - VIRUR-I	IntraState	02/06/2024	09:54	02/06/2024	11:13	EO	Attending Hotspot work R-ph CT clamp
BHUGAON - WARDHA (PG)	IntraState	02/06/2024	23:10	03/06/2024	00:10	HT	H/T due to State OD at Low frequency.
PALGHAR - NALASOPARA	IntraState	03/06/2024	04:27			PO	Replacement of Insulator String Identified in PID.
KHADKI- CENTURY ENKA	IntraState	03/06/2024	07:08			PO	Stringing of conductor from loc 30-30A and stringing of earthwire loc 29A-30 river crossing.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	03/06/2024	08:46			PO	Routine maintenance
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220 / 110 / 33kV 250MVA AT 1 @ BACKBAY	IntraState	02/06/2024	10:14	02/06/2024	17:45	PO	33KV side cable termination replacement work
220/33KV 50MVA T/F-I @ BRIDGESTONE	IntraState	02/06/2024	10:35	02/06/2024	14:10	PO	Diagnostic testing work, half Yearly and pre monsoon maintenance .
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	02/06/2024	12:14	02/06/2024	15:27	PO	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	02/06/2024	15:34	02/06/2024	17:17	PO	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	02/06/2024	17:21	02/06/2024	19:49	PO	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance
220/33 kV 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	03/06/2024	09:24			PO	Quarterly maint. work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 03/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
WAGHIVALI - CHEMBUR	IntraState	02/06/2024	05:44	02/06/2024	16:19	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site
WAGHIVALI - MANKHURD	IntraState	02/06/2024	05:50	02/06/2024	16:29	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage