

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Aug/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	118.205	234.065	1) Gujrat	8.937	16.484
2) Hydro	10.359	21.474	2) Madhya Pradesh	5.321	10.284
3) Gas	0.000	0.000	3) Chattisgarh	2.360	3.830
Total MSPGCL	128.564	255.539	4) Maharashtra	150.149	298.275
B) 1) APLM	42.081	83.547	5) Goa (Amona)	-1.574	-3.383
2) JSWEL	15.498	33.394	Total	165.193	325.490
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.815	70.165
4) RPL(AMT)	25.053	49.343	b) Mumbai Drawl	40.316	79.592
5) SWPGPL	6.720	13.303	c) MSEDCL Bilateral *	99.323	194.224
6) Other IPP	5.882	11.884	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.815	70.165
C) 1) TPCL Thermal	9.658	19.556	Include PX	0.000	0.000
2) TPCL Hydro	4.225	8.583	Standby	0.000	0.000
3) TPCL Gas	2.334	4.913	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.413	16.530	1) MSEDCL	414.501	820.431
D) STATE			2) Mumbai Discoms	64.946	129.174
1) Thermal	231.510	461.622	3) Other Discoms	10.054	20.050
(A1+C1+C4+(B1-B6))			TOTAL STATE	489.501	969.655
2) Hydro	14.584	30.057			
(A2+C2)					
3) Gas	2.334	4.913			
(A3+B7+C3)					
4) Wind	67.492	128.439			
6) SOLAR	8.388	19.134			
TOTAL STATE	324.308	644.165			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5061	4507	5217	5183
MSPGCL Hydro	728	393	528	311
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5789	4900	5745	5494
Central Sector Receipt	8287	7637	7472	5246
WIND	2845	3053	2798	2565
CPP / IPP Thermal	3950	3541	4928	3834
CPP / IPP Gas	0	0	0	0
SOLAR	617	1082	0	0
Exchange with Mumbai	-1834	-2359	-1546	-1100
MSEDCL DEMAND MET	19217	17406	18941	15717
Load Shedding	0	0	0	0
MSEDCL DEMAND	19217	17406	18941	15717
TPCL GENERATION	611	602	935	556
AEML GENERATION	365	288	455	304
MUMBAI DEMAND	2810	3249	2936	1960
OTHER DISCOM DEMAND	436	448	456	322
STATE DEMAND MET	22464	21103	22333	17999
STATE DEMAND	22464	21103	22333	17999
Frequency (Hz)	49.98	50.03	49.99	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.29 Hz at 13.17 Hrs	49.82 Hz at 09.06 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 02/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.22	6.59	155	110
Unit 8	12.24	23.38	578	372
Unit 9	11.92	23.82	560	373
Unit 10	0.00	0.00	0	0
Total	27.37	53.78		
Bhusawal				
Unit 3	2.78	5.63	125	105
Unit 4	8.34	16.92	455	280
Unit 5	6.62	13.40	450	0
Total	17.74	35.95		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	2.81	4.95	143	74
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.24	14.40	335	275
Unit 7	7.17	14.07	329	262
Unit 8	9.73	18.98	441	285
Unit 9	10.08	20.11	458	324
Total	37.03	72.51		
Paras				
Unit 3	4.42	8.68	211	142
Unit 4	4.02	7.88	193	141
Total	8.44	16.56		
Khaparkheda				
Unit 1	2.22	4.48	100	85
Unit 2	2.84	5.60	125	109
Unit 3	3.50	7.08	175	126
Unit 4	3.75	7.33	189	127
Unit 5	8.47	17.41	415	280
Total	20.78	41.89		
Nasik				
Unit 3	3.53	6.89	172	124
Unit 4	0.00	0.00	0	0
Unit 5	3.31	6.48	165	116
Total	6.84	13.37		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.90	2.11	50	0
Total	0.90	2.11		
Koyna				
Stage 1-2	2.04	3.73	300	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	0.86	0	0
Stage 3	1.42	2.98	80	0
Total	3.46	7.57		
Hydro				
KDPH	0.86	1.60	36	36
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.44	0.90	80	0
SMLHY_PTN	4.46	8.65	191	179
GHATGHAR	0.23	0.64	125	0
Total	6.00	11.79		
Wind				
Total	67.49	128.44	0	0
Total	67.49	128.44		
CPP				
APML(Mus)	42.08	83.55	0	0
JSWEL(Mus)	15.50	33.39	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.05	49.34	0	0
SWPGPL-Mus	6.72	13.30	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.89	9.72	254	154
Other(Mus)	0.99	2.17	0	0
Total	95.23	191.47		
SOLAR				
Total	8.39	19.13	0	0
Total	8.39	19.13		
Tata				
Trombay 5	6.50	13.02	330	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.31	2.80	108	39
Trombay 7B	1.02	2.12	65	36
TATA Hydro	4.22	8.58	371	88
Trombay 8	3.16	6.53	160	128
Total	16.22	33.05		
AEML				
DTPS U-1&2	8.41	16.53	500	288
Total	8.41	16.53		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	118.20	234.06	MSPGCL Total	128.56	255.54
			MSPGCL Thml+Gas	118.20	234.06	Koyna 1,2 & 4 Total	2.04	4.60
			MSPGCL Hydro	10.36	21.47	State Total	324.31	644.16

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 02/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	4560	313	0	4873	2521	4101	0	0	6119	5811	-1305	15621	0	0	15621	2296	379	18297	49.99
2	4697	320	0	5017	2625	3773	0	0	5882	5692	-1195	15562	0	0	15562	2136	350	18048	50.02
3	5102	396	0	5498	2649	3883	0	0	5227	5091	-1132	15653	0	0	15653	2036	337	18025	49.99
4	5183	311	0	5494	2565	3834	0	0	5412	5246	-1100	15717	0	0	15717	1960	322	17999	50.02
5	5229	308	0	5537	2563	3800	0	0	6178	5708	-1097	16166	0	0	16166	1960	345	18471	50.02
6	5112	314	0	5426	2561	3860	0	0	7103	6921	-1160	17249	0	0	17249	2078	359	19686	49.97
7	5380	625	0	6005	2546	4203	0	61	7382	7250	-1126	18542	0	0	18542	2282	396	21221	49.96
8	5365	509	0	5874	2528	4213	0	306	8236	7764	-1471	18799	0	0	18799	2485	415	21699	49.99
9	5061	728	0	5789	2845	3950	0	617	8409	8287	-1834	19217	0	0	19217	2810	436	22464	49.98
10	5182	428	0	5610	2924	3974	0	893	7977	7902	-2069	18775	0	0	18775	3100	459	22334	49.97
11	4796	391	0	5187	2913	3650	0	1062	8347	8316	-2362	18308	0	0	18308	3278	458	22044	50.03
12	4395	561	0	4956	3034	3594	0	1197	7996	8104	-2379	18043	0	0	18043	3309	463	21815	50.07
13	4507	393	0	4900	3053	3541	0	1082	7766	7637	-2359	17406	0	0	17406	3249	448	21103	50.03
14	4187	390	0	4577	2995	3176	0	1039	7564	7242	-2198	16402	0	0	16402	3122	429	19953	50.09
15	4232	475	0	4707	3318	3565	0	767	7411	7396	-2173	17151	0	0	17151	3122	429	20702	49.97
16	4544	433	0	4977	3059	3622	0	658	7318	7377	-2192	17042	0	0	17042	3138	459	20639	49.98
17	5029	586	0	5615	2867	3613	0	435	7094	6924	-2102	16898	0	0	16898	3087	454	20439	49.97
18	5436	333	0	5769	2829	3887	0	224	7069	7004	-1939	17310	0	0	17310	3039	463	20813	49.94
19	5279	391	0	5670	2592	4565	0	47	7357	7220	-1783	17842	0	0	17842	2979	469	21290	49.97
20	5217	528	0	5745	2798	4928	0	0	7692	7472	-1546	18941	0	0	18941	2936	456	22333	49.99
21	5040	529	0	5569	2928	4928	0	0	7100	6741	-1515	18209	0	0	18209	2823	442	21474	50.00
22	4973	412	0	5385	2769	4559	0	0	6615	6341	-1477	17138	0	0	17138	2685	438	20262	49.99
23	4956	338	0	5294	3012	4199	0	0	6533	5915	-1380	16611	0	0	16611	2563	428	19603	49.98
24	4743	347	0	5090	2998	3819	0	0	6376	5832	-1422	15899	0	0	15899	2473	418	18790	49.99
MUs	118.21	10.36	0.00	128.56	67.49	95.23	0.00	8.39	170.16	165.19	-40.32	414.50	0.00	0.00	414.50	64.95	10.05	489.50	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 02/Aug/2023

Position as on 6.30 Hrs of 03/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
MSPGCL	Nasik Unit 4	210	19/07/2023	10:50		Continued.	ID Fan Problem(under tolling from 06.04 Hrs DT. 20-7-2023)	
IPP	SWPGPL U-3	135	21/07/2023	01:54		Continued.	Non-availability of linkage coal stock and due to continuous rains.	03/08/2023
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	DUE TO HPT DIFFERENTIAL EXPANSION ON HIGHER SIDE	22/08/2023
MSPGCL	Uran Unit 6	108	27/07/2023	20:10		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	28/07/2023	15:30		Continued.	Zero Schedule.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Aug/2023

Position as on 6.30 Hrs of 03/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 8	250	28/07/2023	21:07		Continued.	Zero Schedule.	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	06/08/2023
MSPGCL	Bhusawal Unit 5	500	02/08/2023	07:47	02/08/2023	10:19	Flame Failure	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 02/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 03/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
765/400KV 1500 MVA ICT-1 @ TIRORA	IntraState	02/08/2023	09:42			PO	Annual Maintenance of Transformer. Annual maintenance of main bay and tie bay equipments.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV TBC Outages/Trippings							
BUS COUPLER @ BABHALESHWAR	IntraState	02/08/2023	09:20			PO	ABB Circuit Breaker Pole & Mechanism overhauling
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 406 OF CHANDRAPUR CKT - 1 @ BHADRAVATI	InterState	02/08/2023	09:23	02/08/2023	14:34	PO	AMP Works
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\Delta Y \Delta$ phase Protection CT Of NTPP I (RPL 1)
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03			PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
KHADKA-AURANGABAD (WALUJ)	IntraState	01/08/2023	22:15	02/08/2023	07:46	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 1	IntraState	02/08/2023	00:00	02/08/2023	07:45	HT	H/T on overvoltage
KHADKA-AURANGABAD (WALUJ)	IntraState	02/08/2023	21:57	03/08/2023	07:58	HT	H/T for voltage management.
MAIN BUS - 2 @ LONIKAND 2	IntraState	03/08/2023	09:00			PO	RRS Jumpering work
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	03/08/2023	10:49			PO	400 kV Deepnagar - Aurangabad to be kept OFF as per MSPGCL requirement during outage on 400 kV Main Bus-1
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44			PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	03/08/2023	09:02			PO	RRS Jumpering work
400 KV BUSBAR Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 02/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 03/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400KV MAIN BUS 1 @ 400KV DEEPNAGAR	IntraState	03/08/2023	11:30			PO	For Connecting jumpers of Station 6A Main Bay & GT-6 Main Bay to 400 kV Main Bus-1
220 KV TIEBAY Outages/Trippings							
HYBRID SWITCHGEAR (245kV) @ THEUR	IntraState	03/08/2023	12:03	03/08/2023	16:33	PO	Resolving issue with earth switch heater AC circuit of mechanism drive of 245kV Hybrid Switchgear.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
GHODBUNDER - MSETCL BOISAR	IntraState	02/08/2023	07:43	02/08/2023	19:03	PO	For the replacement of old hardwares at various critical locations.
BORIVALI - BOISAR II LINE	IntraState	02/08/2023	07:52	02/08/2023	19:10	PO	For the replacement of old hardwares at various critical locations.
LONAND-BARAMATI	IntraState	02/08/2023	08:30	02/08/2023	19:59	HT	For load management
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	02/08/2023	08:46	02/08/2023	19:55	PO	Replacement of Damaged conductor at cut point locations.
MUMEWADI -HALKARNI 2 LINE	IntraState	02/08/2023	09:13	02/08/2023	14:24	PO	For replacement of Puncture insulator
URAN - KHARGHAR 2	IntraState	02/08/2023	09:25	03/08/2023	17:12	PO	OPGW stringing work by Project Dn Kalwa
KHAPARKHEDA-KALMESHVAR	IntraState	02/08/2023	10:14	02/08/2023	12:45	PO	For Replacement Of Flashover String At Location No.71.
MAIN BUS @ TEMBHURNI	IntraState	02/08/2023	10:40	02/08/2023	12:50	PO	Outage is required for Quarterly Maintenance
TEMBHURNI - JEUR	IntraState	02/08/2023	10:40	02/08/2023	12:50	PO	Outage is required for Quarterly Maintenance
TBC @ SOUTH SOLAPUR	IntraState	02/08/2023	14:00	02/08/2023	17:01	PO	Outage is required for Quarterly Maintenance
VANKUSWADE - KDPH	IntraState	02/08/2023	14:30	02/08/2023	21:10	T	TRIPPED ON DISTANCE PROTECTION ONLY FROM KDPH END
HALKARNI - TILARI LINE	IntraState	02/08/2023	14:57	02/08/2023	18:26	PO	For replacement of Puncture insulator
LONAND-BARAMATI	IntraState	03/08/2023	08:26			HT	for load management
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	03/08/2023	08:30			PO	Replacement of Damaged conductor at cut point locations.
HALKARNI-MAHALAXMI LINE	IntraState	03/08/2023	09:17	03/08/2023	13:09	PO	For replacement of Puncture insulator
BORIVALI - TARAPUR	IntraState	03/08/2023	12:10			PO	Replacement of old hardware at critical location
BORIVALI - BOISAR (PG)	IntraState	03/08/2023	12:14			PO	Replacement of old hardware at critical location
BOMBAY DYEING - SAHARA	IntraState	03/08/2023	12:24			T	Tripped on distance protection
APTA - BOMBAY DYEING	IntraState	03/08/2023	12:24			T	Tripped on distance protection
MUMEWADI -HALKARNI 1 LINE	IntraState	03/08/2023	14:10	03/08/2023	16:25	PO	For replacement of Puncture insulator
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	02/08/2023	07:05	02/08/2023	10:05	EO	To check & attend oil leakage from Top Plate of 220/100 KV 100 MVA ICT 1 @ VASAI-II.
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	IntraState	02/08/2023	10:47	02/08/2023	12:27	PO	Outage is required for Quarterly Maintenance
220/33-33 KV 100 MVA PTR No.2 @ BOISAR-II	IntraState	02/08/2023	17:30	02/08/2023	18:16	T	TRIPPED ON DIFFERENTIAL PROTECTION, LV1 Y-PHASE CT BURST

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 02/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 03/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33-33 KV 100 MVA PTR 2 @ BOISAR-II	IntraState	02/08/2023	19:41	02/08/2023	20:06	HT	Yph CT is replaced with new one and for confirmation of current injection, 100MVA TF2 HT is required.
220/100 KV 200 MVA ICT 2 @ TALOJA	IntraState	03/08/2023	10:10	03/08/2023	16:30	PO	Y-ph CT Hot-spot attending work & Jumper replacement work
220/132 KV 100 MVA ICT - 1 @KALWAN	IntraState	03/08/2023	10:57	03/08/2023	12:53	PO	Maintenance work
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIVPURI - AMBERNATH CKT - 1	IntraState	02/08/2023	10:11	02/08/2023	12:35	PO	Tree trimming

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage