

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Sep/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	133.397	257.330	1) Gujrat	8.174	15.996
2) Hydro	18.668	29.836	2) Madhya Pradesh	2.736	6.414
3) Gas	2.943	5.672	3) Chattisgarh	3.310	6.790
Total MSPGCL	155.008	292.838	4) Maharashtra	170.195	341.591
B) 1) APLM	61.460	110.409	5) Goa (Amona)	-0.749	-1.283
2) JSWEL	20.505	39.636	Total	183.666	369.508
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.970	63.609
4) RPL(AMT)	11.104	21.590	b) Mumbai Drawl	36.892	69.897
5) SWPGPL	5.388	10.863	c) MSEDCL Bilateral *	44.679	110.815
6) Other IPP	6.342	12.603	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.956	63.595
C) 1) TPCL Thermal	12.262	25.322	Include PX	0.000	0.000
2) TPCL Hydro	6.095	13.469	Standby	0.014	0.014
3) TPCL Gas	2.505	3.448	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.992	20.581	1) MSEDCL	412.691	801.819
D) STATE			2) Mumbai Discoms	67.745	132.716
1) Thermal	260.450	498.334	3) Other Discoms	9.241	18.466
(A1+C1+C4+(B1-B6))			TOTAL STATE	489.677	953.001
2) Hydro (A2+C2)	24.763	43.305			
3) Gas (A3+B7+C3)	5.448	9.120			
4) Wind	4.998	11.903			
6) SOLAR	10.353	20.832			
TOTAL STATE	306.012	583.494			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5500	5614	5621	5643
MSPGCL Hydro	440	469	1908	283
MSPGCL Gas	118	110	109	110
MSPGCL Total Generation	6058	6193	7638	6036
Central Sector Receipt	8580	8592	7966	6458
WIND	303	139	80	236
CPP / IPP Thermal	3820	4327	5069	4188
CPP / IPP Gas	0	0	0	0
SOLAR	1317	951	0	0
Exchange with Mumbai	-2312	-2177	-1410	-884
MSEDCL DEMAND MET	17354	17598	18935	15728
Load Shedding	0	0	0	0
MSEDCL DEMAND	17354	17598	18935	15728
TPCL GENERATION	685	741	1218	927
AEML GENERATION	400	429	499	421
MUMBAI DEMAND	3397	3347	3127	2232
OTHER DISCOM DEMAND	411	428	408	306
STATE DEMAND MET	21163	21372	22470	18266
STATE DEMAND	21163	21372	22470	18266
Frequency (Hz)	49.97	49.98	49.81	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 08.51 Hrs	49.5 Hz at 19.18 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 02/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.74	6.96	185	100
Unit 7	0.00	0.00	0	0
Unit 8	11.49	22.48	502	430
Unit 9	0.00	0.00	0	0
Unit 10	11.42	22.40	505	437
Total	26.65	51.84		
Bhusawal				
Unit 3	3.14	5.44	150	100
Unit 4	9.44	17.77	430	330
Unit 5	0.00	0.00	0	0
Total	12.59	23.21		
Parli				
Unit 6	4.58	8.88	206	160
Unit 7	4.39	8.59	198	155
Unit 8	4.32	8.30	190	162
Total	13.30	25.76		
Chandrapur				
Unit 3	3.46	6.74	164	125
Unit 4	3.58	6.60	158	120
Unit 5	0.00	0.00	0	0
Unit 6	7.96	15.68	360	285
Unit 7	7.44	15.29	380	246
Unit 8	10.80	20.23	470	392
Unit 9	10.45	20.22	461	367
Total	43.69	84.76		
Paras				
Unit 3	4.86	9.46	238	162
Unit 4	4.55	8.92	206	173
Total	9.41	18.38		
Khaparkheda				
Unit 1	2.88	5.48	135	105
Unit 2	2.86	5.22	135	90
Unit 3	3.63	6.96	175	135
Unit 4	3.98	7.46	193	143
Unit 5	8.49	16.55	400	285
Total	21.83	41.67		
Nasik				
Unit 3	3.14	6.12	144	116
Unit 4	0.00	0.00	0	0
Unit 5	2.79	5.60	126	101
Total	5.93	11.72		
Uran				
All Units	2.94	5.67	187	107
Total	2.94	5.67		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	1.19	25	25
Total	0.60	1.19		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.44	6.09	430	35
Stage 4	4.40	5.58	748	0
Stage 3	1.81	2.58	240	0
Total	10.66	14.25		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.67	1.47	60	0
TILLARI	0.52	1.04	58	0
BHIRA T.R.	0.46	0.94	60	0
SMLHY_PTN	5.24	10.26	227	202
GHATGHAR	0.53	0.69	125	0
Total	7.42	14.40		
Wind				
Total	5.00	11.90	0	0
Total	5.00	11.90		
CPP				
APML(Mus)	61.46	110.41	0	0
JSWEL(Mus)	20.50	39.64	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	11.10	21.59	0	0
SWPGPL-Mus	5.39	10.86	0	0
Other(Mus)	6.34	12.60	0	0
Total	104.80	195.10		
SOLAR				
Total	10.35	20.83	0	0
Total	10.35	20.83		
Tata				
Trombay 5	8.26	17.07	449	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.44	2.15	113	41
Trombay 7B	1.07	1.29	66	36
TATA Hydro	6.10	13.47	446	26
Trombay 8	4.00	8.26	231	128
Total	20.86	42.24		
AEML				
DTPS U-1&2	9.99	20.58	499	322
Total	9.99	20.58		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	133.40	257.33	MSPGCL Total	155.01	292.84
			MSPGCL Thml+Gas	136.34	263.00	Koyna 1,2 & 4 Total	8.85	11.67
			MSPGCL Hydro	18.67	29.84	State Total	306.01	583.49

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 02/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5708	290	110	6108	204	4312	0	0	6453	6662	-927	15999	0	15999	2552	360	18911	50.00
2	5668	284	121	6073	208	4279	0	0	6658	6614	-847	15989	0	15989	2375	338	18702	50.00
3	5643	283	110	6036	236	4188	0	0	6844	6458	-884	15728	0	15728	2232	306	18266	50.01
4	5612	287	121	6020	233	4076	0	0	6998	6909	-939	16008	0	16008	2115	291	18414	50.00
5	5614	292	110	6016	248	4433	0	0	6918	7204	-1122	16467	0	16467	2081	312	18860	50.00
6	5612	655	111	6378	269	4465	0	0	6972	6589	-1012	16358	0	16358	2148	331	18837	50.00
7	5577	1484	120	7181	450	4434	0	60	6732	7015	-1014	17765	0	17765	2224	361	20350	49.98
8	5615	1046	112	6773	449	4352	0	377	7429	7612	-1341	17824	0	17824	2394	398	20616	50.00
9	5582	402	123	6107	409	4278	0	824	8400	8056	-1739	17526	0	17526	2743	409	20678	50.05
10	4987	444	108	5539	419	3762	0	1155	9016	8870	-2087	17240	0	17240	3089	418	20747	50.00
11	5299	780	108	6187	366	3468	0	1233	8540	8723	-2252	17292	0	17292	3336	433	21061	50.02
12	5500	440	118	6058	303	3820	0	1317	8588	8580	-2312	17354	0	17354	3397	411	21163	49.97
13	5474	797	107	6378	231	3490	0	1335	8608	8549	-2351	17228	0	17228	3383	405	21015	49.95
14	5550	565	117	6232	159	3656	0	1212	8427	8507	-2234	17130	0	17130	3255	402	20787	50.01
15	5603	587	116	6306	118	4002	0	1059	8478	8500	-2299	17290	0	17290	3328	396	21014	49.94
16	5614	469	110	6193	139	4327	0	951	8595	8592	-2177	17598	0	17598	3347	428	21372	49.98
17	5568	441	119	6128	87	4308	0	615	8607	8574	-2003	17272	0	17272	3266	437	20975	49.97
18	5525	890	109	6524	61	4685	0	199	7949	8033	-1898	17174	0	17174	3200	430	20804	49.99
19	5560	1654	121	7335	50	4892	0	15	7449	7761	-1613	18015	0	18015	3194	425	21634	49.91
20	5621	1908	109	7638	80	5069	0	0	7479	7966	-1410	18935	0	18935	3127	408	22470	49.81
21	5646	1705	138	7489	63	5120	0	0	7409	7355	-1236	18396	0	18396	2907	395	21698	50.00
22	5657	1241	187	7085	56	5107	0	0	6984	7049	-1134	17765	0	17765	2754	398	20917	49.99
23	5633	985	168	6786	78	5143	0	0	6752	6839	-1049	17413	0	17413	2665	384	20462	49.98
24	5529	743	170	6442	82	5133	0	0	6722	6645	-1012	16923	0	16923	2634	367	19924	49.99
MUs	133.40	18.67	2.94	155.01	5.00	104.80	0.00	10.35	183.01	183.67	-36.89	412.69	0.00	412.69	67.75	9.24	489.68	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 02/Sep/2022

Position as on 6.30 Hrs of 03/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-3	250	27/08/2022	12:00	03/09/2022	18:30	Governing System Upgradation	05/09/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	05/09/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
IPP	RPL(AMT) U-5	270	19/08/2022	11:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	
IPP	Adani U-3	660	28/08/2022	23:48	02/09/2022	15:53	APH Gear Box Abnormal Sound	03/09/2022
MSPGCL	Chandrapur Unit 5	500	29/08/2022	01:00	03/09/2022	10:58	APH abnormal Sound	03/09/2022
MSPGCL	Uran Unit 6	108	30/08/2022	16:23	02/09/2022	20:07	Gas shortage	
IPP	RPL(AMT) U-4	270	31/08/2022	00:00		Continued.	Coal Shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Sep/2022

Position as on 6.30 Hrs of 03/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	03/09/2022	08:45	03/09/2022	11:35	Flame Failure	03/09/2022
MSPGCL	Chandrapur Unit 5	500	03/09/2022	18:00		Continued.	Poor Coal Receipt	
MSPGCL	Bhusawal Unit 4	500	03/09/2022	21:45		Continued.	Flame Failure	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 02/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 03/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	01/09/2022	23:13	02/09/2022	03:58	EO	For removing grass from pole-1 DC filter area and pole -1 non base filter area and anti weeding
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
JAIGAD - KARAD CKT - 2	IntraState	31/08/2022	21:21	02/09/2022	08:44	HT	H/T FOR O/V
WARORA - IEPL	IntraState	01/09/2022	07:36			PO	1. Dis-Connecting Horizontal Jumper and covert 400kV IEPL-PGCIL Deoli Ckt (Temporary Arrangement for 10 Days) 400kV IEPL-Warora Ckt. 2. Connecting 400kV IEPL-Warora through new towers.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	01/09/2022	11:52	02/09/2022	14:47	HT	Hand tripped for load control of 400 KV Kalwa Talegaon PG line.
PARLI-SOLAPUR (LAMBOTI)	IntraState	01/09/2022	18:25	02/09/2022	10:26	T	TRIPPED ON DISTANCE PROTECTION
KHADKA-AURANGABAD (WALUJ)	IntraState	01/09/2022	21:50	02/09/2022	07:36	HT	HT for Overvoltage Control
TBC 2 @ CHANDRAPUR	IntraState	02/09/2022	09:16	02/09/2022	14:22	PO	1)Measurement of CT tandelta & capacitance. 2) Maintenance and alignment of isolators.
DHULE- - BABLESHWAR - I	IntraState	02/09/2022	10:56	02/09/2022	18:29	EO	During vertical patrolling ,it is observed that at loc No. 152 and 148 Disc insulator found broken, it is necessary for replacement otherwise line will be breakdown.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	02/09/2022	15:01	03/09/2022	13:00	EO	To attend Hot Spot on 89C Aux. Bus PG Isolator
LONIKAND II - LONIKAND I (INTERCONNECTOR) - 2	IntraState	02/09/2022	15:29	02/09/2022	19:33	EO	Attending hotspot (149 degree) observed on 29A Isolator R ph IPS Tube Clamp Nut bolt of 400 kV Lonikand 1-2 Interconnector Ckt 2 by shifting load on 400KV TBC Bay
KHADKA-AURANGABAD (WALUJ)	IntraState	03/09/2022	21:57		Continued.	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							
95 MVA STN TF - II @KORADI 2	IntraState	23/08/2022	12:26	02/09/2022	18:40	PO	1)Transformer testing and oil filtration 2)Transformer bus duct inspection 3) Station switch gear checking , breaker and relay testing
500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	IntraState	03/09/2022	17:15	03/09/2022	21:07	T	Tripped on Buchholz Alarm
220 KV TBC Outages/Trippings							
AUXILIARY BUS @ MALEGAON	IntraState	29/08/2022	16:50			PO	Shifting of TBC Bay new 50MVA 220/33kV PTR 3
BUS COUPLER @ PHURSUNGI	IntraState	02/09/2022	11:42	02/09/2022	14:14	PO	Bay Half yearly maintenance work, CB CRM & Timing work & CT Tan Delta & C testing work.
220 KV LINE Outages/Trippings							
220 KV HARANGUL - PARLY (PG) CKT	InterState	03/09/2022	09:43	03/09/2022	20:13	HT	R&M at Parli PG
PADGHE - NALASOPARA	IntraState	01/09/2022	11:57	02/09/2022	02:25	T	TRIPPED ON DISTANCE PROTECTION
KALWA - COLOURCHEM	IntraState	02/09/2022	06:13	02/09/2022	09:20	PO	Removing of Jumpers at 220KV CTT Tower for correction in phase sequence of 2000 Sq.mm at 220KV DCHI S/stn.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 03/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY DHARAVI - 5	IntraState	02/09/2022	07:54	02/09/2022	09:56	PO	Testing work at Trombay end
NERLE - PEDAMBE	IntraState	02/09/2022	09:50	02/09/2022	16:23	T	DP
KANDALGAON - SONA ALLOYS	IntraState	02/09/2022	09:56	02/09/2022	18:25	EO	Replacement of damaged conductor at Loc No.D7, 258 and 259
NANDED CITY-FLAGSHIP	IntraState	02/09/2022	11:21	02/09/2022	21:49	EO	For attending hotspot of Y PH CB of 220 Kv flagship BAY
LAMBOTI - KARKAMB	IntraState	02/09/2022	12:28	02/09/2022	14:43	EO	To attend HOTSPOT on Y-Ph CT
APTA - TAMBATI	IntraState	02/09/2022	14:53	02/09/2022	19:41	PO	For Taking Auto Recloser in Service and Testing work at Apta End.
DASTURI-KANDALGAON LINE	IntraState	02/09/2022	16:05	02/09/2022	17:30	T	Tripped on Distance Protection.
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	02/09/2022	16:05	02/09/2022	23:30	T	Tripped on Distance Protection.
BHUGAON - WARDHA (PG)	IntraState	02/09/2022	19:02	02/09/2022	21:20	HT	For control system Over Drawl at Low Frequency.
WARDHA (PG) - BADNERA	IntraState	02/09/2022	19:03	02/09/2022	21:17	HT	For control system Over Drawl at Low Frequency.
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	02/09/2022	19:11	02/09/2022	20:30	HT	For control system Over Drawl at Low Frequency.
WALUJ - CHITEGAON I	IntraState	02/09/2022	19:18	02/09/2022	20:37	HT	For control system Over Drawl at Low Frequency.
PIRANGUT - HINJAWADI 2	IntraState	03/09/2022	08:23	03/09/2022	11:48	EO	For removal of jumpers at tower no 23near infosys ss to enable to start metro work from tower no 23 to Infosys substation.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/09/2022	09:47	03/09/2022	18:48	EO	Attending the flashover DTN string of R-phase(one complete string of DTN disc insulator got broken and damaged the other string), also damaged its Pilot string at loc.no.121.(location no.121 is on hill top). Due to flashover of R-phase DTN string, 3nos of disc of Y-phase DTN disc insulator string also got damaged at loc.no.121, so need
MAHALAXMI - AMONA	IntraState	03/09/2022	13:28	03/09/2022	14:22	T	Distance protection R-ph ,13.5 km,1.25 KAmpp
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	02/09/2022	11:49	02/09/2022	15:49	EO	For Faulty Relay Inspection & Checking of REC-670 Relay of 100 MVA ICT-1 by testing team.
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	03/09/2022	09:35	03/09/2022	16:35	PO	1. REPLACEMENT OF WTI/OTI OF 220/132KV ICT-1 2. BAY MAINTENANCE OF 220/132KV ICT-1
220/33kV 50MVA TF-2 @ KOPARGAON	IntraState	03/09/2022	16:32	03/09/2022	18:30	PO	For attending hotspot (B Ph LV Bushing)
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 02/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 03/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
KALWA KALYAN	IntraState	02/09/2022	09:02	02/09/2022	20:07	PO	Dismantling of Hoarding Structure in vicinity of line for line diversion work at Runwal Projects (Customer Funded Job
KALYAN KALWA SALSETTE 2	IntraState	02/09/2022	09:07	02/09/2022	19:20	PO	for loop opening at loc no 78A For construction of 220 kV third circuit between Kalwa and Salsette
KALYAN KALWA SALSETTE 1	IntraState	03/09/2022	09:37	03/09/2022	18:20	PO	Removal of Bird Nest & Tree trimming
100 KV LINE Outages/Trippings							
100KV ROAD SIDE BUS @ KALWA	IntraState	02/09/2022	08:36	02/09/2022	18:22	PO	100 KV Earthwire Replacement of all feeders.
CREEK SIDE BUS @ KALWA	IntraState	03/09/2022	10:12	03/09/2022	17:39	PO	100kV Creek side Bus outage for R&M works.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage