

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Dec/2021 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	127.177	264.090	1) Gujrat	-5.554	-12.686
2) Hydro	7.966	14.124	2) Madhya Pradesh	5.509	9.252
3) Gas	4.244	10.001	3) Chattisgarh	5.210	9.730
Total MSPGCL	139.387	288.215	4) Maharashtra	114.773	241.052
B) 1) APLM	49.895	100.063	5) Goa (Amona)	-1.868	-3.719
2) JSWEL	14.216	28.311	Total	118.070	243.629
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.895	50.229
4) RPL(AMT)	19.650	40.251	b) Mumbai Drawl	23.069	48.423
5) SWPGPL	7.049	14.648	c) MSEDCL Bilateral *	15.692	34.803
6) Other IPP	34.939	71.736	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.895	50.229
C) 1) TPCL Thermal	11.389	22.801	Include PX	1.590	1.590
2) TPCL Hydro	4.293	8.734	Standby	0.000	0.000
3) TPCL Gas	1.776	4.782	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.289	17.637	1) MSEDCL	362.805	758.918
D) STATE			2) Mumbai Discoms	48.813	102.374
1) Thermal	272.604	559.537	3) Other Discoms	9.580	19.093
(A1+C1+C4+(B1-B6))			TOTAL STATE	421.198	880.385
2) Hydro (A2+C2)	12.259	22.858			
3) Gas (A3+B7+C3)	6.020	14.783			
4) Wind	9.965	33.394			
6) SOLAR	2.283	6.187			
TOTAL STATE	303.131	636.759			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5964	6057	6107	4356
MSPGCL Hydro	262	481	880	242
MSPGCL Gas	146	154	144	239
MSPGCL Total Generation	6372	6692	7131	4837
Central Sector Receipt	5768	5245	5257	3469
WIND	578	127	128	665
CPP / IPP Thermal	5881	5673	5821	4790
CPP / IPP Gas	0	0	0	0
SOLAR	287	8	0	0
Exchange with Mumbai	-1194	-1064	-965	-608
MSEDCL DEMAND MET	4476	3448	3632	2779
Load Shedding	0	0	0	0
MSEDCL DEMAND	4476	3448	3632	2779
TPCL GENERATION	915	941	996	532
AEML GENERATION	380	382	499	291
MUMBAI DEMAND	2489	2387	2460	1431
OTHER DISCOM DEMAND	357	358	371	280
STATE DEMAND MET	20181	19068	19832	14584
STATE DEMAND	20181	19068	19832	14584
Frequency (Hz)	50.03	49.98	50.00	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 12.03 Hrs	49.78 Hz at 09.05 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 02/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.24	6.71	190	115
Unit 7	0.00	0.00	0	0
Unit 8	13.90	26.51	661	377
Unit 9	0.00	0.00	0	0
Unit 10	13.45	26.13	645	372
Total	30.58	59.35		
Bhusawal				
Unit 3	3.08	6.30	155	44
Unit 4	8.19	16.97	450	280
Unit 5	8.07	16.61	455	280
Total	19.34	39.88		
Parli				
Unit 6	0.00	3.90	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.57	4.43	146	0
Total	0.57	8.32		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.06	3.51	55	0
Unit 5	7.85	15.49	375	280
Unit 6	8.42	15.72	445	269
Unit 7	7.84	15.59	360	290
Unit 8	9.22	18.46	410	300
Unit 9	9.64	18.96	447	285
Total	43.03	87.73		
Paras				
Unit 3	3.87	7.86	230	130
Unit 4	3.89	7.81	232	109
Total	7.77	15.67		
Khaparkheda				
Unit 1	3.14	6.26	160	120
Unit 2	3.10	6.24	170	120
Unit 3	3.38	6.84	155	128
Unit 4	0.37	2.74	125	0
Unit 5	9.82	19.00	470	285
Total	19.81	41.08		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.00	5.94	142	116
Unit 5	3.08	6.12	182	116
Total	6.08	12.06		
Uran				
All Units	4.24	10.00	259	142
Total	4.24	10.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.15	0.25	71	0
Total	0.15	0.25		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.42	4.10	395	35
Stage 4	0.73	0.83	284	0
Stage 3	0.81	1.59	160	0
Total	3.96	6.52		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.26	0.52	80	0
SMLHY_PTN	3.74	7.08	168	128
GHATGHAR	0.00	0.00	0	0
Total	4.00	7.60		
Wind				
Total	9.96	33.39	0	0
Total	9.96	33.39		
CPP				
APML(Mus)	49.90	100.06	0	0
JSWEL(Mus)	14.22	28.31	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.65	40.25	0	0
SWPGPL-Mus	7.05	14.65	0	0
Other(Mus)	34.94	71.74	0	0
Total	125.75	255.01		
SOLAR				
Total	2.28	6.19	0	0
Total	2.28	6.19		
Tata				
Trombay 5	6.77	13.57	427	251
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.00	2.73	77	0
Trombay 7B	0.78	2.05	55	0
Trombay 8	4.62	9.23	217	157
TATA Hydro	4.29	8.73	399	0
Total	17.46	36.32		
AEMIL				
DTPS U-1&2	8.29	17.64	499	289
Total	8.29	17.64		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	127.18	264.09	MSPGCL Total	139.39	288.22
			MSPGCL Thml+Gas	131.42	274.09	Koyna 1,2 & 4 Total	3.15	4.94
			MSPGCL Hydro	7.97	14.12	State Total	303.13	636.76

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 02/Dec/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4450	195	239	4884	821	4590	0	0	3825	3656	-765	12891	0	12891	1607	295	14793	49.93
2	4368	373	249	4990	769	4710	0	0	3614	3469	-651	12992	0	12992	1499	295	14786	49.95
3	4356	242	239	4837	665	4790	0	0	3876	3469	-608	12873	0	12873	1431	280	14584	49.97
4	4334	198	259	4791	653	4724	0	0	3978	3638	-561	12978	0	12978	1398	267	14643	49.93
5	4505	199	239	4943	474	4700	0	0	4421	4144	-548	13424	0	13424	1399	289	15112	50.01
6	4730	222	239	5191	466	4878	0	0	4807	4637	-626	14238	0	14238	1486	308	16032	50.00
7	5321	198	249	5768	531	5112	0	1	4878	4652	-678	15040	0	15040	1613	346	16999	50.02
8	5756	495	190	6441	619	5465	0	38	4911	4973	-857	16324	0	16324	1822	355	18501	49.99
9	6019	203	149	6371	762	5893	0	111	5151	5076	-977	16873	0	16873	2101	363	19337	49.94
10	5858	318	157	6333	739	5680	0	195	5765	5837	-1148	17269	0	17269	2352	367	19988	49.97
11	5964	262	146	6372	578	5881	0	287	5935	5768	-1194	17335	0	17335	2489	357	20181	50.03
12	5586	274	143	6003	578	5495	0	390	6172	5767	-1160	16725	0	16725	2491	348	19564	50.07
13	5202	192	143	5537	395	5092	0	412	6029	6027	-1126	16003	0	16003	2464	334	18801	50.03
14	5126	200	143	5469	335	4948	0	343	5998	6077	-1151	15689	0	15689	2355	332	18376	50.04
15	5344	281	142	5767	308	4943	0	270	5940	5723	-1179	15493	0	15493	2349	339	18181	50.03
16	5479	337	142	5958	167	5134	0	158	5632	5977	-1110	15953	0	15953	2325	331	18609	49.98
17	5556	713	143	6412	171	5310	0	70	5205	5478	-1121	15979	0	15979	2348	341	18668	50.00
18	6057	481	154	6692	127	5673	0	8	5145	5245	-1064	16323	0	16323	2387	358	19068	49.98
19	6107	880	144	7131	128	5821	0	0	5353	5257	-965	17001	0	17001	2460	371	19832	50.00
20	6066	517	144	6727	78	6132	0	0	4772	4569	-1008	16131	0	16131	2382	367	18880	50.02
21	5725	376	144	6245	100	5793	0	0	4583	4491	-1087	15194	0	15194	2242	348	17784	50.01
22	5387	371	145	5903	154	5135	0	0	5062	4942	-1270	14513	0	14513	2090	351	16954	50.01
23	5260	237	146	5643	210	4916	0	0	5016	4559	-1185	13820	0	13820	1935	323	16078	49.99
24	4621	202	156	4979	137	4934	0	0	4929	4639	-1030	13343	0	13343	1791	316	15450	49.99
MUs	127.18	7.97	4.24	139.39	9.97	125.75	0.00	2.28	121.00	118.07	-23.07	364.40	0.00	364.40	48.82	7.98	421.20	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 02/Dec/2021

Position as on 6.30 Hrs of 03/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-4	660	10/11/2021	23.58		Continued.	Capital Overhauling	10/12/2021
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09.55		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Uran Unit 5	108	07/11/2021	23.28		Continued.	Turbine problem.	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	RPL(AMT) U-4	270	13/11/2021	07:15	03/12/2021	23:59	BOTTOM ASH PROBLEM	
IPP	RPL(AMT) U-4	270	16/11/2021	00.00	03/12/2021	23:59	Coal Shortage	
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 3	210	23/11/2021	12:02		Continued.	ID Fan Problem	
MSPGCL	Parli Unit 7	250	28/11/2021	23.57		Continued.	Zero Schedule.	
MSPGCL	Khaparkheda Unit 4	210	01/12/2021	16:34	02/12/2021	20:11	Furnace Pressure High	
MSPGCL	Parli Unit 6	250	02/12/2021	00:00		Continued.	ZERO SCHEDULE	
MSPGCL	Chandrapur Unit 4	210	02/12/2021	00:17		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	02/12/2021	04:00		Continued.	ZERO SCHEDULE	07/12/2021
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Koyna Unit 7	80	02/12/2021	08:10	02/12/2021	18:20	Preventive Maintenance Work	
TPC-G	Trombay 7B	60	02/12/2021	17:13	03/12/2021	22:03	Gas shortage	
TPC-G	Trombay 7A	120	02/12/2021	17:22	03/12/2021	18:13	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	02/12/2021	23:25		Continued.	Boiler Tube Leakage	
CPP	SWPGL U-3	135	03/12/2021	18:37		Continued.	PA Fan problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 02/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 03/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	02/12/2021	10:22	03/12/2021	01:00	T	AC BUS & TRANSFORMER OVERCURRENT PROTECTION
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	02/12/2021	17:33	02/12/2021	18:04	HT	FOR METALIC RETURN MODE
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	02/12/2021	19:03	02/12/2021	20:55	T	POLE-1 ,BASE FILTER TRIPPED
400 KV MAINBAY Outages/Tripping							
BUS COUPLER @ KORADI	IntraState	02/12/2021	15:51	02/12/2021	19:00	EO	Emergency work for attending Hotspot on Bus-1 R ph PG isolator base clamp (Hotspot above 160°C)
400 KV LINE Outages/Tripping							
DHULE - SSNNL CKT - 1	InterState	01/12/2021	19:37	02/12/2021	16:05	T	Distance Protection, Z-1, B-ph, 2.57KA, 139KM from Dhule
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	01/12/2021	09:04		Continued.	HT	OVER VOLTAGE
JAIGAD - KARAD CKT - 1	IntraState	01/12/2021	20:02	02/12/2021	07:31	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	01/12/2021	22:09	02/12/2021	07:33	HT	over voltage.
KARAD - TALANDGE CKT - 1	IntraState	01/12/2021	23:48	03/12/2021	10:14	HT	over voltage
PADGHE - NAGOTHANE CKT - 1	IntraState	01/12/2021	23:55	02/12/2021	08:24	HT	OVER VOLTAGE
NAGOTHANE - DABHOL CKT - 1	IntraState	02/12/2021	02:00	02/12/2021	10:57	T	DIST. PROTECTION
CHANDRAPUR-PARLI CKT-3	IntraState	02/12/2021	09:57	02/12/2021	16:40	PO	(1) C & tan delta measurement of reactor. (2)Bay maintenance work. disc replacement at loc.583 ,631 and earthwire clamping which is rest on cross arm 613 and corona ring fixing at various location (8 location
LONIKAND I -JEJURI	IntraState	02/12/2021	11:42	02/12/2021	17:25	PO	Half yearly bay maintenance and DT work. DT/Line Maintenance (Insulator String Replacement work, Loc No 1-32)
JAIGAD - KARAD CKT - 1	IntraState	02/12/2021	22:21		Continued.	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	02/12/2021	23:11	03/12/2021	08:54	HT	HT FOR OVERVOLTAGE
PADGHE - NAGOTHANE CKT - 2	IntraState	03/12/2021	00:05	03/12/2021	08:55	HT	HAND TRIPPED TO CONTROL OVER VOLTAGE
PARLI-SOLAPUR (LAMBOTI)	IntraState	03/12/2021	06:31	03/12/2021	15:58	T	DIST. PROTECTION
BUS - 1 @ AKOLA 2	IntraState	03/12/2021	09:43	03/12/2021	17:58	PO	Annual Maintenance of Bus Equipment
KARAD - TALANDGE CKT - 1	IntraState	03/12/2021	22:08		Continued.	HT	HT FOR OVERVOLTAGE
400 KV ICT Outages/Tripping							
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	01/12/2021	10:43		Continued.	PO	1) Replacement of 400KV HV Bushings of R & B-ph ICT units. 2) Servicing & Maintenance of CTR make NIFPS. Of R, Y & B-ph ICT units. 3) Inspection of GE make 400KV CB of ICT-2 HV bay. 4) Replacement of support structure of B-ph 400KV HV CT. 5) MTAMC project work.
220 KV TBC Outages/Tripping							
TBC @ AAREY	IntraState	03/12/2021	09:46	03/12/2021	17:51	PO	For Annual maintenance of 1089C side isolator during opportunity outage of Bay-10 i.e 220kV Aarey-TPC Borivali Line
220 KV LINE Outages/Tripping							
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 03/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DAHANU - GHODBUNDER CKT - 1	IntraState	01/12/2021	15:07	02/12/2021	09:46	T	Dist. Protection, R-ph, 5.96KA, 28.04KM from Ghodbunder
KHAREPATAN -PAWAS LINE	IntraState	02/12/2021	11:07	02/12/2021	17:07	PO	C & Tan delta testing of Line CTs; CRM & timing test of CB at Kharepatan end.
URAN - APTA 2	IntraState	02/12/2021	11:22	02/12/2021	18:37	PO	For providing of missing earthwire at Loc.No.43 to 46
WATHAR - MUDSHINGI 3 LINE	IntraState	02/12/2021	12:14	02/12/2021	17:26	PO	For disc insulator string replacement replaced by long rod AF porcelain insulator in foggy region at tower LN-174,183,220.
TILLARI - AMONA LINE	IntraState	02/12/2021	13:36	02/12/2021	14:35	T	Distance protection
HALKARNI-MAHALAXMI LINE	IntraState	02/12/2021	13:36	02/12/2021	15:15	T	Distance Protection
MAHALAXMI - AMONA	IntraState	02/12/2021	13:36	02/12/2021	15:44	T	Distance Protection
URAN - HOC 1	IntraState	02/12/2021	14:53	02/12/2021	15:33	EO	earthwire at Loc No. 42 to 43 is found rusted and damaged and remained intact on only 2 strands. This earthwire may break and snapped on charged 220KV Apta-Uran 1 line
PADGHE - KAMBA 1	IntraState	02/12/2021	18:15	02/12/2021	18:42	T	BUS BAR OPERATED AT KAMBA END
PADGHE - KAMBA 2	IntraState	02/12/2021	18:15	02/12/2021	18:42	T	BUS BAR OPERATED AT KAMBA END
KAMBA - VASAI	IntraState	02/12/2021	18:15	02/12/2021	18:59	T	BUS BAR OPERATED AT KAMBA END
KAMBA - KOLSHET	IntraState	02/12/2021	18:15	02/12/2021	18:56	T	BUS BAR OPERATED AT KAMBA END
JEJURI - KONDHWA	IntraState	02/12/2021	18:55	02/12/2021	19:12	EO	for SF6 gas refilling work.
CHALISGAON - SAYNE	IntraState	03/12/2021	00:29	03/12/2021	01:39	T	DIST. PROT Z-1,B-PH, 2.619KA, 26.15KM FROM SAYNE
JEJURI - BARAMATI	IntraState	03/12/2021	04:49	03/12/2021	05:07	T	DIST. PROTECTION
PADGHE - NALASOPARA	IntraState	03/12/2021	11:20	03/12/2021	15:50	PO	For faulty relay replacement REL670 by Testing Team Kalwa.
KAMBA - KOLSHET	IntraState	03/12/2021	12:04	03/12/2021	17:18	EO	Breaker spring Not charging ,hence to check whether motor Jam or any other Electrical problem
BUS SECTIONIZER @ BIDRI	IntraState	03/12/2021	15:15	03/12/2021	18:10	PO	For Tan delta testing & Maintenance Work
CHALISGAON - SAYNE	IntraState	03/12/2021	17:05	03/12/2021	18:34	EO	replacement of flashovered Bph polymer insulator string at locn 8 of 220kV Chalisgaon - Sayane line
JEJURI - BARAMATI	IntraState	03/12/2021	18:08	03/12/2021	18:18	EO	Autoreclose trials on 220kV Jejuri-Baramati Line CB is required. This is in view of investigation of non-autoreclose of CB after transient fault at 04:49 hrs on 03.12.2021 at 400kV Jejuri S/s.
LAMBOTI - KARKAMB	IntraState	03/12/2021	23:03		Continued.	T	DIST. PROTECTION , Z-1, R-PH, 2.6KA, 65KM FROM LAMBOTI
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/132KV 200MVA PTR 2 @ LONAND	IntraState	01/12/2021	22:49	02/12/2021	17:55	T	TRIPPED ON BUCHHLZ INDICATION
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	02/12/2021	14:07	02/12/2021	18:01	EO	200MVA ICT-IV, CB Control Valve Heavy Air leakage on HV Side CB due to which compressor is continuously on.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 03/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 25 MVA PTR 3 @ BIDRI	IntraState	03/12/2021	09:40	03/12/2021	18:08	PO	For Tan delta Testing & Maintenance work
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	03/12/2021	10:52	03/12/2021	12:50	PO	Diagnostic testing of Transformer, CT and LV CB
220/22 KV 50 MVA PTR 1 @ TEMGHAR	IntraState	03/12/2021	13:20	03/12/2021	15:55	PO	Diagnostic Testing and R&M Work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage