

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 02/Dec/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.632	273.254	1) Gujrat	7.303	14.644
2) Hydro	4.899	10.818	2) Madhya Pradesh	9.552	18.472
3) Gas	7.089	13.947	3) Chattisgarh	5.220	10.270
Total MSPGCL	148.620	298.019	4) Maharashtra	161.843	323.905
B) 1) APLM	19.783	40.109	5) Goa (Amona)	-1.455	-3.107
2) JSWEL	22.328	44.462	Total	182.463	364.184
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.078	68.662
4) RPL(AMT)	24.408	48.079	b) Mumbai Drawl	39.351	77.217
5) SWPGPL	10.332	19.993	c) MSEDCL Bilateral *	83.915	124.339
6) Other IPP	31.366	63.933	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.078	68.662
C) 1) TPCL Thermal	10.928	21.145	Include PX	0.000	0.000
2) TPCL Hydro	2.931	6.091	Standby	0.000	0.000
3) TPCL Gas	2.090	4.364	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.538	12.441	1) MSEDCL	412.496	818.196
D) STATE			2) Mumbai Discoms	59.838	121.258
1) Thermal	260.315	523.416	3) Other Discoms	10.220	20.547
(A1+C1+C4+(B1-B6))			TOTAL STATE	482.554	960.001
2) Hydro	7.830	16.909			
(A2+C2)					
3) Gas	9.179	18.311			
(A3+B7+C3)					
4) Wind	10.818	16.458			
6) SOLAR	11.949	20.723			
TOTAL STATE	300.091	595.817			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6284	6419	6367	5293
MSPGCL Hydro	162	167	343	190
MSPGCL Gas	300	288	288	304
MSPGCL Total Generation	6746	6874	6998	5787
Central Sector Receipt	7897	8048	9023	6381
WIND	471	404	642	348
CPP / IPP Thermal	4592	5045	5134	4349
CPP / IPP Gas	0	0	0	0
SOLAR	1184	56	0	0
Exchange with Mumbai	-1745	-1618	-1617	-1205
MSEDCL DEMAND MET	18690	18332	19692	15337
Load Shedding	0	0	0	0
MSEDCL DEMAND	18690	18332	19692	15337
TPCL GENERATION	743	1001	1096	513
AEML GENERATION	178	204	197	189
MUMBAI DEMAND	2666	2823	2910	1907
OTHER DISCOM DEMAND	455	477	488	323
STATE DEMAND MET	21811	21632	23090	17567
STATE DEMAND	21811	21632	23090	17567
Frequency (Hz)	50.05	50.02	50.04	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 13.05 Hrs	49.74 Hz at 08.20 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 02/Dec/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.58	7.34	175	125
Unit 8	13.36	25.64	626	378
Unit 9	12.28	24.58	575	381
Unit 10	12.48	24.56	565	406
Total	41.69	82.12		
Bhusawal				
Unit 3	3.20	6.47	170	120
Unit 4	8.27	12.93	475	285
Unit 5	7.76	15.92	445	280
Total	19.24	35.31		
Parli				
Unit 6	0.00	1.90	0	0
Unit 7	0.00	1.92	0	0
Unit 8	2.28	6.15	236	0
Total	2.28	9.97		
Chandrapur				
Unit 3	3.28	6.40	156	115
Unit 4	3.20	6.41	152	120
Unit 5	8.22	16.19	435	285
Unit 6	0.06	0.06	65	0
Unit 7	7.33	13.81	334	277
Unit 8	9.29	18.28	492	280
Unit 9	9.38	18.66	484	282
Total	40.76	79.82		
Paras				
Unit 3	5.07	10.15	231	188
Unit 4	5.33	10.80	243	169
Total	10.40	20.94		
Khaparkheda				
Unit 1	2.90	5.78	145	105
Unit 2	1.96	4.25	88	71
Unit 3	3.47	6.98	164	125
Unit 4	3.81	7.63	190	128
Unit 5	10.11	20.46	450	285
Total	22.26	45.10		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	7.09	13.95	305	283
Total	7.09	13.95		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.07	0.45	41	0
Total	0.07	0.45		
Koyna				
Stage 1-2	1.07	2.37	80	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	0.00	0	0
Stage 3	0.42	0.80	80	0
Total	1.49	3.17		
Hydro				
KDPH	0.59	1.46	36	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.62	5.30	114	104
GHATGHAR	0.12	0.43	62	0
Total	3.34	7.19		
Wind				
Total	10.82	16.46	0	0
Total	10.82	16.46		
CPP				
APML(Mus)	19.78	40.11	0	0
JSWEL(Mus)	22.33	44.46	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.41	48.08	0	0
SWPGPL-Mus	10.33	19.99	0	0
Dhariwal	0.00	0.00	0	0
IEPL	3.98	8.74	268	0
Other(Mus)	27.38	55.19	0	0
JPL	0.00	0.00	0	0
Total	108.22	216.58		
SOLAR				
Total	11.95	20.72	0	0
Total	11.95	20.72		
Tata				
Trombay 5	7.22	13.99	366	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.14	2.42	108	39
Trombay 7B	0.94	1.94	64	35
TATA Hydro	2.93	6.09	381	26
Trombay 8	3.71	7.15	214	131
Total	15.95	31.60		
AEML				
DTPS U-1&2	4.54	12.44	214	167
Total	4.54	12.44		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.63	273.25	MSPGCL Total	148.62	298.02
			MSPGCL Thml+Gas	143.72	287.20	Koyna 1,2 & 4 Total	1.07	2.37
			MSPGCL Hydro	4.90	10.82	State Total	300.09	595.82

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 02/Dec/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5358	190	301	5849	374	4308	0	0	6589	6543	-1428	15251	0	0	15251	2179	395	17825	50.00
2	5343	190	303	5836	406	4353	0	0	6620	6525	-1299	15459	0	0	15459	2019	362	17840	50.04
3	5293	190	304	5787	348	4349	0	0	6362	6381	-1205	15337	0	0	15337	1907	323	17567	50.00
4	5474	190	302	5966	351	4364	0	0	6393	6266	-1161	15466	0	0	15466	1840	320	17626	50.00
5	5605	190	303	6098	361	4419	0	0	6512	6685	-1150	16069	0	0	16069	1839	344	18252	49.98
6	6045	189	304	6538	378	4425	0	0	6877	7188	-1235	16946	0	0	16946	1917	348	19211	49.99
7	6363	184	305	6852	442	4764	0	6	7323	7477	-1323	17847	0	0	17847	2016	371	20234	49.97
8	6545	194	304	7043	432	5050	0	171	7987	8178	-1432	19022	0	0	19022	2153	420	21595	49.96
9	6340	183	301	6824	395	4780	0	652	8103	8004	-1612	18606	0	0	18606	2387	437	21430	49.92
10	6284	162	300	6746	471	4592	0	1184	7780	7897	-1745	18690	0	0	18690	2666	455	21811	50.05
11	5825	220	298	6343	329	4390	0	1647	7810	7817	-1904	18162	0	0	18162	2894	460	21516	50.04
12	5030	258	292	5580	272	4044	0	1794	8116	8005	-1923	17314	0	0	17314	2964	458	20736	49.97
13	4693	184	285	5162	230	3823	0	1895	8041	8041	-2021	16661	0	0	16661	2962	469	20092	49.98
14	4655	166	285	5106	210	3986	0	1723	7916	7888	-1979	16496	0	0	16496	2848	438	19782	50.07
15	4799	168	283	5250	168	4324	0	1442	8385	8373	-2040	17065	0	0	17065	2855	452	20372	50.00
16	5149	172	287	5608	152	4532	0	957	8188	8308	-1981	17097	0	0	17097	2873	479	20449	50.00
17	6135	167	287	6589	219	4760	0	422	7966	7993	-1847	17659	0	0	17659	2841	477	20977	50.00
18	6419	167	288	6874	404	5045	0	56	7777	8048	-1618	18332	0	0	18332	2823	477	21632	50.02
19	6367	343	288	6998	642	5134	0	0	8660	9023	-1617	19692	0	0	19692	2910	488	23090	50.04
20	6377	330	294	7001	837	4984	0	0	8297	8387	-1805	18942	0	0	18942	2819	462	22223	49.99
21	5848	248	294	6390	891	4527	0	0	7792	8007	-1867	17488	0	0	17488	2704	460	20652	49.95
22	6060	259	293	6612	804	4446	0	0	7332	7240	-1805	16837	0	0	16837	2579	460	19876	50.02
23	5534	189	293	6016	850	4409	0	0	7176	7220	-1720	16335	0	0	16335	2461	440	19236	49.98
24	5091	166	295	5552	852	4409	0	0	6895	6969	-1634	15723	0	0	15723	2382	425	18530	49.99
MUs	136.63	4.90	7.09	148.62	10.82	108.22	0.00	11.95	180.90	182.46	-39.35	412.50	0.00	0.00	412.50	59.84	10.22	482.55	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 02/Dec/2023

Position as on 6.30 Hrs of 03/Dec/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	15/02/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Nasik Unit 4	210	19/11/2023	15:48		Continued.	Stator Earth Fault (Converted into AOH from 00:00 hrs dt.20/11/2023)	12/12/2023
MSPGCL	Koyna STG-IV Unit-3	250	24/11/2023	08:00		Continued.	Capital Overhauling	19/01/2024
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/12/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Uran Unit 6	108	05/10/2023	00:29		Continued.	Gas shortage	
IPP	RPL(AMT) U-2	270	12/10/2023	07:59		Continued.	Tripped Due to Electrical protection opted.	15/12/2023
IPP	JPL Unit 1	150	03/11/2023	00:01		Continued.	Under shutdown condition Due to low net sales Realization cost.	30/11/2023
IPP	Adani U-5	660	16/11/2023	23:16		Continued.	Zero Schedule	
IPP	Adani U-4	660	27/11/2023	04:13		Continued.	zero schedule	
IPP	Adani U-1	660	28/11/2023	23:53		Continued.	ZERO SCHEDULE	
MSPGCL	Chandrapur Unit 6	500	29/11/2023	08:24	02/12/2023	23:20	Boiler Tube Leakage	02/12/2023
MSPGCL	Nasik Unit 5	210	30/11/2023	05:24		Continued.	Suspected BTL.	04/12/2023
MSPGCL	Nasik Unit 3	210	30/11/2023	23:40	03/12/2023	02:05	Furnace Pressure High	02/12/2023
MSPGCL	Parli Unit 6	250	01/12/2023	12:31		Continued.	Zero Schedule Given By MSEDCL	
MSPGCL	Parli Unit 7	250	01/12/2023	12:32		Continued.	Zero Schedule Given By MSEDCL	
AEML	AEML Unit 1	250	01/12/2023	23:51	03/12/2023	06:44	Boiler Chemical Parameter issue.	
IPP	IEPL Unit 1	270	02/12/2023	09:36	02/12/2023	13:25	Unit PMCC incomer - 1 trip	
MSPGCL	Parli Unit 8	250	02/12/2023	14:20		Continued.	Zero schedule	
MSPGCL	Bhusawal Unit 3	210	03/12/2023	11:00		Continued.	Boiler Tube Leakage	05/12/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 02/Dec/2023

Statement-VII

Position as on 6.30 Hrs of 03/Dec/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
AKOLA II - EKTUNI CKT - 1	IntraState	02/12/2023	04:01	02/12/2023	07:21	T	B-ph Line Reactor Buchholz Protection at Ektuni
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	01/12/2023	08:48			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	01/12/2023	08:48			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	01/12/2023	08:48			PO	Annual Maintenance work AC & DC Yard Equipment, Valve Hall, Diagnostic testing, Line Maintenance etc
400 KV TBC Outages/Tripping							
220 KV TBC	IntraState	02/12/2023	10:10	02/12/2023	13:10	HT	For c and tan delta measurement and maintenance work.
400 KV MAINBAY Outages/Tripping							
400/11.5 KV 110MVA STN T/F 6A @ DEEPNAGAR	InterState	09/11/2023	15:36			PO	For alignment work of 89L isolator of Station Transformer 6A
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Tripping							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
400KV-PARLI NEW-PARLI-M-2	InterState	02/12/2023	21:06	02/12/2023	23:16	HT	For replacement of isolator arm and to make tbc make available for other feeders at parli msetcl end.
400KV NANDED(KUMBHARGAON)-PARLY CKT 2	InterState	03/12/2023	23:31	03/12/2023	07:16	EO	Broken conductor strands repair
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\epsilon Y \epsilon$ phase Protection CT Of NTPP I (RPL 1)
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	23/11/2023	11:55			PO	Scheme work of replacement of existing 0.5 ACSR conductor by HTLS conductor
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/11/2023	19:17			HT	HT Load Management
NEW KOYNA-KARAD CKT - 1	IntraState	29/11/2023	23:25		Continued.	HT	Hand tripped due to high voltages.
KHADKA-AURANGABAD (WALUJ)	IntraState	30/11/2023	21:25		Continued.	HT	H/T For Voltage Management
CHANDRAPUR GCR - CHANDRAPUR HVDC - 2	IntraState	01/12/2023	08:48			PO	1. CB pole overhauling work. 2.Diagnostic testing work of CT, CB. 3. Bay maintenance work.
PADGHE - PADGHE HVDC CKT- 2	IntraState	01/12/2023	08:48			PO	1.Bay Maintenance Work. 2.Diagnostic Testing Work. 3.MTAMC work. 4.Replacement of old BHEL Make 7 Core CT with New 7 Core CT of CGL make. 5.Replacement of A Bus B Ph PG Isolator under LES Scheme.
JAIGAD - KARAD CKT - 2	IntraState	01/12/2023	23:52		Continued.	HT	HT to control Overvoltage
NEW KOYNA - DABHOL CKT - 2	IntraState	02/12/2023	05:16	02/12/2023	07:03	T	Distance Protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Dec/2023

Statement-VII

Position as on 6.30 Hrs of 03/Dec/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NAGOTHANE - DABHOL CKT - 1	IntraState	02/12/2023	05:17	02/12/2023	06:37	T	Distance Protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	01/12/2023	13:22			PO	R-PHASE BUSHING CHECKING, REPLACEMENT AND ASSOCIATED WORKS.
400/220KV 315MVA ICT - 3 @ CHAKAN	IntraState	02/12/2023	10:46	02/12/2023	19:44	PO	Routine maintenance and DT work
400 KV BR Outages/Trippings							
BUS REACTOR (80 MVA) - 1 @ BABHALESHWAR	IntraState	02/12/2023	10:37	02/12/2023	15:05	PO	CB DCRM/Timing;Differential relay testing
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - PADGHE	IntraState	20/11/2023	17:31			HT	HT for load management from Padghe end
AAREY - AEML SAKI CKT - 1	IntraState	24/11/2023	09:01	02/12/2023	20:52	PO	Control Cable rewiring from LCC and CRP panels for Commissioning of New CRP
TROMBAY - DHARAVI 9	IntraState	02/12/2023	08:34	02/12/2023	12:54	PO	C PHASE LA REPLACEMENT
NIWALI - PAWAS LINE	IntraState	02/12/2023	09:34	02/12/2023	17:55	PO	Cold washing of line insulators.
220 KV NANDED(400 KV) - WAGHALA CKT- II	IntraState	02/12/2023	10:30	02/12/2023	17:15	HT	CT tan D test work.
220 KV SURYALAXMI - KHAPARKHEDA	IntraState	02/12/2023	11:08	02/12/2023	19:16	HT	1) diagnostic testing work 2) conversion of single jumper into twin jumper and 3) routine maintenance work.
VALVE-JAMDE	IntraState	02/12/2023	12:29	02/12/2023	12:29	T	On PDR.
KALWA - SALESETTE CKT - 5	IntraState	03/12/2023	08:05	03/12/2023	08:48	PO	BIRD NEST REMOVAL
KALWA SALSETTE - 3	IntraState	03/12/2023	09:08	03/12/2023	15:37	PO	For Remove twist from C Ph twin Casablanca conductors and providing spacers on twin Casablanca conductors in span 27 to 30
ADLABS - PEDAMBE	IntraState	03/12/2023	10:35	03/12/2023	18:46	PO	Earthwire Replacement,Cold washing and other line maintenance work
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	02/12/2023	09:50	02/12/2023	15:01	PO	1. Replacement of WTI and OTI meter, bay maintenance work. 2. Attending red hot on Bushing stud.
220/132KV 100 MVA ICT 2@ PETH	IntraState	02/12/2023	10:05	02/12/2023	16:10	PO	Quarterly Maintenance Work
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	02/12/2023	10:28	02/12/2023	13:20	PO	Diagnostic testing : Tan Delta of winding ,bushing and CTs
220 KV BUSBAR Outages/Trippings							
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 02/Dec/2023

Statement-VII

Position as on 6.30 Hrs of 03/Dec/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage