

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 03/Jan/2023 TUESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 140.189        | 430.946         | 1) Gujrat                      | -2.589         | -14.366         |
| 2) Hydro            | 22.291         | 44.040          | 2) Madhya Pradesh              | 6.863          | 12.774          |
| 3) Gas              | 3.787          | 9.744           | 3) Chattisgarh                 | 5.670          | 17.790          |
| <b>Total MSPGCL</b> | <b>166.267</b> | <b>484.730</b>  | 4) Maharashtra                 | 187.625        | 547.284         |
| B) 1) APLM          | 54.011         | 140.556         | 5) Goa (Amona)                 | -2.001         | -4.747          |
| 2) JSWEL            | 20.257         | 60.803          | <b>Total</b>                   | <b>195.568</b> | <b>558.735</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 23.767         | 65.258          |
| 4) RPL(AMT)         | 16.335         | 57.834          | b) Mumbai Drawl                | 27.425         | 76.267          |
| 5) SWPGPL           | 8.846          | 25.478          | c) MSEDCL Bilateral *          | 81.656         | 242.951         |
| 6) Other IPP        | 45.850         | 136.946         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 23.767         | 65.258          |
| C) 1) TPCL Thermal  | 10.927         | 31.148          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 3.835          | 8.884           | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.046          | 6.893           | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.581          | 24.682          | 1) MSEDCL                      | 485.480        | 1411.420        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 52.814         | 147.874         |
| 1) Thermal          | 304.996        | 908.393         | 3) Other Discoms               | 9.721          | 28.699          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>548.015</b> | <b>1587.993</b> |
| 2) Hydro (A2+C2)    | 26.126         | 52.924          |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 5.833          | 16.637          |                                |                |                 |
| 4) Wind             | 4.698          | 14.661          |                                |                |                 |
| 6) SOLAR            | 10.794         | 36.643          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>352.447</b> | <b>1029.258</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 24 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 6171                      | 6154                  | 6080                      | 3979                       |
| MSPGCL Hydro               | 1765                      | 1064                  | 1222                      | 724                        |
| MSPGCL Gas                 | 108                       | 150                   | 236                       | 194                        |
| MSPGCL Total Generation    | 8044                      | 7368                  | 7538                      | 4897                       |
| Central Sector Receipt     | 9254                      | 9454                  | 7464                      | 7166                       |
| WIND                       | 135                       | 75                    | 182                       | 328                        |
| CPP / IPP Thermal          | 6496                      | 6152                  | 6621                      | 5470                       |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                          |
| SOLAR                      | 1426                      | 1680                  | 2                         | 0                          |
| Exchange with Mumbai       | -1157                     | -1432                 | -1107                     | -1072                      |
| <b>MSEDCL DEMAND MET</b>   | <b>23756</b>              | <b>22876</b>          | <b>20250</b>              | <b>16396</b>               |
| Load Shedding              | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 23756                     | 22876                 | 20250                     | 16396                      |
| TPCL GENERATION            | 1061                      | 768                   | 1011                      | 497                        |
| AEML GENERATION            | 502                       | 494                   | 478                       | 300                        |
| <b>MUMBAI DEMAND</b>       | <b>2720</b>               | <b>2694</b>           | <b>2596</b>               | <b>1869</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>442</b>                | <b>421</b>            | <b>450</b>                | <b>393</b>                 |
| STATE DEMAND MET           | 26918                     | 25991                 | 23296                     | 18658                      |
| <b>STATE DEMAND</b>        | <b>26918</b>              | <b>25991</b>          | <b>23296</b>              | <b>18658</b>               |
| Frequency (Hz)             | 50.01                     | 50.01                 | 49.91                     | 50.03                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.23 Hz at 13.06 Hrs | 49.49 Hz at 05.54 Hrs | 49.97         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 03/Jan/2023

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 5.18         | 15.26         | 290      | 205      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 12.82        | 39.41         | 562      | 510      |
| Unit 9             | 0.00         | 10.08         | 0        | 0        |
| Unit 10            | 11.96        | 38.40         | 507      | 480      |
| <b>Total</b>       | <b>29.96</b> | <b>103.15</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 10.08        | 29.63         | 485      | 280      |
| Unit 5             | 8.95         | 27.82         | 420      | 280      |
| <b>Total</b>       | <b>19.03</b> | <b>57.45</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 5.03         | 13.79         | 235      | 150      |
| Unit 7             | 4.65         | 13.70         | 248      | 0        |
| Unit 8             | 3.82         | 11.16         | 178      | 148      |
| <b>Total</b>       | <b>13.49</b> | <b>38.65</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.05         | 9.75          | 160      | 88       |
| Unit 4             | 2.96         | 8.99          | 140      | 50       |
| Unit 5             | 6.50         | 20.69         | 310      | 0        |
| Unit 6             | 8.98         | 25.85         | 415      | 282      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.15        | 32.05         | 496      | 0        |
| Unit 9             | 11.08        | 32.59         | 495      | 0        |
| <b>Total</b>       | <b>43.72</b> | <b>129.92</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.20         | 15.06         | 227      | 198      |
| Unit 4             | 0.20         | 0.20          | 106      | 0        |
| <b>Total</b>       | <b>5.41</b>  | <b>15.27</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.94         | 8.44          | 135      | 110      |
| Unit 2             | 2.73         | 8.54          | 138      | 0        |
| Unit 3             | 3.46         | 11.04         | 178      | 0        |
| Unit 4             | 2.87         | 9.04          | 142      | 0        |
| Unit 5             | 9.98         | 30.56         | 435      | 380      |
| <b>Total</b>       | <b>21.98</b> | <b>67.62</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.31         | 9.60          | 159      | 119      |
| Unit 5             | 3.29         | 9.29          | 156      | 113      |
| <b>Total</b>       | <b>6.60</b>  | <b>18.89</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 3.79         | 9.74          | 242      | 96       |
| <b>Total</b>       | <b>3.79</b>  | <b>9.74</b>   |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.43         | 1.32          | 44       | 0        |
| <b>Total</b>       | <b>0.43</b>  | <b>1.32</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 6.32          | 12.73         | 565      | 40       |
| Stage 4         | 9.17          | 14.08         | 750      | 0        |
| Stage 3         | 3.37          | 5.77          | 320      | 0        |
| <b>Total</b>    | <b>18.87</b>  | <b>32.58</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.76          | 2.48          | 36       | 0        |
| VTRNA           | 0.00          | 0.04          | 0        | 0        |
| TILLARI         | 0.55          | 1.96          | 58       | 0        |
| BHIRA T.R.      | 0.18          | 0.48          | 40       | 0        |
| SMLHY_PTN       | 1.51          | 3.92          | 66       | 61       |
| GHATGHAR        | 0.00          | 1.26          | 0        | 0        |
| <b>Total</b>    | <b>2.99</b>   | <b>10.14</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 4.70          | 14.66         | 0        | 0        |
| <b>Total</b>    | <b>4.70</b>   | <b>14.66</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 54.01         | 140.56        | 0        | 0        |
| JSWEL(Mus)      | 20.26         | 60.80         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 16.34         | 57.83         | 0        | 0        |
| SWPGPL-Mus      | 8.85          | 25.48         | 0        | 0        |
| Other(Mus)      | 45.85         | 136.95        | 0        | 0        |
| <b>Total</b>    | <b>145.30</b> | <b>421.62</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 10.79         | 36.64         | 0        | 0        |
| <b>Total</b>    | <b>10.79</b>  | <b>36.64</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 7.19          | 20.62         | 450      | 262      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 1.11          | 3.88          | 54       | 41       |
| Trombay 7B      | 0.93          | 3.01          | 46       | 35       |
| TATA Hydro      | 3.84          | 8.88          | 398      | 8        |
| Trombay 8       | 3.74          | 10.52         | 229      | 130      |
| <b>Total</b>    | <b>16.81</b>  | <b>46.92</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 8.58          | 24.68         | 502      | 284      |
| <b>Total</b>    | <b>8.58</b>   | <b>24.68</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 140.19      | 430.95        | MSPGCL Total        | 166.27      | 484.73        |
|                |             |         | MSPGCL Thml+Gas | 143.98      | 440.69        | Koyna 1,2 & 4 Total | 15.50       | 26.82         |
|                |             |         | MSPGCL Hydro    | 22.29       | 44.04         | State Total         | 352.45      | 1029.26       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 03/Jan/2023

### Annexure-2

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | LOAD SHED DING | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|----------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |      | THM       | GAS  |       |          |          |                |                  |                |                      |               |                     |              |            |
| 1            | 5370        | 197   | 96   | 5663   | 253  | 5254      | 0    | 0     | 7686     | 7566     | -923           | 17451            | 0              | 17451                | 1720          | 362                 | 19533        | 49.97      |
| 2            | 5465        | 198   | 96   | 5759   | 301  | 5267      | 0    | 0     | 7842     | 7477     | -834           | 17632            | 0              | 17632                | 1604          | 338                 | 19574        | 50.00      |
| 3            | 5538        | 198   | 97   | 5833   | 254  | 5274      | 0    | 0     | 7856     | 7661     | -761           | 17942            | 0              | 17942                | 1526          | 319                 | 19787        | 50.02      |
| 4            | 5414        | 197   | 97   | 5708   | 225  | 5333      | 0    | 0     | 7921     | 7732     | -702           | 17983            | 0              | 17983                | 1481          | 313                 | 19777        | 50.01      |
| 5            | 5672        | 197   | 97   | 5966   | 270  | 5443      | 0    | 0     | 7887     | 7734     | -712           | 18373            | 0              | 18373                | 1487          | 328                 | 20188        | 49.96      |
| 6            | 6002        | 200   | 96   | 6298   | 378  | 5909      | 0    | 0     | 7899     | 7880     | -830           | 19274            | 0              | 19274                | 1619          | 361                 | 21254        | 49.80      |
| 7            | 6061        | 800   | 96   | 6957   | 237  | 6445      | 0    | 6     | 8137     | 8290     | -978           | 20576            | 0              | 20576                | 1823          | 381                 | 22780        | 49.93      |
| 8            | 6074        | 1552  | 97   | 7723   | 171  | 6783      | 0    | 125   | 7706     | 7932     | -950           | 21375            | 0              | 21375                | 2005          | 409                 | 23789        | 49.91      |
| 9            | 6131        | 1732  | 98   | 7961   | 211  | 6704      | 0    | 534   | 7276     | 7785     | -974           | 21786            | 0              | 21786                | 2289          | 435                 | 24510        | 49.98      |
| 10           | 6123        | 1800  | 100  | 8023   | 142  | 6588      | 0    | 1034  | 7903     | 8691     | -979           | 23060            | 0              | 23060                | 2623          | 439                 | 26122        | 49.85      |
| 11           | 6171        | 1765  | 108  | 8044   | 135  | 6496      | 0    | 1426  | 8947     | 9254     | -1157          | 23756            | 0              | 23756                | 2720          | 442                 | 26918        | 50.01      |
| 12           | 6150        | 1482  | 132  | 7764   | 120  | 6390      | 0    | 1605  | 8983     | 9052     | -1401          | 23103            | 0              | 23103                | 2752          | 427                 | 26282        | 50.01      |
| 13           | 6154        | 1064  | 150  | 7368   | 75   | 6152      | 0    | 1680  | 9203     | 9454     | -1432          | 22876            | 0              | 22876                | 2694          | 421                 | 25991        | 50.01      |
| 14           | 6159        | 481   | 156  | 6796   | 78   | 6156      | 0    | 1604  | 9462     | 9847     | -1578          | 22485            | 0              | 22485                | 2562          | 418                 | 25465        | 50.04      |
| 15           | 6102        | 706   | 191  | 6999   | 96   | 6187      | 0    | 1356  | 9711     | 10010    | -1634          | 22588            | 0              | 22588                | 2580          | 426                 | 25594        | 49.98      |
| 16           | 6102        | 1102  | 218  | 7422   | 91   | 6237      | 0    | 888   | 9579     | 9782     | -1603          | 22377            | 0              | 22377                | 2591          | 440                 | 25408        | 49.98      |
| 17           | 6136        | 1459  | 236  | 7831   | 91   | 6270      | 0    | 448   | 8417     | 8240     | -1443          | 20985            | 0              | 20985                | 2583          | 452                 | 24020        | 49.96      |
| 18           | 6128        | 1386  | 237  | 7751   | 116  | 6341      | 0    | 86    | 7389     | 7343     | -1245          | 19939            | 0              | 19939                | 2561          | 453                 | 22953        | 49.91      |
| 19           | 6080        | 1222  | 236  | 7538   | 182  | 6621      | 0    | 2     | 6937     | 7464     | -1107          | 20250            | 0              | 20250                | 2596          | 450                 | 23296        | 49.91      |
| 20           | 6022        | 1625  | 238  | 7885   | 228  | 6326      | 0    | 0     | 6890     | 7173     | -1214          | 19953            | 0              | 19953                | 2524          | 445                 | 22922        | 50.02      |
| 21           | 6054        | 814   | 238  | 7106   | 196  | 6211      | 0    | 0     | 7238     | 7386     | -1378          | 19087            | 0              | 19087                | 2371          | 434                 | 21892        | 50.04      |
| 22           | 5953        | 668   | 241  | 6862   | 234  | 5931      | 0    | 0     | 7447     | 7134     | -1306          | 18427            | 0              | 18427                | 2199          | 428                 | 21054        | 50.04      |
| 23           | 5149        | 722   | 242  | 6113   | 286  | 5511      | 0    | 0     | 7658     | 7515     | -1212          | 17809            | 0              | 17809                | 2035          | 404                 | 20248        | 49.92      |
| 24           | 3979        | 724   | 194  | 4897   | 328  | 5470      | 0    | 0     | 7535     | 7166     | -1072          | 16396            | 0              | 16396                | 1869          | 393                 | 18658        | 50.03      |
| MUs          | 140.19      | 22.29 | 3.79 | 166.27 | 4.70 | 145.30    | 0.00 | 10.79 | 193.51   | 195.57   | -27.42         | 485.48           | 0.00           | 485.48               | 52.81         | 9.72                | 548.02       | 49.97      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 03/Jan/2023**

**Position as on 6.30 Hrs of 04/Jan/2023**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                | Koyna STG-IV Unit-1     | 250      | 02/12/2022   | 18:20        |            | Continued. | Annual Overhaul                                                                                                                                         | 01/02/2023    |
| IPP                   | Adani U-5               | 660      | 10/12/2022   | 23:56        |            | Continued. | COH activities.                                                                                                                                         | 10/01/2023    |
| MSPGCL                | Parli Unit 7            | 250      | 03/01/2023   | 22:16        |            | Continued. | Annual Overhaul                                                                                                                                         | 31/01/2023    |
| IPP                   | JSW (J) U4              | 300      | 04/01/2023   | 23:45        |            | Continued. | NO SCHEDULE                                                                                                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                                                                                   | 07/02/2023    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      | 28/02/2023    |
| MSPGCL                | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      |               |
| MSPGCL                | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |            | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 29/11/2022   | 09:30        |            | Continued. | DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.                                                                                                        | 20/01/2023    |
| MSPGCL                | Nasik Unit 3            | 210      | 07/12/2022   | 21:25        |            | Continued. | Boiler Tube Leakage. Unit on tolling from 22:00Hrs Dtd 09.12.2022                                                                                       |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/12/2022   | 17:45        |            | Continued. | Bottom Ash evacuation problem                                                                                                                           | 13/01/2023    |
| IPP                   | SWPGPL U-4              | 135      | 28/12/2022   | 00:00        |            | Continued. | BOTTOM ASH EVACUATION PROBLEM                                                                                                                           | 13/01/2023    |
| MSPGCL                | Paras Unit 4            | 250      | 30/12/2022   | 22:09        | 03/01/2023 | 21:24      | Boiler Tube Leakage                                                                                                                                     |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 31/12/2022   | 09:43        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 06/01/2023    |
| MSPGCL                | Koradi Unit 9           | 660      | 01/01/2023   | 20:49        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 09/01/2023    |
| MSPGCL                | Uran Unit 8             | 108      | 01/01/2023   | 23:55        | 03/01/2023 | 09:30      | for filter replacement of GT-8                                                                                                                          |               |
| MSPGCL                | Uran Unit B0            | 120      | 01/01/2023   | 23:56        | 03/01/2023 | 14:08      | for filter replacement of GT-8                                                                                                                          |               |
| MSPGCL                | Koradi Unit 9           | 660      | 03/01/2023   | 20:49        | 03/01/2023 | 20:50      | invalid entry                                                                                                                                           |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 03/01/2023   | 21:49        |            | Continued. | DUE TO EMPLOYEES ON STRIKE.                                                                                                                             |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 03/01/2023   | 22:15        | 04/01/2023 | 23:58      | Due to employees on Strike.                                                                                                                             |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 03/Jan/2023**

**Position as on 6.30 Hrs of 04/Jan/2023**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage             | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------|---------------|
| MSPGCL             | Khaparkheda Unit 3      | 210      | 03/01/2023   | 22:46        |            | Continued. | Due to Employees on Strike.  |               |
| MSPGCL             | Chandrapur Unit 5       | 500      | 03/01/2023   | 22:52        |            | Continued. | Ash Handling System problem. | 05/01/2023    |
| MSPGCL             | Uran Unit B0            | 120      | 03/01/2023   | 23:09        | 04/01/2023 | 20:38      | Due to Strike                |               |
| MSPGCL             | Chandrapur Unit 4       | 210      | 03/01/2023   | 23:15        |            | Continued. | Air heater problem           | 07/01/2023    |
| MSPGCL             | Paras Unit 4            | 250      | 04/01/2023   | 07:08        | 04/01/2023 | 19:08      | High drum level.             |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Jan/2023**

**Statement-VII**

Position as on 6.30 Hrs of 04/Jan/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                               |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                |
| KOLHAPUR - KOLHAPUR (PG) CKT - 1          | InterState                | 28/11/2022   | 10:12        |            |            | PO          | For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2. |
| DHULE - SSNNL CKT - 1                     | InterState                | 03/01/2023   | 09:03        | 03/01/2023 | 18:38      | PO          | Maintenance work.                                                                                                                                                                                                                              |
| KORADI - SATPUR                           | InterState                | 03/01/2023   | 13:24        | 03/01/2023 | 22:05      | HT          | To attend Hotspot at Satpur end.                                                                                                                                                                                                               |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2       | IntraState                | 08/11/2022   | 07:32        |            | Continued. | HT          | For Load Management                                                                                                                                                                                                                            |
| NAGOTHANE - DABHOL CKT - 1                | IntraState                | 03/01/2023   | 11:29        | 04/01/2023 | 19:35      | PO          | Replacement of Surge Arrestor for Y & B poles                                                                                                                                                                                                  |
| <b>220 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                |
| EKLAHARE (OCR) - NAVASARI CKT - 2         | IntraState                | 18/12/2022   | 22:52        |            |            | HT          | To control overloading                                                                                                                                                                                                                         |
| EKLAHARE (OCR) - PADGHE                   | IntraState                | 19/12/2022   | 18:12        | 03/01/2023 | 17:02      | HT          | HT for Load Management                                                                                                                                                                                                                         |
| TROMBAY SALSETTE LINE-2                   | IntraState                | 02/01/2023   | 22:58        | 03/01/2023 | 05:15      | PO          | 400 KV KVPTL WORK PROJECT WORK                                                                                                                                                                                                                 |
| MALEGAON-SATANA                           | IntraState                | 03/01/2023   | 06:17        | 03/01/2023 | 17:37      | HT          | To control overload                                                                                                                                                                                                                            |
| PEDHAMBE ONI LINE                         | IntraState                | 03/01/2023   | 09:15        | 03/01/2023 | 18:43      | PO          | For cold washing of line insulators.                                                                                                                                                                                                           |
| NAGOTHANE - WADKHAL (GIS) CKT-2           | IntraState                | 03/01/2023   | 10:23        | 03/01/2023 | 18:05      | PO          | cold line insulator cleaning work                                                                                                                                                                                                              |
| TEMBHURNI - JEUR                          | IntraState                | 03/01/2023   | 10:50        | 03/01/2023 | 19:47      | PO          | Outage is required for Replacement of Faulty string at Loc. No. 174 (R-ph), 179 (R-ph), 171 (R-ph) & 175 (B-ph) Found during PID                                                                                                               |
| VITTAL SUGAR CO GEN (VSSK) - JEUR         | IntraState                | 03/01/2023   | 10:52        | 03/01/2023 | 20:40      | PO          | Outage is required for Replacement of Faulty string at Loc. No. 174 (R-ph), 179 (R-ph), 171 (R-ph) & 175 (B-ph) Found during PID                                                                                                               |
| PADGHE - JAMBHUL 1                        | IntraState                | 04/01/2023   | 17:44        | 04/01/2023 | 21:07      | T           | Distance Protection                                                                                                                                                                                                                            |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                               |
| 220/132KV 100MVA PTR 1 @ KHAREPATAN       | IntraState                | 22/09/2022   | 16:35        |            |            | T           | ICT bursted                                                                                                                                                                                                                                    |
| 220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE | IntraState                | 10/11/2022   | 10:35        |            |            | EO          | For attending to abnormal Nosie from ICT                                                                                                                                                                                                       |
| 220/22 KV 50 MVA PTR 1 @ ANANDNAGAR       | IntraState                | 23/12/2022   | 09:30        |            | Continued. | PO          | For TF Diagnostic Testing work , HV CT Tandelta , HV & LV Breaker CRM, Timing and R&M work                                                                                                                                                     |
| 220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)  | IntraState                | 02/01/2023   | 11:08        | 03/01/2023 | 18:29      | PO          | Continuous outage for 2 dyas required for ICT 3 oil filtration work                                                                                                                                                                            |
| 220/132KV 100MVA ICT 1 @ SATARA MIDC      | IntraState                | 03/01/2023   | 11:11        | 03/01/2023 | 16:07      | PO          | Diagnostic testing & quarterly maintenance Work.                                                                                                                                                                                               |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage