

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 03/Feb/2019 SUNDAY**

| I GENERATION (MUs)  |                |                | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly        | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 127.165        | 392.456        | 1) Gujrat                      | 2.971          | 10.082          |
| 2) Hydro            | 8.127          | 22.576         | 2) Madhya Pradesh              | 12.454         | 37.254          |
| 3) Gas              | 7.277          | 18.547         | 3) Chattisgarh                 | 5.890          | 17.410          |
| <b>Total MSPGCL</b> | <b>142.569</b> | <b>433.579</b> | 4) Maharashtra                 | 93.829         | 278.543         |
| B) 1) APMIL         | 60.724         | 196.004        | 5) Goa (Amona)                 | -0.440         | -1.540          |
| 2) JSWEL            | 21.443         | 64.002         | <b>Total</b>                   | <b>114.704</b> | <b>341.749</b>  |
| 3) VIPL             | 0.000          | 0.000          | a) Mumbai Schedule             | 13.121         | 44.344          |
| 4) RPL(AMT)         | 0.000          | 0.000          | b) Mumbai Drawl                | 14.041         | 47.940          |
| 5) WPCL             | 0.000          | 0.000          | c) MSEDCL Bilateral *          | 14.932         | 42.788          |
| 6) Other IPP        | 12.425         | 38.171         | Include PX                     | 0.148          | -1.113          |
| 7) PGPL             | 0.000          | 0.000          | d) Mumbai Bilateral *          | 13.121         | 44.344          |
| C) 1) TPCL Thermal  | 13.202         | 40.438         | Include PX                     | 2.767          | 11.338          |
| 2) TPCL Hydro       | 0.304          | 6.386          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 3.765          | 11.717         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.512          | 28.752         | 1) MSEDCL                      | 351.620        | 1059.343        |
| D) STATE            |                |                | 2) Mumbai Discoms              | 40.824         | 135.234         |
| 1) Thermal          | 244.471        | 759.823        | <b>TOTAL STATE</b>             | <b>392.444</b> | <b>1194.577</b> |
| (A1+C1+C4+(B1-B6))  |                |                |                                |                |                 |
| 2) Hydro            | 8.431          | 28.962         |                                |                |                 |
| (A2+C2)             |                |                |                                |                |                 |
| 3) Gas              | 11.042         | 30.264         |                                |                |                 |
| (A3+B7+C3)          |                |                |                                |                |                 |
| 4) Wind             | 8.510          | 16.879         |                                |                |                 |
| 6) SOLAR            | 5.286          | 16.899         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>277.740</b> | <b>852.827</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5313                      | 5557                  | 5485                      | 4773                      |
| MSPGCL Hydro             | 1008                      | 538                   | 350                       | 299                       |
| MSPGCL Gas               | 295                       | 287                   | 305                       | 305                       |
| MSPGCL Total Generation  | 6616                      | 6382                  | 6140                      | 5377                      |
| Central Sector Receipt   | 5541                      | 5465                  | 4929                      | 3753                      |
| WIND                     | 640                       | 349                   | 267                       | 299                       |
| CPP / IPP Thermal        | 4356                      | 4237                  | 3949                      | 3569                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 667                       | 839                   | 0                         | 0                         |
| Exchange with Mumbai     | -633                      | -605                  | -781                      | -292                      |
| <b>MSEDCL DEMAND MET</b> | <b>17187</b>              | <b>16667</b>          | <b>14504</b>              | <b>12706</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17187                     | 16667                 | 14504                     | 12706                     |
| TPCL GENERATION          | 860                       | 877                   | 734                       | 626                       |
| AEML GENERATION          | 502                       | 503                   | 372                       | 373                       |
| <b>MUMBAI DEMAND</b>     | <b>1995</b>               | <b>1985</b>           | <b>1887</b>               | <b>1291</b>               |
| STATE DEMAND MET         | 19182                     | 18652                 | 16391                     | 13997                     |
| <b>STATE DEMAND</b>      | <b>19182</b>              | <b>18652</b>          | <b>16391</b>              | <b>13997</b>              |
| Frequency (Hz)           | 49.94                     | 49.97                 | 49.97                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.23 Hz at 06.03 Hrs | 49.7 Hz at 08.19 Hrs | 49.97         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 03/Feb/2019

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 1.88         | 9.42          | 170      | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 10.47        | 32.90         | 500      | 360      |
| Unit 9             | 10.52        | 33.30         | 463      | 381      |
| Unit 10            | 10.40        | 28.53         | 473      | 355      |
| <b>Total</b>       | <b>33.26</b> | <b>104.16</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.60         | 28.69         | 480      | 350      |
| Unit 5             | 0.31         | 0.31          | 190      | 0        |
| <b>Total</b>       | <b>9.90</b>  | <b>29.00</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 4.09         | 12.10         | 190      | 163      |
| Unit 4             | 4.09         | 12.28         | 183      | 157      |
| Unit 5             | 9.23         | 27.56         | 410      | 355      |
| Unit 6             | 3.48         | 23.39         | 387      | 0        |
| Unit 7             | 9.58         | 29.16         | 430      | 365      |
| Unit 8             | 10.62        | 31.82         | 490      | 360      |
| Unit 9             | 10.58        | 31.36         | 492      | 360      |
| <b>Total</b>       | <b>51.67</b> | <b>167.67</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.48         | 5.56          | 250      | 0        |
| <b>Total</b>       | <b>3.48</b>  | <b>5.56</b>   |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.78         | 11.10         | 165      | 145      |
| Unit 2             | 3.83         | 11.23         | 160      | 150      |
| Unit 3             | 3.79         | 11.34         | 160      | 152      |
| Unit 4             | 3.85         | 11.28         | 162      | 155      |
| Unit 5             | 9.70         | 28.90         | 440      | 375      |
| <b>Total</b>       | <b>24.95</b> | <b>73.86</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.90         | 12.21         | 167      | 158      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>3.90</b>  | <b>12.21</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.28         | 18.55         | 319      | 286      |
| <b>Total</b>       | <b>7.28</b>  | <b>18.55</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.00         | 0.04          | 0        | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.00</b>  | <b>0.04</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 3.18         | 8.10          | 315      | 40       |
| Stage 4         | 0.52         | 1.52          | 250      | 0        |
| Stage 3         | 0.82         | 2.07          | 80       | 0        |
| <b>Total</b>    | <b>4.52</b>  | <b>11.69</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.44         | 1.33          | 19       | 18       |
| VTRNA           | 0.72         | 2.10          | 61       | 0        |
| TILLARI         | 0.42         | 1.27          | 60       | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.08         | 0.42          | 43       | 0        |
| RNGR+BHTSA      | 0.31         | 0.92          | 13       | 12       |
| BHANDARDRA      | 0.00         | 0.00          | 0        | 0        |
| ELDARY          | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.14         | 0.92          | 14       | 4        |
| GHATGHAR        | 1.50         | 3.93          | 250      | 0        |
| <b>Total</b>    | <b>3.61</b>  | <b>10.88</b>  |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 8.51         | 16.88         | 0        | 0        |
| <b>Total</b>    | <b>8.51</b>  | <b>16.88</b>  |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 60.72        | 196.00        | 0        | 0        |
| JSWEL(Mus)      | 21.44        | 64.00         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| Other(Mus)      | 12.42        | 38.17         | 0        | 0        |
| <b>Total</b>    | <b>94.59</b> | <b>298.18</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 5.29         | 16.90         | 0        | 0        |
| <b>Total</b>    | <b>5.29</b>  | <b>16.90</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 8.29         | 24.95         | 479      | 307      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.31         | 7.26          | 116      | 64       |
| Trombay 7B      | 1.46         | 4.46          | 68       | 50       |
| Trombay 8       | 4.91         | 15.49         | 218      | 198      |
| TATA Hydro      | 0.30         | 6.39          | 72       | 0        |
| <b>Total</b>    | <b>17.27</b> | <b>58.54</b>  |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 9.51         | 28.75         | 503      | 372      |
| <b>Total</b>    | <b>9.51</b>  | <b>28.75</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 127.16      | 392.46        | MSPGCL Total        | 142.57      | 433.58        |
|                |             |         | MSPGCL Thml+Gas | 134.44      | 411.00        | Koyna 1,2 & 4 Total | 3.70        | 9.62          |
|                |             |         | MSPGCL Hydro    | 8.13        | 22.58         | State Total         | 277.74      | 852.83        |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 03/Feb/2019

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5195        | 84   | 314  | 5593   | 184  | 3563      | 0    | 0     | 3837        | 3735        | -476                 | 12599                 | 0                    | 12599                     | 1515             | 14114           | 49.97         |
| 2                  | 5155        | 229  | 315  | 5699   | 211  | 3579      | 0    | 0     | 3341        | 3554        | -383                 | 12660                 | 0                    | 12660                     | 1400             | 14060           | 50.01         |
| 3                  | 5095        | 144  | 316  | 5555   | 257  | 3563      | 0    | 0     | 3649        | 3678        | -324                 | 12729                 | 0                    | 12729                     | 1328             | 14057           | 49.96         |
| 4                  | 4773        | 299  | 305  | 5377   | 299  | 3569      | 0    | 0     | 3656        | 3753        | -292                 | 12706                 | 0                    | 12706                     | 1291             | 13997           | 49.99         |
| 5                  | 4766        | 170  | 316  | 5252   | 346  | 3576      | 0    | 0     | 4194        | 4242        | -298                 | 13118                 | 0                    | 13118                     | 1295             | 14413           | 49.93         |
| 6                  | 5039        | 75   | 317  | 5431   | 390  | 3785      | 0    | 0     | 4730        | 4858        | -378                 | 14086                 | 0                    | 14086                     | 1377             | 15463           | 49.99         |
| 7                  | 5347        | 155  | 319  | 5821   | 533  | 4226      | 0    | 0     | 5000        | 5058        | -451                 | 15187                 | 0                    | 15187                     | 1454             | 16641           | 50.04         |
| 8                  | 5509        | 395  | 318  | 6222   | 631  | 4628      | 0    | 50    | 5316        | 5376        | -529                 | 16378                 | 0                    | 16378                     | 1534             | 17912           | 49.93         |
| 9                  | 5563        | 460  | 315  | 6338   | 613  | 4835      | 0    | 233   | 5280        | 5272        | -691                 | 16600                 | 0                    | 16600                     | 1703             | 18303           | 49.82         |
| 10                 | 5430        | 893  | 310  | 6633   | 660  | 4726      | 0    | 466   | 5091        | 5066        | -702                 | 16849                 | 0                    | 16849                     | 1874             | 18723           | 49.84         |
| 11                 | 5313        | 1008 | 295  | 6616   | 640  | 4356      | 0    | 667   | 5327        | 5541        | -633                 | 17187                 | 0                    | 17187                     | 1995             | 19182           | 49.94         |
| 12                 | 5420        | 922  | 291  | 6633   | 457  | 4343      | 0    | 810   | 5439        | 5550        | -646                 | 17147                 | 0                    | 17147                     | 2026             | 19173           | 49.87         |
| 13                 | 5557        | 538  | 287  | 6382   | 349  | 4237      | 0    | 839   | 5215        | 5465        | -605                 | 16667                 | 0                    | 16667                     | 1985             | 18652           | 49.97         |
| 14                 | 5573        | 371  | 286  | 6230   | 257  | 4032      | 0    | 779   | 5342        | 5326        | -539                 | 16085                 | 0                    | 16085                     | 1893             | 17978           | 50.01         |
| 15                 | 5600        | 274  | 286  | 6160   | 226  | 3969      | 0    | 631   | 5324        | 5310        | -642                 | 15654                 | 0                    | 15654                     | 1812             | 17466           | 50.02         |
| 16                 | 5600        | 85   | 288  | 5973   | 159  | 3987      | 0    | 464   | 5242        | 5415        | -618                 | 15380                 | 0                    | 15380                     | 1738             | 17118           | 49.98         |
| 17                 | 5608        | 123  | 289  | 6020   | 129  | 4016      | 0    | 269   | 5125        | 4806        | -650                 | 14590                 | 0                    | 14590                     | 1725             | 16315           | 50.02         |
| 18                 | 5491        | 222  | 292  | 6005   | 161  | 3951      | 0    | 78    | 4609        | 4943        | -677                 | 14461                 | 0                    | 14461                     | 1747             | 16208           | 50.03         |
| 19                 | 5485        | 350  | 305  | 6140   | 267  | 3949      | 0    | 0     | 4871        | 4929        | -781                 | 14504                 | 0                    | 14504                     | 1887             | 16391           | 49.97         |
| 20                 | 5398        | 245  | 296  | 5939   | 291  | 3936      | 0    | 0     | 4983        | 4906        | -863                 | 14209                 | 0                    | 14209                     | 1982             | 16191           | 50.00         |
| 21                 | 5237        | 202  | 308  | 5747   | 301  | 3653      | 0    | 0     | 4683        | 4819        | -814                 | 13706                 | 0                    | 13706                     | 1954             | 15660           | 50.00         |
| 22                 | 5085        | 362  | 300  | 5747   | 322  | 3552      | 0    | 0     | 4477        | 4527        | -773                 | 13375                 | 0                    | 13375                     | 1896             | 15271           | 50.00         |
| 23                 | 5021        | 217  | 309  | 5547   | 399  | 3390      | 0    | 0     | 4504        | 4400        | -689                 | 13047                 | 0                    | 13047                     | 1776             | 14823           | 49.96         |
| 24                 | 4905        | 304  | 300  | 5509   | 428  | 3171      | 0    | 0     | 3793        | 4175        | -587                 | 12696                 | 0                    | 12696                     | 1637             | 14333           | 50.00         |
| MUs                | 127.16      | 8.13 | 7.28 | 142.57 | 8.51 | 94.59     | 0.00 | 5.29  | 113.03      | 114.70      | -14.04               | 351.62                | 0.00                 | 351.62                    | 40.82            | 392.44          | 49.97         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 03/Feb/2019**

**Position as on 6.30 Hrs of 04/Feb/2019**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                                                                | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                                                                 |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                                                                                                                                                                                 |               |
| MSPGCL                | Nasik Unit 5            | 210      | 22/11/2018   | 03.50        |            | Continued. | Boiler Tube Leakage Work Completed On 24/11/2018. Available Against Case 4 From 25/11/2018. Converted To COH From 00:00 Hrs of 05/12/2018 (Converted COH to Zero sch by MSEDCL from 29.01.2019) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                                                                 |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                                                                                                                                               |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                                                                                                                         |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                                                                                               |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                                                                                                                                               |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                                                                                     |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                                                                                                                                                     |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure.                                                                                                                                                             |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                                                                                                                                                                               |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |            | Continued. | Withdrawn Due To B0 & U-7                                                                                                                                                                       |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |            | Continued. | Stator Earth Fault                                                                                                                                                                              |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| MSPGCL                | Koyana Unit 1           | 70       | 26/11/2018   | 00.00        |            | Continued. | Oil Cooler Leakage.                                                                                                                                                                             |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                                                                                                                                                                                    |               |
| MSPGCL                | Parli Unit 7            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| MSPGCL                | Parli Unit 6            | 250      | 12/12/2018   | 00.00        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 14/12/2018   | 03.00        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| IPP                   | RPL(AMT) U-3            | 270      | 14/12/2018   | 16.30        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| CPP                   | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |            | Continued. | No Schedule                                                                                                                                                                                     |               |
| IPP                   | RPL(AMT) U-2            | 270      | 27/12/2018   | 19.30        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| IPP                   | RPL(AMT) U-5            | 270      | 28/12/2018   | 19.30        |            | Continued. | Zero Schedule.                                                                                                                                                                                  |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                                                                                                                                                   |               |
| MSPGCL                | Nasik Unit 3            | 210      | 09/01/2019   | 19.30        |            | Continued. | Zero Schedule                                                                                                                                                                                   |               |
| IPP                   | Dhariwal                | 300      | 12/01/2019   | 10.15        |            | Continued. | Coal Shortage                                                                                                                                                                                   |               |
| MSPGCL                | Parli Unit 8            | 250      | 12/01/2019   | 12.00        |            | Continued. | Zero Schedule by MSEDCL                                                                                                                                                                         |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                                                                                                                                                   |               |
| MSPGCL                | Koradi Unit 7           | 210      | 19/01/2019   | 18.21        |            | Continued. | Poor Coal Receipt                                                                                                                                                                               |               |
| IPP                   | RPL(AMT) U-1            | 270      | 27/01/2019   | 02.17        |            | Continued. | Withdrawn On RSD.                                                                                                                                                                               |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 31/01/2019   | 03.48        | 03/02/2019 | 21.36      | Boiler Tube Leakage                                                                                                                                                                             |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 03/Feb/2019**

**Position as on 6.30 Hrs of 04/Feb/2019**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage          | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------|---------------|
| MSPGCL             | Paras Unit 4            | 250      | 03/02/2019   | 02.43        | 03/02/2019 | 09.48      | Low Vaccum                |               |
| MSPGCL             | Koradi Unit 6           | 210      | 03/02/2019   | 02.58        | 03/02/2019 | 11.07      | Flame Failure             |               |
| MSPGCL             | Chandrapur Unit 6       | 500      | 03/02/2019   | 10.00        |            | Continued. | Boiler Tube Leakage       |               |
| IPP                | Adani U-5               | 660      | 03/02/2019   | 10.08        |            | Continued. | Bottom ASH Hopper leakage |               |
| MSPGCL             | Koradi Unit 6           | 210      | 03/02/2019   | 22.09        |            | Continued. | Boiler Tube Leakage       |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Feb/2019**

**Statement-VII**

**Position as on 6.30 Hrs of 04/Feb/2019**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                               |
| Dhule Sar'Sarovar I                               | InterState                | 02/02/2019   | 17.50        | 04/02/2019 | 08.50      | PO          | Work at SSP end                                                                                                                        |
| Dhule Sar'Sarovar II                              | InterState                | 04/02/2019   | 09.08        |            | Continued. | PO          | Work At SSP End.                                                                                                                       |
| Padghe - Kalwa-II                                 | IntraState                | 25/01/2019   | 09.17        |            | Continued. | PO          | Dismantalling Erection & Conductor Replacement Work For MMRDA.                                                                         |
| Bhusawal-Aurangabad                               | IntraState                | 02/02/2019   | 17.42        | 03/02/2019 | 08.55      | HT          | Over Voltage                                                                                                                           |
| Lonikand I - Koyna stage-IV                       | IntraState                | 03/02/2019   | 00.04        | 03/02/2019 | 08.48      | HT          | Over Voltage                                                                                                                           |
| Padghe - Nagothane - II                           | IntraState                | 03/02/2019   | 00.09        | 03/02/2019 | 09.50      | HT          | Over Voltage                                                                                                                           |
| Dhule - Bableshwar - li                           | IntraState                | 03/02/2019   | 01.08        | 03/02/2019 | 08.38      | T           | Distance Protection                                                                                                                    |
| Bhusawal-Aurangabad                               | IntraState                | 03/02/2019   | 16.31        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Lonikand I - Koyna stage-IV                       | IntraState                | 03/02/2019   | 23.34        | 04/02/2019 | 09.13      | HT          | Over Voltage                                                                                                                           |
| Nagothane - Dabhol I                              | IntraState                | 04/02/2019   | 10.05        |            | Continued. | PO          | Work At Dhabhol End.                                                                                                                   |
| N.Koyna-Karad -Ckt I                              | IntraState                | 04/02/2019   | 14.01        |            | Continued. | EO          | Replacement Of Insulator String.                                                                                                       |
| Kala Kudus Ckt-II                                 | IntraState                | 04/02/2019   | 15.14        | 04/02/2019 | 19.21      | T           | Distance Protection                                                                                                                    |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe               | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection, Declared Faulty.                                                                                              |
| 400/220/33 Kv 105 Mva Bhel Spare Ict 1 @Nagothane | IntraState                | 04/02/2019   | 12.55        | 04/02/2019 | 17.30      | PO          | Diagnostic Testing.                                                                                                                    |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                               | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                               | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I                       | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet 86 To 107.                   |
| Chandrapur GCR - Wani                             | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                                   | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading.                                                                                                               |
| Bhira Dharavi 8                                   | IntraState                | 01/02/2019   | 07.56        |            | Continued. | PO          | Tower Erection work                                                                                                                    |
| Mumewadi -Halkarni II                             | IntraState                | 03/02/2019   | 16.03        | 03/02/2019 | 20.32      | T           | Distance Protection                                                                                                                    |
| Padegaon-Sawangi                                  | IntraState                | 04/02/2019   | 08.50        | 04/02/2019 | 18.52      | PO          | Disc Insulator Replacement Work                                                                                                        |
| Trombay-Salsette II                               | IntraState                | 04/02/2019   | 08.56        | 04/02/2019 | 22.48      | PO          | CVT Replacement Work.                                                                                                                  |
| Kolhapur - 5 Star Ckt I                           | IntraState                | 04/02/2019   | 09.02        | 04/02/2019 | 15.58      | EO          | Attending Hot Spot At Jumper of B Ph.                                                                                                  |
| Miraj-Ichalkaranji I                              | IntraState                | 04/02/2019   | 09.49        | 04/02/2019 | 19.43      | OO          | To Control Over Loading, kolhapur to Ichalkarnji 1.                                                                                    |
| Talandge(400kv)- Ichalkaranji 1                   | IntraState                | 04/02/2019   | 09.50        | 04/02/2019 | 19.38      | PO          | Line Insulator Cleaning.                                                                                                               |
| Deepnagar Khadaka 2                               | IntraState                | 04/02/2019   | 10.11        | 04/02/2019 | 12.39      | PO          | Attending Hot Spot Work On CT At Deepnagar.                                                                                            |
| Nashik-Airoli Knowledge Park                      | IntraState                | 04/02/2019   | 10.31        | 04/02/2019 | 18.41      | HT          | To manage Load For Availing outage On 220 KV NASHIK - BBLR-1.                                                                          |
| Nashik-Padgha                                     | IntraState                | 04/02/2019   | 10.47        | 04/02/2019 | 18.50      | HT          | To Manage Load For Availing Outage On 220 KV NASHIK - BBLR-1.                                                                          |
| chandrapur-Tadali                                 | IntraState                | 04/02/2019   | 11.40        | 04/02/2019 | 13.58      | PO          | Replacement of MFM to ABT Meter.                                                                                                       |
| Karad - Vita Ckt- II                              | IntraState                | 04/02/2019   | 11.50        |            | Continued. | T           | Distance Protection,Z1 4.5KM Y TP BPH 6.5KA                                                                                            |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Feb/2019**

**Statement-VII**

Position as on 6.30 Hrs of 04/Feb/2019

| Name of Line                         | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                         |
|--------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------------------|
| Uran - Hoc 1                         | IntraState                   | 04/02/2019      | 13.12           | 04/02/2019 | 16.27         | EO             | For Attending Oil Leakage At URAN End.   |
| New Koyna - Loteparshuram            | IntraState                   | 04/02/2019      | 14.16           | 04/02/2019 | 18.02         | T              | Distance Protection Z1.BPH.5.89KM.11.3A. |
| <b>220 KV ICT Outages/Trippings</b>  |                              |                 |                 |            |               |                |                                          |
| 220/132 Kv 200 MVA ICT-I @Malegaon   | IntraState                   | 04/02/2019      | 10.29           | 04/02/2019 | 16.38         | PO             | Tan Delta DCRM And Breaker Timing.       |
| <b>132 KV LINE Outages/Trippings</b> |                              |                 |                 |            |               |                |                                          |
| Mansar Pench                         | InterState                   | 22/01/2019      | 18.40           |            | Continued.    | HT             | After Completion of Outage.              |
| Kanhan-Pench                         | IntraState                   | 22/01/2019      | 18.44           |            | Continued.    | HT             | After Completion of Outage.              |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage