

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 03/Mar/2016 THURSDAY**

| I GENERATION (MUs)  |                |                | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly        | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 95.996         | 304.368        | 1) Gujrat                      | -2.130         | -10.682         |
| 2) Hydro            | 10.694         | 18.981         | 2) Madhya Pradesh              | 11.630         | 29.014          |
| 3) Gas              | 10.188         | 30.007         | 3) Chattisgarh                 | 7.190          | 18.740          |
| <b>Total MSPGCL</b> | <b>116.878</b> | <b>353.356</b> | 4) Maharashtra Net             | 85.441         | 252.940         |
| B) 1) APML          | 63.235         | 187.357        | 5) Goa (Amona)                 | -0.630         | -1.844          |
| 2) JSWEL            | 20.765         | 69.146         | 6) TAPS 1&2 Injection          | 3.715          | 10.842          |
| 3) VIPL             | 11.417         | 33.626         | 7) RGPPL Injection             | 11.451         | 34.378          |
| 4) RPL(AMT)         | 14.466         | 44.345         | 8) Pench (MS)                  | 0.137          | 0.295           |
| 5) WPCL             | 2.544          | 11.975         | 9) Pench (Excess)              | -0.137         | -0.295          |
| 6) Other IPP        | 8.287          | 25.478         | <b>Total</b>                   | <b>116.530</b> | <b>333.093</b>  |
| C) 1) TPCL Thermal  | 12.310         | 32.095         | a) Mumbai Schedule             | 20.463         | 59.384          |
| 2) TPCL Hydro       | 4.069          | 11.954         | b) Mumbai Drawl                | 27.631         | 86.192          |
| 3) TPCL Gas         | 3.857          | 12.026         | c) MSEDCL Bilateral *          | 24.793         | 82.568          |
| 4) R-INFRA Thermal  | 11.551         | 33.251         | Include PX                     | -1.930         | -1.930          |
| <b>D) STATE</b>     |                |                | d) Mumbai Bilateral *          | 20.463         | 59.384          |
| 1) Thermal          | 240.571        | 741.641        | Include PX                     | 3.455          | 10.613          |
| (A1+C1+C4+(B1-B6))  |                |                | Include Standby                | 0.000          | 0.000           |
| 2) Hydro            | 14.763         | 30.935         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 14.045         | 42.033         | 1) MSEDCL                      | 333.130        | 997.284         |
| 4) Wind             | 5.522          | 21.955         | 2) Mumbai Discoms              | 59.418         | 175.518         |
| 6) SOLAR            | 1.117          | 3.145          | <b>TOTAL STATE</b>             | <b>392.548</b> | <b>1172.802</b> |
| <b>TOTAL STATE</b>  | <b>276.018</b> | <b>839.709</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4202                      | 4236                  | 3826                      | 3805                      |
| MSPGCL Hydro             | 751                       | 694                   | 1161                      | 127                       |
| MSPGCL Gas               | 426                       | 420                   | 282                       | 426                       |
| MSPGCL Total Generation  | 5379                      | 5350                  | 5269                      | 4358                      |
| Central Sector Receipt   | 5698                      | 5315                  | 5285                      | 3714                      |
| WIND                     | 39                        | 24                    | 181                       | 248                       |
| CPP / IPP                | 5250                      | 5437                  | 5044                      | 4574                      |
| SOLAR                    | 168                       | 193                   | 0                         | 0                         |
| Exchange with Mumbai     | -1372                     | -1418                 | -1223                     | -686                      |
| <b>MSEDCL DEMAND MET</b> | <b>15162</b>              | <b>14901</b>          | <b>14556</b>              | <b>12208</b>              |
| Load Shedding            | 4                         | 4                     | 4                         | 4                         |
| MSEDCL DEMAND            | 15166                     | 14905                 | 14560                     | 12212                     |
| TPCL GENERATION          | 1127                      | 1068                  | 1078                      | 652                       |
| R-INFRA GENERATION       | 514                       | 518                   | 519                       | 403                       |
| <b>MUMBAI DEMAND</b>     | <b>3013</b>               | <b>3004</b>           | <b>2820</b>               | <b>1741</b>               |
| STATE DEMAND MET         | 18175                     | 17905                 | 17376                     | 13949                     |
| <b>STATE DEMAND</b>      | <b>18179</b>              | <b>17909</b>          | <b>17380</b>              | <b>13953</b>              |
| Frequency (Hz)           | 49.91                     | 49.98                 | 49.99                     | 49.94                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.14 Hz at 12.01 Hrs | 49.7 Hz at 20.34 Hrs | 49.95         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 03/Mar/2016

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 4.01          | 0        | 0        |
| Unit 8             | 8.41         | 25.82         | 355      | 350      |
| <b>Total</b>       | <b>8.41</b>  | <b>29.83</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 2             | 0.00         | 1.70          | 0        | 0        |
| Unit 3             | 4.06         | 11.21         | 175      | 160      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 8.52         | 26.53         | 360      | 350      |
| <b>Total</b>       | <b>12.58</b> | <b>39.44</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| Unit 3             | 4.36         | 12.94         | 207      | 163      |
| Unit 4             | 4.33         | 12.81         | 198      | 167      |
| Unit 5             | 9.46         | 28.47         | 440      | 360      |
| Unit 6             | 9.22         | 27.81         | 405      | 365      |
| Unit 7             | 9.53         | 28.33         | 451      | 350      |
| <b>Total</b>       | <b>36.90</b> | <b>110.36</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.24         | 4.81          | 154      | 0        |
| Unit 4             | 0.00         | 5.35          | 0        | 0        |
| <b>Total</b>       | <b>0.24</b>  | <b>10.16</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.83         | 11.65         | 165      | 155      |
| Unit 2             | 3.93         | 11.88         | 175      | 160      |
| Unit 3             | 3.86         | 11.92         | 165      | 157      |
| Unit 4             | 3.92         | 12.03         | 194      | 159      |
| Unit 5             | 10.58        | 31.19         | 500      | 365      |
| <b>Total</b>       | <b>26.11</b> | <b>78.66</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.95         | 11.92         | 165      | 160      |
| Unit 4             | 3.89         | 11.23         | 167      | 155      |
| Unit 5             | 3.91         | 11.80         | 169      | 159      |
| <b>Total</b>       | <b>11.75</b> | <b>34.95</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 10.19        | 30.01         | 519      | 282      |
| <b>Total</b>       | <b>10.19</b> | <b>30.01</b>  |          |          |

| Generating unit   | Generation    |               |          |          |
|-------------------|---------------|---------------|----------|----------|
|                   | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |               |               |          |          |
| Pench (MS)        | 0.14          | 0.30          | 42       | 0        |
| <b>Total</b>      | <b>0.14</b>   | <b>0.30</b>   |          |          |
| <b>Koyna</b>      |               |               |          |          |
| Stage 1-2         | 3.72          | 7.52          | 550      | 40       |
| Stage 4           | 2.73          | 3.42          | 421      | 0        |
| Stage 3           | 1.75          | 1.88          | 240      | 0        |
| <b>Total</b>      | <b>8.21</b>   | <b>12.82</b>  |          |          |
| <b>Hydro</b>      |               |               |          |          |
| KDPH              | 0.64          | 1.48          | 35       | 17       |
| VTRNA             | 0.00          | 0.00          | 0        | 0        |
| TILLARI           | 0.19          | 0.38          | 63       | 0        |
| BHTGR/VEER        | 0.00          | 0.00          | 0        | 0        |
| BHIRA T.R.        | 0.27          | 0.72          | 40       | 0        |
| RNGR+BHTSA        | 0.21          | 0.45          | 11       | 0        |
| BHANDARDRA        | 0.00          | 0.00          | 0        | 0        |
| ELDARY            | 0.00          | 0.00          | 0        | 0        |
| SMLHY_PTN         | 1.17          | 3.12          | 49       | 48       |
| GHATGHAR          | 0.00          | 0.00          | 0        | 0        |
| <b>Total</b>      | <b>2.49</b>   | <b>6.16</b>   |          |          |
| <b>Wind</b>       |               |               |          |          |
| Total             | 5.52          | 21.96         | 0        | 0        |
| <b>Total</b>      | <b>5.52</b>   | <b>21.96</b>  |          |          |
| <b>CPP</b>        |               |               |          |          |
| APML(Mus)         | 63.24         | 187.36        | 0        | 0        |
| JSWEL(Mus)        | 20.76         | 69.15         | 0        | 0        |
| VIPL(Mus)         | 11.42         | 33.63         | 0        | 0        |
| RPLAMT(Mus)       | 14.47         | 44.34         | 0        | 0        |
| WPCL(Mus)         | 2.54          | 11.98         | 0        | 0        |
| Other(Mus)        | 8.29          | 25.48         | 0        | 0        |
| <b>Total</b>      | <b>120.71</b> | <b>371.93</b> |          |          |
| <b>SOLAR</b>      |               |               |          |          |
| Total             | 1.12          | 3.14          | 0        | 0        |
| <b>Total</b>      | <b>1.12</b>   | <b>3.14</b>   |          |          |
| <b>Tata</b>       |               |               |          |          |
| Trombay 5         | 8.24          | 27.76         | 458      | 315      |
| Trombay 6         | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A        | 2.36          | 7.44          | 119      | 50       |
| Trombay 7B        | 1.49          | 4.59          | 70       | 42       |
| Trombay 8         | 4.06          | 4.33          | 245      | 41       |
| TATA Hydro        | 4.07          | 11.95         | 435      | 9        |
| <b>Total</b>      | <b>20.24</b>  | <b>56.08</b>  |          |          |
| <b>R-INFRA</b>    |               |               |          |          |
| 1-2               | 11.55         | 33.25         | 519      | 402      |
| <b>Total</b>      | <b>11.55</b>  | <b>33.25</b>  |          |          |

|                     |              |      |          |      |
|---------------------|--------------|------|----------|------|
| <b>Infirm Power</b> | Chandrapur 8 | 0.00 | Koradi 9 | 0.00 |
|---------------------|--------------|------|----------|------|

| Summary         |             |               |
|-----------------|-------------|---------------|
| Particulars     | Daily (Mus) | Monthly (Mus) |
| MSPGCL Thermal  | 96.00       | 304.37        |
| MSPGCL Thml+Gas | 106.18      | 334.38        |

| Summary      |             |               |
|--------------|-------------|---------------|
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 10.69       | 18.98         |
| MSPGCL Total | 116.88      | 353.36        |

| Summary             |             |               |
|---------------------|-------------|---------------|
| Particulars         | Daily (Mus) | Monthly (Mus) |
| Koyna 1,2 & 4 Total | 6.46        | 10.94         |
| State Total         | 276.02      | 839.71        |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 03/Mar/2016

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |       | TOTAL  | WIND | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|-------|--------|------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS   |        |      |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3801        | 121   | 445   | 4367   | 657  | 4720         | 0     | 4356        | 3865        | -1063                | 12546                 | 4                    | 12550                     | 2085             | 14635           | 49.98         |
| 2                  | 3789        | 126   | 439   | 4354   | 514  | 4584         | 0     | 3875        | 3742        | -885                 | 12309                 | 4                    | 12313                     | 1924             | 14237           | 49.95         |
| 3                  | 3798        | 126   | 440   | 4364   | 380  | 4577         | 0     | 3759        | 3687        | -768                 | 12240                 | 4                    | 12244                     | 1813             | 14057           | 49.96         |
| 4                  | 3805        | 127   | 426   | 4358   | 248  | 4574         | 0     | 3755        | 3714        | -686                 | 12208                 | 4                    | 12212                     | 1741             | 13953           | 49.94         |
| 5                  | 3816        | 117   | 449   | 4382   | 183  | 4575         | 0     | 3844        | 3958        | -682                 | 12416                 | 4                    | 12420                     | 1740             | 14160           | 49.95         |
| 6                  | 3806        | 157   | 450   | 4413   | 157  | 4650         | 0     | 4565        | 4825        | -767                 | 13278                 | 4                    | 13282                     | 1831             | 15113           | 49.94         |
| 7                  | 4125        | 225   | 450   | 4800   | 130  | 4982         | 0     | 4889        | 4958        | -821                 | 14049                 | 4                    | 14053                     | 2010             | 16063           | 50.00         |
| 8                  | 4176        | 347   | 440   | 4963   | 148  | 5221         | 17    | 4949        | 4948        | -877                 | 14420                 | 4                    | 14424                     | 2114             | 16538           | 49.96         |
| 9                  | 4201        | 389   | 431   | 5021   | 512  | 5238         | 65    | 5095        | 5311        | -1080                | 15067                 | 4                    | 15071                     | 2389             | 17460           | 50.01         |
| 10                 | 4196        | 501   | 434   | 5131   | 514  | 5228         | 109   | 5300        | 5255        | -1287                | 14950                 | 4                    | 14954                     | 2753             | 17707           | 49.98         |
| 11                 | 4198        | 734   | 437   | 5369   | 132  | 5220         | 150   | 5417        | 5591        | -1364                | 15098                 | 4                    | 15102                     | 2986             | 18088           | 49.98         |
| 12                 | 4202        | 751   | 426   | 5379   | 39   | 5250         | 168   | 5532        | 5698        | -1372                | 15162                 | 4                    | 15166                     | 3013             | 18179           | 49.91         |
| 13                 | 4236        | 694   | 420   | 5350   | 24   | 5437         | 193   | 5518        | 5315        | -1418                | 14901                 | 4                    | 14905                     | 3004             | 17909           | 49.98         |
| 14                 | 4190        | 399   | 488   | 5077   | 37   | 5306         | 155   | 5440        | 5375        | -1274                | 14676                 | 4                    | 14680                     | 2878             | 17558           | 49.98         |
| 15                 | 4184        | 393   | 519   | 5096   | 223  | 5118         | 97    | 5471        | 5216        | -1398                | 14352                 | 4                    | 14356                     | 2910             | 17266           | 49.95         |
| 16                 | 4195        | 332   | 472   | 4999   | 265  | 5197         | 83    | 5477        | 5237        | -1457                | 14324                 | 4                    | 14328                     | 2971             | 17299           | 49.93         |
| 17                 | 4021        | 448   | 416   | 4885   | 241  | 5153         | 57    | 5347        | 5438        | -1398                | 14376                 | 4                    | 14380                     | 2967             | 17347           | 49.99         |
| 18                 | 3810        | 725   | 421   | 4956   | 131  | 5080         | 22    | 4427        | 5001        | -1469                | 13721                 | 4                    | 13725                     | 2907             | 16632           | 49.95         |
| 19                 | 3816        | 792   | 352   | 4960   | 156  | 5063         | 1     | 4646        | 4891        | -1326                | 13745                 | 4                    | 13749                     | 2841             | 16590           | 49.93         |
| 20                 | 3826        | 1161  | 282   | 5269   | 181  | 5044         | 0     | 5227        | 5285        | -1223                | 14556                 | 4                    | 14560                     | 2820             | 17380           | 49.99         |
| 21                 | 3830        | 952   | 309   | 5091   | 143  | 5041         | 0     | 5040        | 5099        | -1153                | 14221                 | 4                    | 14225                     | 2557             | 16782           | 49.89         |
| 22                 | 3933        | 674   | 368   | 4975   | 159  | 5179         | 0     | 4843        | 4745        | -1295                | 13763                 | 4                    | 13767                     | 2434             | 16201           | 49.95         |
| 23                 | 3977        | 214   | 443   | 4634   | 178  | 5207         | 0     | 4800        | 4590        | -1339                | 13270                 | 4                    | 13274                     | 2427             | 15701           | 49.90         |
| 24                 | 4065        | 189   | 431   | 4685   | 170  | 5071         | 0     | 4564        | 4790        | -1229                | 13487                 | 4                    | 13491                     | 2303             | 15794           | 49.91         |
| MUs                | 96.00       | 10.69 | 10.19 | 116.88 | 5.52 | 120.71       | 1.12  | 116.14      | 116.53      | -27.63               | 333.13                | 0.10                 | 333.23                    | 59.42            | 392.65          | 49.95         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 03/Mar/2016

Position as on 6.30 Hrs of 04/Mar/2016

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                      | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                       |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                       |               |
| MSPGCL                | Koyna Unit 10           | 80       | 29/12/2015   | 08:00        |            | Continued. | Annual Overhaul                       |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                       |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                         |               |
| RGPL                  | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                          |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                          |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                          |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                           |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                    |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                     |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                        |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                        |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                        |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                       |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                        |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown                     |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 10/11/2015   | 12.10        |            | Continued. | Drum level low                        |               |
| RGPL                  | Dabhol 3B               | 230      | 07/01/2016   | 17:51        |            | Continued. | Change Over.                          |               |
| MSPGCL                | Chandrapur Unit 2       | 210      | 12/01/2016   | 04.47        |            | Continued. | Boiler Tube Leakage                   |               |
| RGPL                  | Dabhol 3X               | 290      | 03/02/2016   | 15:36        |            | Continued. | Change Over                           |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 09/02/2016   | 18.00        |            | Continued. | oil filtration work.                  |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 14/02/2016   | 12.10        |            | Continued. | Zero Schedule Given by MSEDCL.        |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 15/02/2016   | 00.00        |            | Continued. | Attending Water valve Leakage.        |               |
| IPP                   | RPL(AMT) U-2            | 270      | 16/02/2016   | 01.14        |            | Continued. | Due to Zero Schedule Given by MSEDCL. |               |
| IPP                   | RPL(AMT) U-3            | 270      | 16/02/2016   | 01.17        |            | Continued. | Due to Zero Schedule Given by MSEDCL. |               |
| CPP                   | WPCL U-1                | 135      | 16/02/2016   | 17.09        |            | Continued. | Change Over , No Schedule             |               |
| MSPGCL                | Koradi Unit 5           | 200      | 18/02/2016   | 11.21        |            | Continued. | MSEDCL Zero Shedule.                  |               |
| IPP                   | WPCL U-2                | 135      | 29/02/2016   | 21.46        |            | Continued. | Change over against Unit III          |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 01/03/2016   | 10.13        |            | Continued. | Boiler Tube Leakage                   |               |
| MSPGCL                | Uran Unit 5             | 108      | 01/03/2016   | 13.09        |            | Continued. | Gas Pressure Low.                     |               |
| MSPGCL                | Paras Unit 3            | 250      | 01/03/2016   | 22.09        | 03/03/2016 | 18.57      | Boiler Tube Leakage                   |               |
| MSPGCL                | Koradi Unit 7           | 210      | 01/03/2016   | 23.55        |            | Continued. | Zero Schedule Given by MSEDCL.        |               |
| IPP                   | JSW (J) U3              | 300      | 02/03/2016   | 13.45        |            | Continued. | Cooling Water Leakage.                |               |
| MSPGCL                | Paras Unit 4            | 250      | 02/03/2016   | 22.50        |            | Continued. | Air heater problem                    |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 03/Mar/2016**

Position as on 6.30 Hrs of 04/Mar/2016

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                   | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------|---------------|
| CPP                | WPCL U-4                | 135      | 03/03/2016   | 00.01        |            | Continued. | ESP BACK FILTER MAINTENANCE. WORK. |               |
| MSPGCL             | Paras Unit 3            | 250      | 03/03/2016   | 19.33        | 03/03/2016 | 22.14      | Drum level high                    |               |
| TPC_G              | Trombay 8               | 250      | 03/03/2016   | 20.25        |            | Continued. | main steam line leakage            |               |
| MSPGCL             | Khaparkheda Unit 3      | 210      | 04/03/2016   | 05.10        |            | Continued. | Boiler Tube Leakage                |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Mar/2016**

**Statement-VII**

**Position as on 6.30 Hrs of 04/Mar/2016**

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Dhule Sar'Sarovar I                  | InterState                | 02/03/2016   | 17.18        | 03/03/2016 | 07.43      | HT          | Over Voltage                                                                                                        |
| Kolhapur Solapur(PG) I               | InterState                | 02/03/2016   | 18.20        | 03/03/2016 | 08.05      | HT          | Over Voltage                                                                                                        |
| Chakan Talegaon(Pg)                  | InterState                | 03/03/2016   | 07.24        | 03/03/2016 | 19.03      | HT          | conductor stringing work                                                                                            |
| Akola Wardha li                      | InterState                | 03/03/2016   | 09.30        | 03/03/2016 | 18.30      | PO          | Insulator Replacement Work                                                                                          |
| Dhule Sar'Sarovar I                  | InterState                | 03/03/2016   | 13.47        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Kolhapur Solapur(PG) I               | InterState                | 03/03/2016   | 18.07        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Akola II - Taptitanda ckt-II         | IntraState                | 31/12/2015   | 18.16        |            | Continued. | HT          | Change over                                                                                                         |
| Babhaleshwar-Taptitanda ckt-II       | IntraState                | 11/02/2016   | 18.40        |            | Continued. | HT          | CHANGE OVER                                                                                                         |
| Bhusawal-Aurangabad                  | IntraState                | 26/02/2016   | 17.08        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Padghe - Nagothane - I               | IntraState                | 02/03/2016   | 09.53        | 03/03/2016 | 09.33      | PO          | Faulty String Replacement Work.                                                                                     |
| Akola II - Taptitanda ckt-II         | IntraState                | 02/03/2016   | 10.34        |            | Continued. | PO          | For Commissioning 765kv Ekt Uni s/s.                                                                                |
| karad -kolhapur-II                   | IntraState                | 02/03/2016   | 16.20        | 03/03/2016 | 11.53      | HT          | Over Voltage                                                                                                        |
| Karad-Jaigad - I                     | IntraState                | 02/03/2016   | 16.34        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV          | IntraState                | 02/03/2016   | 23.58        | 03/03/2016 | 06.22      | HT          | Over Voltage                                                                                                        |
| Padghe - Nagothane - II              | IntraState                | 03/03/2016   | 09.50        |            | Continued. | PO          | Maintenance Work RFC at 20.30 hrs                                                                                   |
| N.Koyna-Karad -Ckt I                 | IntraState                | 03/03/2016   | 12.08        |            | Continued. | PO          | Attend hot spot RFC at 14.45                                                                                        |
| karad -kolhapur-I                    | IntraState                | 03/03/2016   | 16.32        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Dhule - Bableswhar - li              | IntraState                | 03/03/2016   | 17.15        | 03/03/2016 | 17.39      | T           | Distance Protection                                                                                                 |
| <b>400 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 400/220/33kv 315mva lct3 @Lonikand   | IntraState                | 03/03/2016   | 09.52        | 03/03/2016 | 17.51      | PO          | Testing Work                                                                                                        |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Hingoli- Girawali                    | InterState                | 14/02/2016   | 12.37        |            | Continued. | HT          | To Improve Voltage @ Hingoli.                                                                                       |
| Chandrapur GCR - Warora - I          | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kalwa - Borivali                     | IntraState                | 10/01/2016   | 09:15        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| GIS Bhandup - Borivali               | IntraState                | 11/01/2016   | 07.42        |            | Continued. | PO          | Tower Erection Work.                                                                                                |
| Padghe - Vasai                       | IntraState                | 24/01/2016   | 08.32        |            | Continued. | PO          | For Formation of Temp. Padgha-Borivali (Charge upto 51/1).                                                          |
| Bableswhar- Alephata                 | IntraState                | 03/02/2016   | 06.28        |            | Continued. | HT          | controlling bblsr ICT Overloading                                                                                   |
| Bableswhar- Ranjangaon               | IntraState                | 03/02/2016   | 07.12        |            | Continued. | HT          | controlling bblsr ICT Overloading                                                                                   |
| Khadka-Chalisgaon-1                  | IntraState                | 29/02/2016   | 10:08        |            | Continued. | PO          | For Diversion of CKT Which Submerges in Waghur Dam.                                                                 |
| Khadka-Chalisgaon-2                  | IntraState                | 29/02/2016   | 10:14        |            | Continued. | PO          | For Diversion of CKT Which Submerges in Waghur Dam.                                                                 |
| Karad - Vita Ckt- I                  | IntraState                | 02/03/2016   | 20.14        | 03/03/2016 | 14.00      | T           | Distance Protection                                                                                                 |
| Chakan-Chinchwad                     | IntraState                | 02/03/2016   | 20.58        | 03/03/2016 | 05.22      | PO          | Erection of Narow Base M/C Tower.                                                                                   |
| Chinchwad-Hinjewadi I                | IntraState                | 02/03/2016   | 21.08        | 03/03/2016 | 05.32      | HT          | Over Voltage                                                                                                        |
| Telco- Chinchwad                     | IntraState                | 02/03/2016   | 21.10        | 03/03/2016 | 05.24      | PO          | Erection of Narow Base M/C Tower.                                                                                   |
| Chinchwad-Hinjewadi I                | IntraState                | 03/03/2016   | 07.08        | 03/03/2016 | 20.25      | HT          | H/T for Talegaon chakan line                                                                                        |
| Kharepatan -Pawas Line               | IntraState                | 03/03/2016   | 09.05        | 03/03/2016 | 14.55      | PO          | insulator cleaning                                                                                                  |
| Wadkhal - NDIL-III                   | IntraState                | 03/03/2016   | 10.40        | 03/03/2016 | 19.30      | PO          | safety purpose                                                                                                      |

**HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage**

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Mar/2016**

**Statement-VII**

Position as on 6.30 Hrs of 04/Mar/2016

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                   |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------|
| Lonikand (400 Kv)-Theur I                | IntraState                | 03/03/2016   | 10.40        |            | Continued. | PO          | shifted on TBC                                                     |
| Eklahara(Gcr)(Nasik)- Bableshtar 2       | IntraState                | 03/03/2016   | 11.24        | 03/03/2016 | 12.18      | T           | Distance Protection                                                |
| Dahanu-Viraj                             | IntraState                | 03/03/2016   | 21.51        | 04/03/2016 | 00.24      | T           | Distance Protection                                                |
| <b>220 KV ICT Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                    |
| 220/100 Kv 200 MVA ICT III @Borivali     | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning) |
| 220/132 Kv 200 Mva Ict - 2 @Harangul     | IntraState                | 15/02/2016   | 13.04        |            | Continued. | PO          | Work of Oil Filtration of ICT.                                     |
| 220/33kV 100 MVA ICT-II @ Boisar         | IntraState                | 20/02/2016   | 14.51        |            | Continued. | T           | Differential Protn.Optd./Internal Fault.Declared Faulty.           |
| 220/22 Kv 50 Mva Cgl Ptr 1 @Kalwa        | IntraState                | 01/03/2016   | 16.04        |            | Continued. | T           | Differential Protection OLTC Buculze Tripped,Declared Faulty.      |
| 220/132 Kv 200 Mva Cgl Ptr No 5 @Parvati | IntraState                | 03/03/2016   | 09.26        | 03/03/2016 | 15.36      | PO          | Annual Maintenance Work                                            |
| <b>132 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                    |
| Theur-Purander                           | IntraState                | 03/03/2016   | 08.55        |            | Continued. | PO          | Annual Maintenance Work                                            |
| Amravati-Lalkhedi                        | IntraState                | 03/03/2016   | 19.22        | 03/03/2016 | 19.50      | T           | Buculze Protection Optd                                            |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage