

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 03/Mar/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	174.730	517.512	1) Gujrat	4.846	14.688
2) Hydro	13.601	30.482	2) Madhya Pradesh	2.337	8.923
3) Gas	5.309	16.013	3) Chattisgarh	3.630	11.300
Total MSPGCL	193.640	564.007	4) Maharashtra	169.125	498.397
B) 1) APLM	61.227	200.037	5) Goa (Amona)	-0.544	-1.727
2) JSWEL	26.544	76.816	Total	179.394	531.581
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.298	82.090
4) RPL(AMT)	31.272	93.573	b) Mumbai Drawl	36.603	111.933
5) SWPGPL	10.467	28.532	c) MSEDCL Bilateral *	85.575	260.730
6) Other IPP	45.573	136.723	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.298	82.090
C) 1) TPCL Thermal	13.187	36.447	Include PX	0.000	0.000
2) TPCL Hydro	3.323	9.984	Standby	0.000	0.000
3) TPCL Gas	3.685	8.300	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.760	34.665	1) MSEDCL	527.023	1568.292
D) STATE			2) Mumbai Discoms	68.558	201.329
1) Thermal	374.760	1124.305	3) Other Discoms	10.284	30.631
(A1+C1+C4+(B1-B6))			TOTAL STATE	605.865	1800.252
2) Hydro (A2+C2)	16.924	40.466			
3) Gas (A3+B7+C3)	8.994	24.313			
4) Wind	12.299	37.874			
6) SOLAR	13.494	41.713			
TOTAL STATE	426.471	1268.671			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7369	7315	7451	7274
MSPGCL Hydro	703	244	743	160
MSPGCL Gas	207	197	219	235
MSPGCL Total Generation	8279	7756	8413	7669
Central Sector Receipt	9004	8890	7325	6777
WIND	572	784	433	465
CPP / IPP Thermal	7376	7055	7329	7283
CPP / IPP Gas	0	0	0	0
SOLAR	1946	2012	0	0
Exchange with Mumbai	-2150	-2126	-1480	-1137
MSEDCL DEMAND MET	24554	23899	21561	20739
Load Shedding	0	0	0	0
MSEDCL DEMAND	24554	23899	21561	20739
TPCL GENERATION	792	793	1134	581
AEML GENERATION	462	492	498	495
MUMBAI DEMAND	3404	3411	3112	2213
OTHER DISCOM DEMAND	472	472	459	318
STATE DEMAND MET	28430	27782	25132	23270
STATE DEMAND	28430	27782	25132	23270
Frequency (Hz)	50.00	50.04	50.02	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 18.02 Hrs	49.76 Hz at 18.47 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 03/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.88	14.46	210	185
Unit 8	14.24	43.72	621	572
Unit 9	13.71	41.60	612	531
Unit 10	12.36	38.94	570	426
Total	45.18	138.72		
Bhusawal				
Unit 3	3.54	10.35	160	120
Unit 4	9.68	28.70	460	280
Unit 5	10.28	32.01	495	280
Total	23.50	71.06		
Parli				
Unit 6	5.54	13.16	250	149
Unit 7	4.92	14.69	238	144
Unit 8	3.29	10.11	153	126
Total	13.75	37.96		
Chandrapur				
Unit 3	3.85	11.10	175	140
Unit 4	3.41	9.77	155	121
Unit 5	0.00	0.00	0	0
Unit 6	9.32	27.16	405	310
Unit 7	9.02	23.82	393	315
Unit 8	11.80	35.40	500	481
Unit 9	11.22	34.50	500	444
Total	48.61	141.76		
Paras				
Unit 3	5.00	15.42	230	193
Unit 4	5.26	16.69	251	194
Total	10.26	32.11		
Khaparkheda				
Unit 1	2.86	8.84	135	100
Unit 2	3.27	9.52	144	130
Unit 3	4.09	11.89	181	146
Unit 4	4.17	12.09	189	154
Unit 5	11.47	31.85	495	452
Total	25.85	74.20		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.77	10.90	170	119
Unit 5	3.80	10.80	174	117
Total	7.57	21.71		
Uran				
All Units	5.31	16.01	241	196
Total	5.31	16.01		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	0.58	40	0
Total	0.19	0.58		
Koyna				
Stage 1-2	3.62	7.50	440	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.12	7.48	993	0
Stage 3	1.79	3.09	320	0
Total	9.53	18.06		
Hydro				
KDPH	0.49	2.14	36	18
VTRNA	1.00	2.92	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.12	0.54	40	0
SMLHY_PTN	2.28	6.23	100	90
GHATGHAR	0.00	0.00	0	0
Total	3.89	11.84		
Wind				
Total	12.30	37.87	0	0
Total	12.30	37.87		
CPP				
APML(Mus)	61.23	200.04	0	0
JSWEL(Mus)	26.54	76.82	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.27	93.57	0	0
SWPGPL-Mus	10.47	28.53	0	0
Dhariwal	6.34	18.86	298	218
IEPL	5.70	17.09	263	196
Other(Mus)	33.54	100.77	0	0
Total	175.08	535.68		
SOLAR				
Total	13.49	41.71	0	0
Total	13.49	41.71		
Tata				
Trombay 5	8.49	23.44	454	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.25	5.42	108	42
Trombay 7B	1.44	2.88	65	40
TATA Hydro	3.32	9.98	362	5
Trombay 8	4.70	13.01	225	132
Total	20.20	54.73		
AEML				
DTPS U-1&2	11.76	34.66	501	462
Total	11.76	34.66		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	174.73	517.51	MSPGCL Total	193.64	564.01
			MSPGCL Thml+Gas	180.04	533.52	Koyna 1,2 & 4 Total	7.74	14.97
			MSPGCL Hydro	13.60	30.48	State Total	426.47	1268.67

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 03/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7399	210	234	7843	406	7307	0	0	6447	6502	-1237	20435	0	20435	2492	386	23313	49.93
2	7420	222	234	7876	470	7348	0	0	6512	6721	-1212	20840	0	20840	2342	363	23545	49.97
3	7274	160	235	7669	465	7283	0	0	6606	6777	-1137	20739	0	20739	2213	318	23270	50.00
4	7160	205	237	7602	531	7329	0	0	6726	6790	-1061	20871	0	20871	2137	320	23328	49.98
5	7156	571	239	7966	489	7312	0	0	6587	6902	-1054	21272	0	21272	2136	343	23751	50.00
6	7159	1255	238	8652	454	7481	0	0	6498	6707	-1070	21848	0	21848	2230	376	24454	49.96
7	7360	1742	241	9343	507	7451	0	5	6628	6755	-1085	22568	0	22568	2390	408	25366	49.98
8	7344	1950	236	9530	454	7463	0	218	6764	6925	-1172	23000	0	23000	2551	418	25969	50.03
9	7328	1103	239	8670	345	7509	0	684	7391	7763	-1410	23107	0	23107	2831	454	26392	50.03
10	7364	664	225	8253	332	7511	0	1272	8022	8188	-1642	23444	0	23444	3110	470	27024	50.03
11	7377	635	220	8232	386	7491	0	1667	8679	8655	-1891	24057	0	24057	3323	483	27863	50.01
12	7369	703	207	8279	572	7376	0	1946	8927	9004	-2150	24554	0	24554	3404	472	28430	50.00
13	7315	244	197	7756	784	7055	0	2012	9138	8890	-2126	23899	0	23899	3411	472	27782	50.04
14	6805	218	197	7220	794	7018	0	1940	8883	8785	-2019	23291	0	23291	3271	446	27009	50.07
15	6834	277	199	7310	732	7068	0	1601	8833	9131	-2233	23144	0	23144	3308	465	26917	49.98
16	7234	336	196	7766	678	7120	0	1168	8727	8881	-2258	22893	0	22893	3357	462	26712	49.96
17	7333	457	198	7988	701	7164	0	705	7667	7740	-1717	22107	0	22107	3318	474	25899	49.99
18	7339	238	201	7778	563	7239	0	267	7089	7731	-1525	21575	0	21575	3224	478	25277	50.02
19	7325	669	213	8207	469	7196	0	9	7070	6915	-1629	20696	0	20696	3139	471	24306	49.91
20	7451	743	219	8413	433	7329	0	0	6906	7325	-1480	21561	0	21561	3112	459	25132	50.02
21	7328	220	222	7770	467	7295	0	0	6664	6974	-1427	20627	0	20627	2967	452	24046	50.05
22	7171	226	228	7625	443	7180	0	0	6398	6777	-1462	20109	0	20109	2841	454	23404	50.03
23	7476	227	223	7926	432	7313	0	0	6048	6281	-1309	20212	0	20212	2751	431	23394	49.99
24	7409	326	231	7966	392	7247	0	0	6399	6275	-1297	20173	0	20173	2700	410	23283	49.97
MUs	174.73	13.60	5.31	193.64	12.30	175.08	0.00	13.49	175.61	179.39	-36.60	527.02	0.00	527.02	68.56	10.28	605.87	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Mar/2023

Position as on 6.30 Hrs of 04/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	06/03/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	boiler tube leakage (under tooling from dtd-27.2.2023 @ 16:00 hrs	
IPP	Adani U-4	660	02/03/2023	00:00		Continued.	APH-A Hot PA bellow leakage	06/03/2023
MSPGCL	Khaparkheda Unit 4	210	04/03/2023	17:35	04/03/2023	20:01	Due to control valves closed.	
MSPGCL	Uran Unit B0	120	04/03/2023	23:58		Continued.	Maintenance work	06/03/2023
MSPGCL	Uran Unit 8	108	04/03/2023	23:58		Continued.	Maintenance work	06/03/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 03/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 04/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	03/03/2023	09:31	03/03/2023	19:05	PO	For Replacement of PID Suspecious Disc & other Maintenance work.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
BABHALESHWAR - PADGHE CKT - 2	IntraState	02/03/2023	22:59	03/03/2023	02:35	EO	1) To attend the problem of CB closing issue of own CB while giving closing command to TBC CB . 2) At present 400kV BBLR -2 in service through TBC after resolving the issue TBC will be free .
MAIN BUS - 1 @ LONIKAND 2	IntraState	03/03/2023	07:05	03/03/2023	18:12	PO	Diagnostic testing and Maintenance
WARORA - IEPL	IntraState	03/03/2023	09:35	03/03/2023	19:15	PO	Routine Maintenance & Dignostic testing work .
JEJURI - KARAD	IntraState	03/03/2023	16:14	03/03/2023	19:20	T	Tripped on Distance Protection.
KARAD - TALANDGE CKT - 1	IntraState	04/03/2023	15:12	04/03/2023	18:18	T	Tripped on Distance Protection.
KHADKA-AURANGABAD (WALUJ)	IntraState	04/03/2023	18:02	04/03/2023	21:17	HT	Emergency outage to attend hotspot
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 500 MVA ICT @ ALKUD	IntraState	02/03/2023	18:25	03/03/2023	02:31	EO	To take Spare ICT unit into service on the place of Y Phase ICT unit by RRS
400/220 KV SPARE 167 MVA ICT @ ALKUD	IntraState	02/03/2023	18:37	03/03/2023	02:31	EO	To take Spare ICT into service on the place of Y Phase ICT unit by RRS
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	03/03/2023	11:42	03/03/2023	16:42	PO	1) Diagnostic CB Testing Work 2) Routine Maintenance Work. 400/220/33 KV 315 MVA ICT - 1 @ WALUJ (Through TBC Bay)
400/220/33 KV 315 MVA ICT - 2 @ KOLHAPUR	IntraState	03/03/2023	15:05	03/03/2023	15:23	HT	Heavy sparking observed on A-Bus, B-Ph PG isolator.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	04/03/2023	23:56		Continued.	T	Tripped on NDR optd.
220 KV MAINBAY Outages/Trippings							
MAIN BUS - 2 @ NEW KOYNA	IntraState	02/03/2023	11:55		Continued.	PO	A) Bus isolator Routine maint. Works following bay will be transfer on A Bus by TBC Shifting 1) 220KV side ICT-I 2)220KV Pedhambe 3)220KV Niwali 4) 220KV side 25 MVA T/F-II B) Jumper works for ICT-3 New Bay
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54	04/03/2023	06:58	HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 04/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
KALWA - PANCHANAND	IntraState	01/03/2023	22:12		Continued.	PO	For erection of Termination kit on newly erected 2 nos. of newly erected CTT Monopole in between Loc no. 686 - 687.
PIRANGUT - HINJAWADI 2	IntraState	02/03/2023	08:30	03/03/2023	18:02	PO	1)Dismantaling of conductor and E/W from Guide tower (Loc No 35) to Gantry (Pirangut line bay) 2)Dismantaling of conductor and E/W from tower Loc No 34 to tower Loc No 35 3) Dismantaling of 220kV DC tower no.35 (Guide tower)
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	02/03/2023	10:24	03/03/2023	00:50	HT	H/T for Load Management.
HALKARNI - TILARI LINE	IntraState	02/03/2023	10:43	03/03/2023	23:40	PO	attending CB Pole overhauling works and arresting of heavy SF6 gas leakage at Tillari SS
KARAD -MUDSHINGI CKT- 4	IntraState	02/03/2023	14:07	03/03/2023	22:09	T	Tripped on Dist. Protection.
APTA - KALWA	IntraState	02/03/2023	21:01			EO	Shifting of Kalwa-Apta line from TBC to own CB at Kalwa end. 220kV Kalwa Panchanand Line (under outage) differential relay will be tested by testing team in co-ordination with 220kV TBC. 220KV Kalwa-Panchanand line will be shifted on TBC after outage of Project Dn.
TROMBAY - DHARAVI 9	IntraState	02/03/2023	22:39	03/03/2023	05:19	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
TROMBAY SALSETTE LINE-2	IntraState	02/03/2023	23:48	03/03/2023	07:45	PO	Project work of 400 KV KVTL- 220 KV VIKHROLI TROMBAY -IV CABLE MOUNTING ON Monopole.
GHATGHAR - BAPGAON	IntraState	03/03/2023	04:21	03/03/2023	04:38	T	Tripped at Ghatghar end only
GADCHANDUR - VIRUR-II	IntraState	03/03/2023	08:18	03/03/2023	13:00	EO	To attend Hot Spot
WARDHA - WARDHA (PG)	IntraState	03/03/2023	09:34	03/03/2023	21:06	PO	bus bar#1 testing of main bay 212 (outage of 220kV Wardha Wardha (M) shall also required) Wardha for upcoming 220kV Wardha yavatmal TL ckt-2 (constrution outage)
VANKUSWADE - KDPH	IntraState	03/03/2023	09:40	03/03/2023	17:15	PO	Work of land/Hill cutting between Loc. No.54-55 & 86-87 due to low ground clearance beside & below the line conductor.
URAN - APTA 4	IntraState	03/03/2023	09:50	03/03/2023	18:47	PO	For disc insulator string replacement work & Diagnostic testing and bay maint's work.
AMBAZARI - KARANJA CKT	IntraState	03/03/2023	09:55	03/03/2023	17:22	PO	Restringing of Conductor

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 04/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR II - BOISAR (PG) CKT - 3	IntraState	03/03/2023	10:04	03/03/2023	14:51	PO	For AMP works of LTE at Boisar PG end.
BOISAR II - BOISAR (PG) CKT - 3	IntraState	03/03/2023	10:04	03/03/2023	18:51	PO	Bay Maintenance Work at 220KV Boisar-II S/stn.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/03/2023	10:56	04/03/2023	00:01	HT	For load management
KARAD -MUDSHINGI CKT- 4	IntraState	03/03/2023	10:56	03/03/2023	18:24	HT	Due to heavy sparking at Yph line isolator.
GHATGHAR - JINDAL	IntraState	03/03/2023	10:57	03/03/2023	18:54	PO	1.Billing main and check meter replacement at consumer end. 2. Equipment Diagnostic Testing at MSETCL End.
KALWA - SIEMENS	IntraState	03/03/2023	11:04	03/03/2023	14:51	PO	Annual Relay Testing work.
PADGHE - JINDAL	IntraState	03/03/2023	11:09	03/03/2023	18:54	PO	1.Billing main and check meter replacement at consumer end. 2. Equipment Diagnostic Testing at MSETCL End.
BOTHE - SWARAJ CO GEN	IntraState	03/03/2023	11:33	03/03/2023	14:20	PO	Diagnostic testing & quarterly maintenance work.
URSE-CHINCHWAD	IntraState	03/03/2023	15:21	03/03/2023	16:22	PO	Discom Meter replacement activity at 220kV Shri Sant Tukaram SSK consumer end.
POPHALI - KDPH	IntraState	03/03/2023	16:10	03/03/2023	19:30	T	Tripped on Distance Protection.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	03/03/2023	17:31	03/03/2023	18:38	HT	H/T for load Management.
TROMBAY - SALSETTE CKT - 1	IntraState	03/03/2023	22:32	04/03/2023	06:43	PO	Project work of 400 KV KVTL-220 KV Trombay-Vikhroli -III cable mounting on mono pole
TROMBAY - DHARAVI 9	IntraState	03/03/2023	22:44	04/03/2023	04:53	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
LAMBOTI -SOLAPUR 2(BALE) CKT- 2	IntraState	04/03/2023	00:40	04/03/2023	06:06	T	Tripped on Dist. Protection.
EKLAHARE (GCR) - GHATGHAR	IntraState	04/03/2023	06:46	04/03/2023	08:01	T	Tripped at Ghatghar end only
MAIN BUS SECTION - 1 @ EKLAHARE (GCR)	IntraState	04/03/2023	08:52	04/03/2023	20:43	PO	Isolator replacement work Hotline work also required. Hot spot attending work at various location
LONIDEOKAR TAP ON WALCHANDNAGAR- BHIGWAN CKT	IntraState	04/03/2023	09:07	04/03/2023	11:50	PO	To replace flashover string observed at loc. No. 68 R phase on dt. 01.03.2023.
KHARGHAR - SONKHAR	IntraState	04/03/2023	09:36	04/03/2023	19:06	PO	For Bay strengthning Work & Routine Maintenance Work
SALSETTE - SAHAR CKT	IntraState	04/03/2023	10:04	04/03/2023	19:08	PO	TREE TRIMMING
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	04/03/2023	10:33	04/03/2023	12:34	PO	Replacement (Tightening) of B ph jump at Loc 108 (Found red hot in thermovision .
BOMBAY DYEING - SAHARA	IntraState	04/03/2023	12:48	04/03/2023	18:42	PO	Work :- 1) 220kV CB overhauling work on 220kV Sahara-Bombay dying Line at 220kV Sahara SS. 2) Inclined string alignment work at Loc. No. 76,77,78 3) Chemical washing work 4) Line Signature test. 5) Jump nut-bolt tightening work at loc no. 122 & 125.
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT II	IntraState	04/03/2023	13:49	04/03/2023	21:05	T	Distance protection
220 KV BAMBHORI - DEEPNAGAR CKT	IntraState	04/03/2023	14:41	04/03/2023	16:01	HT	Emergency outage for attending hot spot
DASTURI-KANDALGAON LINE	IntraState	04/03/2023	16:10	04/03/2023	23:30	PO	Jumper replacement at Loc.No.197,Cold washing of insulator string ,Outage tree cutting and other line maintenance work.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 03/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 04/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KANDALGAON - KOYNA (POPHALI)	IntraState	04/03/2023	17:06	04/03/2023	17:30	T	Tripped on Distance Protection.
ADLABS - PEDAMBE	IntraState	04/03/2023	17:57	04/03/2023	19:33	T	Tripped on Distance Protection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	02/03/2023	03:31			PO	Repairing of OLTC selector switch mechanism situated inside main tank of ICT.
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	03/03/2023	09:10	03/03/2023	18:16	PO	For Diagnostic testing of ICT by TCC, Vashi, NIFPS AMC work by CTR Pune and R&M work.
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	03/03/2023	18:10	04/03/2023	04:01	PO	For attending TF oil leakage
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	03/03/2023	10:36	03/03/2023	17:50	PO	For MAIN BUS 2 insulator string replacement work.
MAIN BUS - 2 @ URAN	IntraState	04/03/2023	10:48	04/03/2023	15:15	PO	For MAIN BUS 2 insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage