

State Load Despatch Center,Airoli (MSETCL) Statement I
Daily system Report for 03/Apr/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.019	463.602	1) Gujrat	-1.766	-4.715
2) Hydro	18.111	32.158	2) Madhya Pradesh	8.625	26.508
3) Gas	2.731	8.167	3) Chattisgarh	4.670	14.970
Total MSPGCL	179.861	503.927	4) Maharashtra	175.331	527.119
B) 1) APML	73.799	218.694	5) Goa (Amona)	-1.235	-3.608
2) JSWEL	20.688	63.449	Total	185.625	560.274
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.586	89.346
4) RPL(AMT)	30.940	85.859	b) Mumbai Drawl	34.543	101.390
5) SWPGPL	12.302	36.512	c) MSEDCL Bilateral *	96.336	303.212
6) Other IPP	25.898	73.435	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.586	89.346
C) 1) TPCL Thermal	10.048	28.934	Include PX	0.000	0.000
2) TPCL Hydro	5.058	11.185	Standby	0.000	0.000
3) TPCL Gas	2.009	6.028	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.512	28.818	1) MSEDCL	515.865	1510.988
D) STATE			2) Mumbai Discoms	62.170	176.355
1) Thermal	343.206	999.303	3) Other Discoms	10.206	29.942
(A1+C1+C4+(B1-B6))			TOTAL STATE	588.241	1717.285
2) Hydro (A2+C2)	23.169	43.343			
3) Gas (A3+B7+C3)	4.740	14.195			
4) Wind	14.604	48.233			
6) SOLAR	16.897	51.937			
TOTAL STATE	402.616	1157.011			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6765	6284	6702	6290
MSPGCL Hydro	731	707	1662	193
MSPGCL Gas	114	113	114	113
MSPGCL Total Generation	7610	7104	8478	6596
Central Sector Receipt	9240	9482	7205	6678
WIND	124	235	729	1059
CPP / IPP Thermal	6494	6822	6882	6738
CPP / IPP Gas	0	0	0	0
SOLAR	2171	2190	0	0
Exchange with Mumbai	-1858	-1783	-1417	-1140
MSEDCL DEMAND MET	23321	23607	21402	19566
Load Shedding	0	0	0	0
MSEDCL DEMAND	23321	23607	21402	19566
TPCL GENERATION	752	767	919	700
AEML GENERATION	490	477	473	425
MUMBAI DEMAND	3100	3027	2809	2265
OTHER DISCOM DEMAND	460	443	475	365
STATE DEMAND MET	26881	27077	24686	22196
STATE DEMAND	26881	27077	24686	22196
Frequency (Hz)	49.96	49.90	49.99	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 18:01 Hrs	49.66 Hz at 05:54 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 03/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.50	14.13	205	135
Unit 8	13.02	39.86	582	493
Unit 9	0.00	0.00	0	0
Unit 10	13.49	39.42	585	540
Total	31.00	93.41		
Bhusawal				
Unit 3	3.28	9.61	160	120
Unit 4	7.45	25.99	485	0
Unit 5	11.43	30.20	495	410
Total	22.16	65.80		
Parli				
Unit 6	4.55	13.12	252	141
Unit 7	4.53	12.60	252	144
Unit 8	3.60	10.40	168	141
Total	12.68	36.12		
Chandrapur				
Unit 3	3.79	10.76	170	130
Unit 4	3.42	9.99	154	120
Unit 5	8.50	24.69	405	280
Unit 6	8.55	23.56	405	295
Unit 7	9.29	25.87	432	293
Unit 8	10.56	29.16	492	294
Unit 9	11.45	33.11	495	439
Total	55.55	157.14		
Paras				
Unit 3	2.50	4.52	233	0
Unit 4	4.68	15.92	240	0
Total	7.18	20.44		
Khaparkheda				
Unit 1	2.83	8.44	125	110
Unit 2	0.27	3.62	70	0
Unit 3	4.27	12.12	184	148
Unit 4	4.47	12.16	191	155
Unit 5	10.66	32.41	480	420
Total	22.49	68.75		
Nasik				
Unit 3	4.12	11.39	181	160
Unit 4	0.00	0.00	0	0
Unit 5	3.84	10.56	171	134
Total	7.96	21.96		
Uran				
All Units	2.73	8.17	119	110
Total	2.73	8.17		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.18	0.50	49	0
Total	0.18	0.50		
Koyna				
Stage 1-2	3.73	7.75	530	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	8.08	8.53	860	0
Stage 3	2.15	3.20	240	0
Total	13.96	19.48		
Hydro				
KDPH	0.86	2.59	36	36
VTRNA	1.20	3.58	61	0
TILLARI	0.46	1.39	58	0
BHIRA T.R.	0.12	0.58	40	0
SMLHY_PTN	1.33	4.03	57	54
GHATGHAR	0.00	0.00	0	0
Total	3.98	12.17		
Wind				
Total	14.60	48.23	0	0
Total	14.60	48.23		
CPP				
APML(Mus)	73.80	218.69	0	0
JSWEL(Mus)	20.69	63.45	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.94	85.86	0	0
SWPGPL-Mus	12.30	36.51	0	0
Dhariwal	5.72	16.81	269	207
IEPL	4.76	14.36	216	196
Other(Mus)	15.42	42.27	0	0
Total	163.63	477.95		
SOLAR				
Total	16.90	51.94	0	0
Total	16.90	51.94		
Tata				
Trombay 5	6.76	19.36	378	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.07	3.22	46	44
Trombay 7B	0.94	2.81	40	39
TATA Hydro	5.06	11.18	430	48
Trombay 8	3.29	9.57	173	129
Total	17.12	46.15		
AEML				
DTPS U-1&2	10.51	28.82	492	315
Total	10.51	28.82		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.02	463.60	MSPGCL Total	179.86	503.93
			MSPGCL Thml+Gas	161.75	471.77	Koyna 1,2 & 4 Total	11.81	16.28
			MSPGCL Hydro	18.11	32.16	State Total	402.62	1157.01

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 03/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Trans mission Constr aint					
1	6290	193	113	6596	1059	6738	0	0	7209	6678	-1140	19566	0	0	19566	2265	365	22196	49.98
2	6280	193	114	6587	1028	6731	0	0	6699	7022	-1066	19957	0	0	19957	2105	345	22407	50.00
3	6405	192	113	6710	1019	6723	0	0	6660	6902	-999	20029	0	0	20029	1988	326	22343	49.96
4	6471	193	115	6779	912	6748	0	0	6818	6837	-979	19976	0	0	19976	1911	321	22208	49.91
5	6598	291	113	7002	854	6733	0	0	7143	7276	-919	20614	0	0	20614	1898	332	22844	49.96
6	6844	795	115	7754	797	6810	0	0	6971	7082	-908	21172	0	0	21172	2028	363	23563	49.88
7	6899	1532	112	8543	650	7222	0	45	7170	7245	-969	22337	0	0	22337	2153	399	24889	49.93
8	6956	1046	113	8115	449	7199	0	516	7336	7235	-1115	21975	0	0	21975	2324	424	24723	50.06
9	6752	514	119	7385	306	7070	0	1199	7964	7900	-1523	21891	0	0	21891	2617	446	24954	50.02
10	6490	497	114	7101	226	6968	0	1747	8790	8606	-1758	22434	0	0	22434	2885	456	25775	49.97
11	6524	556	116	7196	150	6888	0	2108	9225	9124	-1851	23159	0	0	23159	3064	456	26679	49.98
12	6765	731	114	7610	124	6494	0	2171	9547	9240	-1858	23321	0	0	23321	3100	460	26881	49.96
13	6284	707	113	7104	235	6822	0	2190	9435	9482	-1783	23607	0	0	23607	3027	443	27077	49.90
14	6476	476	112	7064	348	6468	0	2106	9138	9085	-1866	22760	0	0	22760	2910	445	26115	49.98
15	6819	466	114	7399	500	6898	0	1918	9280	8928	-1956	23220	0	0	23220	2985	467	26672	49.94
16	7005	626	115	7746	600	6553	0	1560	8971	8782	-2002	22770	0	0	22770	3015	469	26254	49.96
17	6766	634	114	7514	603	6566	0	965	8700	8594	-1978	21805	0	0	21805	2984	459	25248	49.94
18	6609	1101	114	7824	690	6648	0	355	7942	7941	-1827	21143	0	0	21143	2936	488	24567	49.96
19	6688	1033	114	7835	668	6771	0	17	7242	7287	-1503	20588	0	0	20588	2824	487	23899	49.99
20	6702	1662	114	8478	729	6882	0	0	6981	7205	-1417	21402	0	0	21402	2809	475	24686	49.99
21	6572	1336	114	8022	745	6906	0	0	6939	6809	-1360	20652	0	0	20652	2715	470	23837	50.02
22	6618	918	114	7650	723	7006	0	0	6752	6583	-1275	20229	0	0	20229	2608	458	23295	49.98
23	6626	997	110	7733	645	6915	0	0	6827	6932	-1259	20526	0	0	20526	2537	440	23503	49.97
24	6580	1422	112	8114	544	6868	0	0	6865	6850	-1232	20728	0	0	20728	2482	416	23626	49.97
MUs	159.02	18.11	2.73	179.86	14.60	163.63	0.00	16.90	186.60	185.63	-34.54	515.86	0.00	0.00	515.86	62.17	10.21	588.24	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Apr/2023

Position as on 6.30 Hrs of 04/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 2	70	03/04/2023	08:30	03/04/2023	18:00	Preventive Maintenance Work	03/04/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 4	210	29/03/2023	04:36		Continued.	Boiler Tube Leakage (Under tolling from 00:00 hrs. from 04.04.23)	
MSPGCL	Uran Unit 6	108	29/03/2023	08:33		Continued.	Zero Schedule	
MSPGCL	Koradi Unit 9	660	31/03/2023	23:45		Continued.	Boiler Tube Leakage	05/04/2023
MSPGCL	Paras Unit 3	250	01/04/2023	11:01	03/04/2023	12:01	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 2	210	02/04/2023	07:49	03/04/2023	18:52	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 4	500	03/04/2023	17:08		Continued.	Boiler Tube Leakage	06/04/2023
MSPGCL	Paras Unit 4	250	03/04/2023	20:13		Continued.	Boiler Tube Leakage	06/04/2023
MSPGCL	Koyna Unit 3	70	04/04/2023	08:30	04/04/2023	17:00	Preventive Maintenance Work	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 03/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 04/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AKOLA - WARDHA(PG) CKT - 2	InterState	04/04/2023	09:38	04/04/2023	19:22	PO	Insulator Replacement Work
BABHALESHWAR - PADGHE CKT - 2	IntraState	02/04/2023	20:52	03/04/2023	02:49	EO	Permission for Shifting of 400KV BBLR-Padghe Line 2 on TBC on urgent basis due to 254 degree Hotspot observed in Thermovision
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	03/04/2023	11:52	03/04/2023	18:50	EO	TO REPLACE B.PH CC LMU AS TRANSMIT LEVEL IS DROPPING.
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	03/04/2023	08:19	03/04/2023	19:19	PO	1) Erection of tertiary side IPS tube for RRS project work . 2) Routine Bay maintenance work.
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	03/04/2023	12:34	03/04/2023	19:40	PO	Tan delta & capacitance measurement of Bushing & winding. Testing of CTR make NIFPS by M/s CTR Ltd, Pune for healthiness of NIFPS
400/220/33 KV 500 MVA ICT - 1 @ LAMBOTI	IntraState	03/04/2023	15:04	03/04/2023	16:56	EO	For attending HOTSPOT
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	04/04/2023	06:27	04/04/2023	14:14	PO	Tan delta & capacitance measurement of Bushing & winding. Testing of CTR make NIFPS by M/s CTR Ltd, Pune for healthiness of NIFPS
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	04/04/2023	08:27	04/04/2023	19:40	PO	1) Erection of tertiary side IPS tube for RRS project work . 2) Routine Bay maintenance work.
400 KV BUSBAR Outages/Tripping							
400 KV AUX BUS @ CHANDRAPUR	IntraState	04/04/2023	09:54	04/04/2023	14:34	EO	"Replacement of Faulty disc Insulator string at Gantry Loc No. 04 of 400KV Auxiliary Bus. (Section-1) by hot line technique."
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AEML BORIVALI - TPC BORIVALI LINE	IntraState	20/03/2023	00:14			T	Tripped due to cable joint failure.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 04/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
RANJANGAON - U TECH SUGAR CKT	IntraState	30/03/2023	13:30			PO	1) Bunching of 220kV Lonikand-Kathapur at 321 opening the jump 2) Bunching of 220kV Utech-Ranjangaon at 303 opening the jump 3) after opening jump at 321 & 303 line will be dead. after bunching circuit become 220kV Lonikand2-Ranjangaon & 220kV Kathapur-Utech 4) Tower erection work L.No-16 (inline tower) of 220kV Kathapur-lonikad line (for making L.ILO of 220kV Lonikand2-Kathapur line at 220kV Khedcity SS)
PARGAON(KATHAPUR)-LONIKAND	IntraState	30/03/2023	13:43			PO	1) Bunching of 220kV Lonikand-Kathapur at 321 opening the jump 2) Bunching of 220kV Utech-Ranjangaon at 303 opening the jump 3) after opening jump at 321 & 303 line will be dead. after bunching circuit become 220kV Lonikand2-Ranjangaon & 220kV Kathapur-Utech 4) Tower erection work L.No-16 (inline tower) of 220kV Kathapur-lonikad line (for making L.ILO of 220kV Lonikand2-Kathapur line at 220kV Khedcity SS)
CHIKHALI-JALNA II	IntraState	03/04/2023	03:21	03/04/2023	08:46	PO	To Control Akola ICT Overloading
CHIKHALI-JALNA I	IntraState	03/04/2023	03:21	03/04/2023	08:46	PO	To Control Akola ICT Overloading
URAN - SEZ JNPT	IntraState	03/04/2023	10:57	03/04/2023	17:12	PO	Tightening of jumper & cold line cleaning of insulator of all towers.
MUDSHINGI- BELEWADI LINE	IntraState	03/04/2023	11:01	03/04/2023	11:01	PO	Replacement of insulator string at loc no. 105 Rphase
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	03/04/2023	11:32	03/04/2023	17:39	EO	Replacement of faulty suspension polymer string at loc no. 27,55,58
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/04/2023	11:38	03/04/2023	18:08	HT	H/T TO CONTROL LINE LOADING
NERLE - DASGAON	IntraState	03/04/2023	12:06	03/04/2023	18:19	PO	Quarterly bay maintenance work
MIRAJ - ICHALKARANJI	IntraState	03/04/2023	16:38	03/04/2023	20:22	EO	To attend HOt spot on R & Y Ph of Wave Trap of 220KV Talandage-Tilwani-1,
TALANDGE - ICHALKARANJI 1	IntraState	03/04/2023	16:41	03/04/2023	20:14	HT	MERGENCY OUTAGE AVAILED to attend R & Y Ph Wave Trap Hot spot AT ICHALKARANJI
APTA - KALWA	IntraState	03/04/2023	22:56			PO	Erection of Cable Termination kit on newly erected 2 nos. of CTT Monopole with fixing of Cross arm in between loc no. 686 to 687 in r/o newly proposed 220KV GIS substation of M/s. Print House (India) Pvt. Ltd.
CHIKHALI-JALNA II	IntraState	04/04/2023	03:47	04/04/2023	07:57	HT	To control loading on Akola ICT3
CHIKHALI-JALNA I	IntraState	04/04/2023	03:47	04/04/2023	07:57	HT	To control loading on Akola ICT 3
CHEMBUR (AEML) - NERUL (M)	IntraState	04/04/2023	08:01		Continued.	PO	Dimension measurement of conductor and shield inside main bus -1 chamber. Work to be executed under MERC Approved BKC Project Scheme.
MAIN BUS - 1 @ CHEMBUR	IntraState	04/04/2023	08:53		Continued.	PO	Dimension measurement of conductor and shield inside main bus -1 chamber. Work to be executed under MERC Approved BKC Project Scheme.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 03/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 04/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	04/04/2023	09:03	04/04/2023	19:10	PO	Outage for cold washing of insulator strings.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	04/04/2023	09:20	04/04/2023	19:09	HT	Load management
NERLE - DASGAON	IntraState	04/04/2023	10:10	04/04/2023	19:22	PO	B Ph CT replacement Work
CHIKHALI-JALNA I	IntraState	04/04/2023	16:56	04/04/2023	18:30	EO	Removal of Polythene
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 25 MVA PTR 2 @ NAGOTHANE	IntraState	27/03/2023	09:40			PO	CB replacement work
220/33 KV 50MVA T/F - 2 @ MIRAJ	IntraState	04/04/2023	10:03	04/04/2023	16:52	PO	Y ph CT & Radiator oil leakage attending work.
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	04/04/2023	11:02	04/04/2023	13:23	PO	Hot spot attending and Bay maintenance work
110 KV LINE Outages/Trippings							
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	04/04/2023	21:59			PO	FOR 400 KV KVPTL WORK
WAGHIVALI - MANKHURD	IntraState	04/04/2023	23:57			PO	FOR 400 KV KVPTL WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage