

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 03/Jun/2020 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	78.634	301.810	1) Gujrat	0.512	9.795
2) Hydro	4.689	17.774	2) Madhya Pradesh	-0.762	16.243
3) Gas	0.000	5.647	3) Chattisgarh	3.980	14.390
Total MSPGCL	83.323	325.231	4) Maharashtra	63.063	277.612
B) 1) APMIL	50.779	172.938	5) Goa (Amona)	0.000	-0.022
2) JSWEL	13.036	44.265	Total	66.793	318.018
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.348	66.575
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	18.015	65.871
5) WPCL	2.214	7.027	c) MSEDCL Bilateral *	24.376	95.203
6) Other IPP	7.252	22.406	Include PX	2.127	23.811
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.348	66.575
C) 1) TPCL Thermal	7.354	22.320	Include PX	13.164	46.933
2) TPCL Hydro	2.116	11.673	Standby	0.000	0.000
3) TPCL Gas	4.401	13.191	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.788	27.368	1) MSEDCL	247.534	910.237
D) STATE			2) Mumbai Discoms	40.674	140.423
1) Thermal	168.057	598.134	TOTAL STATE	288.208	1050.660
(A1+C1+C4+(B1-B6))					
2) Hydro	6.805	29.447			
(A2+C2)					
3) Gas	4.401	18.838			
(A3+B7+C3)					
4) Wind	38.930	73.584			
6) SOLAR	3.222	12.639			
TOTAL STATE	221.415	732.642			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	3539	3526	2826	2806
MSPGCL Hydro	246	180	125	92
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	3785	3706	2951	2898
Central Sector Receipt	3534	2198	2935	2315
WIND	1929	1819	1471	1489
CPP / IPP Thermal	3270	3266	2782	2836
CPP / IPP Gas	0	0	0	0
SOLAR	422	416	0	0
Exchange with Mumbai	-889	-848	-782	-797
MSEDCL DEMAND MET	12051	10557	9357	8741
Load Shedding	0	0	0	0
MSEDCL DEMAND	12051	10557	9357	8741
TPCL GENERATION	521	512	590	647
AEML GENERATION	373	374	374	343
MUMBAI DEMAND	1783	1734	1746	1787
STATE DEMAND MET	13834	12291	11103	10528
STATE DEMAND	13834	12291	11103	10528
Frequency (Hz)	50.02	50.04	49.94	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.24 Hz at 18.02 Hrs	49.79 Hz at 17.12 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 03/Jun/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	18.14	0	0
Unit 10	0.91	18.21	424	0
Total	0.91	36.35		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	2.50	0	0
Unit 5	0.00	4.40	0	0
Total	0.00	6.91		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	2.61	0	0
Total	0.00	2.61		
Chandrapur				
Unit 3	2.11	9.95	163	0
Unit 4	2.03	9.39	160	0
Unit 5	5.45	23.58	368	0
Unit 6	8.70	26.65	370	348
Unit 7	8.48	26.71	370	321
Unit 8	8.64	27.40	360	360
Unit 9	8.65	27.20	365	350
Total	44.06	150.88		
Paras				
Unit 3	4.76	14.05	206	188
Unit 4	4.78	15.06	205	189
Total	9.54	29.11		
Khaparkheda				
Unit 1	3.82	11.70	175	150
Unit 2	3.86	12.00	165	160
Unit 3	3.83	12.02	165	158
Unit 4	3.86	11.91	161	160
Unit 5	8.77	28.33	375	360
Total	24.12	75.96		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	0.00	5.65	0	0
Total	0.00	5.65		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	0.46	26	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.14	0.46		
Koyna				
Stage 1-2	2.10	7.82	370	35
Stage 4	0.00	1.18	0	0
Stage 3	0.88	2.09	140	0
Total	2.99	11.10		
Hydro				
KDPH	0.70	2.09	29	29
VTRNA	0.00	0.00	0	0
TILLARI	0.24	1.32	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.00	0.53	0	0
RNGR+BHTSA	0.26	0.78	11	10
BHANDARDRA	0.43	1.29	18	17
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.07	0.66	4	3
GHATGHAR	0.00	0.00	0	0
Total	1.70	6.68		
Wind				
Total	38.93	73.58	0	0
Total	38.93	73.58		
CPP				
APML(Mus)	50.78	172.94	0	0
JSWEL(Mus)	13.04	44.26	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.21	7.03	0	0
Other(Mus)	7.25	22.41	0	0
Total	73.28	246.64		
SOLAR				
Total	3.22	12.64	0	0
Total	3.22	12.64		
Tata				
Trombay 5	7.35	22.32	308	304
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	8.42	118	116
Trombay 7B	1.59	4.77	67	65
Trombay 8	0.00	0.00	0	0
TATA Hydro	2.12	11.67	409	10
Total	13.87	47.18		
AEML				
DTPS U-1&2	8.79	27.37	375	332
Total	8.79	27.37		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	78.63	301.81	MSPGCL Total	83.32	325.23
			MSPGCL Thml+Gas	78.63	307.46	Koyna 1,2 & 4 Total	2.10	9.01
			MSPGCL Hydro	4.69	17.77	State Total	221.42	732.64

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 03/Jun/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3916	429	0	4345	1356	3227	0	0	3527	3542	-744	11726	0	11726	2016	13742	49.95
2	3918	105	0	4023	1443	3230	0	0	4144	3582	-668	11610	0	11610	1891	13501	50.00
3	3577	120	0	3697	1526	3276	0	0	3695	3750	-802	11447	0	11447	1797	13244	49.98
4	3479	165	0	3644	1499	3261	0	0	3450	3537	-805	11136	0	11136	1716	12852	49.96
5	3486	100	0	3586	1685	3275	0	0	3794	3530	-779	11297	0	11297	1683	12980	49.99
6	3504	111	0	3615	1616	3277	0	0	4249	3731	-765	11474	0	11474	1674	13148	50.02
7	3501	106	0	3607	2037	3248	0	28	4077	3865	-722	12063	0	12063	1631	13694	50.00
8	3523	101	0	3624	2365	3235	0	116	4039	3561	-719	12182	0	12182	1626	13808	50.03
9	3548	206	0	3754	2174	3262	0	210	3441	3277	-766	11911	0	11911	1672	13583	50.01
10	3535	508	0	4043	2065	3263	0	326	3093	3052	-839	11910	0	11910	1737	13647	50.00
11	3539	246	0	3785	1929	3270	0	422	3596	3534	-889	12051	0	12051	1783	13834	50.02
12	3556	239	0	3795	1887	3276	0	433	3544	2895	-899	11387	0	11387	1788	13175	49.98
13	3526	180	0	3706	1819	3266	0	416	3440	2198	-848	10557	0	10557	1734	12291	50.04
14	3271	142	0	3413	1649	3241	0	362	2619	1399	-745	9319	0	9319	1633	10952	50.03
15	3202	101	0	3303	1575	3028	0	433	2669	1094	-670	8763	0	8763	1551	10314	50.07
16	2864	101	0	2965	1543	2679	0	232	2432	1501	-644	8276	0	8276	1475	9751	50.08
17	2857	136	0	2993	1026	2683	0	161	1901	1728	-616	7975	0	7975	1448	9423	49.93
18	2856	356	0	3212	983	2687	0	77	1497	2205	-638	8526	0	8526	1489	10015	49.97
19	2860	536	0	3396	1361	2686	0	6	1428	1861	-696	8614	0	8614	1562	10176	50.04
20	2841	201	0	3042	1461	2687	0	0	2754	2658	-752	9096	0	9096	1664	10760	49.96
21	2826	125	0	2951	1471	2782	0	0	3178	2935	-782	9357	0	9357	1746	11103	49.94
22	2819	141	0	2960	1494	2809	0	0	2857	2472	-656	9079	0	9079	1776	10855	49.96
23	2824	142	0	2966	1477	2797	0	0	3182	2571	-774	9037	0	9037	1795	10832	49.97
24	2806	92	0	2898	1489	2836	0	0	2924	2315	-797	8741	0	8741	1787	10528	49.96
MUs	78.63	4.69	0.00	83.32	38.93	73.28	0.00	3.22	75.53	66.79	-18.02	247.53	0.00	247.53	40.67	288.21	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Jun/2020

Position as on 6.30 Hrs of 04/Jun/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Shaft position	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Shaft Position	
MSPGCL	Koradi Unit-8	660	31/05/2020	22.56		Continued.	Heavy steam Leakage in super heater.(Converted in To Zero schedule w.e.f	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Jun/2020

Position as on 6.30 Hrs of 04/Jun/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							03.06.2020 01.28)	
MSPGCL	Bhusawal Unit 4	500	01/06/2020	07.16		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 5	500	01/06/2020	12.21		Continued.	Zero schedule By MSEDCL	
MSPGCL	Parli Unit 8	250	01/06/2020	13.13		Continued.	Zero schedule By MSEDCL	
MSPGCL	Koradi Unit 9	660	02/06/2020	15.42		Continued.	Flame Failure	
MSPGCL	Uran Unit A0	120	02/06/2020	17.07		Continued.	Jerk In the Grid.	
MSPGCL	Uran Unit 6	108	02/06/2020	17.07		Continued.	Jerk In the Grid.	
MSPGCL	Koradi Unit 10	660	03/06/2020	02.20		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 3	210	03/06/2020	13.07		Continued.	RSD	
MSPGCL	Chandrapur Unit 4	210	03/06/2020	13.15		Continued.	RSD	
MSPGCL	Chandrapur Unit 5	500	03/06/2020	15.00		Continued.	RSD	
IPP	Adani U-1	660	03/06/2020	15.02		Continued.	RSD	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 04/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	02/06/2020	12.39		Continued.	PO	REPLACEMENT OF PID SUSPICIOUS DISC INSULATOR AND MAINTENANCE WORK RFC AT 18:40.
Dhule Khandwa I	InterState	02/06/2020	20.53		Continued.	HT	Over Voltage
Chandrapur Bhadravati I	InterState	02/06/2020	20.53		Continued.	HT	Over Voltage
Chandrapur Bhadravati II	InterState	02/06/2020	20.53		Continued.	HT	Over Voltage
Dhule Khandwa II	InterState	02/06/2020	21.23		Continued.	HT	Over Voltage
Dabhol Nagothane II	InterState	03/06/2020	10.50		Continued.	T	Distance Protection
Dabhol Nagothane I	InterState	03/06/2020	11.03		Continued.	T	Distance Protection
Parli(MS)-Parli (PG) II	InterState	03/06/2020	14.01	03/06/2020	15.05	T	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	31/05/2020	17.29		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	02/06/2020	18.38	03/06/2020	11.10	HT	Over Voltage
Babhaleshwar - Padghe-I	IntraState	02/06/2020	21.06		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	02/06/2020	21.35	03/06/2020	09.54	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/06/2020	02.40		Continued.	T	Over Voltage
N.Koyna-Karad -Ckt I	IntraState	03/06/2020	10.48	03/06/2020	11.03	T	Distance Protection
New Koyna - Dabhol - II	IntraState	03/06/2020	10.50	03/06/2020	20.32	T	Distance Protection
karad -kolhapur-II	IntraState	03/06/2020	12.04	03/06/2020	12.44	T	Distance Protection
Padghe - Nagothane - I	IntraState	03/06/2020	13.16	03/06/2020	20.46	T	B-Ph To Earth Fault
Babhaleshwar - Padghe-II	IntraState	03/06/2020	13.39	03/06/2020	16.02	HT	Over Voltage
Padghe - Kalwa-II	IntraState	03/06/2020	14.23	04/06/2020	07.49	HT	Over Voltage
Padghe - Nagothane - II	IntraState	03/06/2020	14.35	03/06/2020	16.35	T	Distance Protection
Kharghar-Talegaon(PG)	IntraState	03/06/2020	14.52	03/06/2020	18.52	T	Distance Protection
Kalwa - Talegaon(PG)	IntraState	03/06/2020	14.52	03/06/2020	16.25	T	Over Voltage
Babhaleshwar - Padghe-I	IntraState	03/06/2020	15.23		Continued.	T	Distance Protection
Kalwa - Kharghar	IntraState	03/06/2020	15.53	04/06/2020	10.17	T	Over Voltage
Ektuni-Bableswhar ckt I	IntraState	03/06/2020	23.29	04/06/2020	06.27	HT	Over Voltage
Dhule - Bableswhar - II	IntraState	04/06/2020	01.48	04/06/2020	06.35	HT	Over Voltage
BABHALESHWAR - RPL(NASHIK) CKT - 2	IntraState	04/06/2020	03.01		Continued.	T	Over Voltage
Deepnagar Taptitanda	IntraState	04/06/2020	03.51		Continued.	T	Over Voltage
Khadka- Deepnagar Ckt 1	IntraState	04/06/2020	04.22		Continued.	T	Over Voltage
Babhaleshwar - Bhusawal II	IntraState	04/06/2020	06.27		Continued.	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	03/06/2020	08.28		Continued.	HT	Over Voltage
400/220 Kv 315 Mva Ict -2 @New Koyna	IntraState	03/06/2020	11.01	03/06/2020	17.42	T	Heavy Sparking In Isolator.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	03/06/2020	13.20		Continued.	HT	Over Voltage
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	03/06/2020	15.18	03/06/2020	20.59	HT	Over Voltage
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	03/06/2020	15.18	03/06/2020	16.41	HT	Over Voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 04/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	03/06/2020	15.30		Continued.	T	Oil Leval low
400/220/33 Kv 500 Mva Ict-3 @Nagothane	IntraState	03/06/2020	16.22	03/06/2020	17.00	HT	Over Voltage
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	03/06/2020	16.22		Continued.	T	Tripped during Rain.
400/220/33 Kv 600 MVA ICT 4 @Padghe	IntraState	03/06/2020	17.32		Continued.	HT	Low On Oil Level.
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	03/06/2020	17.37		Continued.	HT	Over Voltage
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Tillari Amona	InterState	03/06/2020	22.20		Continued.	T	LA blast at Amona end.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Pusad-Ghatodi	IntraState	02/06/2020	08.35		Continued.	HT	In view Of outage On 220Kv Pusad wardha PG CKT.
Kandalgaon - Bhira	IntraState	02/06/2020	19.39		Continued.	T	Backup Protection
Uran - Kharghar 2	IntraState	02/06/2020	20.34	03/06/2020	22.58	T	R Phase To Earth Fault.
Niwali - Pawas Line	IntraState	03/06/2020	09.14		Continued.	T	Distance Protection
Koyna (Pophali) - Kdph	IntraState	03/06/2020	10.55		Continued.	T	Distance Protection
Vasai Kamba	IntraState	03/06/2020	11.08	03/06/2020	16.30	EO	Replacement of isolator
Bombay Dyeing - Sahara	IntraState	03/06/2020	12.00		Continued.	T	Backup Protection
Apta - Bombay Dyeing	IntraState	03/06/2020	12.00	03/06/2020	12.10	T	Backup Protection
Nagothane-Wadkhal-I	IntraState	03/06/2020	12.58	03/06/2020	20.20	T	B-Ph LA Burst.
Mahad - Pedambe	IntraState	03/06/2020	13.04	03/06/2020	19.53	T	Distance Protection
Mahad-Kandalgaon	IntraState	03/06/2020	13.04		Continued.	T	Distance Protection
Nagothane - Posco	IntraState	03/06/2020	13.18		Continued.	T	Distance Protection
Adlabs - Pedambe	IntraState	03/06/2020	13.18		Continued.	T	Distance Protection
Nagothane-Wadkhal II	IntraState	03/06/2020	13.25	03/06/2020	17.18	T	Distance Protection
Centuri Enka- Bhosari	IntraState	03/06/2020	13.35	03/06/2020	17.56	T	Distance Protection
Kandalgaon - Pirangut	IntraState	03/06/2020	13.43	03/06/2020	21.04	T	Distance Protection
Uran - Apta II	IntraState	03/06/2020	13.58		Continued.	T	Distance Protection
Lonikand1 (400 Kv)-Theur I	IntraState	03/06/2020	14.02	03/06/2020	18.13	T	Distance Protection
Uran - Apta IV	IntraState	03/06/2020	14.06	03/06/2020	16.02	T	Distance Protection
Vita-Khanapur(Mahuli Tap)	IntraState	03/06/2020	14.52	03/06/2020	15.27	T	Distance Protection
Apta - Hoc	IntraState	03/06/2020	15.14		Continued.	T	Distance Protection
Kharghar-Borivali ckt I	IntraState	03/06/2020	15.53		Continued.	T	Distance Protection
Kandalgaon - ONGC Panvel	IntraState	03/06/2020	16.00	04/06/2020	00.07	T	Distance Protection
Infosys - Hinjawadi 1	IntraState	03/06/2020	16.02	03/06/2020	23.43	T	Distance Protection
Pigasus-Hinjewadi-II	IntraState	03/06/2020	16.03		Continued.	T	Distance Protection
Pirangut - Hinjawadi 2	IntraState	03/06/2020	16.05	03/06/2020	23.16	T	Distance Protection
Kandalgaon - Koyna (Pophali)	IntraState	03/06/2020	16.25		Continued.	T	Distance Protection
Babhleshwar- Alephata ckt I	IntraState	03/06/2020	18.46	04/06/2020	00.08	T	Distance Protection
Tuljapur-Lamboti(Tap to Vairag s/st.)	IntraState	03/06/2020	20.15	03/06/2020	22.47	T	Y phase jumper to suspension String
Satana-Gangapur	IntraState	03/06/2020	21.17		Continued.	T	Y Phase LA Burst At Gangapur End.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 04/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Halkarni - Tillari II	IntraState	03/06/2020	22.22	03/06/2020	22.54	T	Backup protection
220 KV ICT Outages/Trippings							
220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2)	IntraState	03/06/2020	19.50	04/06/2020	06.55	HT	Over Voltage
220/132 KV ICT II @ Kopergaon	IntraState	03/06/2020	19.50	04/06/2020	06.55	HT	To Control Over voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage