

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 03/Jun/2023 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 147.107        | 436.318         | 1) Gujrat                      | -4.853         | -10.099         |
| 2) Hydro            | 37.562         | 96.807          | 2) Madhya Pradesh              | 9.082          | 27.899          |
| 3) Gas              | 5.164          | 15.884          | 3) Chattisgarh                 | 4.520          | 14.700          |
| <b>Total MSPGCL</b> | <b>189.833</b> | <b>549.009</b>  | 4) Maharashtra                 | 226.905        | 672.513         |
| B) 1) APMIL         | 60.570         | 184.294         | 5) Goa (Amona)                 | -1.592         | -4.283          |
| 2) JSWEL            | 26.816         | 76.740          | <b>Total</b>                   | <b>234.062</b> | <b>700.730</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 43.006         | 133.592         |
| 4) RPL(AMT)         | 31.212         | 93.307          | b) Mumbai Drawl                | 47.836         | 146.698         |
| 5) SWPGPL           | 10.725         | 31.325          | c) MSEDCL Bilateral *          | 117.372        | 360.373         |
| 6) Other IPP        | 2.580          | 7.986           | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 43.006         | 133.592         |
| C) 1) TPCL Thermal  | 13.482         | 39.207          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 4.789          | 16.491          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.120          | 6.373           | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 6.847          | 21.905          | 1) MSEDCL                      | 536.075        | 1590.119        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 75.074         | 230.674         |
| 1) Thermal          | 299.339        | 891.082         | 3) Other Discoms               | 10.682         | 32.150          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>621.831</b> | <b>1852.943</b> |
| 2) Hydro (A2+C2)    | 42.351         | 113.298         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 7.284          | 22.257          |                                |                |                 |
| 4) Wind             | 22.646         | 75.736          |                                |                |                 |
| 6) SOLAR            | 16.149         | 49.840          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>387.769</b> | <b>1152.213</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 8 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6037                      | 6063                  | 6131                      | 6085                      |
| MSPGCL Hydro               | 1408                      | 1804                  | 1980                      | 1802                      |
| MSPGCL Gas                 | 204                       | 203                   | 205                       | 226                       |
| MSPGCL Total Generation    | 7650                      | 8070                  | 8316                      | 8112                      |
| Central Sector Receipt     | 10464                     | 10373                 | 9051                      | 9341                      |
| WIND                       | 340                       | 609                   | 1236                      | 627                       |
| CPP / IPP Thermal          | 5208                      | 5570                  | 5633                      | 5505                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2021                      | 1373                  | 0                         | 612                       |
| Exchange with Mumbai       | -2350                     | -2436                 | -1796                     | -1765                     |
| <b>MSEDCL DEMAND MET</b>   | <b>22848</b>              | <b>23090</b>          | <b>21947</b>              | <b>21989</b>              |
| Load Shedding              | 0                         | 687                   | 0                         | 0                         |
| MSEDCL DEMAND              | 22848                     | 23777                 | 21947                     | 21989                     |
| TPCL GENERATION            | 697                       | 966                   | 1136                      | 519                       |
| AEML GENERATION            | 431                       | 232                   | 246                       | 305                       |
| <b>MUMBAI DEMAND</b>       | <b>3478</b>               | <b>3634</b>           | <b>3178</b>               | <b>2589</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>484</b>                | <b>469</b>            | <b>493</b>                | <b>444</b>                |
| STATE DEMAND MET           | 26810                     | 27194                 | 25618                     | 25022                     |
| <b>STATE DEMAND</b>        | <b>26810</b>              | <b>27880</b>          | <b>25618</b>              | <b>25022</b>              |
| Frequency (Hz)             | 49.93                     | 49.96                 | 50.04                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.21 Hz at 17:02 Hrs | 49.75 Hz at 13:40 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 03/Jun/2023

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.69         | 14.16         | 205      | 170      |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| Unit 10            | 13.90        | 38.97         | 605      | 526      |
| <b>Total</b>       | <b>18.58</b> | <b>53.13</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.34         | 10.08         | 150      | 100      |
| Unit 4             | 9.69         | 29.23         | 435      | 350      |
| Unit 5             | 10.95        | 31.22         | 475      | 430      |
| <b>Total</b>       | <b>23.98</b> | <b>70.53</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 5.38         | 16.64         | 250      | 176      |
| Unit 7             | 5.45         | 14.27         | 248      | 151      |
| Unit 8             | 4.69         | 12.89         | 205      | 185      |
| <b>Total</b>       | <b>15.52</b> | <b>43.80</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 1.08         | 7.99          | 149      | 0        |
| Unit 4             | 3.73         | 11.10         | 158      | 152      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 8.96         | 27.38         | 395      | 330      |
| Unit 7             | 8.90         | 27.62         | 384      | 352      |
| Unit 8             | 11.51        | 34.74         | 498      | 447      |
| Unit 9             | 11.53        | 34.76         | 497      | 446      |
| <b>Total</b>       | <b>45.72</b> | <b>143.59</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 5.21         | 15.51         | 230      | 202      |
| Unit 4             | 5.59         | 15.96         | 247      | 225      |
| <b>Total</b>       | <b>10.80</b> | <b>31.48</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.20         | 9.55          | 140      | 120      |
| Unit 2             | 3.09         | 9.35          | 139      | 115      |
| Unit 3             | 1.62         | 2.88          | 180      | 0        |
| Unit 4             | 4.44         | 13.47         | 189      | 181      |
| Unit 5             | 11.19        | 33.56         | 475      | 433      |
| <b>Total</b>       | <b>23.54</b> | <b>68.81</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.74         | 0.74          | 162      | 0        |
| Unit 4             | 4.18         | 12.23         | 180      | 156      |
| Unit 5             | 4.04         | 12.01         | 172      | 163      |
| <b>Total</b>       | <b>8.95</b>  | <b>24.98</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 5.16         | 15.88         | 232      | 199      |
| <b>Total</b>       | <b>5.16</b>  | <b>15.88</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.18         | 0.28          | 47       | 0        |
| <b>Total</b>       | <b>0.18</b>  | <b>0.28</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 7.54         | 19.28         | 475      | 40       |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 4         | 19.92         | 49.64         | 1010     | 251      |
| Stage 3         | 6.28          | 15.82         | 320      | 136      |
| <b>Total</b>    | <b>33.73</b>  | <b>84.73</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.47          | 1.43          | 20       | 20       |
| VTRNA           | 1.14          | 3.38          | 60       | 0        |
| TILLARI         | 0.12          | 1.04          | 58       | 0        |
| BHIRA T.R.      | 0.33          | 1.13          | 80       | 0        |
| SMLHY_PTN       | 1.59          | 4.81          | 70       | 63       |
| GHATGHAR        | 0.00          | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>3.65</b>   | <b>11.79</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 22.65         | 75.74         | 0        | 0        |
| <b>Total</b>    | <b>22.65</b>  | <b>75.74</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 60.57         | 184.29        | 0        | 0        |
| JSWEL(Mus)      | 26.82         | 76.74         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 31.21         | 93.31         | 0        | 0        |
| SWPGPL-Mus      | 10.72         | 31.32         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00          | 0        | 0        |
| IEPL            | 0.00          | 0.00          | 0        | 0        |
| Other(Mus)      | 2.58          | 7.99          | 0        | 0        |
| <b>Total</b>    | <b>131.90</b> | <b>393.65</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 16.15         | 49.84         | 0        | 0        |
| <b>Total</b>    | <b>16.15</b>  | <b>49.84</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 8.84          | 25.77         | 434      | 272      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 1.16          | 3.51          | 107      | 37       |
| Trombay 7B      | 0.96          | 2.87          | 63       | 34       |
| TATA Hydro      | 4.79          | 16.49         | 392      | 40       |
| Trombay 8       | 4.64          | 13.44         | 230      | 132      |
| <b>Total</b>    | <b>20.39</b>  | <b>62.07</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 6.85          | 21.90         | 431      | 220      |
| <b>Total</b>    | <b>6.85</b>   | <b>21.90</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 147.11      | 436.32        | MSPGCL Total        | 189.83      | 549.01        |
|                |             |         | MSPGCL Thml+Gas | 152.27      | 452.20        | Koyna 1,2 & 4 Total | 27.45       | 68.91         |
|                |             |         | MSPGCL Hydro    | 37.56       | 96.81         | State Total         | 387.77      | 1152.21       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 03/Jun/2023

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |       | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 6135        | 1662  | 225  | 8022   | 1473  | 5628      | 0    | 0     | 8672     | 8840     | -1783          | 21766            | 784           | 0                        | 22550                | 3261          | 415                 | 26226        | 50.01      |
| 2            | 6170        | 1274  | 225  | 7668   | 1463  | 5654      | 0    | 0     | 9177     | 9521     | -1648          | 22270            | 389           | 0                        | 22659                | 3062          | 388                 | 26110        | 50.04      |
| 3            | 6186        | 1238  | 225  | 7650   | 1332  | 5637      | 0    | 0     | 9596     | 9449     | -1662          | 22052            | 0             | 0                        | 22052                | 2865          | 353                 | 25270        | 50.00      |
| 4            | 6174        | 1450  | 226  | 7850   | 1240  | 5596      | 0    | 0     | 9526     | 9706     | -1755          | 22322            | 0             | 0                        | 22322                | 2707          | 314                 | 25344        | 49.98      |
| 5            | 6151        | 1638  | 229  | 8018   | 1176  | 5644      | 0    | 0     | 9292     | 9418     | -1716          | 22184            | 0             | 0                        | 22184                | 2639          | 356                 | 25178        | 49.96      |
| 6            | 6181        | 1716  | 231  | 8128   | 1067  | 5656      | 0    | 1     | 9769     | 9748     | -1688          | 22523            | 0             | 0                        | 22523                | 2607          | 389                 | 25518        | 49.91      |
| 7            | 6156        | 1672  | 232  | 8060   | 875   | 5518      | 0    | 174   | 9409     | 9661     | -1701          | 22165            | 0             | 0                        | 22165                | 2544          | 421                 | 25130        | 49.96      |
| 8            | 6085        | 1802  | 226  | 8112   | 627   | 5505      | 0    | 612   | 8979     | 9341     | -1765          | 21989            | 0             | 0                        | 21989                | 2589          | 444                 | 25022        | 50.00      |
| 9            | 6017        | 1194  | 227  | 7438   | 549   | 5225      | 0    | 1252  | 9827     | 9792     | -1957          | 21816            | 0             | 11                       | 21816                | 2799          | 484                 | 25098        | 49.98      |
| 10           | 6033        | 836   | 216  | 7084   | 431   | 5208      | 0    | 1645  | 10577    | 10293    | -2121          | 22066            | 0             | 13                       | 22066                | 3100          | 475                 | 25640        | 49.92      |
| 11           | 6053        | 942   | 205  | 7200   | 370   | 5227      | 0    | 1991  | 10755    | 10607    | -2344          | 22573            | 0             | 25                       | 22573                | 3359          | 477                 | 26410        | 49.98      |
| 12           | 6037        | 1408  | 204  | 7650   | 340   | 5208      | 0    | 2021  | 10503    | 10464    | -2350          | 22848            | 0             | 109                      | 22848                | 3478          | 484                 | 26810        | 49.93      |
| 13           | 6100        | 1274  | 203  | 7576   | 301   | 5216      | 0    | 2021  | 10756    | 10545    | -2405          | 22793            | 0             | 144                      | 22793                | 3485          | 462                 | 26740        | 49.92      |
| 14           | 6095        | 1270  | 202  | 7568   | 549   | 5221      | 0    | 1959  | 10687    | 10628    | -2469          | 23008            | 0             | 57                       | 23008                | 3416          | 448                 | 26872        | 49.92      |
| 15           | 6053        | 1500  | 201  | 7754   | 396   | 5384      | 0    | 1732  | 10385    | 10890    | -2492          | 23205            | 347           | 194                      | 23552                | 3543          | 459                 | 27554        | 49.92      |
| 16           | 6063        | 1804  | 203  | 8070   | 609   | 5570      | 0    | 1373  | 10329    | 10373    | -2436          | 23090            | 687           | 315                      | 23777                | 3634          | 469                 | 27880        | 49.96      |
| 17           | 6088        | 1840  | 202  | 8130   | 705   | 5537      | 0    | 919   | 10435    | 10496    | -2305          | 22987            | 89            | 100                      | 23076                | 3533          | 494                 | 27104        | 50.05      |
| 18           | 6108        | 1740  | 199  | 8048   | 924   | 5524      | 0    | 394   | 10352    | 10452    | -2228          | 22619            | 0             | 9                        | 22619                | 3343          | 494                 | 26456        | 50.06      |
| 19           | 6145        | 1498  | 205  | 7848   | 1164  | 5543      | 0    | 55    | 9551     | 9321     | -2106          | 21324            | 0             | 11                       | 21324                | 3191          | 502                 | 25016        | 50.07      |
| 20           | 6131        | 1980  | 205  | 8316   | 1236  | 5633      | 0    | 0     | 8942     | 9051     | -1796          | 21947            | 0             | 3                        | 21947                | 3178          | 493                 | 25618        | 50.04      |
| 21           | 6215        | 1940  | 213  | 8368   | 1253  | 5656      | 0    | 0     | 8649     | 8681     | -1768          | 21713            | 0             | 0                        | 21713                | 3154          | 478                 | 25344        | 50.04      |
| 22           | 6231        | 1982  | 218  | 8430   | 1227  | 5628      | 0    | 0     | 8359     | 8787     | -1727          | 21872            | 0             | 0                        | 21872                | 3134          | 473                 | 25480        | 50.05      |
| 23           | 6205        | 1974  | 220  | 8400   | 1548  | 5609      | 0    | 0     | 8666     | 9061     | -1753          | 22396            | 0             | 0                        | 22396                | 3176          | 469                 | 26040        | 50.00      |
| 24           | 6295        | 1930  | 222  | 8446   | 1791  | 5676      | 0    | 0     | 8686     | 8937     | -1861          | 22548            | 0             | 0                        | 22548                | 3277          | 442                 | 26266        | 50.01      |
| MUs          | 147.11      | 37.56 | 5.16 | 189.83 | 22.65 | 131.90    | 0.00 | 16.15 | 231.88   | 234.06   | -47.84         | 536.07           | 2.30          | 0.99                     | 538.37               | 75.07         | 10.68               | 624.13       | 49.99      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

1) FLS for load management due to tripping of 220KV Nasik-BBLSR-I line. 2) ELR done due to state overdrawal.3) FLS for Load management after LTS operated.4) DLS done due to overloading of Urse-chinchwad Line and low Voltage at 400KV Lonikand S/stn.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 03/Jun/2023**

**Position as on 6.30 Hrs of 04/Jun/2023**

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR          | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 01/04/2024    |
| CENT.SECTOR          | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 01/05/2024    |
| MSPGCL               | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      | 31/07/2023    |
| MSPGCL               | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 23/07/2023    |
| MSPGCL               | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |            | Continued. | Material replacement work.                                                                                                                              | 01/03/2024    |
| MSPGCL               | Nasik Unit 3            | 210      | 20/05/2023   | 08:45        | 03/06/2023 | 17:53      | IEPL UNIT 1( CASE 4) UNDER OUTAGE                                                                                                                       |               |
| MSPGCL               | Chandrapur Unit 5       | 500      | 22/05/2023   | 19:00        |            | Continued. | Stator Earth Fault                                                                                                                                      | 27/06/2023    |
| IPP                  | IEPL Unit 1             | 270      | 24/05/2023   | 20:10        |            | Continued. | Clinker formation in furnace                                                                                                                            | 07/06/2023    |
| MSPGCL               | Koradi Unit 8           | 660      | 29/05/2023   | 05:36        |            | Continued. | Boiler Tube Leakage                                                                                                                                     |               |
| MSPGCL               | Koradi Unit 9           | 660      | 30/05/2023   | 00:08        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 07/06/2023    |
| MSPGCL               | Khaparkheda Unit 3      | 210      | 01/06/2023   | 07:43        | 03/06/2023 | 13:19      | Boiler Tube Leakage                                                                                                                                     | 04/06/2023    |
| IPP                  | Adani U-2               | 660      | 01/06/2023   | 08:04        | 04/06/2023 | 18:14      | Air heater problem                                                                                                                                      | 04/06/2023    |
| MSPGCL               | Uran Unit 6             | 108      | 01/06/2023   | 19:57        |            | Continued. | No Schedule                                                                                                                                             |               |
| MSPGCL               | Koyna STG-IV Unit-4     | 250      | 02/06/2023   | 07:28        | 03/06/2023 | 02:15      | Governor accumulator oil pressure very low and quick stop requested.                                                                                    |               |
| MSPGCL               | Koyna Unit 1            | 70       | 03/06/2023   | 03:45        | 03/06/2023 | 08:47      | Major Governor failure                                                                                                                                  |               |
| MSPGCL               | Chandrapur Unit 3       | 210      | 03/06/2023   | 07:48        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 05/06/2023    |
| AEML                 | AEML Unit 1             | 250      | 03/06/2023   | 12:44        | 04/06/2023 | 00:11      | Air heater problem                                                                                                                                      |               |
| MSPGCL               | Nasik Unit 3            | 210      | 04/06/2023   | 02:10        |            | Continued. | Boiler Tube Leakage                                                                                                                                     |               |
| MSPGCL               | Koyna STG-IV Unit-1     | 250      | 04/06/2023   | 05:11        | 04/06/2023 | 10:00      | Safety bolt rupture fault                                                                                                                               |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Jun/2023**

**Statement-VII**

Position as on 6.30 Hrs of 04/Jun/2023

| Name of Line                                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                  |
|------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                   |
| AKOLA II - EKTUNI CKT - 2                                  | IntraState                | 04/06/2023   | 13:46        | 04/06/2023 | 15:30      | HT          | TRIPPED ON DISTANCE PROTECTION                                                                                                                                                                                                                                                                                                    |
| <b>400 KV TIEBAY Outages/Trippings</b>                     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                   |
| 400KV TIE BAY 402 STN TF 1 AND AKOLA2 CKT 1 @ NANDGAONPETH | InterState                | 01/06/2023   | 06:09        | 03/06/2023 | 19:42      | PO          | ST-1 Tie 402 bay following work to be carried out:-<br>1. total 6 nos. bay CT testing work.<br>2. ST-1 tie bay relay testing work<br>3. ST-1 tie breaker testing work(DCRM, CRM and timing testing)<br>4. ST-1 Tie bay isolator maintenance work.                                                                                 |
| <b>400 KV MAINBAY Outages/Trippings</b>                    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                   |
| MAIN BAY 401 OF STN T/F 1 @ NANDGAONPETH                   | InterState                | 01/06/2023   | 06:09        | 03/06/2023 | 19:42      | PO          | ST-1 (401bay) following work to be carried out<br>1. all three poles circuit breakers maintenance and testing work(DCRM, timing and CRM testing)<br>2. 3 nos. Bay CT tan testing work<br>3. 401 Bay protection relay testing work<br>4. isolator maintenance work.                                                                |
| 400/6.9KV 63MVA STN T/F 1 @ NANDGAONPETH                   | InterState                | 01/06/2023   | 06:09        |            | Continued. | PO          | ST-1 transformer oil leakage arresting, maintenance, diagnostic testing, Metering CT and CVT testing and ST1 transformer protection relay testing work.<br>ST-1 transformer painting work                                                                                                                                         |
| <b>400 KV LINE Outages/Trippings</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                   |
| TALANDGE - KOLHAPUR (PG) CKT - 2                           | InterState                | 20/03/2023   | 07:49        |            |            | PO          | For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1                                                                                                                                                                             |
| DHULE - SSNNL CKT - 1                                      | InterState                | 04/06/2023   | 10:11        |            | Continued. | T           | Distance Protection                                                                                                                                                                                                                                                                                                               |
| 400KV RPL - AKOLA CKT 1                                    | InterState                | 04/06/2023   | 14:07        | 04/06/2023 | 14:53      | T           | Tripped on Distance protection, Heavy storm.                                                                                                                                                                                                                                                                                      |
| 400KV RPL-AKOLA 2 CKT 2                                    | InterState                | 04/06/2023   | 14:09        | 04/06/2023 | 16:14      | T           | Tripped on Distance protection, Heavy storm.                                                                                                                                                                                                                                                                                      |
| LONIKAND I - TALEGAON (PGCIL)                              | InterState                | 04/06/2023   | 14:32        |            | Continued. | T           | Y-Phase wave trap burst at Lonikand, heavy storm.                                                                                                                                                                                                                                                                                 |
| DHULE - SSNNL CKT - 2                                      | InterState                | 04/06/2023   | 22:36        |            | Continued. | EO          | While ground patrolling carried out, at loc no. 278 to 280 Snapping of earth wire observed so please give permission for emergency outage on 400 KV Dhule-SSNNL-2 line & 400kV Dhule SSNL 1 line is already in Breakdown & work s already progressed on 400kV Dhule SSNL 1 line for stringing of earth wire ( LOC No.267 to 268). |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Jun/2023**

**Statement-VII**

Position as on 6.30 Hrs of 04/Jun/2023

| Name of Line                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                          |
|------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| DABHOL - NEW KOYNA CKT - 2                     | IntraState                | 22/05/2023   | 13:26        |            | Continued. | PO          | Dismantling of exising tilted old tower at location no 94 and erection of new tower ( B+9ST) with foundation and stringing of conductor.                                                                                  |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1            | IntraState                | 23/05/2023   | 09:46        | 03/06/2023 | 21:20      | HT          | For load management                                                                                                                                                                                                       |
| KHADKA- DEEPNAGAR CKT 2                        | IntraState                | 25/05/2023   | 10:02        |            |            |             | Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.                                                                                                                                                 |
| B - BUS @ KHARGHAR                             | IntraState                | 03/06/2023   | 03:07        | 03/06/2023 | 07:32      | PO          | 1) Bus Extension Connection work along with charging of 2 nos of new 400KV Vikhroli Line Bay's at Kharghar(First time Charging).<br>2) For work of Damaged Quadraple conductor span replacement and Bus maintenance work. |
| CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1            | IntraState                | 03/06/2023   | 08:17        | 04/06/2023 | 00:53      | PO          | For main-2 relay retrofitting work                                                                                                                                                                                        |
| CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2     | IntraState                | 04/06/2023   | 02:32        | 04/06/2023 | 14:45      | T           | Tripped on distance protection                                                                                                                                                                                            |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2            | IntraState                | 04/06/2023   | 10:21        | 04/06/2023 | 13:51      | HT          | HT for Load Management                                                                                                                                                                                                    |
| KHADKA-AURANGABAD (WALUJ)                      | IntraState                | 04/06/2023   | 12:36        | 04/06/2023 | 22:38      | T           | Distance Protection                                                                                                                                                                                                       |
| 220 KV KHADKA (400 KV)- CHALISGAON CKT -1      | IntraState                | 04/06/2023   | 12:53        | 04/06/2023 | 16:09      | T           | Distance Protection.                                                                                                                                                                                                      |
| PARLI - KARJAT CKT - 2                         | IntraState                | 04/06/2023   | 14:32        | 04/06/2023 | 16:48      | T           | Tripped on Over Voltage.                                                                                                                                                                                                  |
| LONIKAND 2 - KARJAT CKT - 2                    | IntraState                | 04/06/2023   | 14:32        | 04/06/2023 | 17:00      | T           | Tripped Due to heavy rainfall and thunderstorm, 400kV Lonikand I- PGCIL Line tripped due to bursting of Rph wavetrap at Lonikand I leading to REVERSE ZONE tripping.                                                      |
| LONIKAND 2 - KARJAT CKT - 1                    | IntraState                | 04/06/2023   | 14:32        | 04/06/2023 | 15:48      | T           | Tripped Due to heavy rainfall and thunderstorm, 400kV Lonikand I- PGCIL Line tripped due to bursting of Rph wavetrap at Lonikand I leading to REVERSE ZONE tripping.                                                      |
| LONIKAND II - LONIKAND I (INTERCONNECTOR ) - 2 | IntraState                | 04/06/2023   | 14:32        | 04/06/2023 | 15:17      | T           | Tripped due to heavy storm, Y-phase wave trap of 400KV Lonikand-Talegaon PG burst, R-phase LA of 400KV Loniknad-Lonikad2 Ckt-I burst at Lonikand1 end.                                                                    |
| LONIKAND II - LONIKAND I (INTERCONNECTOR ) - 1 | IntraState                | 04/06/2023   | 14:32        | 04/06/2023 | 19:50      | T           | R-Phase LA burst at 400KV Lonikand.                                                                                                                                                                                       |
| LONIKAND I - CHAKAN                            | IntraState                | 04/06/2023   | 14:32        | 04/06/2023 | 15:27      | T           | Tripped due to heavy storm, Y-phase wave trap of 400KV Lonikand-Talegaon PG burst, R-phase LA of 400KV Loniknad-Lonikad2 Ckt-I burst at Lonikand1 end.                                                                    |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1            | IntraState                | 04/06/2023   | 23:37        |            |            | HT          | HT for load management                                                                                                                                                                                                    |
| <b>400 KV ICT Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                                                                                                           |
| STATION TF No 3 @ CHANDRAPUR GCR               | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                            |
| 400/220 KV 500MVA ICT - 4 @ KALWA              | IntraState                | 02/06/2023   | 22:48        | 03/06/2023 | 01:09      | EO          | Attending Hot spot 360 deg , LV side , 29 A Isolator B ph( line side) of 400/220 KV,500 MVA ICT-IV LV by shifting this LV side on TBC                                                                                     |
| 400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2      | IntraState                | 03/06/2023   | 06:24        | 03/06/2023 | 12:17      | PO          | Premonsoon Maintenance                                                                                                                                                                                                    |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Jun/2023**

**Statement-VII**

Position as on 6.30 Hrs of 04/Jun/2023

| Name of Line                                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                         |
|------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------|
| 400/132 KV 200 MVA ICT - 1 @ KHADKA                  | IntraState                | 03/06/2023   | 08:15        | 03/06/2023 | 16:55      | PO          | For Premonsoon maintenance Work, HV and LV side routine bay maintenance works etc. of 400/132kv 200MVA - ICT No. 01                      |
| 400/132 KV 200 MVA ICT - 1 @ KHADKA                  | IntraState                | 03/06/2023   | 08:15        | 03/06/2023 | 15:15      | PO          | Premonsoon maintenance work                                                                                                              |
| <b>220 KV MAINBAY Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                                          |
| 220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)  | IntraState                | 02/06/2023   | 10:10        |            |            | HT          | For rectification of punch points of 220kv wani- pandharkawada line ph-i line.                                                           |
| 220 KV WANI - PANDHARKAWDA CKT II BAY (TEST CHARGED) | IntraState                | 02/06/2023   | 10:10        |            |            | HT          | For rectification of punch points of 220kv wani- pandharkawada line ph-i line.                                                           |
| BUS COUPLER @ BOISAR PG                              | IntraState                | 03/06/2023   | 11:55        | 03/06/2023 | 18:17      | PO          | AMP WORKS                                                                                                                                |
| INTERCONNECTOR @ KALWA                               | IntraState                | 03/06/2023   | 13:55        | 03/06/2023 | 17:47      | EO          | Jumper replacement work of 29 B R ph toward CB                                                                                           |
| <b>220 KV LINE Outages/Trippings</b>                 |                           |              |              |            |            |             |                                                                                                                                          |
| EKLAHARE (OCR) - NAVASARI CKT - 1                    | IntraState                | 10/02/2023   | 09:45        |            |            | PO          | Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)                                           |
| EKLAHARE (OCR) - PADGHE                              | IntraState                | 05/03/2023   | 08:55        |            |            | HT          | For load management                                                                                                                      |
| AAREY - AEML SAKI CKT - 1                            | IntraState                | 28/05/2023   | 17:23        |            |            | T           | Tripped on Differential protection.                                                                                                      |
| LONIKAND (400 KV)-THEUR II                           | IntraState                | 01/06/2023   | 14:10        | 03/06/2023 | 17:36      | PO          | 220kV Theur Ckt 2, C.B mechanism overhauling work by shifting its load on 220kV T.B.C Bay                                                |
| BOMBAY DYEING - SAHARA                               | IntraState                | 02/06/2023   | 08:55        | 03/06/2023 | 08:30      | EO          | CB overhauling work of 220 kv Sahara-Bombay dying line bay.                                                                              |
| BOISAR II - TARAPUR                                  | IntraState                | 02/06/2023   | 10:20        | 03/06/2023 | 19:08      | HT          | PLANNED OUTAGE AVAILED AT TARAPUR END                                                                                                    |
| TIFIL - KALWA                                        | IntraState                | 03/06/2023   | 09:10        | 03/06/2023 | 14:56      | PO          | R ph CT bottom support frame member replacement work due to heavy rusting                                                                |
| MUMEWADI -HALKARNI 1 LINE                            | IntraState                | 03/06/2023   | 09:10        | 03/06/2023 | 15:57      | PO          | Insulator Cleaning work                                                                                                                  |
| KALMESHVAR-PANDHURNA                                 | IntraState                | 03/06/2023   | 09:23        | 03/06/2023 | 18:12      | PO          | FOR LINE MAINTENANCE WORK                                                                                                                |
| TALANDAGE - FIVE STAR MIDC 1                         | IntraState                | 03/06/2023   | 09:55        | 03/06/2023 | 14:14      | PO          | for dignostic testing and quarterly maintenance work                                                                                     |
| 220KV KARJAT-AHMEDNAGAR-CKT-1                        | IntraState                | 03/06/2023   | 10:05        | 03/06/2023 | 16:46      | PO          | Replacement of Y ph (Cut point) flashover insu. String at loc 49 & R Ph at loc 108 ( Found during monkey patrolling)                     |
| BHANDARA-ULTRATECH CEMENT                            | IntraState                | 03/06/2023   | 10:58        | 03/06/2023 | 11:20      | PO          | Replacement of Backup over current Relay                                                                                                 |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 1                    | IntraState                | 03/06/2023   | 12:31        | 03/06/2023 | 12:49      | T           | Tripped on Distance Protection.                                                                                                          |
| BOMBAY DYEING - SAHARA                               | IntraState                | 03/06/2023   | 13:52        | 03/06/2023 | 17:02      | EO          | Work :- CB overhauling work of 220 kv Sahara-Bombay dying line bay.                                                                      |
| TALANDAGE - FIVE STAR MIDC 1                         | IntraState                | 03/06/2023   | 14:23        | 03/06/2023 | 21:44      | T           | TRIPPED ON DISTANCE PROTECTION                                                                                                           |
| APTA - KALWA                                         | IntraState                | 03/06/2023   | 17:58        | 04/06/2023 | 20:23      | PO          | Stringing on newly erected 3 nos. of Tower between Loc no.676 to 680 and de-stringing of line from ERS Tower and ckt will be normalised. |
| KALWA - SALESETTE CKT - 5                            | IntraState                | 03/06/2023   | 18:07        | 03/06/2023 | 20:10      | HT          | Emergency outage availed due to GIS bay SF6 Pressure is low                                                                              |
| GHODBUNDER - MSETCL BOISAR                           | IntraState                | 04/06/2023   | 07:10        | 04/06/2023 | 07:20      | EO          | Bird Nest removing from Bph Stub Bus gantry.                                                                                             |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Jun/2023**

**Statement-VII**

Position as on 6.30 Hrs of 04/Jun/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                         |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| KALMESHWAR-PANDHURNA                      | IntraState                | 04/06/2023   | 09:11        | 04/06/2023 | 19:26      | PO          | Line Maintenance Work.                                                                                                                                                   |
| KALMESHWAR-PANDHURNA                      | IntraState                | 04/06/2023   | 09:11        | 04/06/2023 | 19:26      | PO          | FOR LINE MAINTENANCE WORK                                                                                                                                                |
| NERUL - SEAWOOD CABLE CKT - 1             | IntraState                | 04/06/2023   | 11:04        | 04/06/2023 | 14:13      | EO          | Maintenance work by Railways                                                                                                                                             |
| WPCL-WARORA 2                             | IntraState                | 04/06/2023   | 11:18        | 04/06/2023 | 17:16      | PO          | Attending Hot Spot.                                                                                                                                                      |
| BUS - A @ PADGHE                          | IntraState                | 04/06/2023   | 11:49        | 04/06/2023 | 13:34      | EO          | Attending Red Hot on Rph A bus conductor by hot line method                                                                                                              |
| RANJANGAON-FIAT 2                         | IntraState                | 04/06/2023   | 13:45        | 04/06/2023 | 17:15      | PO          | M/S Fiat India Automobile Pvt. Ltd . Has requested for outage on Dt. 04.06.2023 for Instaulation of Power quality meter in AMR Cabinet in series with Discom Check meter |
| RANJANGAON-FIAT 1                         | IntraState                | 04/06/2023   | 13:45        | 04/06/2023 | 17:15      | PO          | M/S Fiat India Automobile Pvt. Ltd . Has requested for outage on Dt. 04.06.2023 for Instaulation of Power quality meter in AMR Cabinet in series with Discom Check meter |
| PUSAD - WARDHA (PG)                       | IntraState                | 04/06/2023   | 14:24        | 04/06/2023 | 17:11      | T           | Tripped on Distance protection.                                                                                                                                          |
| PUSAD - WARDHA (PG)                       | IntraState                | 04/06/2023   | 14:24        | 04/06/2023 | 17:11      | T           | Distance Protection.                                                                                                                                                     |
| LONIKAND 2 - VSNL                         | IntraState                | 04/06/2023   | 14:25        | 04/06/2023 | 16:09      | T           | Tripped on Distance protection                                                                                                                                           |
| LONIKAND 2 - BHOSARI                      | IntraState                | 04/06/2023   | 14:26        | 04/06/2023 | 15:54      | T           | Tripped on over current protection.                                                                                                                                      |
| KANDALGAON - ONGC PANVEL                  | IntraState                | 04/06/2023   | 14:27        | 04/06/2023 | 16:24      | T           | line tripped on distance protection, lightening as heavy rain.                                                                                                           |
| GHATODI-NANDED                            | IntraState                | 04/06/2023   | 14:30        | 04/06/2023 | 19:39      | T           | Distance Protection.                                                                                                                                                     |
| 220 PARLI U-8 - NEW GCR PARLI CKT II      | IntraState                | 04/06/2023   | 15:13        | 04/06/2023 | 17:36      | T           | Distance Protection.                                                                                                                                                     |
| PARLI NEW TPS - BEED CKT 2                | IntraState                | 04/06/2023   | 16:26        | 04/06/2023 | 18:30      | EO          | B Ph La Found Bend.                                                                                                                                                      |
| WANI-WARORA 1                             | IntraState                | 04/06/2023   | 16:31        | 04/06/2023 | 17:30      | T           | Distance Protection.                                                                                                                                                     |
| 220 KV CHANDRAPUR GCR (400 KV) - WANI CKT | IntraState                | 04/06/2023   | 16:31        | 04/06/2023 | 17:57      | T           | Distance Protection.                                                                                                                                                     |
| MAIN BUS - 2 @ AAREY                      | IntraState                | 04/06/2023   | 18:01        | 04/06/2023 | 19:40      | EO          | Charging of 125 MVA TR-2 after shifting from AIS Bay no. 05 to New GIS Bay no. 21. Work to be executed under MERC approved 220kV AIS to GIS conversion scheme.           |
| SAHARA-URSE                               | IntraState                | 04/06/2023   | 21:12        |            | Continued. | EO          | CB overhauling work of 220kV Sahara-Urse line bay.                                                                                                                       |
| <b>220 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                          |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                         |
| 220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE | IntraState                | 10/11/2022   | 10:35        |            |            | EO          | For attending to abnormal Nosie from ICT                                                                                                                                 |
| 220 / 110 / 33kV 250MVA AT 2 @ BACKBAY    | IntraState                | 03/06/2023   | 08:17        | 04/06/2023 | 17:13      | PO          | protection panel replacement.                                                                                                                                            |
| 220/100 KV 100 MVA ICT 2 @ KANDALGAON     | IntraState                | 03/06/2023   | 09:30        | 03/06/2023 | 18:18      | PO          | Diagnostic testing & relay testing work to be carried out.                                                                                                               |
| 220/33 KV 25MVA PTR NO 2 @ BHIGWAN        | IntraState                | 03/06/2023   | 10:01        | 03/06/2023 | 11:54      | PO          | for Pre monsoon maint work                                                                                                                                               |
| 220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR     | IntraState                | 03/06/2023   | 10:14        | 03/06/2023 | 18:41      | EO          | Attending LV Y ph bushing red hot (temp 160 ),oil leakage arresting, Premonsoon work, diagnostic testing, quarterly maintenance work                                     |
| 220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)   | IntraState                | 03/06/2023   | 10:44        | 03/06/2023 | 13:02      | PO          | Pre monsoon maintenance work.                                                                                                                                            |
| 220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR  | IntraState                | 03/06/2023   | 15:27        | 03/06/2023 | 17:30      | EO          | Outage is required for Repacement of faulty LV backup and REF (Combined) relay.                                                                                          |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 03/Jun/2023**

**Statement-VII**

Position as on 6.30 Hrs of 04/Jun/2023

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                     |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------|
| 220/132 KV 100 MVA ICT 1 @ BHENDA         | IntraState                | 03/06/2023   | 16:55        | 03/06/2023 | 16:55      | PO          | To check and release the accumulated gas in OLTC OSR to avoid the abnormal tripping. |
| 220 / 110 / 33kV 250MVA ICT 10 @ DHARAVI  | IntraState                | 04/06/2023   | 08:31        | 04/06/2023 | 16:52      | PO          | R/M AND TESTING                                                                      |
| 220 / 110 / 23kV 250 MVA ICT 3 @ SALSETTE | IntraState                | 04/06/2023   | 17:12        | 04/06/2023 | 18:42      | EO          | for the removal of hanging Net on 110kV A-phase bushing.                             |
| <b>132 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                      |
| RISOD-YELDARI                             | IntraState                | 20/04/2023   | 17:57        |            |            | HT          | TO CONTROL LOADING ON RISOD - MALEGAON CKT                                           |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                      |
| SALSETTE POWAI                            | IntraState                | 27/03/2023   | 11:04        |            |            | PO          | Replacement of tower number 77 & 78 for TDS project work.                            |
| AMBERNATH - KALYAN CKT - 2                | IntraState                | 02/06/2023   | 15:15        | 03/06/2023 | 16:42      | EO          | Bird nest removal 25,26,28                                                           |
| AMBERNATH - KALYAN CKT - 1                | IntraState                | 03/06/2023   | 07:27        | 03/06/2023 | 08:52      | EO          | Removing Bird & hanging object from LOC 23 & 25                                      |
| WAGHIVALI - CHEMBUR                       | IntraState                | 03/06/2023   | 08:39        | 03/06/2023 | 09:14      | PO          | Bird nest Removal                                                                    |
| AMBERNATH - KALYAN CKT - 2                | IntraState                | 03/06/2023   | 17:41        | 03/06/2023 | 20:05      | PO          | For bus fault stability test                                                         |
| KHOPOLI - BHIVPURI CKT - 1                | IntraState                | 04/06/2023   | 05:56        | 04/06/2023 | 12:59      | EO          | For Installation of TLA                                                              |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage