

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 03/Jun/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.926	485.434	1) Gujrat	0.550	3.900
2) Hydro	17.919	50.628	2) Madhya Pradesh	5.562	13.540
3) Gas	7.654	21.723	3) Chattisgarh	3.370	9.210
Total MSPGCL	183.499	557.785	4) Maharashtra	208.675	618.684
B) 1) APLM	73.907	213.108	5) Goa (Amona)	-2.434	-7.125
2) JSWEL	28.062	83.292	Total	215.723	638.209
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.522	129.708
4) RPL(AMT)	25.401	76.533	b) Mumbai Drawl	47.809	135.407
5) SWPGPL	12.448	36.013	c) MSEDCL Bilateral *	98.107	293.915
6) Other IPP	15.989	47.830	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	45.522	129.708
C) 1) TPCL Thermal	13.904	39.731	Include PX	0.000	0.000
2) TPCL Hydro	7.038	16.134	Standby	0.000	0.000
3) TPCL Gas	4.128	12.384	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.496	33.840	1) MSEDCL	531.291	1600.653
D) STATE			2) Mumbai Discoms	84.375	237.496
1) Thermal	339.133	1015.781	3) Other Discoms	11.990	33.949
(A1+C1+C4+(B1-B6))			TOTAL STATE	627.656	1872.098
2) Hydro	24.957	66.762			
(A2+C2)					
3) Gas	11.782	34.107			
(A3+B7+C3)					
4) Wind	19.876	67.562			
6) SOLAR	16.185	49.677			
TOTAL STATE	411.933	1233.889			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6560	6713	6680	6336
MSPGCL Hydro	464	482	1232	126
MSPGCL Gas	283	371	373	289
MSPGCL Total Generation	7308	7566	8286	6750
Central Sector Receipt	10364	10271	8055	9186
WIND	296	662	1342	970
CPP / IPP Thermal	5263	6704	6777	6538
CPP / IPP Gas	0	0	0	0
SOLAR	2290	1335	0	0
Exchange with Mumbai	-2214	-2388	-1901	-1629
MSEDCL DEMAND MET	22777	23613	21991	21404
Load Shedding	0	0	0	0
MSEDCL DEMAND	22777	23613	21991	21404
TPCL GENERATION	1263	1271	1175	722
AEML GENERATION	503	502	503	489
MUMBAI DEMAND	3980	4161	3579	2840
OTHER DISCOM DEMAND	529	536	568	411
STATE DEMAND MET	27286	28310	26138	24656
STATE DEMAND	27286	28310	26138	24656
Frequency (Hz)	49.97	50.00	50.04	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 18:02 Hrs	49.76 Hz at 12:49 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 03/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.13	12.28	190	137
Unit 8	14.13	41.52	613	545
Unit 9	13.17	17.14	591	520
Unit 10	12.64	39.59	588	490
Total	44.07	110.54		
Bhusawal				
Unit 3	0.06	2.34	59	0
Unit 4	10.97	32.32	485	405
Unit 5	10.74	31.44	470	350
Total	21.76	66.10		
Parli				
Unit 6	4.82	14.82	249	145
Unit 7	3.82	13.73	248	0
Unit 8	5.12	14.40	244	150
Total	13.76	42.95		
Chandrapur				
Unit 3	3.85	11.39	167	150
Unit 4	3.90	11.56	167	144
Unit 5	7.72	22.99	425	170
Unit 6	5.12	22.23	225	195
Unit 7	9.38	28.18	404	352
Unit 8	10.36	31.62	455	409
Unit 9	0.00	21.70	0	0
Total	40.33	149.66		
Paras				
Unit 3	4.11	10.59	222	0
Unit 4	0.52	1.10	185	0
Total	4.63	11.69		
Khaparkheda				
Unit 1	3.64	11.12	165	125
Unit 2	4.69	13.61	204	175
Unit 3	0.00	4.10	0	0
Unit 4	4.42	13.04	196	168
Unit 5	10.72	32.98	455	430
Total	23.47	74.84		
Nasik				
Unit 3	3.27	9.64	161	0
Unit 4	3.44	10.02	148	137
Unit 5	3.19	10.01	152	113
Total	9.90	29.66		
Uran				
All Units	7.65	21.72	380	280
Total	7.65	21.72		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	4.24	13.86	500	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	7.35	20.54	1000	0
Stage 3	2.92	7.83	320	0
Total	14.52	42.23		
Hydro				
KDPH	0.47	1.45	20	20
VTRNA	0.42	1.25	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.71	4.66	75	66
GHATGHAR	0.80	1.04	125	0
Total	3.40	8.40		
Wind				
Total	19.88	67.56	0	0
Total	19.88	67.56		
CPP				
APML(Mus)	73.91	213.11	0	0
JSWEL(Mus)	28.06	83.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.40	76.53	0	0
SWPGPL-Mus	12.45	36.01	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.08	18.20	268	232
Other(Mus)	5.26	16.10	0	0
JPL	4.66	13.54	270	129
Total	155.81	456.78		
SOLAR				
Total	16.18	49.68	0	0
Total	16.18	49.68		
Tata				
Trombay 5	9.16	26.18	455	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	7.78	108	108
Trombay 7B	1.54	4.61	64	64
TATA Hydro	7.04	16.13	439	81
Trombay 8	4.75	13.55	227	130
Total	25.07	68.25		
AEML				
DTPS U-1&2	11.50	33.84	505	312
Total	11.50	33.84		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.93	485.43	MSPGCL Total	183.50	557.78
			MSPGCL Thml+Gas	165.58	507.16	Koyna 1,2 & 4 Total	11.60	34.40
			MSPGCL Hydro	17.92	50.63	State Total	411.93	1233.89

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 03/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6406	1942	286	8634	1018	6790	0	0	8201	7853	-1793	22057	675	0	22732	3466	445	26642	50.02
2	6442	1570	286	8298	870	6794	0	0	8691	8374	-1633	22279	64	0	22343	3261	424	26028	50.03
3	6535	1192	287	8014	817	6748	0	0	8957	8647	-1670	22151	0	0	22151	3055	404	25610	50.03
4	6552	236	288	7076	870	6626	0	0	9686	8868	-1683	21360	0	0	21360	2913	397	24670	50.03
5	6336	126	289	6750	970	6538	0	0	9854	9186	-1629	21404	0	0	21404	2840	411	24656	49.96
6	6412	126	290	6828	1085	6649	0	0	10107	9821	-1640	22311	0	2	22311	2822	432	25566	49.91
7	6423	420	287	7130	960	6412	0	131	9561	9079	-1683	21565	0	14	21565	2782	463	24811	49.93
8	6725	448	288	7462	867	6506	0	521	8581	8355	-1843	21382	0	10	21382	2901	485	24768	49.99
9	6584	320	290	7194	816	6093	0	997	9211	9270	-2225	21620	0	1	21620	3216	525	25361	49.99
10	6661	360	285	7306	568	6195	0	1562	9670	9259	-2221	22136	0	147	22136	3581	532	26249	50.01
11	6518	358	283	7160	367	5858	0	2025	10340	9661	-2310	22237	0	454	22237	3840	523	26600	49.98
12	6560	464	283	7308	296	5263	0	2290	10680	10364	-2214	22777	0	537	22777	3980	529	27286	49.97
13	6668	454	283	7406	237	5832	0	2209	10009	9581	-2323	22413	0	419	22413	3992	529	26934	49.94
14	6651	584	280	7516	284	6310	0	2126	9845	9733	-2348	23083	0	1	23083	3967	538	27588	50.01
15	6655	480	298	7432	406	6653	0	1671	10381	10152	-2320	23464	0	93	23464	4090	530	28084	50.03
16	6713	482	371	7566	662	6704	0	1335	10663	10271	-2388	23613	0	12	23613	4161	536	28310	50.00
17	6658	580	370	7608	491	6688	0	883	10281	10216	-2338	22995	0	4	22995	4072	554	27621	50.01
18	6661	562	368	7592	756	6726	0	384	10334	9676	-2262	22319	0	0	22319	3880	553	26752	50.02
19	6594	376	360	7330	1105	6688	0	52	9715	9047	-2114	21545	0	0	21545	3656	563	25764	50.07
20	6680	1232	373	8286	1342	6777	0	0	8413	8055	-1901	21991	0	0	21991	3579	568	26138	50.04
21	6762	1328	374	8464	1456	6751	0	0	7763	7505	-1748	21887	0	0	21887	3516	541	25944	49.99
22	6671	1000	377	8048	1498	6746	0	0	7648	7334	-1761	21335	0	0	21335	3511	530	25376	49.99
23	6507	1508	380	8394	1155	6729	0	0	7501	7654	-1844	21593	0	0	21593	3599	495	25688	50.03
24	6552	1772	378	8702	980	6731	0	0	7640	7762	-1918	21772	507	0	22279	3695	485	26458	50.03
MUs	157.93	17.92	7.65	183.50	19.88	155.81	0.00	16.19	223.73	215.72	-47.81	531.29	1.25	1.69	532.54	84.38	11.99	628.90	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) Due to system under voltage (372KV) at 400KV Lonikand - 400KV Jejuri line, Due to overloading of 132KV NCL - Kothrud line, due to overloading of 220KV/22KV 50MVA TF No.1. 2) 132KV BBLR to Rahuri line overload. 3) DLS done due to low voltage & overloading of ICT and PGCIL (Solapur) - Jeur line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Jun/2024

Position as on 6.30 Hrs of 04/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Paras Unit 4	250	01/06/2024	02:27	03/06/2024	19:36	Drum level low	04/06/2024
MSPGCL	Khaparkheda Unit 3	210	02/06/2024	03:05	04/06/2024	03:23	Boiler Tube Leakage	04/06/2024
MSPGCL	Paras Unit 3	250	02/06/2024	06:16	03/06/2024	02:23	Valve malfunction operate.	
MSPGCL	Chandrapur Unit 9	500	02/06/2024	22:52		Continued.	Condenser Vacuum low	04/06/2024
MSPGCL	Bhusawal Unit 3	210	03/06/2024	00:30		Continued.	Boiler tube leakage (On tolling).	05/06/2024
MSPGCL	Parli Unit 7	250	03/06/2024	22:36		Continued.	Boiler Tube Leakage	
Total Capacity MSPGCL		1915						
IPP								
IPP	RPL(AMT) U-4	270	28/05/2024	18:57		Continued.	Due to ID Fan tripped on high vibration..	28/06/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2505						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	02/06/2024	02:00	03/06/2024	14:44	Due to Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	04/06/2024	02:00		Continued.	As MSEDCL requirement	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Jun/2024

Position as on 6.30 Hrs of 04/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 04/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
500 KV TBC Outages/Trippings							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	04/06/2024	06:24			T	Unbalanced level 2 Protection
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
220 KV PARLI (400 KV)- GIRWALI I/C -2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
220 KV KHADKA (400 KV) - CHALISGAON CKT -3	IntraState	03/06/2024	08:31	03/06/2024	13:35	PO	For restringing of conductor.
BABHALESHWAR - PADGHE CKT - 2	IntraState	03/06/2024	17:44			T	Tripped on distance protection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	20:19	03/06/2024	22:58	T	Differential Protection
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	03/06/2024	20:19	03/06/2024	22:50	T	Differential Protection
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	03/06/2024	20:24	03/06/2024	23:10	T	NDR protection
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34	03/06/2024	19:48	PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay
132 kv GHATODI ARNI	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104) .
132 KV GHATODI (220 KV) - DIGRAS CKT	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104).
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
GORAI -MSETCL BORIVALI CKT -1	IntraState	28/05/2024	17:59	04/06/2024	01:13	T	Bus fault
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 04/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAMBA - VASAI	IntraState	02/06/2024	04:39	03/06/2024	01:17		1) Cut point formation over newly erected monopole & work will be carried out at loc no 4 9 and also related de-stringing & stringing work will be carried out. 2) Dismantling of old existing tower no. 53 & 54. 3) After cut point formation & conductor stringing work kamba-Vasai line will be charged at 22:00 Hrs of 02.06.2024.
KAMBA - VASAI	IntraState	02/06/2024	04:39	03/06/2024	01:17		Work of replacement of old C&R panel by new and diagnostic testing work
KAMBA - VASAI	IntraState	02/06/2024	04:39	03/06/2024	01:17	PO	work 1) Cut point formation over newly erected Monopole work will be carry out at loc.no.48,49 and amp;49A on 220kV Kamba-Vasai line and also related tower 65533;s conductor destringing & stringing work will be carry out of above said ckt. 2) Dismantaling work of old existing tower at Loc.No.48 & amp;49
BHUGAON - WARDHA (PG)	IntraState	02/06/2024	23:10	03/06/2024	00:10	HT	H/T due to State OD at Low frequency.
PALGHAR - NALASOPARA	IntraState	03/06/2024	04:27	03/06/2024	08:30	PO	Replacement of Insulator String Identified in PID.
KHADKI- CENTURY ENKA	IntraState	03/06/2024	07:08	03/06/2024	16:28	PO	Stringing of conductor from loc 30-30A and stringing of earthwire loc 29A-30 river crossing.
220 KV DHULE(400 KV) - AMALNER	IntraState	03/06/2024	07:37	03/06/2024	08:47	PO	For replacement flash over string.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	03/06/2024	08:46	03/06/2024	13:29	PO	Routine maintenance
MAIN BUS @ ONI	IntraState	03/06/2024	09:36	03/06/2024	18:08	PO	1) For changing Line CT Ratio of 220 kV Oni-Kharepatan Line at both end S/s 2) Replacement of 220kV PT Y Phase of 220 kV Main Bus
HALKARNI-OLAM AGRO (HEMRUS) LINE	IntraState	03/06/2024	09:42	03/06/2024	14:02	PO	QM work of Olam bay
TALANDGE - SAWANTWADI	IntraState	03/06/2024	10:50	03/06/2024	14:56	PO	Insulator replacement work
CHIKHALI-JALNA I	IntraState	03/06/2024	12:24	03/06/2024	17:54	PO	For replacement of damage earth wire span.
CHIKHALI-JALNA II	IntraState	03/06/2024	12:25	03/06/2024	17:54	PO	For replacement of damage earth wire span.
MHAISAL - ALKUD	IntraState	03/06/2024	17:24	04/06/2024	02:06	PO	Wedge Connector Work
WAGHIVALI - DHARAVI 7	IntraState	04/06/2024	01:25			PO	Resagging of conductor at S G Barve Metro - 2B crossing
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	04/06/2024	01:42			PO	Resagging of conductor at S G Barve Metro - 2B crossing
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220 KV /132 KV 100 MVA ICT 1 @ CHITEGAON	IntraState	03/06/2024	08:15	03/06/2024	09:45	PO	Hot spot is observe on R-ph lv side bushing.
220/33 KV 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	03/06/2024	09:24	03/06/2024	16:28	PO	Quarterly maint. work
100 MVA 220/132 KV ICT II	IntraState	03/06/2024	09:35	03/06/2024	14:02	PO	Tan delta testing of ict will be carried out by mobile testing unit, Akola.
220/110 KV ICT - 1 @ BHIRA	IntraState	03/06/2024	09:40	03/06/2024	12:08	PO	PM CHECKS

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 04/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33kV 50MVA TF-3 @ 5 STAR MIDC	IntraState	03/06/2024	10:34	03/06/2024	13:30	PO	for pre monsoon maintenance work
200 MVA 220/132 KV ICT 1 @ GIRWALI	IntraState	03/06/2024	11:36	03/06/2024	13:34	PO	Current mismatch and consumption mismatch observed during reading.
220/33KV 50MVA PTR 3	IntraState	03/06/2024	11:44	03/06/2024	14:21	PO	Pre-monsoon maintenance work.
220/110 KV ICT - 2 @ BHIRA	IntraState	03/06/2024	14:15	03/06/2024	15:33	PO	PM CHECKS
200 MVA 220/132 KV ICT 2 @ GIRWALI	IntraState	03/06/2024	14:44	03/06/2024	17:14	PO	To check CT cables.
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage