

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 03/Oct/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	133.383	391.304	1) Gujrat	2.842	24.688
2) Hydro	9.621	17.998	2) Madhya Pradesh	2.346	7.600
3) Gas	3.707	16.653	3) Chattisgarh	5.100	15.410
Total MSPGCL	146.711	425.955	4) Maharashtra	124.185	369.522
B) 1) APMIL	58.190	163.649	5) Goa (Amona)	-1.512	-4.144
2) JSWEL	24.506	69.761	Total	132.961	413.076
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.315	64.212
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	25.818	80.517
5) WPCL	2.700	8.081	c) MSEDCL Bilateral *	33.950	94.778
6) Other IPP	9.379	25.938	Include PX	4.430	14.195
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.315	64.212
C) 1) TPCL Thermal	8.640	23.757	Include PX	5.352	21.873
2) TPCL Hydro	2.815	8.913	Standby	0.000	0.000
3) TPCL Gas	4.375	13.139	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.652	28.997	1) MSEDCL	367.733	1079.378
D) STATE			2) Mumbai Discoms	52.300	155.322
1) Thermal	247.450	711.487	TOTAL STATE	420.033	1234.700
(A1+C1+C4+(B1-B6))					
2) Hydro	12.436	26.911			
(A2+C2)					
3) Gas	8.082	29.792			
(A3+B7+C3)					
4) Wind	12.119	34.192			
6) SOLAR	6.985	19.243			
TOTAL STATE	287.072	821.625			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5814	5786	5594	5361
MSPGCL Hydro	214	286	1116	80
MSPGCL Gas	140	130	140	140
MSPGCL Total Generation	6168	6202	6850	5581
Central Sector Receipt	6442	6205	4961	4673
WIND	221	252	1062	522
CPP / IPP Thermal	4219	4176	4168	3323
CPP / IPP Gas	0	0	0	0
SOLAR	917	985	0	0
Exchange with Mumbai	-1363	-1418	-736	-913
MSEDCL DEMAND MET	16604	16402	16306	13186
Load Shedding	0	0	0	0
MSEDCL DEMAND	16604	16402	16306	13186
TPCL GENERATION	653	676	1033	489
AEML GENERATION	501	486	502	372
MUMBAI DEMAND	2517	2580	2271	1774
STATE DEMAND MET	19121	18982	18576	14960
STATE DEMAND	19121	18982	18576	14960
Frequency (Hz)	50.02	49.98	50.03	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 22.00 Hrs	49.84 Hz at 05.09 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 03/Oct/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.45	32.16	595	418
Unit 9	10.45	32.31	490	380
Unit 10	8.88	27.26	405	340
Total	31.78	91.73		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.14	29.20	465	360
Unit 5	10.24	29.18	485	360
Total	20.38	58.38		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	2.16	0	0
Unit 4	3.67	10.76	160	132
Unit 5	10.16	30.02	430	404
Unit 6	10.01	29.10	428	375
Unit 7	0.00	0.00	0	0
Unit 8	10.72	31.66	460	430
Unit 9	10.64	31.88	460	418
Total	45.20	135.58		
Paras				
Unit 3	5.43	15.20	250	140
Unit 4	5.64	15.47	253	115
Total	11.07	30.67		
Khaparkheda				
Unit 1	3.49	10.49	160	130
Unit 2	3.98	12.08	170	155
Unit 3	3.52	11.01	155	135
Unit 4	3.69	11.20	170	140
Unit 5	10.28	30.17	475	365
Total	24.95	74.94		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	3.71	16.65	279	130
Total	3.71	16.65		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.63	2.26	54	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.63	2.26		
Koyna				
Stage 1-2	4.34	8.00	530	40
Stage 4	1.29	1.77	535	0
Stage 3	1.32	2.53	240	0
Total	6.95	12.31		
Hydro				
KDPH	0.65	0.77	37	0
VTRNA	0.25	0.25	60	0
TILLARI	0.75	1.81	58	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.35	0.92	40	0
RNGR+BHTSA	0.14	0.14	13	0
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.54	1.62	23	22
SMLHY_PTN	0.00	0.17	0	0
GHATGHAR	0.00	0.01	0	0
Total	2.67	5.69		
Wind				
Total	12.12	34.19	0	0
Total	12.12	34.19		
CPP				
APML(Mus)	58.19	163.65	0	0
JSWEL(Mus)	24.51	69.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.70	8.08	0	0
Other(Mus)	9.38	25.94	0	0
Total	94.78	267.43		
SOLAR				
Total	6.98	19.24	0	0
Total	6.98	19.24		
Tata				
Trombay 5	8.64	23.76	417	300
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.80	8.41	118	116
Trombay 7B	1.57	4.73	66	64
Trombay 8	0.00	0.00	0	0
TATA Hydro	2.82	8.91	446	2
Total	15.83	45.81		
AEML				
DTPS U-1&2	10.65	29.00	502	371
Total	10.65	29.00		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	133.38	391.30	MSPGCL Total	146.71	425.96
			MSPGCL Thml+Gas	137.09	407.96	Koyna 1,2 & 4 Total	5.63	9.78
			MSPGCL Hydro	9.62	18.00	State Total	287.07	821.62

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 03/Oct/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5409	92	189	5690	684	3387	0	0	5058	5077	-1240	13598	0	13598	2104	15702	50.03
2	5382	80	140	5602	685	3332	0	0	4933	4933	-1105	13448	0	13448	1968	15416	50.00
3	5262	96	140	5498	516	3329	0	0	4829	4989	-992	13340	0	13340	1854	15194	50.00
4	5361	80	140	5581	522	3323	0	0	4766	4673	-913	13186	0	13186	1774	14960	50.01
5	5502	110	150	5762	578	3633	0	0	4830	4845	-880	13938	0	13938	1739	15677	50.01
6	5626	99	130	5855	476	3905	0	0	5317	5325	-889	14672	0	14672	1755	16427	49.97
7	5666	294	140	6100	437	3964	0	26	5867	5946	-732	15741	0	15741	1782	17523	49.99
8	5640	262	140	6042	316	4014	0	227	6367	6545	-782	16362	0	16362	1863	18225	50.01
9	5570	404	130	6104	190	4050	0	510	6328	6617	-963	16508	0	16508	2063	18571	50.01
10	5639	214	130	5983	238	4063	0	740	6412	6374	-1188	16210	0	16210	2312	18522	50.01
11	5814	214	140	6168	221	4219	0	917	6396	6442	-1363	16604	0	16604	2517	19121	50.02
12	5782	250	130	6162	199	4198	0	989	6265	6345	-1402	16491	0	16491	2592	19083	50.01
13	5786	286	130	6202	252	4176	0	985	6199	6205	-1418	16402	0	16402	2580	18982	49.98
14	5577	220	140	5937	211	4192	0	899	6127	6210	-1529	15920	0	15920	2483	18403	50.00
15	5502	652	130	6284	224	4205	0	747	5997	6260	-1373	16347	0	16347	2514	18861	49.94
16	5620	722	130	6472	268	4193	0	543	5986	6012	-1329	16159	0	16159	2506	18665	49.96
17	5612	881	130	6623	399	4158	0	327	5728	5579	-1167	15919	0	15919	2448	18367	49.98
18	5613	988	140	6741	656	4159	0	75	5407	5399	-1055	15975	0	15975	2394	18369	50.01
19	5648	1112	140	6900	858	4146	0	0	5152	5046	-918	16032	0	16032	2411	18444	50.00
20	5594	1116	140	6850	1062	4168	0	0	4890	4961	-736	16306	0	16306	2271	18576	50.03
21	5572	452	152	6176	969	4086	0	0	4709	4514	-719	15026	0	15026	2173	17200	50.02
22	5437	367	219	6023	817	3987	0	0	4567	4757	-856	14728	0	14728	2103	16831	50.03
23	5386	295	278	5959	721	3945	0	0	4681	5167	-1110	14682	0	14682	2061	16743	50.03
24	5383	334	279	5996	620	3943	0	0	4642	4740	-1159	14140	0	14140	2033	16173	50.01
MUs	133.38	9.62	3.71	146.71	12.12	94.78	0.00	6.99	131.45	132.96	-25.82	367.73	0.00	367.73	52.30	420.03	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Oct/2020

Position as on 6.30 Hrs of 04/Oct/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CPP	SWPGL U-3	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
CPP	SWPGL U-4	135	12/08/2020	00.45		Continued.	Zero Schedule by MSEDCL	
IPP	Adani U-2	660	01/09/2020	19.41		Continued.	Air pre-heater PA Bellow leakage.	
MSPGCL	Parli Unit 6	250	11/09/2020	23.55		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	14/09/2020	00.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	14/09/2020	20.45		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 7	500	29/09/2020	01.58		Continued.	Tripped On Generator Protection.	
MSPGCL	Ghatghar Unit-1	125	30/09/2020	18.05		Continued.	Turbine Guide Bearing problem	
MSPGCL	Chandrapur Unit 3	210	01/10/2020	16.00		Continued.	Main turbine bearing problem.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Oct/2020

Position as on 6.30 Hrs of 04/Oct/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	03/10/2020	00.29	03/10/2020	20.07	Filter Replacement work	
MSPGCL	Chandrapur Unit 4	210	04/10/2020	05.00		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 04/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa II	InterState	23/09/2020	17.54		Continued.	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	03/10/2020	02.25	03/10/2020	10.16	T	DT Received Y phase Tripped
Dhule Sar'Sarovar I	InterState	03/10/2020	16.30		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	16/09/2020	23.34		Continued.	HT	Over Voltage (Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Jaigad-Karad Ckt-I	IntraState	27/09/2020	18.59		Continued.	T	Distance Protection(Tower Collapsed Loc No.150 at 18.59Hrs DT.27/09/2020).
Padghe - Nagothane - II	IntraState	29/09/2020	20.38	03/10/2020	10.45	HT	Over Voltage
Bus Coupler @ Kharghar	IntraState	02/10/2020	11.24	04/10/2020	19.06	PO	1)For replacement of quadruple bus conductor span between 400kv Talegaon & Kalwa line of 400kv 'A' Bus.
Khadka-Aurangabad (Waluj)	IntraState	02/10/2020	18.06	03/10/2020	08.29	HT	Over Voltage
Dhule- Bableshwar - I	IntraState	02/10/2020	19.57	03/10/2020	08.58	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/10/2020	01.02	03/10/2020	09.45	HT	Over Voltage
Akola - Bhusawal	IntraState	03/10/2020	08.41	03/10/2020	19.31	PO	Testing Work
Ektuni-Bableshwar ckt II	IntraState	03/10/2020	10.12	03/10/2020	19.48	PO	Quarterly Maintenance Work
Lonikand 1 - Chakan	IntraState	03/10/2020	12.16	03/10/2020	16.17	T	Distance Protection
Babhaleshwar - Padghe-II	IntraState	03/10/2020	16.03	03/10/2020	19.40	T	Distance Protection
Taptitanda Waluj	IntraState	03/10/2020	16.34	03/10/2020	22.09	EO	B Phase one Disc Insulator String Burst of the DSN
Dhule- Bableshwar - I	IntraState	03/10/2020	19.53		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	03/10/2020	22.16	04/10/2020	09.37	HT	Over Voltage
Kharghar-Talegaon(PG)	IntraState	04/10/2020	10.08	04/10/2020	16.24	EO	Replacement of damaged bus conductor.
Khadka-Aurangabad (Waluj)	IntraState	04/10/2020	16.22		Continued.	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt-II	IntraState	04/10/2020	17.54		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/09/2020	09.58		Continued.	PO	Replacement of Existing 315 MVA ICT by 3*167 MVA ICT.
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	23/09/2020	09.12		Continued.	PO	Augmentation work of 400/220 315MVA ICT-II to 501MVA
400/220/33 Kv 315 Mva ICT 2 @Padghe	IntraState	03/10/2020	14.46	03/10/2020	16.02	PO	Jumper Replacement work
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
PARLY (PG) - OSMANABAD	InterState	03/10/2020	11.57	03/10/2020	12.47	PO	Vibration Damper fixing work
Borivali(MS) Boisar(PG)	InterState	03/10/2020	12.10	03/10/2020	12.33	EO	To attend Hot Spot
Theur-Phursungi	IntraState	14/08/2020	09.46		Continued.	HT	Outage Arrangement HTLS Work.
Theur- Magar Patta City	IntraState	14/08/2020	10.27		Continued.	HT	Outage Arrangement HTLS Work.
Parli 3 (Old Gcr)-Girwali Ckt-3	IntraState	20/08/2020	13.05		Continued.	PO	Erection of Tower Due to Railway Crossing
Parli 3(Old Gcr)- Girwali Ckt 4	IntraState	20/08/2020	13.06		Continued.	PO	Erection of Tower Due to Railway Crossing
Lonikand1 (400 Kv)-Theur I	IntraState	03/10/2020	07.58	03/10/2020	19.44	PO	Twin stub Bus stringing for 220KV Lonikand1 Bay

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Oct/2020

Statement-VII

Position as on 6.30 Hrs of 04/Oct/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	03/10/2020	08.58	03/10/2020	16.16	PO	Insulator Replacement Work
220kv Halkarni- Tillary	IntraState	03/10/2020	09.07	03/10/2020	17.00	PO	Insulator cleaning
Chandrapur(MIDC)-Ballarshah II	IntraState	03/10/2020	10.10	03/10/2020	18.52	PO	Rectification work of 220KV M/C Tower
BOISAR BORIVALI	IntraState	03/10/2020	11.28	03/10/2020	12.32	HT	Load Management
Boisar Versova Line	IntraState	03/10/2020	11.50	03/10/2020	12.24	HT	Load Management
Kalmeshwar-Kalmeshwar Rly Tss 1	IntraState	03/10/2020	11.58	03/10/2020	15.03	PO	Making CT&PT connection for Meters of AMR project
Boisar II - Boisar PG II	IntraState	03/10/2020	12.10	03/10/2020	18.12	EO	To attend Hot Spot
Uran - Ongc Uran	IntraState	03/10/2020	12.17	03/10/2020	19.47	PO	Replacement of damaged jumper
Nanded-Parbhani	IntraState	03/10/2020	13.51	03/10/2020	14.16	EO	B Phase Line Isolator sparking in Jaw
Kalmeshwar-Kalmeshwar Rly Tss 2	IntraState	03/10/2020	15.42	03/10/2020	17.34	PO	AMR Project work
Uran - Apta II	IntraState	03/10/2020	18.20	03/10/2020	19.12	T	Distance Protection
Uran - Kharghar 2	IntraState	03/10/2020	18.25	03/10/2020	18.42	T	Distance Protection
220 KV ICT Outages/Trippings							
220/33 KV 100MVA T/F-II @ Gangapur	IntraState	03/10/2020	01.56	03/10/2020	03.39	T	R phase LA Burst
220/132kv 100 Mva Imp Ict 1 @Limbala Midc Hingoli	IntraState	03/10/2020	10.36	03/10/2020	18.21	PO	Measurment of Tan Delta and SFRA of ICT
200 MVA 220/132 KV ICT - 2 @VIRODA	IntraState	03/10/2020	12.07	03/10/2020	14.21	PO	To collect OLTC Oil sample
220/132KV 100MVA ICT-I@ Kathapur	IntraState	03/10/2020	13.16	03/10/2020	18.27	PO	Testing Work
200 MVA 220/132 KV ICT - 1 @VIRODA	IntraState	03/10/2020	14.36	03/10/2020	16.43	PO	To collect OLTC Oil sample
220/33kv 100 MVA Transformer 3 @Versova R/S	IntraState	03/10/2020	15.51	03/10/2020	17.05	EO	Emergency work to Remove wire from LA
220/132 Kv 200 Mva Vijai Ict 1 @Ranjangaon	IntraState	04/10/2020	17.18	04/10/2020	21.07	T	To attend hot spot on bushing.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage