

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 03/Oct/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	125.620	376.823	1) Gujrat	9.386	28.010
2) Hydro	9.711	21.888	2) Madhya Pradesh	4.634	11.368
3) Gas	2.112	6.301	3) Chattisgarh	5.240	13.210
Total MSPGCL	137.443	405.012	4) Maharashtra	181.229	496.600
B) 1) APLM	44.521	150.387	5) Goa (Amona)	-1.294	-3.655
2) JSWEL	18.161	52.880	Total	199.195	545.533
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.772	97.158
4) RPL(AMT)	25.509	73.559	b) Mumbai Drawl	39.462	103.330
5) SWPGPL	7.946	23.032	c) MSEDCL Bilateral *	76.019	219.637
6) Other IPP	6.690	16.742	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.765	97.152
C) 1) TPCL Thermal	10.889	33.088	Include PX	0.000	0.000
2) TPCL Hydro	3.635	9.298	Standby	0.007	0.007
3) TPCL Gas	2.144	6.974	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.764	27.543	1) MSEDCL	417.730	1220.670
D) STATE			2) Mumbai Discoms	64.894	180.209
1) Thermal	248.100	754.054	3) Other Discoms	9.541	27.958
(A1+C1+C4+(B1-B6))			TOTAL STATE	492.165	1428.837
2) Hydro	13.346	31.186			
(A2+C2)					
3) Gas	4.256	13.275			
(A3+B7+C3)					
4) Wind	14.843	47.770			
6) SOLAR	12.425	37.043			
TOTAL STATE	292.970	883.328			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5045	5238	5281	5183
MSPGCL Hydro	537	220	1769	127
MSPGCL Gas	88	81	88	91
MSPGCL Total Generation	5670	5539	7138	5401
Central Sector Receipt	9155	9711	8178	6486
WIND	389	488	603	872
CPP / IPP Thermal	3887	3862	4664	4347
CPP / IPP Gas	0	0	0	0
SOLAR	1695	1271	0	0
Exchange with Mumbai	-2044	-2243	-1422	-1154
MSEDCL DEMAND MET	18324	18191	18722	15657
Load Shedding	0	0	0	0
MSEDCL DEMAND	18324	18191	18722	15657
TPCL GENERATION	739	577	1090	518
AEML GENERATION	468	318	498	292
MUMBAI DEMAND	3251	3138	3010	1964
OTHER DISCOM DEMAND	428	437	439	295
STATE DEMAND MET	22003	21766	22171	17916
STATE DEMAND	22003	21766	22171	17916
Frequency (Hz)	50.03	49.99	50.01	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 06:01 Hrs	49.89 Hz at 15:50 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 03/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.65	30.96	470	380
Unit 9	1.04	20.55	395	0
Unit 10	10.64	30.58	490	420
Total	22.33	82.09		
Bhusawal				
Unit 3	2.03	7.20	140	0
Unit 4	8.97	24.08	415	340
Unit 5	9.97	26.40	450	370
Total	20.97	57.69		
Parli				
Unit 6	3.46	11.06	187	107
Unit 7	4.27	12.04	202	144
Unit 8	3.49	10.11	156	132
Total	11.22	33.21		
Chandrapur				
Unit 3	2.96	8.53	130	110
Unit 4	3.36	9.43	160	117
Unit 5	6.90	20.66	319	270
Unit 6	7.86	22.01	400	275
Unit 7	7.58	22.67	340	280
Unit 8	0.00	0.00	0	0
Unit 9	8.90	25.28	428	307
Total	37.57	108.58		
Paras				
Unit 3	5.22	14.46	230	200
Unit 4	0.00	0.00	0	0
Total	5.22	14.46		
Khaparkheda				
Unit 1	2.74	8.58	140	95
Unit 2	3.26	8.70	150	115
Unit 3	4.05	10.65	191	127
Unit 4	3.04	9.28	140	117
Unit 5	8.69	24.71	405	275
Total	21.78	61.90		
Nasik				
Unit 3	3.34	9.76	158	127
Unit 4	3.20	9.13	154	116
Unit 5	0.00	0.00	0	0
Total	6.54	18.89		
Uran				
All Units	2.11	6.30	95	81
Total	2.11	6.30		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	1.78	26	25
Total	0.60	1.78		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.70	6.10	465	35
Stage 4	2.55	3.84	807	0
Stage 3	1.16	2.48	240	0
Total	6.41	12.43		
Hydro				
KDPH	0.29	0.29	18	0
VTRNA	0.38	1.82	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.23	0.77	77	0
SMLHY_PTN	1.51	4.51	67	58
GHATGHAR	0.28	0.28	125	0
Total	2.70	7.68		
Wind				
Total	14.84	47.77	0	0
Total	14.84	47.77		
CPP				
APML(Mus)	44.52	150.39	0	0
JSWEL(Mus)	18.16	52.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.51	73.56	0	0
SWPGPL-Mus	7.95	23.03	0	0
Other(Mus)	6.69	16.74	0	0
Total	102.83	316.60		
SOLAR				
Total	12.42	37.04	0	0
Total	12.42	37.04		
Tata				
Trombay 5	7.31	22.39	449	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.16	3.84	62	40
Trombay 7B	0.98	3.13	50	35
TATA Hydro	3.64	9.30	390	8
Trombay 8	3.58	10.70	215	130
Total	16.67	49.36		
AEML				
DTPS U-1&2	8.76	27.54	498	285
Total	8.76	27.54		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	125.62	376.82	MSPGCL Total	137.44	405.01
			MSPGCL Thml+Gas	127.73	383.12	Koyna 1,2 & 4 Total	5.25	9.95
			MSPGCL Hydro	9.71	21.89	State Total	292.97	883.33

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 03/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5503	121	90	5714	714	4305	0	0	6864	6885	-1484	15791	0	15791	2371	343	18505	49.97
2	5392	123	91	5606	744	4293	0	0	6658	6556	-1336	15540	0	15540	2186	323	18049	49.94
3	5201	121	90	5412	852	4323	0	0	6481	6580	-1230	15627	0	15627	2056	310	17993	49.99
4	5183	127	91	5401	872	4347	0	0	6425	6486	-1154	15657	0	15657	1964	295	17916	49.95
5	5325	188	90	5603	832	4420	0	0	6629	6979	-1127	16379	0	16379	1942	328	18649	49.98
6	5301	312	91	5704	786	4558	0	0	7467	7621	-1179	17124	0	17124	2054	366	19544	50.00
7	5354	133	91	5578	805	4757	0	81	8762	8741	-1265	18302	0	18302	2190	395	20887	50.01
8	5356	188	90	5634	628	4464	0	474	8906	8814	-1512	18104	0	18104	2383	398	20885	49.99
9	4925	183	95	5203	599	4206	0	1039	9415	9174	-1817	17984	0	17984	2733	420	21137	50.04
10	4796	308	87	5191	458	3869	0	1438	8964	9260	-1881	17901	0	17901	3055	434	21390	50.03
11	5045	537	88	5670	389	3887	0	1695	8878	9155	-2044	18324	0	18324	3251	428	22003	50.03
12	5168	232	84	5484	401	4038	0	1695	9089	8971	-2102	18055	0	18055	3281	432	21768	49.98
13	5051	239	83	5373	335	3709	0	1633	9078	9297	-2042	17883	0	17883	3225	422	21530	50.00
14	5153	205	83	5441	417	3785	0	1484	9073	9183	-2169	17734	0	17734	3080	407	21221	50.04
15	5238	220	81	5539	488	3862	0	1271	9628	9711	-2243	18191	0	18191	3138	437	21766	49.99
16	5270	204	82	5556	446	4252	0	931	9517	9478	-2245	17984	0	17984	3175	434	21593	50.01
17	5360	165	86	5611	479	4389	0	546	9211	9187	-2090	17695	0	17695	3128	427	21250	49.96
18	5300	781	86	6167	544	4413	0	137	8604	8603	-1915	17516	0	17516	3065	433	21014	49.99
19	5288	1640	87	7015	500	4556	0	1	8061	8437	-1690	18374	0	18374	3057	445	21876	49.98
20	5281	1769	88	7138	603	4664	0	0	7544	8178	-1422	18722	0	18722	3010	439	22171	50.01
21	5330	951	89	6370	580	4395	0	0	8323	8257	-1372	17797	0	17797	2826	433	21056	50.02
22	5306	371	89	5766	761	4403	0	0	8216	8179	-1452	17249	0	17249	2664	408	20321	49.98
23	5254	345	90	5689	816	4429	0	0	7782	7911	-1423	17032	0	17032	2559	390	19981	49.99
24	5240	250	90	5580	794	4503	0	0	7632	7550	-1268	16766	0	16766	2501	393	19660	50.02
MUs	125.62	9.71	2.11	137.44	14.84	102.83	0.00	12.42	197.21	199.19	-39.46	417.73	0.00	417.73	64.89	9.54	492.16	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Oct/2022

Position as on 6.30 Hrs of 04/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	22/10/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20	04/10/2022	09:05	Generator winding differential protection	03/10/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	10/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	06/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/10/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44	04/10/2022	19:39	Bottom Ash Evacuation problem (Coal Shortage) w.e.f 1.10.2022.	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	29/09/2022	21:00		Continued.	Seal Trough Leakage(converted to Critical Coal Stock w.e.f.21.00 Hrs Dt.30-09-	
IPP	Adani U-5	660	01/10/2022	14:38	04/10/2022	15:13	APH-A hot PA below Leakage	04/10/2022
MSPGCL	Koradi Unit 9	660	03/10/2022	03:12		Continued.	Boiler Tube Leakage	08/10/2022
IPP	Adani U-2	660	03/10/2022	06:56		Continued.	Air heater problem	07/10/2022
IPP	IEPL Unit 1	270	03/10/2022	11:57	03/10/2022	17:54	Drum Level High	
TPC-G	Bhira PSU	150	03/10/2022	16:42	03/10/2022	19:12	Turbine bearing Vibration	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Oct/2022

Position as on 6.30 Hrs of 04/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 3	210	03/10/2022	17:51		Continued.	Boiler Tube Leakage	08/10/2022
MSPGCL	Koyna STG-IV Unit-1	250	03/10/2022	18:24	03/10/2022	19:48	Shaft Seal water Circulation Lost.	
IPP	SWPGPL U-2	135	04/10/2022	11:17		Continued.	Ash Conveyer problem	08/10/2022
IPP	Adani U-4	660	04/10/2022	12:05		Continued.	due to APH-A hot PA bellow leakage.	
IPP	RPL(AMT) U-1	270	04/10/2022	12:42		Continued.	botttom ash problem	
IPP	RPL(AMT) U-4	270	04/10/2022	22:00		Continued.	CW tube leakage.	07/10/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 03/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 04/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY - 404 OF 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	04/10/2022	09:26	04/10/2022	18:12	PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - AURANGABAD(PG) CKT -1	InterState	04/10/2022	10:58	04/10/2022	16:53	PO	For 403 Bay AMP at Waluj
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	03/10/2022	06:26	03/10/2022	18:27	PO	Replacement of Disc Insulator Strings by Long Rod Porcelain strings
MAIN BUS - 2 @ KORADI 2	IntraState	03/10/2022	09:40	03/10/2022	11:30	EO	"1)Jumper (Rph) connected between 400KV Main Bus-II & Jack Bus provided for GT#10 Tie Bay 402(image attached) 2)Isolator 402-89A (rph & Yph) at bay 402 (Bay 4 needs to be tripped)"
GT-10 @ KORADI-2	IntraState	03/10/2022	11:57	03/10/2022	22:08	EO	1) On dated 03.10.2022 during the operation at for outage at Bay 402, heavy spark observed at Rph CT at Bay 401on inspection hot spot 675 degree celcius observed at CT Clamp, also oil leakage has started
PADGHE - KALWA CKT - 2	IntraState	03/10/2022	23:42	04/10/2022	05:11	EO	To attend Hot spot at Loc no. 96 B -Phase (113 deg C), Loc no. 127- Y-Phase (116 deg C), Loc no. 108 Y-Phase (88 deg C), B-Phase (65.8 deg C), Loc 115 R-Phase (88.5 deg C), Loc 118 B-Phase (79.3 deg C) & Loc no 119 Y-Phase (142 deg C)
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	04/10/2022	06:12	04/10/2022	18:03	PO	Replacement of Disc Insulator Strings by Long Rod Porcelain strings
GT-9 @ KORADI-2	IntraState	04/10/2022	09:02	04/10/2022	14:10	EO	"1) Tightning of jumper connection from 400kV Main Bus-II to isolator 414-89B at GT9 Tie Bay 414 by hot line method. 2) Routine Bay maintenance work. "
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	04/10/2022	09:18	04/10/2022	19:01	PO	(1) Main-2 distance relay testing. (2)Bay maintenance work. (3)Hardware tightening & fitting
400 KV ICT Outages/Tripping							
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	26/09/2022	11:32	04/10/2022	15:40		Oil filtration, Oil leakage attending, Electrical Testing and painting of Station Transformer -8A Station Transformer -8A Bus duct servicing, maintenance and below replacement
400220kV 167MVA SPARE ICT @ DEEPNAGAR	IntraState	03/10/2022	10:50	03/10/2022	12:45	PO	Diagnostic testing work and bay maintenance work
400/220/33 KV 500 MVA ICT - 2 @ NANDED	IntraState	03/10/2022	11:23	03/10/2022	12:24	T	Tripped on differential protection
400/220/33KV SPARE ICT @ KORADI 2	IntraState	03/10/2022	15:02			EO	Attending oil leakage at CT (y ph) at spare ICT Bay 431
220 KV MAINBAY Outages/Tripping							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 04/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS SECTION-2 @ VSNL	IntraState	04/10/2022	13:15	04/10/2022	14:48	PO	Replacement damaged jumps from 220kV Bus B to Bus Isolator of 220kV Bus Section from Ionikand side bay
220 KV LINE Outages/Trippings							
BAPGAON - KALWA	IntraState	02/10/2022	14:31			PO	CB pole O/H work line will be in service through in TBC
EKLAHARE (OCR) - PADGHE	IntraState	03/10/2022	08:09	03/10/2022	19:44	HT	For load management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/10/2022	08:40	03/10/2022	18:18	HT	H/T TO CONTROL LINE LOADING
KADEGAON-MIRAJ	IntraState	03/10/2022	10:00	03/10/2022	18:25	PO	Tower painting work
BIDRI - SAWANTWADI	IntraState	03/10/2022	10:00	03/10/2022	16:41	PO	Quarterly Maintenance Work
TALANDGE - MUDSHINGI CKT - 1	IntraState	03/10/2022	11:07	03/10/2022	19:02	EO	To attend hot spot observed in Thermoscaning at tower loc. no. 1 (Y phases jump temp. 124 degree), loc no.2 (Y ph. -95 deg.) , loc no. M/C-11 (Y ph-73.5 deg.) , M/C-21 (B ph- 80.7 deg.).
DAHANU - GHODBUNDER CKT - 2	IntraState	03/10/2022	11:32	03/10/2022	17:11	PO	ANNUAL MAINTENANCE OF CIRCUIT BREAKER
MUDSHINGI - CHIKODI	IntraState	03/10/2022	11:50	04/10/2022	07:45	EO	To attend hot spots of 220kV Talandge- Mudshingi ckt-1 on multi circuit tower loc. no. M/C-11 (Y ph jump), & M/C-21(B ph jump).
220KV TULJAPUR - LAMBOTI(400KV) CKT 2	IntraState	03/10/2022	12:35	03/10/2022	18:25	PO	Troubleshooting of AR circuit & CB-PDR circuit by testing team towards tripping dated 01.10.2022
PEDAMBE-KALAMBANI(TSS)	IntraState	03/10/2022	14:30	03/10/2022	16:40	PO	To attend B Phase M B Isolator to Breaker conductor Red hot spot
KURKUMBH - SHIRSHUPHAL CKT	IntraState	03/10/2022	15:40	03/10/2022	20:30	PO	RECONNECTION OF LINE ISOLATOR , JUMPERING OF LINE ISOLATOR.
BHUGAON - WARDHA (PG)	IntraState	03/10/2022	19:08	03/10/2022	20:14	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
HALKARNI-OLAM AGRO (HEMRUS) LINE	IntraState	04/10/2022	05:53	04/10/2022	07:15	T	Distance Protection
GHATGHAR - BAPGAON	IntraState	04/10/2022	08:05			PO	1.Stringing of 9nos. Of Span. 2.Erection of 3 nos. Of Monopole, 3. Bunching work at location no.329 to from 220kV AKP
EKLAHARE (GCR) - GHATGHAR	IntraState	04/10/2022	08:06			PO	Samrudhi Highway Monopole work, from Loc. No. 128 to Loc. No. 136 from loc.no. 129 to 135A erection, stringing of new conductor and Earth wire is done. Proposed work, 2 nos in line tower (128 and 136) Erection, stringing of new conductor and De-stringing of old conductor, also cutting and stringing of old conductor on new tower.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	04/10/2022	08:10			PO	1.Stringing of 9nos. Of Span. 2.Erection of 3 nos. Of Monopole, 3.Bunching work at location no.329 to from 220kV AKP Bapgaon line.
BABLESHWAR- ALEPHATA CKT - 1	IntraState	04/10/2022	09:09	04/10/2022	09:16	PO	220 Kv Babhaleshwar Alephata Ckt for For replacement of faulty DISC insulators string as per PID report
KADEGAON-MIRAJ	IntraState	04/10/2022	09:40	04/10/2022	14:30	PO	Tower painting work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 03/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 04/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ADLABS - PEDAMBE	IntraState	04/10/2022	11:13	04/10/2022	18:03	PO	Attending of hotspot at Loc no. 495 (Bottom phase), Emergency tree cutting work
BABLESHWAR- ALEPHATA CKT - 1	IntraState	04/10/2022	12:42	04/10/2022	17:50	HT	Planned outage
BORIVALI - BOISAR II LINE	IntraState	04/10/2022	13:50	04/10/2022	19:34	EO	Attending Hot Spot on B-Ph Tension Hardware of Stub Bus
EKLAHARE (OCR) - PADGHE	IntraState	04/10/2022	14:17	04/10/2022	19:50	HT	To control overloading
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/132KV 100MVA ICT -1 @ LONI DEOKAR	IntraState	03/10/2022	11:05	03/10/2022	14:50	PO	CTR OVERHAULING WORK
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	03/10/2022	13:00	03/10/2022	16:49	PO	For Oil Top Up in OLTC Tank and Attending Hot Spot on Y-ph CT P2 Side (106 Degrees).
220/132KV 100MVA ICT -2 @ LONI DEOKAR	IntraState	04/10/2022	11:15	04/10/2022	14:15	PO	CTR OVERHAULING WORK
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage