

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 03/Nov/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	141.180	425.039	1) Gujrat	-9.851	-28.058
2) Hydro	5.991	24.328	2) Madhya Pradesh	0.163	0.092
3) Gas	2.234	6.573	3) Chattisgarh	6.020	18.110
Total MSPGCL	149.405	455.940	4) Maharashtra	165.253	479.896
B) 1) APLM	49.745	158.288	5) Goa (Amona)	-1.714	-4.709
2) JSWEL	13.108	38.541	Total	159.871	465.331
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.022	94.543
4) RPL(AMT)	25.325	76.476	b) Mumbai Drawl	36.144	107.294
5) SWPGPL	5.537	16.241	c) MSEDCL Bilateral *	67.622	194.345
6) Other IPP	25.501	73.241	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.022	94.543
C) 1) TPCL Thermal	10.149	30.295	Include PX	0.000	0.000
2) TPCL Hydro	3.897	11.248	Standby	0.000	0.000
3) TPCL Gas	1.815	6.414	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.288	24.713	1) MSEDCL	413.445	1224.884
D) STATE			2) Mumbai Discoms	60.293	179.964
1) Thermal	278.833	842.834	3) Other Discoms	9.356	28.366
(A1+C1+C4+(B1-B6))			TOTAL STATE	483.094	1433.214
2) Hydro	9.888	35.576			
(A2+C2)					
3) Gas	4.049	12.987			
(A3+B7+C3)					
4) Wind	17.596	38.709			
6) SOLAR	12.857	37.777			
TOTAL STATE	323.223	967.883			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6053	4953	6565	5548
MSPGCL Hydro	176	446	1101	144
MSPGCL Gas	92	90	92	97
MSPGCL Total Generation	6321	5489	7758	5789
Central Sector Receipt	7245	8163	6229	5699
WIND	1119	1018	695	597
CPP / IPP Thermal	5012	4348	5762	4608
CPP / IPP Gas	0	0	0	0
SOLAR	1669	1843	2	0
Exchange with Mumbai	-1720	-2038	-1428	-1026
MSEDCL DEMAND MET	19210	18400	18589	15369
Load Shedding	0	0	0	0
MSEDCL DEMAND	19210	18400	18589	15369
TPCL GENERATION	758	611	1010	506
AEML GENERATION	497	350	482	295
MUMBAI DEMAND	2975	2999	2920	1827
OTHER DISCOM DEMAND	435	423	429	298
STATE DEMAND MET	22621	21822	21938	17494
STATE DEMAND	22621	21822	21938	17494
Frequency (Hz)	49.94	49.98	50.03	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 15.02 Hrs	49.68 Hz at 07.17 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 03/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.39	13.68	210	95
Unit 7	0.00	0.00	0	0
Unit 8	11.96	36.14	531	424
Unit 9	12.00	36.09	553	378
Unit 10	9.18	27.55	400	365
Total	37.53	113.45		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.95	26.35	465	270
Unit 5	9.04	27.54	460	275
Total	17.99	53.89		
Parli				
Unit 6	3.81	7.81	189	150
Unit 7	1.40	9.92	223	0
Unit 8	3.43	10.48	170	124
Total	8.64	28.21		
Chandrapur				
Unit 3	3.14	9.58	150	120
Unit 4	2.99	8.92	152	118
Unit 5	6.85	20.75	330	260
Unit 6	6.77	13.69	315	205
Unit 7	7.28	22.00	350	276
Unit 8	8.90	27.46	467	277
Unit 9	8.91	26.98	443	295
Total	44.84	129.37		
Paras				
Unit 3	5.02	16.26	237	171
Unit 4	0.00	0.00	0	0
Total	5.02	16.26		
Khaparkheda				
Unit 1	2.70	8.22	125	100
Unit 2	2.61	8.63	120	100
Unit 3	3.44	10.00	170	127
Unit 4	3.16	9.59	143	121
Unit 5	9.14	28.35	500	270
Total	21.05	64.79		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.18	9.85	175	113
Unit 5	2.93	9.21	157	109
Total	6.11	19.06		
Uran				
All Units	2.23	6.57	97	88
Total	2.23	6.57		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.08	2.95	48	40
Total	1.08	2.95		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.64	6.98	330	40
Stage 4	0.81	5.56	574	0
Stage 3	0.57	2.77	160	0
Total	3.02	15.30		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.14	0.26	57	0
SMLHY_PTN	1.60	4.96	73	59
GHATGHAR	0.15	0.85	104	0
Total	1.89	6.08		
Wind				
Total	17.60	38.71	0	0
Total	17.60	38.71		
CPP				
APML(Mus)	49.74	158.29	0	0
JSWEL(Mus)	13.11	38.54	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.32	76.48	0	0
SWPGPL-Mus	5.54	16.24	0	0
Other(Mus)	25.50	73.24	0	0
Total	119.22	362.79		
SOLAR				
Total	12.86	37.78	0	0
Total	12.86	37.78		
Tata				
Trombay 5	6.90	20.57	397	269
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.95	3.49	53	36
Trombay 7B	0.87	2.92	44	33
TATA Hydro	3.90	11.25	411	11
Trombay 8	3.25	9.73	171	130
Total	15.86	47.96		
AEMIL				
DTPS U-1&2	8.29	24.71	497	290
Total	8.29	24.71		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	141.18	425.04	MSPGCL Total	149.40	455.94
			MSPGCL Thml+Gas	143.41	431.61	Koyna 1,2 & 4 Total	2.45	12.54
			MSPGCL Hydro	5.99	24.33	State Total	323.22	967.88

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 03/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5425	157	95	5677	632	4536	0	0	5713	5970	-1305	15164	0	15164	2178	346	17688	49.97
2	5506	157	96	5759	641	4552	0	0	5584	5850	-1203	15279	0	15279	2022	320	17621	49.96
3	5510	152	96	5758	602	4420	0	0	5576	5919	-1103	15287	0	15287	1903	309	17499	49.98
4	5548	144	97	5789	597	4608	0	0	5464	5699	-1026	15369	0	15369	1827	298	17494	50.00
5	6144	157	96	6397	481	4933	0	0	5403	5490	-994	15994	0	15994	1802	313	18109	50.00
6	6422	152	96	6670	451	5238	0	0	5853	5971	-1054	16928	0	16928	1875	348	19151	50.01
7	6577	239	96	6912	460	5467	0	47	6465	6638	-1162	17987	0	17987	1979	375	20341	49.92
8	6624	215	96	6935	411	5506	0	399	6397	6720	-1236	18338	0	18338	2150	397	20885	49.93
9	6301	154	95	6550	376	5348	0	961	6776	7274	-1502	18594	0	18594	2450	414	21457	49.98
10	6129	194	94	6417	680	5024	0	1347	7101	7501	-1691	18854	0	18854	2752	424	22030	49.98
11	6053	176	92	6321	1119	5012	0	1669	7329	7245	-1720	19210	0	19210	2975	435	22621	49.94
12	5198	156	91	5445	1140	4433	0	1887	7609	7864	-1822	18526	0	18526	3036	421	21983	50.02
13	4953	446	90	5489	1018	4348	0	1843	7606	8163	-2038	18400	0	18400	2999	423	21822	49.98
14	5151	177	89	5417	856	4415	0	1717	7513	7617	-1979	17651	0	17651	2888	392	20931	50.02
15	5511	154	88	5753	872	4717	0	1427	7563	7856	-2008	18214	0	18214	2926	403	21543	50.03
16	5919	150	89	6158	649	4942	0	1014	7522	7690	-2002	18037	0	18037	2970	414	21421	50.01
17	6368	151	91	6610	578	5086	0	485	7150	7183	-1863	17657	0	17657	2958	422	21037	49.95
18	6497	229	90	6816	536	5550	0	59	6530	6488	-1573	17447	0	17447	2918	429	20794	49.96
19	6565	1101	92	7758	695	5762	0	2	6146	6229	-1428	18589	0	18589	2920	429	21938	50.03
20	6401	476	92	6969	885	5533	0	0	6649	6548	-1477	18024	0	18024	2807	433	21265	50.04
21	5917	311	92	6320	969	5175	0	0	6422	6231	-1551	16729	0	16729	2659	415	19803	50.03
22	5797	261	94	6152	998	5047	0	0	5860	6016	-1511	16286	0	16286	2515	416	19217	50.01
23	5357	232	93	5682	981	4931	0	0	5769	5831	-1462	15566	0	15566	2423	397	18386	50.00
24	5307	250	94	5651	969	4635	0	0	5658	5878	-1434	15314	0	15314	2361	385	18060	49.98
MUs	141.18	5.99	2.23	149.41	17.60	119.22	0.00	12.86	155.66	159.87	-36.14	413.45	0.00	413.45	60.29	9.36	483.09	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Nov/2022

Position as on 6.30 Hrs of 04/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High(converted into coal shortage from 15-10-2022)	
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	14/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	14/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-3	135	21/10/2022	01:33		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	22/10/2022	16:51		Continued.	Turbine Vibration	15/11/2022
IPP	SWPGPL U-1	135	23/10/2022	20:29		Continued.	PA Fan Vibration Problem	06/11/2022
IPP	Adani U-4	660	31/10/2022	08:11	04/11/2022	20:45	APH-B hot PA bellow leakage.	04/11/2022
MSPGCL	Uran Unit 5	108	02/11/2022	17:35		Continued.	Gas shortage	
MSPGCL	Parli Unit 7	250	03/11/2022	08:25	04/11/2022	16:12	Boiler Validity Extension.	05/11/2022
TPC-G	Trombay 7B	60	04/11/2022	04:22		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	04/11/2022	04:44	04/11/2022	17:17	Gas shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 03/Nov/2022

Position as on 6.30 Hrs of 04/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 8	250	04/11/2022	10:50		Continued.	MOT level fluctuate and fire protection operate turbine tripped and boiler hand tripped.	
MSPGCL	Koyana STG-IV Unit-4	250	04/11/2022	18:30	04/11/2022	21:40	D.C.supply fail	
TPC-G	Trombay 7A	120	04/11/2022	19:53		Continued.	Gas shortage	
MSPGCL	Koyana STG-IV Unit-2	250	04/11/2022	21:09	04/11/2022	21:55	cooling water system level low	
MSPGCL	Koyana STG-IV Unit-3	250	04/11/2022	21:09	04/11/2022	22:10	cooling water system level low	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 04/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (704) OF EKTUNI CKT - 1 @ AKOLA 2	IntraState	03/11/2022	09:01	03/11/2022	19:17	PO	Annual Maintenance of Bay Equipment
MAIN BAY (709) OF AKOLA CKT - 1 @ KORADI 3	IntraState	04/11/2022	09:22	04/11/2022	16:22	PO	Annual Maintenance of Bay Equipment
400 KV TIEBAY Outages/Trippings							
TIE BAY (403) OF BUS RECTOR & ICT -1 @ WARORA	IntraState	03/11/2022	09:58	03/11/2022	13:56	PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
TIE BAY (409) OF KARJAT CKT - 2 @ LONIKAND 2	IntraState	03/11/2022	10:53	03/11/2022	12:00	PO	Diagnostic testing and Maintenance
TIE BAY (403) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	03/11/2022	14:23	03/11/2022	16:04	PO	for routine diagnostic testing work of CT Tan delta
400 KV TBC Outages/Trippings							
BUS COUPLER @ AURANGABAD (WALUJ)	IntraState	03/11/2022	12:00	03/11/2022	17:44	PO	1) Diagnostic Testing Work 2) Routine Maintenance Work
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (410) OF KARJAT CKT - 2 @ LONIKAND 2	IntraState	03/11/2022	08:24	03/11/2022	10:43	PO	Diagnostic testing and Maintenance
MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	03/11/2022	10:12	03/11/2022	12:03	PO	for routine diagnostic testing work of CT tan delta
400 KV LR Outages/Trippings							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	04/11/2022	13:37	04/11/2022	17:12	EO	Flashier insulator string replacement on Bph of location 93
400 KV LINE Outages/Trippings							
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	03/11/2022	13:50	03/11/2022	20:42	EO	Hotspot at 1. Y ph WT 2. Rph feeder jump at terminal gantry
KARAD - LONIKAND I	IntraState	10/10/2022	09:28	04/11/2022	08:11	PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/10/2022	10:27		Continued.	HT	For Load management
NEW KOYNA - DABHOL CKT - 2	IntraState	03/11/2022	08:45	03/11/2022	18:34	PO	Cold washing work
CHANDRAPUR-PARLI CKT-3	IntraState	03/11/2022	09:03	03/11/2022	20:03	PO	1) Circuit Breaker timing, CRM & DCRM. 2) Maintenance and alignments of PG-1, PG-2, PG-3 Isolators and CB Isolators. 3) Dismantaling of old reactor relay panel along with its wiring.
TBC @ KOLHAPUR(TALANDGE)	IntraState	03/11/2022	16:15			PO	Overhauling of A bus, B Bus, C Bus PG isolators.
KHADKA-AURANGABAD (WALUJ)	IntraState	03/11/2022	20:08	04/11/2022	06:45	HT	H/T FOR O/V
PADGHE - NAGOTHANE CKT - 1	IntraState	04/11/2022	03:39	04/11/2022	09:16	HT	For Control Over Voltage
DEEPNAGAR - THAPTI TANDA	IntraState	04/11/2022	05:36	04/11/2022	18:04	HT	Outage availed for replacement of faulty insulator strings
DEEPNAGAR - THAPTI TANDA	IntraState	04/11/2022	05:36	04/11/2022	18:04	PO	for replacement of faulty insulator strings by long rod insulator

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 04/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NEW KOYNA - DABHOL CKT - 2	IntraState	04/11/2022	09:31	04/11/2022	18:32	PO	Cold washing work
KHADKA-AURANGABAD (WALUJ)	IntraState	04/11/2022	20:37		Continued.	HT	H/T DUE TO O/V
JAIGAD - KARAD CKT - 2	IntraState	04/11/2022	21:20		Continued.	HT	H/T DUE TO O/V
PADGHE - NAGOTHANE CKT - 1	IntraState	04/11/2022	21:25		Continued.	HT	H/T DUE TO O/V
400 KV ICT Outages/Trippings							
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	IntraState	04/11/2022	08:39	04/11/2022	18:38	PO	Bushing Winding Tan D, HV, MV CT Tan D, NDR and bay maintenance work
400/220 KV 315MVA ICT - 2 @ KARAD	IntraState	04/11/2022	10:04	04/11/2022	19:39	PO	For measurement of IR values of 198 Kv Y ph LA due higher LDM values i.e. Ir corrected-244 MicroAmp which is greater than 150 MicroAmp & replacement of faulty LA stack.Also tandelta & capacitance measurement of Bushing,winding & LV side CTs.
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	04/11/2022	10:16	04/11/2022	18:27	PO	Diagnostic Testing of CT and routine bay maintenance work
220 KV TIEBAY Outages/Trippings							
MAIN BUS SECTIONALIZER -2 @ GHODBUNDER (GIS)	IntraState	03/11/2022	08:24	03/11/2022	17:27	PO	Annual Maint of Bus Sectionalizer 2. facilitating outage of 220kV Main Bus 2
220 KV MAINBAY Outages/Trippings							
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	03/11/2022	08:25	03/11/2022	17:26	PO	Annual Maint of Bus Coupler. facilitating outage of 220kV Main Bus 2
220KV BUS SECTION BAY @ PEDAMBE	IntraState	04/11/2022	09:15	04/11/2022	18:40	PO	R & Y Phase section-I side Isolator to C.T. Jumper replacement
220 KV LINE Outages/Trippings							
AAREY - MSETCL BORIVALI CKT - 2	IntraState	24/10/2022	22:53	04/11/2022	21:30	T	R-ph Differential Protection
ACCIL - APTA	IntraState	02/11/2022	15:57		Continued.	EO	CB DC leakage attending work by testing divison panvel.
TROMBAY MSETCL TIE - 2	IntraState	02/11/2022	18:23	03/11/2022	00:21	EO	1) Hotspot at 29B GOD for C phase (GOD alignment to be done) at Tata end. 2) Hotspot on Breaker Palm towards 29A for B phase (Flexible jumper to be changed) at Tata End. 3) Hotspot on Vertical dropper on C phase and also bolt replacement on CT (Vertical dropper to be changed) at MSETCL end.
CENTURI ENKA- BHOSARI	IntraState	03/11/2022	01:30	03/11/2022	12:21	HT	HOT SPOT
EKLAHARE (OCR) - PADGHE	IntraState	03/11/2022	08:25	04/11/2022	01:18	HT	For load management
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/11/2022	09:24	03/11/2022	22:05	HT	For load management
HINJAWADI I- CHINCHWAD	IntraState	03/11/2022	09:45	03/11/2022	19:06	HT	For load management
SAHARA-URSE	IntraState	03/11/2022	09:56	03/11/2022	18:52	HT	For Main bus section 2 outage at URSE
KARAD -MUDSHINGI CKT 2-TAK	IntraState	03/11/2022	09:59	03/11/2022	15:42	PO	Cold washing work of disc insulator string from Loc no.60 to 82.
URSE - TALEGAON (AMBI) CKT 1	IntraState	03/11/2022	10:01	03/11/2022	18:51	HT	For main bus section 2 outage at Urse
TROMBAY MSETCL TIE - 1	IntraState	03/11/2022	10:06	03/11/2022	15:25	HT	CB REPLACEMENT WORK

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 03/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 04/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
URSE - M. HINODAYA CO	IntraState	03/11/2022	10:07	03/11/2022	18:54	HT	For main bus section 2 at URSE
KADEGAON-MIRAJ	IntraState	03/11/2022	11:00	03/11/2022	14:07	PO	Relay Testing Work
VERSOVA - GHODBUNDER	IntraState	03/11/2022	14:52	03/11/2022	17:11	T	TRIPPED ON DISTANCE PROTECTION
BIDRI - SAWANTWADI	IntraState	04/11/2022	00:17	04/11/2022	08:43	HT	For control Over voltage
MIRAJ - ICHALKARANJI	IntraState	04/11/2022	08:04	04/11/2022	18:10	PO	Stringing between location number 1 to 71 of 110 kv Jaysingpur-Ichalkaranji line
BUS COUPLER @ VERSOVA	IntraState	04/11/2022	09:32	04/11/2022	18:42	PO	Annual Maintenance of the Bay.
BUS - A @ PADGHE	IntraState	04/11/2022	09:39	04/11/2022	22:55	PO	Partial A-Bus outage in upper section For replacement of 70KN suspension & tension type Disc of insulator by 120KN Disc insulator of 220/100kv 200MVA ICT-1 HV Bay and 220/22kV 50MVA T&R make Tf. (During this outage 220/100Kv 200MVA ICT-1 Bay, 220Kv BC bay and 220/22kV 50MVA T&R make Tf. must be under outages)
EKLAHARE (OCR) - PADGHE	IntraState	04/11/2022	09:39		Continued.	HT	For load management
ONGC PANVEL - TSS PANVEL	IntraState	04/11/2022	09:46	04/11/2022	17:24	PO	For stringing of OPGW conductor from loc no. 3 (old line) to Monopole loc no. 1 (New line) of 220kV ONGC-Panvel-TSS
WADA - BHAVEGHAR	IntraState	04/11/2022	10:22	04/11/2022	17:37	PO	For all Diagnostic, Relay testing and Routine Maintenance Work at 220 kV Wada SS.
TROMBAY MSETCL TIE - 1	IntraState	04/11/2022	12:49	04/11/2022	14:02	HT	EMERGENCY OUTAGE AVAILABLE TO ATTEND HOT SPOT AT TATA END
220 KV ICT Outages/Tripping							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	03/11/2022	10:17	03/11/2022	20:35	PO	for OLTC overhauling work and TF oil top up work.
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	03/11/2022	10:36	03/11/2022	21:58	PO	Outage is required for Separation of LA & ICT bushing jumps
220/132 KV 200 MVA PTR NO 3 @ PHURSUNGI	IntraState	03/11/2022	11:00	03/11/2022	12:08	PO	Replacement of buchholz relay due to oil leakage from glass window & oil top up.
220/132 KV 200 MVA PTR 4 @ PHURSUNGI	IntraState	03/11/2022	12:27	03/11/2022	13:27	PO	Oil top up work.
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	04/11/2022	08:48		Continued.	PO	For replacement of 70KN suspension & Tension type Disc of insulator by 120KN Disc insulator of 220/100Kv 200MVA ICT-1 HV Bay
220/22 KV 50 MVA PTR 2 @ PADGHE	IntraState	04/11/2022	08:48		Continued.	PO	For replacement of 70KN suspension & Tension type Disc of insulator by 120KN Disc insulator of 220/22kV 50MVA T&R make Tf
220/33 KV 50 MVA PTR 1 @ KHARGHAR	IntraState	04/11/2022	09:08	04/11/2022	14:52	EO	B Bus Isolator alignment work and replacing broken down pipe and removing B Bus, B-phase Jumper by Hotline method

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 03/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 04/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	04/11/2022	10:01	04/11/2022	19:48	PO	HV CB replacement work
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	IntraState	04/11/2022	10:20	04/11/2022	15:45	PO	ICT Bushing and winding,HV & LV CTs tan delta measurement work and Bay maintenance work
220/33KV 50MVA TF NO.1 @ SAYNE	IntraState	04/11/2022	11:50	04/11/2022	19:02	PO	OLTC Overhauling work of PTR1 33 kv Incomer 1 bus isolator alignment Work
220 KV BUSBAR Outages/Trippings							
MAIN BUS SECTION - 2 @ URSE	IntraState	03/11/2022	10:29	03/11/2022	18:45	PO	Dismantling of existing 220kV Main Bus Section Isolator-1 & Bus to Bus re-jumpering work by Hotline unit for the work of foundation erection & commissioning of 245kV Hybrid Pass switch-gear.
BUS COUPLER @ PADGHE	IntraState	04/11/2022	09:39	04/11/2022	22:55	PO	for replacement of Broken jumper of R phase CT & during Partial A bus outages 220kv BC should be under outage
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage