

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Jan/2025 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 128.763        | 534.951         | 1) Gujrat                      | -6.051         | -19.110         |
| 2) Hydro            | 14.441         | 38.869          | 2) Madhya Pradesh              | 3.166          | 18.274          |
| 3) Gas              | 7.167          | 28.167          | 3) Chattisgarh                 | 5.090          | 22.230          |
| <b>Total MSPGCL</b> | <b>150.371</b> | <b>601.987</b>  | 4) Maharashtra                 | 189.581        | 754.214         |
| B) 1) APLM          | 73.821         | 265.787         | 5) Goa (Amona)                 | -2.556         | -10.044         |
| 2) JSWEL            | 24.150         | 88.552          | <b>Total</b>                   | <b>189.230</b> | <b>765.564</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 35.923         | 150.864         |
| 4) RPL(AMT)         | 25.644         | 102.436         | b) Mumbai Drawl                | 38.717         | 162.420         |
| 5) SWPGPL           | 11.866         | 46.586          | c) MSEDCL Bilateral *          | 88.460         | 338.651         |
| 6) Other IPP        | 47.049         | 184.758         | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 35.888         | 150.722         |
| C) 1) TPCL Thermal  | 4.218          | 16.393          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 2.997          | 12.062          | Standby                        | 0.035          | 0.142           |
| 3) TPCL Gas         | 4.152          | 16.762          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.570          | 32.379          | 1) MSEDCL                      | 507.602        | 2001.521        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 58.654         | 240.016         |
| 1) Thermal          | 324.081        | 1271.842        | 3) Other Discoms               | 12.418         | 49.372          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>578.674</b> | <b>2290.909</b> |
| 2) Hydro            | 17.438         | 50.931          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 11.319         | 44.929          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 12.180         | 66.194          |                                |                |                 |
| 6) SOLAR            | 24.426         | 91.449          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>389.444</b> | <b>1525.345</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5412                      | 4882                  | 5995                      | 4951                      |
| MSPGCL Hydro               | 453                       | 303                   | 1937                      | 206                       |
| MSPGCL Gas                 | 294                       | 279                   | 366                       | 303                       |
| MSPGCL Total Generation    | 6159                      | 5464                  | 8298                      | 5460                      |
| Central Sector Receipt     | 9837                      | 9210                  | 7642                      | 6974                      |
| WIND                       | 449                       | 241                   | 280                       | 959                       |
| CPP / IPP Thermal          | 7758                      | 7304                  | 8121                      | 6762                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 3020                      | 3484                  | 0                         | 0                         |
| Exchange with Mumbai       | -2157                     | -2177                 | -1531                     | -1144                     |
| <b>MSEDCL DEMAND MET</b>   | <b>24526</b>              | <b>22975</b>          | <b>22260</b>              | <b>18595</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 24526                     | 22975                 | 22260                     | 18595                     |
| TPCL GENERATION            | 374                       | 419                   | 819                       | 368                       |
| AEML GENERATION            | 323                       | 314                   | 486                       | 312                       |
| <b>MUMBAI DEMAND</b>       | <b>2854</b>               | <b>2910</b>           | <b>2836</b>               | <b>1824</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>539</b>                | <b>551</b>            | <b>550</b>                | <b>416</b>                |
| STATE DEMAND MET           | 27920                     | 26436                 | 25646                     | 20835                     |
| <b>STATE DEMAND</b>        | <b>27920</b>              | <b>26436</b>          | <b>25646</b>              | <b>20835</b>              |
| Frequency (Hz)             | 49.94                     | 50.04                 | 49.92                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 16.02 Hrs | 49.69 Hz at 07.27 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 04/Jan/2025

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.15         | 16.05         | 177      | 165      |
| Unit 8             | 0.00         | 31.92         | 0        | 0        |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| Unit 10            | 13.50        | 53.10         | 590      | 550      |
| <b>Total</b>       | <b>17.64</b> | <b>101.08</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.52         | 13.56         | 180      | 120      |
| Unit 4             | 8.56         | 32.49         | 490      | 275      |
| Unit 5             | 8.49         | 31.80         | 465      | 285      |
| <b>Total</b>       | <b>20.58</b> | <b>77.86</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.10         | 15.49         | 248      | 139      |
| Unit 7             | 0.00         | 10.23         | 0        | 0        |
| Unit 8             | 4.15         | 16.00         | 231      | 146      |
| <b>Total</b>       | <b>8.25</b>  | <b>41.72</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.61         | 14.27         | 179      | 125      |
| Unit 4             | 0.00         | 4.92          | 0        | 0        |
| Unit 5             | 8.08         | 30.41         | 415      | 278      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 8.38         | 30.99         | 443      | 271      |
| Unit 8             | 9.04         | 37.69         | 412      | 340      |
| Unit 9             | 11.36        | 43.98         | 500      | 410      |
| <b>Total</b>       | <b>40.47</b> | <b>162.26</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.96         | 18.56         | 239      | 155      |
| <b>Total</b>       | <b>4.96</b>  | <b>18.56</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.96         | 15.18         | 175      | 140      |
| Unit 2             | 4.32         | 15.90         | 193      | 144      |
| Unit 3             | 4.58         | 7.58          | 202      | 163      |
| Unit 4             | 3.99         | 15.08         | 179      | 143      |
| Unit 5             | 10.64        | 42.96         | 465      | 425      |
| <b>Total</b>       | <b>27.50</b> | <b>96.71</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.15         | 12.43         | 158      | 110      |
| Unit 4             | 3.06         | 11.91         | 137      | 119      |
| Unit 5             | 3.17         | 12.42         | 163      | 111      |
| <b>Total</b>       | <b>9.38</b>  | <b>36.76</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 7.17         | 28.17         | 366      | 273      |
| <b>Total</b>       | <b>7.17</b>  | <b>28.17</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.54         | 2.19          | 23       | 22       |
| <b>Total</b>       | <b>0.54</b>  | <b>2.19</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 3.53         | 9.89          | 550      | 40       |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 4         | 4.03          | 7.19          | 918      | 0        |
| Stage 3         | 1.83          | 3.97          | 240      | 0        |
| <b>Total</b>    | <b>9.39</b>   | <b>21.05</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.63          | 1.93          | 36       | 18       |
| VTRNA           | 0.00          | 0.04          | 0        | 0        |
| TILLARI         | 0.50          | 2.00          | 62       | 0        |
| BHIRA T.R.      | 0.12          | 0.68          | 40       | 0        |
| SMLHY_PTN       | 3.15          | 11.71         | 139      | 126      |
| GHATGHAR        | 0.66          | 1.46          | 125      | 0        |
| <b>Total</b>    | <b>5.05</b>   | <b>17.82</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 12.18         | 66.19         | 0        | 0        |
| <b>Total</b>    | <b>12.18</b>  | <b>66.19</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 73.82         | 265.79        | 0        | 0        |
| JSWEL(Mus)      | 24.15         | 88.55         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 25.64         | 102.44        | 0        | 0        |
| SWPGPL-Mus      | 11.87         | 46.59         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00          | 0        | 0        |
| IEPL            | 5.99          | 23.62         | 273      | 215      |
| Other(Mus)      | 38.97         | 152.46        | 0        | 0        |
| JPL             | 2.09          | 8.68          | 136      | 73       |
| <b>Total</b>    | <b>182.53</b> | <b>688.12</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 24.43         | 91.45         | 0        | 0        |
| <b>Total</b>    | <b>24.43</b>  | <b>91.45</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 0.00          | 0.00          | 0        | 0        |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 2.60          | 10.51         | 111      | 106      |
| Trombay 7B      | 1.55          | 6.25          | 66       | 64       |
| TATA Hydro      | 3.00          | 12.06         | 421      | 14       |
| Trombay 8       | 4.22          | 16.39         | 225      | 135      |
| <b>Total</b>    | <b>11.37</b>  | <b>45.22</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 8.57          | 32.38         | 499      | 280      |
| <b>Total</b>    | <b>8.57</b>   | <b>32.38</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 128.76      | 534.95        | MSPGCL Total        | 150.37      | 601.99        |
|                |             |         | MSPGCL Thml+Gas | 135.93      | 563.12        | Koyna 1,2 & 4 Total | 7.56        | 17.08         |
|                |             |         | MSPGCL Hydro    | 14.44       | 38.87         | State Total         | 389.44      | 1525.34       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 04/Jan/2025

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 4917        | 196   | 299  | 5412   | 1107  | 6910      | 0    | 0     | 6691        | 6933        | -1451                | 18417                  | 0                | 0                           | 18417                         | 2164             | 493                       | 21075           | 49.99         |
| 2                  | 4933        | 197   | 300  | 5430   | 1010  | 6891      | 0    | 0     | 6715        | 6973        | -1339                | 18509                  | 0                | 0                           | 18509                         | 2006             | 456                       | 20971           | 49.97         |
| 3                  | 4940        | 202   | 301  | 5443   | 956   | 6898      | 0    | 0     | 6709        | 6857        | -1207                | 18513                  | 0                | 0                           | 18513                         | 1899             | 434                       | 20846           | 49.98         |
| 4                  | 4951        | 206   | 303  | 5460   | 959   | 6762      | 0    | 0     | 6731        | 6974        | -1144                | 18595                  | 0                | 0                           | 18595                         | 1824             | 416                       | 20835           | 49.98         |
| 5                  | 5000        | 195   | 304  | 5499   | 973   | 7416      | 0    | 0     | 6751        | 6857        | -1151                | 19164                  | 0                | 0                           | 19164                         | 1823             | 429                       | 21417           | 50.00         |
| 6                  | 5097        | 229   | 310  | 5636   | 1121  | 7652      | 0    | 0     | 7589        | 7618        | -1268                | 20282                  | 0                | 0                           | 20282                         | 1909             | 478                       | 22668           | 49.98         |
| 7                  | 5537        | 646   | 308  | 6491   | 718   | 7870      | 0    | 16    | 7673        | 7645        | -1294                | 20936                  | 0                | 0                           | 20936                         | 2026             | 510                       | 23472           | 49.98         |
| 8                  | 5981        | 1480  | 309  | 7770   | 628   | 8065      | 0    | 368   | 7006        | 7285        | -1120                | 22467                  | 0                | 0                           | 22467                         | 2164             | 529                       | 25160           | 49.89         |
| 9                  | 5979        | 1171  | 306  | 7456   | 552   | 8071      | 0    | 1505  | 7221        | 7504        | -1254                | 23297                  | 0                | 0                           | 23297                         | 2403             | 537                       | 26237           | 50.05         |
| 10                 | 5956        | 440   | 302  | 6698   | 420   | 8032      | 0    | 2424  | 8195        | 8544        | -1637                | 23943                  | 0                | 0                           | 23943                         | 2664             | 538                       | 27145           | 50.02         |
| 11                 | 5412        | 453   | 294  | 6159   | 449   | 7758      | 0    | 3020  | 9445        | 9837        | -2157                | 24526                  | 0                | 0                           | 24526                         | 2854             | 539                       | 27920           | 49.94         |
| 12                 | 5384        | 244   | 281  | 5909   | 352   | 7660      | 0    | 3383  | 9003        | 9298        | -2242                | 23796                  | 0                | 0                           | 23796                         | 2931             | 564                       | 27291           | 49.98         |
| 13                 | 4882        | 303   | 279  | 5464   | 241   | 7304      | 0    | 3484  | 8828        | 9210        | -2177                | 22975                  | 0                | 0                           | 22975                         | 2910             | 551                       | 26436           | 50.04         |
| 14                 | 5011        | 218   | 280  | 5509   | 165   | 7186      | 0    | 3329  | 8795        | 8750        | -2088                | 22330                  | 0                | 0                           | 22330                         | 2760             | 521                       | 25611           | 50.04         |
| 15                 | 5063        | 234   | 273  | 5570   | 159   | 7225      | 0    | 2984  | 9329        | 9098        | -2058                | 22438                  | 0                | 0                           | 22438                         | 2767             | 539                       | 25745           | 49.98         |
| 16                 | 5277        | 312   | 279  | 5868   | 115   | 7371      | 0    | 2364  | 9769        | 9567        | -2097                | 22638                  | 0                | 0                           | 22638                         | 2801             | 550                       | 25989           | 50.01         |
| 17                 | 5868        | 452   | 289  | 6609   | 103   | 7850      | 0    | 1309  | 9037        | 8531        | -1977                | 21868                  | 0                | 2                           | 21868                         | 2786             | 557                       | 25211           | 49.98         |
| 18                 | 5972        | 1653  | 288  | 7913   | 213   | 8072      | 0    | 240   | 7597        | 7415        | -1510                | 21797                  | 0                | 1                           | 21797                         | 2779             | 546                       | 25122           | 49.91         |
| 19                 | 5995        | 1937  | 366  | 8298   | 280   | 8121      | 0    | 0     | 7777        | 7642        | -1531                | 22260                  | 0                | 0                           | 22260                         | 2836             | 550                       | 25646           | 49.92         |
| 20                 | 5843        | 1722  | 297  | 7862   | 379   | 8100      | 0    | 0     | 7845        | 7595        | -1506                | 21873                  | 0                | 0                           | 21873                         | 2772             | 558                       | 25202           | 49.89         |
| 21                 | 5342        | 538   | 299  | 6179   | 383   | 7901      | 0    | 0     | 7997        | 7901        | -1680                | 20130                  | 0                | 0                           | 20130                         | 2618             | 554                       | 23302           | 49.93         |
| 22                 | 5022        | 905   | 299  | 6226   | 352   | 7722      | 0    | 0     | 7809        | 7517        | -1735                | 19550                  | 0                | 0                           | 19550                         | 2453             | 532                       | 22535           | 50.03         |
| 23                 | 5385        | 295   | 300  | 5980   | 280   | 7875      | 0    | 0     | 7221        | 6949        | -1602                | 18948                  | 0                | 0                           | 18948                         | 2306             | 534                       | 21788           | 50.02         |
| 24                 | 5016        | 213   | 301  | 5530   | 265   | 7819      | 0    | 0     | 7095        | 6730        | -1492                | 18349                  | 0                | 0                           | 18349                         | 2199             | 503                       | 21051           | 50.04         |
| MUs                | 128.76      | 14.44 | 7.17 | 150.37 | 12.18 | 182.53    | 0.00 | 24.43 | 188.83      | 189.23      | -38.72               | 507.60                 | 0.00             | 0.00                        | 507.60                        | 58.65            | 12.42                     | 578.67          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

ELR carried out at 132KV Wadzire S/S due to overloading of 25 MVA 132/33KV T/F 1 & T/F 2.

| Maximum Demand scenario for the date 04/Jan/2025 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 27920 MW                                         | 24526 MW                         | 2931 MW                           |
| 11 Hrs                                           | 11 Hrs                           | 12 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 04/Jan/2025

Position as on 6.30 Hrs of 05/Jan/2025

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Chandrapur Unit 6       | 500      | 14/12/2024   | 19:45        |            | Continued. | Capital overhaul                                                                                                                                        | 18/01/2025    |
| MSPGCL                        | Koyna Unit 10           | 80       | 25/12/2024   | 12:00        |            | Continued. | for upgradation of existing protection system to numerical protection system and H.S. Lubrication system work.                                          | 25/01/2025    |
| Total Capacity MSPGCL         |                         | 580      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 4               | 540      | 21/12/2024   | 21:50        |            | Continued. | Annual Overhaul                                                                                                                                         | 17/02/2025    |
| Total Capacity CENT.SECTOR    |                         | 540      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE |                         | 1120     |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/01/2025    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 31/03/2025    |
| MSPGCL                        | Paras Unit 3            | 250      | 25/12/2024   | 03:35        | 05/01/2025 | 10:41      | Generator Elect. Fault                                                                                                                                  | 13/01/2025    |
| MSPGCL                        | Koradi Unit 9           | 660      | 30/12/2024   | 16:36        |            | Continued. | FD Fan Problem.                                                                                                                                         | 15/01/2025    |
| MSPGCL                        | Chandrapur Unit 4       | 210      | 02/01/2025   | 13:07        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 05/01/2025    |
| MSPGCL                        | Koradi Unit 8           | 660      | 03/01/2025   | 06:11        | 05/01/2025 | 18:26      | Boiler Tube Leakage                                                                                                                                     | 06/01/2025    |
| MSPGCL                        | Parli Unit 7            | 250      | 03/01/2025   | 17:45        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 07/01/2025    |
| Total Capacity MSPGCL         |                         | 2275     |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                                                         |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 06/01/2025    |
| IPP                           | JSW (J) U4              | 300      | 05/01/2025   | 00:52        |            | Continued. | Condenser choke                                                                                                                                         | 06/01/2025    |
| Total Capacity IPP            |                         | 570      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 10/01/2025    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 10/01/2025    |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Jan/2025**

Position as on 6.30 Hrs of 05/Jan/2025

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                              | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------|---------------|
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |            |            |                                               |               |
| Total Capacity FORCED OUTAGE                  |                         | 3665     |              |              |            |            |                                               |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                               |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                               |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 29/12/2024   | 20:30        |            | Continued. | No schedule. Utilised as per requirement      |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 30/12/2024   | 19:00        | 04/01/2025 | 18:00      | Due to no Schedule by MSEDCL.                 |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 04/01/2025   | 19:00        | 05/01/2025 | 17:50      | Due to No Schedule by MSEDCL                  |               |
| Total Capacity MSPGCL                         |                         | 324      |              |              |            |            |                                               |               |
| IPP                                           |                         |          |              |              |            |            |                                               |               |
| IPP                                           | JPL Unit 2              | 150      | 21/11/2024   | 01:30        |            | Continued. | Unit Out due to Non-avaialbility of Schedule. |               |
| Total Capacity IPP                            |                         | 150      |              |              |            |            |                                               |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 474      |              |              |            |            |                                               |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                               |               |
| IPP                                           |                         |          |              |              |            |            |                                               |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                          |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                          |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)       |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)        |               |
| Total Capacity IPP                            |                         | 988      |              |              |            |            |                                               |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |            |            |                                               |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jan/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jan/2025

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                             |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| DHULE - SSNNL CKT - 2                        | InterState                | 04/12/2024   | 12:04        |            |            | EO          | 400kV Dhule SSNNL-2 line CB as hydraulic operated CB mechanism oil pressure is 310bar & not building up so it is requested to give permission for shifting of 400KV Dhule SSNNL-2 line load shifting to 400KV TBC urgently & attending same. |
| CHANDRAPUR - BHADRAVATI CKT - 2              | InterState                | 03/01/2025   | 09:55        | 04/01/2025 | 00:00      | PO          | LBB EASUN/2DAB Model relay will be upgraded to Numerical relay under ADD CAP/additional element                                                                                                                                              |
| DHULE - KHANDWA CKT - 1                      | InterState                | 05/01/2025   | 17:49        | 05/01/2025 | 18:29      | T           | Take line reactor in service at dhule end.                                                                                                                                                                                                   |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I    | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                      |
| PADGHE - KALWA CKT - 1                       | IntraState                | 28/12/2024   | 10:28        |            |            |             | Shifting/height rising (Monopole Erection) of 400kV Kalwa Padgha Ckt.1 between loc no. 1143 to 1144 infringing Airoli Katai Naka Highway Projects of MMRDA                                                                                   |
| 33KV HVDC AUXILIARY SUPPLY 2 @ PADGHE-400 KV | IntraState                | 03/01/2025   | 08:53        |            |            | PO          | replacement of 33kV Isolator due to alignment problem.<br>2) 315MVA ICT -2 outage also required for the work.<br>3) 33kV Aux- 1 HVDC source in service.                                                                                      |
| JAIGAD - KARAD CKT - 1                       | IntraState                | 03/01/2025   | 21:24        | 04/01/2025 | 09:23      | HT          | H/T For voltage management.                                                                                                                                                                                                                  |
| KHADKA-AURANGABAD (WALUJ)                    | IntraState                | 03/01/2025   | 22:39        | 04/01/2025 | 09:33      | HT          | SYS O/V                                                                                                                                                                                                                                      |
| KHADKA-AURANGABAD (WALUJ)                    | IntraState                | 03/01/2025   | 22:39        | 04/01/2025 | 09:33      | HT          | H/T for voltage management                                                                                                                                                                                                                   |
| KHADKA-AURANGABAD (WALUJ)                    | IntraState                | 04/01/2025   | 20:11        | 05/01/2025 | 09:54      | HT          | Overvoltage                                                                                                                                                                                                                                  |
| JAIGAD - KARAD CKT - 2                       | IntraState                | 04/01/2025   | 23:34        | 05/01/2025 | 09:52      | HT          | H/T for voltage management.                                                                                                                                                                                                                  |
| NAGOTHANE - DABHOL CKT - 2                   | IntraState                | 05/01/2025   | 13:52        | 05/01/2025 | 15:37      | T           | distance protection                                                                                                                                                                                                                          |
| KHADKA-AURANGABAD (WALUJ)                    | IntraState                | 05/01/2025   | 20:58        |            | Continued. | HT          | Overvoltage                                                                                                                                                                                                                                  |
| JAIGAD - KARAD CKT - 1                       | IntraState                | 05/01/2025   | 21:01        |            | Continued. | HT          | Overvoltage                                                                                                                                                                                                                                  |
| <b>400 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                                              |
| STATION TF No 3 @ CHANDRAPUR GCR             | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                               |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA          | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                      |
| 400/220/33 KV 315 MVA ICT - 2 @ PADGHE       | IntraState                | 03/01/2025   | 12:10        | 04/01/2025 | 03:28      | PO          | 1) Bay Maintenance work.<br>2) Diagonostic Testing work.<br>3)Oil leakage Attending work.                                                                                                                                                    |
| 400/220 KV 3X200 MVA ICT - 2 @ KALWA         | IntraState                | 04/01/2025   | 05:48        | 04/01/2025 | 09:39      | EO          | 400/220kV, 600MVA ICT-2, B ph LV bushing terrut leakage attending work by power seal online gasket method.                                                                                                                                   |
| 400/132 KV 200 MVA ICT - 1 @ KHADKA          | IntraState                | 04/01/2025   | 09:41        | 04/01/2025 | 19:45      | PO          | for Diagnostic testing work such as Winding, Bushing CT -Tan delta,Winding resistance,DFR & Relay testing work                                                                                                                               |
| 400/220 KV 500 MVA ICT - 5 @ PADGHE          | IntraState                | 05/01/2025   | 07:22        | 05/01/2025 | 17:54      | PO          | The outage is required for safety purposes during the pulling of the HTLS conductor at crossing B/w loc 1-2. for 400kV Kalwa-Padgha Ckt.1                                                                                                    |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jan/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jan/2025

| Name of Line                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                   |
|------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 400/220 KV 500 MVA ICT - 5 @ PADGHE      | IntraState                | 05/01/2025   | 07:22        | 05/01/2025 | 17:54      | PO          | 1) Required for safety purpose during pulling of HTLS conductor at crossing<br>B/w loc 1-2 for 400kV Kalwa-1 HTLS conductor.<br>2) Foundation work of gantry and equipment of new ICT-6 below interconnecting line of ICT-5.                                                                                                                                                                       |
| <b>400 KV BR Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BUS REACTOR (80 MVar) - 1 @ BABHALESHWAR | IntraState                | 07/10/2024   | 09:40        |            |            | PO          | The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order |
| <b>220 KV TIEBAY Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| TBC @ PHURSUNGI                          | IntraState                | 04/01/2025   | 10:03        | 04/01/2025 | 16:15      | PO          | Bay half yearly maint. work                                                                                                                                                                                                                                                                                                                                                                        |
| <b>220 KV TBC Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| TBC @ PAL-DOMBIVALI-220 kV               | InterState                | 04/01/2025   | 08:53        | 04/01/2025 | 16:00      | PO          | 1)Removal of TBC Bus jumper of 29A isolator by hot line. 2) Replacement of Isolator support structure.                                                                                                                                                                                                                                                                                             |
| 220 KV TBC                               | IntraState                | 04/01/2025   | 10:15        | 04/01/2025 | 15:45      | HT          | Diagnostic testing work viz. tan delta of ct, crm & timing of cb and routine maintenance work.                                                                                                                                                                                                                                                                                                     |
| BUS COUPLER @ PHURSUNGI                  | IntraState                | 04/01/2025   | 15:26        | 04/01/2025 | 17:40      | PO          | Half yearly maint.                                                                                                                                                                                                                                                                                                                                                                                 |
| <b>220 KV MAINBAY Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| 220KV BUS SECTION BAY @ PEDAMBE          | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                                                                                                                                       |
| BUS SECTION - 2 @ TIFIL                  | IntraState                | 04/01/2025   | 07:30        | 04/01/2025 | 14:48      | PO          | Replacement of 220kV Bus PT Set.(R Y B Ph PT)                                                                                                                                                                                                                                                                                                                                                      |
| <b>220 KV LINE Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BALE - SOLAPUR (PG)                      | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                   |
| PRINT HOUSE - NAVI MUMBAI (PG)           | InterState                | 05/12/2024   | 23:09        |            |            | EO          | 1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Taloja s/stn.<br>2)For opening jumpers at TL no 678/1.                                                                                                                                                                                                                                       |
| OSMANABAD - SOLAPUR (BALE)               | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)                                                                                                                      |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jan/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jan/2025

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                 |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2         | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                                                                              |
| EKLAHARE (OCR) - PADGHE                       | IntraState                | 24/09/2024   | 07:48        |            |            | HT          | For load mgmt                                                                                                                                                                                                                                                                                                                    |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II    | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                                                                                                                                                                                            |
| KALWA - PANCHANAND                            | IntraState                | 17/10/2024   | 12:10        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.                                                                                                                                                                                                            |
| MAIN BUS SECTION - 1 @ TIFIL                  | IntraState                | 12/12/2024   | 11:12        |            |            | PO          | Siemens make bus bar relay replacement work by PAC division Kalwa.                                                                                                                                                                                                                                                               |
| EKLAHARE (OCR) - NAVASARI CKT - 1             | IntraState                | 16/12/2024   | 18:08        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                                                                                         |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                                                                                                                                             |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                                                                                                                                             |
| GIS BHANDUP - BORIVALI                        | IntraState                | 03/01/2025   | 23:02        |            |            | EO          | For live line shifting of 220kV Borivali line on Bus- 1 to 220kV Bus-2 for attending SF6 Gas leakage of 220kV Main Bus-I.                                                                                                                                                                                                        |
| TIFIL - NEXTRA GIS                            | IntraState                | 04/01/2025   | 06:59        | 04/01/2025 | 15:12      | PO          | Replacement of 220kV Bus PT Set.(R Y B Ph PT)                                                                                                                                                                                                                                                                                    |
| ABHIJEET-WARDHA-II                            | IntraState                | 04/01/2025   | 07:34        | 04/01/2025 | 17:08      | HT          | Restrining of conductor between span at loc no. 43 to 55.                                                                                                                                                                                                                                                                        |
| 220kV Koradi-2 - Uppalwadi ckt 1              | IntraState                | 04/01/2025   | 08:41        | 04/01/2025 | 18:02      | HT          | Civil work for construction and height raising of damage power cable joint box jb 1 jb2a at 3x660 mw ktps premises.                                                                                                                                                                                                              |
| HINJAWADI I- CHINCHWAD                        | IntraState                | 04/01/2025   | 08:45        | 04/01/2025 | 21:42      | HT          | Load management.                                                                                                                                                                                                                                                                                                                 |
| BARAMATI - KURKUMBH                           | IntraState                | 04/01/2025   | 11:40        | 04/01/2025 | 18:42      | PO          | Chemical Cleaning of insulator string work                                                                                                                                                                                                                                                                                       |
| EKLAHARE (GCR) - GHATGHAR                     | IntraState                | 04/01/2025   | 12:05        | 04/01/2025 | 18:22      | PO          | "1. for replacement of faulty R-phase SSN disc insulator string at location no.92 found during PID.<br>2. for replacement of faulty R-phase DTN disc insulator string GCR side at location no.159 found during PID.<br>2. attending of damaged conductor at dead end of Y-phase at loc.no.105A (Sinner Ghoti highway crossing)." |
| PADGHE - JINDAL                               | IntraState                | 04/01/2025   | 12:25        | 04/01/2025 | 15:57      | T           | Jindal Ss went into dark as both 220kV Jindal -Ghatghar and 220kV Padghe- Jindal line tripped. Fire reported below 220kV Padghe - Jindal Line.                                                                                                                                                                                   |
| GHATGHAR - JINDAL                             | IntraState                | 04/01/2025   | 12:25        | 04/01/2025 | 12:58      | T           | Jindal Ss went into dark as both 220kV Jindal -Ghatghar and 220kV Padghe- Jindal line tripped. Fire reported below 220kV Padghe - Jindal Line.                                                                                                                                                                                   |
| NEW TPS - WAGHALA CKT 2                       | IntraState                | 04/01/2025   | 12:27        | 04/01/2025 | 17:01      | HT          | Replacement of flash over string.                                                                                                                                                                                                                                                                                                |
| 220 KV ANJANGAON (VIHIGAON) - AKOLA CKT I     | IntraState                | 04/01/2025   | 16:15        | 04/01/2025 | 23:11      | T           | R-PH tripped CKT is in charged condition at 220kv akola end.                                                                                                                                                                                                                                                                     |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jan/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jan/2025

| Name of Line                                       | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                            |
|----------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220kV Koradi-2 - Uppalwadi ckt 1                   | IntraState                | 05/01/2025   | 08:10        | 05/01/2025 | 17:25      | HT          | Safety reasons due to civil work for construction and height raising of damage power cable joint box jib 1 & jib2a at 3x660 mw ktps premises.                               |
| HINJAWADI I- CHINCHWAD                             | IntraState                | 05/01/2025   | 10:11        | 05/01/2025 | 17:38      | HT          | Load management.                                                                                                                                                            |
| BOISAR II - TARAPUR                                | IntraState                | 05/01/2025   | 10:34        | 05/01/2025 | 14:32      | PO          | Boisar feeder outage is required for back charging of TAPS 220 KV Zone-III bus from Boisar feeder & to replace the corroded Zone-1 gantry structure at TAPS 1&2 switchyard. |
| KAMBA - VASAI                                      | IntraState                | 05/01/2025   | 10:45        | 05/01/2025 | 18:50      | PO          | For attending Hotspot on Line Isolator                                                                                                                                      |
| KAMBA - VASAI                                      | IntraState                | 05/01/2025   | 10:45        | 05/01/2025 | 18:50      | PO          | Damage Conductor Replace work                                                                                                                                               |
| MALEGAON-SATANA                                    | IntraState                | 05/01/2025   | 11:19        | 05/01/2025 | 18:17      | HT          | Load management.                                                                                                                                                            |
| TATA BORIVLI MSETCL BORIVLI - 5                    | IntraState                | 05/01/2025   | 12:52        | 05/01/2025 | 21:46      | EO          | Tree trimming work                                                                                                                                                          |
| DASTURI-KANDALGAON LINE                            | IntraState                | 05/01/2025   | 14:59        | 05/01/2025 | 17:33      | T           | distance protection                                                                                                                                                         |
| ADLABS - PEDAMBE                                   | IntraState                | 05/01/2025   | 15:00        | 05/01/2025 | 17:45      | T           | distance protection                                                                                                                                                         |
| KANDALGAON - KOYNA (POPHALI)                       | IntraState                | 05/01/2025   | 15:08        | 05/01/2025 | 16:20      | T           | distance protection                                                                                                                                                         |
| 132 KV PARANDA (220 KV) - Kharda                   | IntraState                | 05/01/2025   | 17:27        | 05/01/2025 | 20:40      | T           | K.END B PH 34.9 KM K.END BPH 6.25K KM.                                                                                                                                      |
| 132 KV PARANDA (220 KV) - BHAIKAVNATH COGENERATION | IntraState                | 05/01/2025   | 17:27        | 05/01/2025 | 21:30      | T           | P.END 12.6KA PH B.                                                                                                                                                          |
| PAWANE GIS - NXTRA GIS (NAVI MUMBAI)               | IntraState                | 05/01/2025   | 17:34        | 05/01/2025 | 21:27      | T           | Distance Protection                                                                                                                                                         |
| TROMBAY - KALWA                                    | IntraState                | 05/01/2025   | 17:34        | 05/01/2025 | 20:41      | T           | distance protection                                                                                                                                                         |
| <b>220 KV ICT Outages/Trippings</b>                |                           |              |              |            |            |             |                                                                                                                                                                             |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2                   | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                 |
| 220/132 KV 100 MVA ICT II @ UPPALWADI              | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                 |
| 220/132 KV 100 MVA ICT I @ UPPALWADI               | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                 |
| 220/132 KV 150 MVA PTR NO 7 @ CHINCHWAD            | IntraState                | 11/11/2024   | 03:05        |            |            | T           | Bucholz Protection                                                                                                                                                          |
| 220/100 KV 200 MVA ICT 1 @ BORIVALI                | IntraState                | 03/01/2025   | 08:51        | 05/01/2025 | 21:21      | PO          | Erection of 03 Nos of 245 kV Isolators and 04 Nos. of 100 kV Isolators under LES.                                                                                           |
| 220/132KV 200MVA ICT 6 @ EKLHARE (GCR)             | IntraState                | 04/01/2025   | 09:07        | 04/01/2025 | 16:20      | PO          | RCC to lattice structure replacement of CT                                                                                                                                  |
| 220/132 KV 200MVA ICT 2 @ DHULE                    | IntraState                | 04/01/2025   | 09:32        | 04/01/2025 | 11:37      | HT          | Attending oil leakage of top plate of ICT.                                                                                                                                  |
| 220/33 KV 50 MVA PTR 4 @ WARORA                    | IntraState                | 05/01/2025   | 10:48        | 05/01/2025 | 10:22      | HT          | Oil filtration work by agency m/s. aniket enterprises, pune.                                                                                                                |
| 220/132 KV 100 MVA ICT 1 @ PARANDA                 | IntraState                | 05/01/2025   | 17:27        | 05/01/2025 | 18:45      | T           | OC EF OPTD.                                                                                                                                                                 |
| <b>220 KV BUSBAR Outages/Trippings</b>             |                           |              |              |            |            |             |                                                                                                                                                                             |
| BUS-1@GIS BHANDUP                                  | IntraState                | 03/01/2025   | 23:04        |            |            | EO          | SF6 Gas leakage observed in 220kV Main Bus-I. Outage is required for attending SF6 Gas leakage of 220kV Main Bus-I.                                                         |
| MAIN BUS-PT @TIFIL                                 | IntraState                | 04/01/2025   | 07:29        | 04/01/2025 | 14:48      | PO          | Replacement of 220kV Bus PT Set.(R Y B Ph PT)                                                                                                                               |
| <b>132 KV LINE Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                                                                             |
| MANSAR-PENCH                                       | InterState                | 26/09/2024   | 14:40        |            |            | HT          | H/T at 132KV Pench end                                                                                                                                                      |
| CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP           | IntraState                | 16/10/2024   | 07:02        |            |            | HT          | For Load Management                                                                                                                                                         |
| <b>132 KV ICT Outages/Trippings</b>                |                           |              |              |            |            |             |                                                                                                                                                                             |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jan/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jan/2025

| Name of Line                          | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                   |
|---------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------|
| 132/33 KV 50 MVA PTR 2 @<br>DONDAICHA | IntraState                   | 15/11/2024      | 11:40           |            |               | T              | Tripped on Buchholz alarm                                                                                                                          |
| <b>110 KV LINE Outages/Trippings</b>  |                              |                 |                 |            |               |                |                                                                                                                                                    |
| TATA BORIVLI MSETCL BORIVLI 2         | IntraState                   | 03/01/2025      | 08:50           | 05/01/2025 | 13:53         | PO             | Erection of 03 Nos of 245 kV<br>Isolators and 04 Nos. of 100 kV<br>Isolators under LES.                                                            |
| WAGHIVALI - CHEMBUR                   | IntraState                   | 04/01/2025      | 15:48           |            |               | PO             | pROJECT WORK-Tower erection<br>work at Loc 78N & 126N                                                                                              |
| KALYAN KALWA SALSETTE 1               | IntraState                   | 05/01/2025      | 07:35           | 05/01/2025 | 10:54         | PO             | Loop open and coil back towards<br>Salsette side at loc. 78 (LHS &<br>RHS Ckt) For tower erection at<br>loc. 117 at Shangrila Metro-4<br>Crossing. |
| KALYAN KALWA SALSETTE 2               | IntraState                   | 05/01/2025      | 10:58           | 05/01/2025 | 11:42         | EO             | hanging object removal on 110 kV<br>KKS2                                                                                                           |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage