

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Feb/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	150.945	591.842	1) Gujrat	-9.205	-25.770
2) Hydro	12.450	39.687	2) Madhya Pradesh	4.007	21.920
3) Gas	5.712	22.624	3) Chattisgarh	5.090	17.890
Total MSPGCL	169.107	654.153	4) Maharashtra	175.735	699.004
B) 1) APML	70.619	275.650	5) Goa (Amona)	-1.674	-6.601
2) JSWEL	18.016	69.657	Total	173.953	706.443
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.219	122.105
4) RPL(AMT)	30.961	122.277	b) Mumbai Drawl	35.688	141.030
5) SWPGPL	9.681	38.203	c) MSEDCL Bilateral *	69.940	302.148
6) Other IPP	46.588	185.469	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.177	122.039
C) 1) TPCL Thermal	3.836	15.926	Include PX	0.000	0.000
2) TPCL Hydro	3.977	18.624	Standby	0.043	0.066
3) TPCL Gas	1.833	8.760	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.174	39.199	1) MSEDCL	497.280	1979.898
D) STATE			2) Mumbai Discoms	54.508	223.539
1) Thermal	339.820	1338.223	3) Other Discoms	9.694	39.657
(A1+C1+C4+(B1-B6))			TOTAL STATE	561.482	2243.094
2) Hydro	16.427	58.311			
(A2+C2)					
3) Gas	7.545	31.384			
(A3+B7+C3)					
4) Wind	8.021	51.349			
6) SOLAR	15.716	57.384			
TOTAL STATE	387.529	1536.651			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6612	6239	6707	5917
MSPGCL Hydro	776	342	1160	205
MSPGCL Gas	238	227	238	244
MSPGCL Total Generation	7626	6808	8105	6366
Central Sector Receipt	8761	8716	6351	6130
WIND	297	108	375	613
CPP / IPP Thermal	7642	7427	7766	6849
CPP / IPP Gas	0	0	0	0
SOLAR	1946	2193	0	0
Exchange with Mumbai	-1761	-1877	-1362	-1135
MSEDCL DEMAND MET	24078	22950	20786	18503
Load Shedding	0	0	0	0
MSEDCL DEMAND	24078	22950	20786	18503
TPCL GENERATION	464	389	761	217
AEML GENERATION	492	459	466	303
MUMBAI DEMAND	2717	2725	2589	1655
OTHER DISCOM DEMAND	433	425	449	320
STATE DEMAND MET	27228	26100	23824	20478
STATE DEMAND	27228	26100	23824	20478
Frequency (Hz)	49.96	49.97	50.00	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18:02 Hrs	49.72 Hz at 14:50 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.85	19.72	215	165
Unit 8	13.80	53.93	611	547
Unit 9	13.10	53.30	600	479
Unit 10	12.60	44.51	590	433
Total	44.35	171.46		
Bhusawal				
Unit 3	3.30	12.64	165	110
Unit 4	10.14	39.64	500	275
Unit 5	9.66	38.10	495	280
Total	23.10	90.38		
Parli				
Unit 6	4.29	16.82	232	145
Unit 7	2.21	2.21	158	0
Unit 8	3.87	15.45	218	141
Total	10.37	34.48		
Chandrapur				
Unit 3	3.41	13.28	165	121
Unit 4	3.00	11.85	145	115
Unit 5	6.85	27.68	315	270
Unit 6	8.42	32.21	435	284
Unit 7	0.00	0.00	0	0
Unit 8	11.39	42.37	500	399
Unit 9	0.00	14.70	0	0
Total	33.07	142.09		
Paras				
Unit 3	4.42	15.25	219	150
Unit 4	5.87	22.50	250	231
Total	10.29	37.75		
Khaparkheda				
Unit 1	2.70	10.48	130	95
Unit 2	2.46	10.64	113	92
Unit 3	3.57	13.29	182	127
Unit 4	3.38	13.85	158	127
Unit 5	10.77	41.17	475	360
Total	22.89	89.43		
Nasik				
Unit 3	3.48	14.13	177	115
Unit 4	0.00	2.54	0	0
Unit 5	3.41	9.58	177	110
Total	6.88	26.25		
Uran				
All Units	5.71	22.62	247	224
Total	5.71	22.62		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.71	1.59	53	23
Total	0.71	1.59		
Koyna				
Stage 1-2	2.50	10.40	335	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.98	6.67	652	0
Stage 3	1.02	3.84	240	0
Total	6.50	20.91		
Hydro				
KDPH	0.86	1.88	36	36
VTRNA	0.42	2.02	60	0
TILLARI	0.35	0.70	58	0
BHIRA T.R.	0.28	1.12	80	0
SMLHY_PTN	2.59	8.75	116	100
GHATGHAR	0.74	2.72	125	0
Total	5.24	17.19		
Wind				
Total	8.02	51.35	0	0
Total	8.02	51.35		
CPP				
APML(Mus)	70.62	275.65	0	0
JSWEL(Mus)	18.02	69.66	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.96	122.28	0	0
SWPGPL-Mus	9.68	38.20	0	0
Dhariwal	4.16	18.40	227	127
IEPL	5.23	18.34	264	197
Other(Mus)	37.20	148.73	0	0
Total	175.86	691.26		
SOLAR				
Total	15.72	57.38	0	0
Total	15.72	57.38		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.96	4.81	49	35
Trombay 7B	0.87	3.95	41	33
TATA Hydro	3.98	18.62	441	4
Trombay 8	3.84	15.93	230	132
Total	9.65	43.31		
AEML				
DTPS U-1&2	9.17	39.20	498	288
Total	9.17	39.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	150.94	591.84	MSPGCL Total	169.11	654.15
			MSPGCL Thml+Gas	156.66	614.47	Koyna 1,2 & 4 Total	5.48	17.07
			MSPGCL Hydro	12.45	39.69	State Total	387.53	1536.65

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 04/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5778	199	243	6220	331	6807	0	0	6520	6601	-1394	18210	0	18210	1926	355	20491	49.97
2	5930	204	244	6378	441	6814	0	0	6520	6405	-1263	18429	0	18429	1796	346	20571	50.00
3	5951	205	242	6398	522	6882	0	0	6420	6241	-1190	18529	0	18529	1719	324	20572	50.00
4	5917	205	244	6366	613	6849	0	0	6447	6130	-1135	18503	0	18503	1655	320	20478	50.04
5	6102	204	244	6550	598	6936	0	0	6386	6499	-1150	19110	0	19110	1662	323	21095	50.01
6	6492	204	243	6939	607	7346	0	0	6699	6578	-1261	19847	0	19847	1768	362	21977	50.00
7	6700	332	245	7277	657	7687	0	2	6788	6884	-1198	20915	0	20915	1884	394	23193	50.00
8	6717	1258	247	8222	557	7804	0	222	6476	6576	-1095	21870	0	21870	2035	416	24321	50.02
9	6643	997	246	7886	363	7800	0	864	7128	6945	-1294	22151	0	22151	2267	413	24831	50.06
10	6518	667	240	7425	309	7696	0	1486	7994	8047	-1440	23113	0	23113	2516	410	26039	49.91
11	6612	776	238	7626	297	7642	0	1946	8648	8761	-1761	24078	0	24078	2717	433	27228	49.96
12	6527	571	228	7326	218	7614	0	2144	8817	8937	-1809	24000	0	24000	2762	430	27192	49.96
13	6239	342	227	6808	108	7427	0	2193	8730	8716	-1877	22950	0	22950	2725	425	26100	49.97
14	5675	601	227	6503	83	7009	0	2162	9098	8809	-1908	22245	0	22245	2577	413	25235	50.01
15	5620	976	224	6820	107	6766	0	1925	9129	9137	-1918	22407	0	22407	2580	430	25417	49.85
16	6050	643	224	6917	80	7108	0	1559	9059	9113	-1915	22437	0	22437	2582	425	25444	49.96
17	6457	460	231	7148	73	7563	0	925	8342	8088	-1873	21477	0	21477	2577	447	24501	49.97
18	6593	433	233	7259	89	7677	0	287	7801	7429	-1686	20602	0	20602	2545	453	23600	50.04
19	6649	1088	235	7972	200	7790	0	1	6567	6387	-1408	20487	0	20487	2605	455	23547	49.96
20	6707	1160	238	8105	375	7766	0	0	6465	6351	-1362	20786	0	20786	2589	449	23824	50.00
21	6421	267	243	6931	386	7615	0	0	6405	6161	-1355	19294	0	19294	2466	444	22204	50.03
22	6287	226	241	6754	355	7301	0	0	6509	6270	-1502	18766	0	18766	2322	412	21500	50.04
23	6247	213	242	6702	322	7004	0	0	6544	6479	-1492	18612	0	18612	2181	403	21196	49.96
24	6113	217	243	6573	330	6962	0	0	6544	6411	-1402	18477	0	18477	2052	397	20926	49.92
MUs	150.94	12.45	5.71	169.11	8.02	175.86	0.00	15.72	176.04	173.95	-35.69	497.29	0.00	497.29	54.51	9.68	561.48	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Feb/2023

Position as on 6.30 Hrs of 05/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	22/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16	04/02/2023	03:58	Annual Overhaul	31/01/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
IPP	Dhariwal	300	05/02/2023	00:00		Continued.	Annual Overhaul	22/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	20/02/2023
IPP	JSW (J) U3	300	28/01/2023	06:38		Continued.	Non availability of load schedule	
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24		Continued.	NASHIK TPS U#4 TOLLING FROM DATED 02.02.2023 at 03.43 A.M	06/02/2023
MSPGCL	Chandrapur Unit 9	500	02/02/2023	12:59	05/02/2023	22:36	Boiler Tube Leakage	05/02/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 04/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 05/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (706) OF KORADI 3 CKT-1 @ AKOLA 2	IntraState	04/02/2023	11:20	04/02/2023	17:26	EO	To attending hotspot on 706 CT
400 KV TIEBAY Outages/Trippings							
TIE BAY (415) OF 500MVA ICT - 2 & STATION TF 4A @ DEEPNAGAR	IntraState	02/02/2023	17:54			PO	For servicing & overhauling of 400KV AREVA make STN-4A Tie C.B. Mechanism
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
LAMBOTI - SOLAPUR (PG)	InterState	04/02/2023	10:07	04/02/2023	14:34	PO	string replacement
CHAKAN - TALEGAON(PG)	InterState	04/02/2023	13:26	04/02/2023	17:41	PO	PID scanning of insulator strings
PADGHE - TARAPUR CKT - 1	InterState	05/02/2023	15:58	05/02/2023	18:38	T	Distance Protection
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
NEW KOYNA-KARAD CKT - 2	IntraState	04/02/2023	09:36	04/02/2023	18:31	PO	PID Faulty disc insulator replacement work & Cold line washing work
400 KV ICT Outages/Trippings							
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	03/02/2023	12:46		Continued.	PO	for oil filtration, Dagonostic testing and maintenance work
400/220/33KV 315MVA ICT - 2 @ LONIKAND	IntraState	04/02/2023	08:48	04/02/2023	19:03	PO	O/H & Servicing of 29 C PG Isolator and replacement of PGI mechanism box.
220 KV TBC Outages/Trippings							
TBC @ MAHAPE	IntraState	04/02/2023	11:10	04/02/2023	18:17	PO	CGL make circuit breaker mechanism overhauling work.
TBC @ MAHAPE	IntraState	05/02/2023	10:15	05/02/2023	15:20	PO	CGL make circuit breaker mechanism overhauling work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52	04/02/2023	10:06	HT	To control overloading
NIGADE- PETH LINE	IntraState	30/01/2023	12:32			PO	For erection of new DXS tower at Loc. No. 81(220KV Karad-Mudshingi ckt) for 132KV Peth-Borgaon Line crossing & dismantling of existing D/C tower loc. No. 81 of old Karad - Mudshingi Ckt. 1 & 2 line.
EKLAHARE (OCR) - PADGHE	IntraState	01/02/2023	18:13	05/02/2023	08:20	HT	For load mgmt
CHIKHALI-JALNA I	IntraState	02/02/2023	08:22	04/02/2023	15:16	HT	CONTROL LOADINGOF AKOLA ICT
CHIKHALI-JALNA II	IntraState	02/02/2023	08:22	04/02/2023	15:16	HT	CONTROL LOADINGOF AKOLA ICT
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/02/2023	10:31	04/02/2023	02:32	HT	H/T For Load Management
KHARGHAR - BORIVALI CKT - 2	IntraState	04/02/2023	08:26	04/02/2023	18:45	PO	To attend damage conductor between Loc. No. 2, 3 & 21, 22 by fixing repair sleeve.
KALWA - TFIPL	IntraState	04/02/2023	08:28	04/02/2023	17:26	PO	Outage is required for safety purpose for work of attending damaged conductor between loc no. 2-3 and 21-22 of 220KV Kharghar-Borivali-2 line as both the lines are on same M/C tower.
TALANDGE - SAWANTWADI	IntraState	04/02/2023	09:28	04/02/2023	18:05	PO	Insulator cleaning work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 05/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS SECTION - 1 @ EKLAHARE (GCR)	IntraState	04/02/2023	10:15	04/02/2023	20:38	PO	Hot spot attending work at various location e.g-CT CB,Isolator.Hotline work also involved and Replacement of
PADGHE - TEMGHAR - 2	IntraState	04/02/2023	10:20		Continued.	HT	HT for Load management
KHARGHAR - TOPWORTH	IntraState	04/02/2023	11:14	04/02/2023	17:04	EO	For repair of damaged conductor at loc no 528.
VITA - MIRAJ	IntraState	04/02/2023	12:47	04/02/2023	21:44	PO	Replacement work of DSN String at Loc No.127 Y Ph
INFOSYS - HINJAWADI 1	IntraState	04/02/2023	13:01	04/02/2023	16:54	PO	Jumper connection at tower No 1. JUmpers connection at CTT Removal of jumper at Tower no 4 (220kV Pirungut -Hinjewadi II Line)
PIRANGUT - HINJAWADI 2	IntraState	04/02/2023	13:12	04/02/2023	16:52	PO	Jumper connection at tower No 1. JUmpers connection at CTT Removal of jumper at Tower no 4 (220kV Pirungut -Hinjewadi II Line)
URSE-CHINCHWAD	IntraState	04/02/2023	13:28	04/02/2023	14:35	T	Tripped on dist Protection.
132 KV CHITEGAON - PAITHAN CKT	IntraState	04/02/2023	13:43	04/02/2023	18:43	PO	CT tan delta measurement work is to be carried out.
132KV CHITEGAON(220KV)-SATARA(DEOLAI)CKT	IntraState	04/02/2023	13:43	04/02/2023	17:40	PO	CT tan delta measurement is to be carried out
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	04/02/2023	18:33			HT	For load management
HINJAWADI I- CHINCHWAD	IntraState	04/02/2023	22:05	05/02/2023	01:48	HT	For Talegaon PG - Talegaon Ambi ckt 2 outage
SAHARA-URSE	IntraState	04/02/2023	22:17	05/02/2023	01:47	HT	For 220 KV Talegaon PG - Talegaon Ambi ckt 2 emergency outage
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	04/02/2023	22:17	05/02/2023	00:28	HT	For load management
TALEGAON (AMBI)-TALEGAON (PG) CKT 2	IntraState	04/02/2023	23:06	05/02/2023	01:37	HT	For emergency work at Talegaon PG end .
LONAND-BARAMATI	IntraState	05/02/2023	07:02	05/02/2023	09:36	T	TRIPPED ON DISTANCE PROTECTION
WAGHIVALI - DHARAVI 7	IntraState	05/02/2023	07:17	05/02/2023	08:08	PO	Emergency tree trimming in span 95-96
HINJAWADI I- CHINCHWAD	IntraState	05/02/2023	11:21	05/02/2023	20:22	PO	For insertion of steel cage in the pit of tower no 161 A- Monopole Type 220V MC- PD(30-60)
SAHARA-URSE	IntraState	05/02/2023	12:56	05/02/2023	20:10	HT	H/T FOR TALEGAON AMBI CKT-2 E/O WORK
TALEGAON (AMBI)-TALEGAON (PG) CKT 2	IntraState	05/02/2023	13:29	05/02/2023	20:00	EO	R-ph CT replacement work of PGCIL-II line bay, Half yearly maintenance, Diagnostic testing.
TALANDGE - SAWANTWADI	IntraState	05/02/2023	13:45	05/02/2023	20:05	T	Distance Protection
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	04/02/2023	09:31	04/02/2023	18:17	PO	Anticorrosive Painting/ Chemical Resistance Coating.
220/100 KV 200 MVA ICT 3 @ KALWA	IntraState	04/02/2023	09:46	04/02/2023	16:06	EO	220/100kV, 200MVA ICT-3, Y ph bus isolator bus side jaw hotspot attending work.
220/33KV 50MVA T/F-I @ BRIDGESTONE	IntraState	05/02/2023	08:57	05/02/2023	17:49	PO	For Annual maintence and Testing work of TF and 33kV Bus maintenace work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 05/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 125 MVA ICT 2 @ JAMBHUL	IntraState	05/02/2023	09:50	05/02/2023	18:17	PO	Anticorrosive Painting/ Chemical Resistance Coating.
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	05/02/2023	10:05	05/02/2023	15:05	PO	OLTC repairing work.
110 KV LINE Outages/Trippings							
BHIRA (T) - DAVDI	IntraState	04/02/2023	08:18	04/02/2023	09:47	PO	110 KV BUS OUTAGE AT DAVDI
BHIVPURI - AMBERNATH CKT - 1	IntraState	04/02/2023	10:15	04/02/2023	13:36	PO	Line Side GOD R/M and CT Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage