

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Mar/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	179.768	697.280	1) Gujrat	3.576	18.264
2) Hydro	14.732	45.214	2) Madhya Pradesh	3.387	12.310
3) Gas	5.272	21.285	3) Chattisgarh	3.450	14.750
Total MSPGCL	199.772	763.779	4) Maharashtra	170.350	668.747
B) 1) APLM	62.258	262.295	5) Goa (Amona)	-1.647	-3.374
2) JSWEL	27.700	104.516	Total	179.116	710.697
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.048	111.138
4) RPL(AMT)	31.217	124.790	b) Mumbai Drawl	38.260	150.193
5) SWPGPL	10.469	39.001	c) MSEDCL Bilateral *	87.328	348.058
6) Other IPP	44.918	181.641	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.048	111.138
C) 1) TPCL Thermal	11.726	48.173	Include PX	0.000	0.000
2) TPCL Hydro	2.921	12.905	Standby	0.000	0.000
3) TPCL Gas	2.636	10.936	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.692	46.357	1) MSEDCL	531.615	2099.907
D) STATE			2) Mumbai Discoms	67.235	268.564
1) Thermal	379.748	1504.053	3) Other Discoms	9.991	40.622
(A1+C1+C4+(B1-B6))			TOTAL STATE	608.841	2409.093
2) Hydro	17.653	58.119			
(A2+C2)					
3) Gas	7.908	32.221			
(A3+B7+C3)					
4) Wind	11.140	49.014			
6) SOLAR	13.276	54.989			
TOTAL STATE	429.725	1698.396			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7643	7446	7398	7447
MSPGCL Hydro	898	480	1166	218
MSPGCL Gas	206	204	214	221
MSPGCL Total Generation	8747	8130	8778	7886
Central Sector Receipt	8967	9016	7429	6549
WIND	446	484	325	295
CPP / IPP Thermal	7230	7091	7480	7421
CPP / IPP Gas	0	0	0	0
SOLAR	1928	2000	0	0
Exchange with Mumbai	-1990	-2011	-1788	-1574
MSEDCL DEMAND MET	24893	24280	21773	20156
Load Shedding	0	0	0	0
MSEDCL DEMAND	24893	24280	21773	20156
TPCL GENERATION	772	744	793	741
AEML GENERATION	476	488	499	499
MUMBAI DEMAND	3238	3243	3080	2814
OTHER DISCOM DEMAND	435	430	451	421
STATE DEMAND MET	28566	27953	25304	23391
STATE DEMAND	28566	27953	25304	23391
Frequency (Hz)	49.99	49.97	50.03	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.48 Hz at 18.02 Hrs	49.69 Hz at 21.07 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.94	19.40	210	200
Unit 8	14.74	58.46	639	527
Unit 9	13.91	55.52	630	500
Unit 10	13.07	52.01	575	526
Total	46.66	185.38		
Bhusawal				
Unit 3	3.68	14.02	165	125
Unit 4	10.92	39.63	470	435
Unit 5	11.58	43.58	490	435
Total	26.18	97.24		
Parli				
Unit 6	5.67	18.83	250	202
Unit 7	4.92	19.61	238	104
Unit 8	3.35	13.46	158	128
Total	13.94	51.91		
Chandrapur				
Unit 3	3.87	14.97	170	130
Unit 4	3.38	13.15	150	125
Unit 5	0.00	0.00	0	0
Unit 6	9.51	36.67	410	365
Unit 7	9.55	33.37	421	361
Unit 8	11.82	47.22	500	484
Unit 9	11.66	46.17	500	467
Total	49.79	191.55		
Paras				
Unit 3	4.54	19.96	238	122
Unit 4	5.42	22.11	241	210
Total	9.96	42.07		
Khaparkheda				
Unit 1	2.94	11.79	130	110
Unit 2	3.31	12.83	149	127
Unit 3	4.24	16.13	182	160
Unit 4	3.68	15.77	185	0
Unit 5	11.49	43.34	490	465
Total	25.66	99.86		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.85	14.76	176	127
Unit 5	3.73	14.53	175	96
Total	7.58	29.29		
Uran				
All Units	5.27	21.28	237	203
Total	5.27	21.28		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	0.73	45	0
Total	0.14	0.73		
Koyna				
Stage 1-2	3.56	11.05	420	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.65	12.12	873	0
Stage 3	1.74	4.83	240	0
Total	9.94	28.00		
Hydro				
KDPH	0.86	3.01	36	36
VTRNA	1.01	3.94	61	0
TILLARI	0.29	0.29	58	0
BHIRA T.R.	0.12	0.66	40	0
SMLHY_PTN	2.36	8.59	148	79
GHATGHAR	0.00	0.00	0	0
Total	4.64	16.49		
Wind				
Total	11.14	49.01	0	0
Total	11.14	49.01		
CPP				
APML(Mus)	62.26	262.30	0	0
JSWEL(Mus)	27.70	104.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.22	124.79	0	0
SWPGPL-Mus	10.47	39.00	0	0
Dhariwal	6.31	25.18	273	229
IEPL	6.29	23.38	271	230
Other(Mus)	32.31	133.08	0	0
Total	176.56	712.24		
SOLAR				
Total	13.28	54.99	0	0
Total	13.28	54.99		
Tata				
Trombay 5	7.82	31.26	432	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.48	6.89	107	49
Trombay 7B	1.16	4.04	65	43
TATA Hydro	2.92	12.90	326	2
Trombay 8	3.90	16.91	224	131
Total	17.28	72.01		
AEML				
DTPS U-1&2	11.69	46.36	501	460
Total	11.69	46.36		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	179.77	697.28	MSPGCL Total	199.77	763.78
			MSPGCL Thml+Gas	185.04	718.56	Koyna 1,2 & 4 Total	8.20	23.17
			MSPGCL Hydro	14.73	45.21	State Total	429.72	1698.40

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 04/Mar/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7482	234	233	7949	404	7379	0	0	6650	6687	-1460	20583	0	20583	2571	376	23530	50.00
2	7419	389	235	8043	487	7340	0	0	6628	6827	-1360	20980	0	20980	2418	357	23755	49.98
3	7485	311	235	8031	606	7237	0	0	6922	6671	-1236	20976	0	20976	2287	333	23596	49.98
4	7484	172	237	7893	735	7246	0	0	6680	6656	-1162	21050	0	21050	2207	318	23575	50.01
5	7542	168	234	7944	715	7329	0	0	6676	6578	-1120	21101	0	21101	2181	344	23627	49.99
6	7525	681	237	8443	635	7415	0	0	6486	6687	-1081	21729	0	21729	2257	370	24356	49.99
7	7595	1053	234	8882	620	7473	0	4	6666	6770	-1071	22267	0	22267	2339	412	25017	50.05
8	7717	1244	234	9195	544	7530	0	230	6633	6889	-1134	22843	0	22843	2444	412	25698	50.02
9	7729	740	231	8700	276	7477	0	680	7131	7446	-1352	22778	0	22778	2670	449	25897	50.01
10	7775	618	227	8620	310	7448	0	1236	7562	7718	-1595	23287	0	23287	2935	450	26672	49.94
11	7699	1004	212	8915	321	7390	0	1680	8206	8394	-1844	24408	0	24408	3172	448	28028	50.04
12	7643	898	206	8747	446	7230	0	1928	9081	8967	-1990	24893	0	24893	3238	435	28566	49.99
13	7446	480	204	8130	484	7091	0	2000	9075	9016	-2011	24280	0	24280	3243	430	27953	49.97
14	7263	410	211	7884	479	7089	0	1897	8717	8677	-1944	23647	0	23647	3125	435	27207	49.88
15	7460	592	208	8260	412	7170	0	1590	8601	8798	-2095	23706	0	23706	3142	429	27277	49.88
16	7413	903	205	8521	416	7270	0	1126	8640	8656	-2141	23410	0	23410	3175	438	27023	49.96
17	7437	1331	203	8971	428	7396	0	663	7441	7600	-1856	22744	0	22744	3144	459	26346	50.10
18	7391	763	206	8360	447	7437	0	233	7594	7793	-1663	22144	0	22144	3082	462	25689	50.03
19	7296	579	209	8084	427	7459	0	9	7489	7532	-1722	21320	0	21320	3057	469	24846	50.00
20	7398	1166	214	8778	325	7480	0	0	7323	7429	-1788	21773	0	21773	3080	451	25304	50.03
21	7409	299	216	7924	499	7442	0	0	7221	7142	-1779	20789	0	20789	2982	439	24210	50.03
22	7240	221	216	7677	474	7346	0	0	7129	7001	-1787	20262	0	20262	2892	449	23603	49.99
23	7447	218	221	7886	295	7421	0	0	6542	6549	-1574	20156	0	20156	2814	421	23391	50.02
24	7473	260	204	7937	355	7466	0	0	6543	6631	-1495	20488	0	20488	2780	406	23674	50.02
MUs	179.77	14.73	5.27	199.77	11.14	176.56	0.00	13.28	177.64	179.12	-38.26	531.62	0.00	531.62	67.23	9.99	608.84	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Mar/2023

Position as on 6.30 Hrs of 05/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	06/03/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	boiler tube leakage (under tooling from dtd-27.2.2023 @ 16:00 hrs	
IPP	Adani U-4	660	02/03/2023	00:00		Continued.	APH-A Hot PA bellow leakage	06/03/2023
MSPGCL	Khaparkheda Unit 4	210	04/03/2023	17:35	04/03/2023	20:01	Due to control valves closed.	
MSPGCL	Uran Unit B0	120	04/03/2023	23:58		Continued.	Maintenance work	06/03/2023
MSPGCL	Uran Unit 8	108	04/03/2023	23:58		Continued.	Maintenance work	06/03/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 04/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
LONIKAND I - TALEGAON (PGCIL)	InterState	05/03/2023	18:45		Continued.	PO	Bay ISO Copper contact cleaning work and Relay Testing Works.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
KARAD - TALANDGE CKT - 1	IntraState	04/03/2023	15:12	04/03/2023	18:18	T	Tripped on Distance Protection.
KHADKA-AURANGABAD (WALUJ)	IntraState	04/03/2023	18:02	04/03/2023	21:17	HT	Emergency outage to attend hotspot
BABHALESHWAR - PADGHE CKT-1	IntraState	05/03/2023	09:29	05/03/2023	17:14	PO	Chemical Cleaning of Insulator string and Routine Line maintenance work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	04/03/2023	23:56	05/03/2023	08:21	T	Tripped on NDR optd.
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	05/03/2023	06:16	05/03/2023	12:25	PO	Diagnostic SFRA & DFR testing work,leakage attending work from HV side B ph turrets Bushing.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	05/03/2023	07:57	05/03/2023	19:57	PO	1. The erection work 220kv D-type tower. 2. Tan delta of LV CT & routine maintenance work
220 KV MAINBAY Outages/Trippings							
MAIN BUS - 2 @ NEW KOYNA	IntraState	02/03/2023	11:55	05/03/2023	10:59	PO	A) Bus isolator Routine maint. Works following bay will be transfer on A Bus by TBC Shifting 1) 220KV side ICT-I 2)220KV Pedhambe 3)220KV Niwali 4) 220KV side 25 MVA T/F-II B) Jumper works for ICT-3 New Bay
BUS COUPLER @ KHARGHAR	IntraState	05/03/2023	08:32	05/03/2023	15:59	PO	For Bay strengthening Work & Routine Maintenance Work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54	04/03/2023	06:58	HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - PANCHANAND	IntraState	01/03/2023	22:12	05/03/2023	02:43	PO	For erection of Termination kit on newly erected 2 nos. of newly erected CTT Monopole in between Loc no. 686 - 687.
APTA - KALWA	IntraState	02/03/2023	21:01			EO	Shifting of Kalwa-Apta line from TBC to own CB at Kalwa end. 220kV Kalwa Panchanand Line (under outage) differential relay will be tested by testing team in co-ordination with 220kV TBC. 220KV Kalwa-Panchanand line will be shifted on TBC after outage of Project Dn.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	03/03/2023	10:56	04/03/2023	00:01	HT	For load management
TROMBAY - SALSETTE CKT - 1	IntraState	03/03/2023	22:32	04/03/2023	06:43	PO	Project work of 400 KV KVTL-220 KV Trombay-Vikhroli -III cable mounting on mono pole
TROMBAY - DHARAVI 9	IntraState	03/03/2023	22:44	04/03/2023	04:53	PO	Third Party Work - Diversion of Line at Sejal Shakti Project site
LAMBOTI -SOLAPUR 2(BALE) CKT-2	IntraState	04/03/2023	00:40	04/03/2023	06:06	T	Tripped on Dist. Protection.
EKLAHARE (GCR) - GHATGHAR	IntraState	04/03/2023	06:46	04/03/2023	08:01	T	Tripped at Ghatghar end only
MAIN BUS SECTION - 1 @ EKLAHARE (GCR)	IntraState	04/03/2023	08:52	04/03/2023	20:43	PO	Isolator replacement work Hotline work also required. Hot spot attending work at various location
LONIDEOKAR TAP ON WALCHANDNAGAR- BHIGWAN CKT	IntraState	04/03/2023	09:07	04/03/2023	11:50	PO	To replace flashover string observed at loc. No. 68 R phase on dt. 01.03.2023.
KHARGHAR - SONKHAR	IntraState	04/03/2023	09:36	04/03/2023	19:06	PO	For Bay strengthening Work & Routine Maintenance Work
SALSETTE - SAHAR CKT	IntraState	04/03/2023	10:04	04/03/2023	19:08	PO	TREE TRIMMING
220KV KARJAT-AHMEDNAGAR-CKT-1	IntraState	04/03/2023	10:33	04/03/2023	12:34	PO	Replacement (Tightening) of B ph jump at Loc 108 (Found red hot in thermovision .
BOMBAY DYEING - SAHARA	IntraState	04/03/2023	12:48	04/03/2023	18:42	PO	Work :- 1) 220kV CB overhauling work on 220kV Sahara-Bombay dying Line at 220kV Sahara SS. 2) Inclined string alignment work at Loc. No. 76,77,78 3) Chemical washing work 4) Line Signature test. 5) Jump nut-bolt tightening work at loc no. 122 & 125.
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT II	IntraState	04/03/2023	13:49	04/03/2023	21:05	T	Distance protection
220 KV BAMBHORI - DEEPNAGAR CKT	IntraState	04/03/2023	14:41	04/03/2023	16:01	HT	Emergency outage for attending hot spot
DASTURI-KANDALGAON LINE	IntraState	04/03/2023	16:10	04/03/2023	23:30	PO	Jumper replacement at Loc.No.197,Cold washing of insulator string ,Outage tree cutting and other line maintenance work.
KANDALGAON - KOYNA (POPHALI)	IntraState	04/03/2023	17:06	04/03/2023	17:30	T	Tripped on Distance Protection.
ADLABS - PEDAMBE	IntraState	04/03/2023	17:57	04/03/2023	19:33	T	Tripped on Distance Protection.
EKLAHARE (GCR) - GHATGHAR	IntraState	05/03/2023	01:53	05/03/2023	02:25	T	Tripped on Dist. Protection at Ghatghar end only.
DAHANU - GHODBUNDER CKT - 2	IntraState	05/03/2023	05:02	05/03/2023	10:07	PO	Debunching of lines on tower - LS 98, 101, 111, 258 & SS 261. Post debunching - Line will be reconfigured as earlier i.e. 220 kV Dahanu - Ghodbunder line 02.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KOLSHET - KHARBAO	IntraState	05/03/2023	07:44	05/03/2023	17:02	PO	Shifting of line from ERS system to newly erected towers between loc no 113 to 116.
BOMBAY DYEING - SAHARA	IntraState	05/03/2023	08:28	05/03/2023	18:20	EO	Emergency Bulging of conductor to be attended by replacement of dead end and Tee, palms at location nos 122 and 125.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	05/03/2023	08:39		Continued.	HT	For load management
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
DAHANU - GHODBUNDER CKT - 1	IntraState	05/03/2023	10:48	05/03/2023	13:21	PO	Debunching of lines on tower - LS 98, 101 & SS 82. Post debunching - Line will be reconfigured as earlier i.e.220kV Dahanu - Ghodbunder line 01.
KANDALGAON - KOYNA (POPHALI)	IntraState	05/03/2023	12:04	05/03/2023	20:47	PO	For replacement of bus side jump of B ph WT and Y ph line side jump at Gantry , replacement of Y ph damaged conductor of Gantry to 1 st tower , replacement of bolted T to press T at of B and Y ph LA.
BOISAR - VERSOVA	IntraState	05/03/2023	14:24	05/03/2023	19:37	PO	Debunching of lines on tower - LS 98, 101 and SS 82,Post Debunching - Line will will be reconfigured as earlier i.e. 220kV Dahanu- AEML Versova Line and 220KV MSETCL Boisar- AEML Versova Line.
DAHANU - VERSOVA	IntraState	05/03/2023	14:24	05/03/2023	18:59	PO	Debunching of lines on tower - LS 98, 101 & SS 82 Post debunching - Line will be reconfigured as earlier i.e. 220 kV Dahanu - Versova line & 220 kV Boisar - Versova Line.
KANDALGAON - SONA ALLOYS	IntraState	05/03/2023	16:53	05/03/2023	21:48	PO	Jumper nut bolt tightening work, Outage tree cutting work and other line maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/03/2023	11:09			EO	Replacement of Diverter shaft
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	02/03/2023	03:31			PO	Repairing of OLTC selector switch mechanism situated inside main tank of ICT.
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	03/03/2023	18:10	04/03/2023	04:01	PO	For attending TF oil leakage
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	04/03/2023	10:48	04/03/2023	15:15	PO	For MAIN BUS 2 insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
100 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHAHAPUR - BHATSA	IntraState	05/03/2023	14:24			PO	1. Restoration of the line from ERS system to newly erected tower between Pillar No.10-1 1.of 100KV Bhatsa-Shahapur @Ch.No.667 +197 2) Shifting of the line to ERS system on 100KV Bhatsa - Salambe (Phutali) between Pillar No. 19-20.LILO line @ Ch.No 667+298.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage