

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Mar/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	152.742	642.294	1) Gujrat	3.849	21.053
2) Hydro	6.393	27.672	2) Madhya Pradesh	12.269	45.381
3) Gas	7.226	25.222	3) Chattisgarh	4.220	14.870
Total MSPGCL	166.361	695.188	4) Maharashtra	179.511	679.290
B) 1) APLM	52.616	213.310	5) Goa (Amona)	-1.958	-8.188
2) JSWEL	25.638	98.384	Total	197.891	752.406
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.319	124.526
4) RPL(AMT)	31.206	123.290	b) Mumbai Drawl	32.485	138.251
5) SWPGPL	12.209	48.417	c) MSEDCL Bilateral *	100.845	406.795
6) Other IPP	46.574	188.627	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.319	124.526
C) 1) TPCL Thermal	10.165	42.937	Include PX	0.000	0.000
2) TPCL Hydro	3.206	11.770	Standby	0.000	0.000
3) TPCL Gas	3.743	13.372	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.071	32.989	1) MSEDCL	513.873	2064.623
D) STATE			2) Mumbai Discoms	57.670	239.315
1) Thermal	339.221	1390.248	3) Other Discoms	10.868	42.543
(A1+C1+C4+(B1-B6))			TOTAL STATE	582.411	2346.481
2) Hydro (A2+C2)	9.599	39.442			
3) Gas (A3+B7+C3)	10.969	38.594			
4) Wind	6.674	59.951			
6) SOLAR	18.057	65.844			
TOTAL STATE	384.520	1594.079			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6065	5924	7248	5948
MSPGCL Hydro	397	299	435	172
MSPGCL Gas	291	293	298	310
MSPGCL Total Generation	6753	6516	7981	6430
Central Sector Receipt	10062	9560	8088	6986
WIND	129	131	232	554
CPP / IPP Thermal	6982	6888	7807	6544
CPP / IPP Gas	0	0	0	0
SOLAR	2395	2456	0	0
Exchange with Mumbai	-1929	-2013	-1332	-933
MSEDCL DEMAND MET	23905	23065	22268	19219
Load Shedding	0	0	0	0
MSEDCL DEMAND	23905	23065	22268	19219
TPCL GENERATION	663	632	922	521
AEML GENERATION	380	282	426	301
MUMBAI DEMAND	2972	2927	2680	1755
OTHER DISCOM DEMAND	487	473	508	362
STATE DEMAND MET	27364	26465	25456	21336
STATE DEMAND	27364	26465	25456	21336
Frequency (Hz)	49.98	50.00	50.03	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.3 Hz at 13.03 Hrs	49.82 Hz at 19.17 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.30	16.70	190	155
Unit 8	13.34	55.30	622	387
Unit 9	12.51	48.83	596	440
Unit 10	11.96	51.41	585	465
Total	42.10	172.24		
Bhusawal				
Unit 3	2.22	11.54	180	0
Unit 4	9.16	33.98	500	285
Unit 5	7.32	32.90	500	0
Total	18.70	78.43		
Parli				
Unit 6	3.56	14.26	195	135
Unit 7	3.58	14.20	216	133
Unit 8	3.52	14.21	202	140
Total	10.66	42.66		
Chandrapur				
Unit 3	2.92	12.04	137	103
Unit 4	3.07	12.39	165	120
Unit 5	7.26	28.96	410	272
Unit 6	7.34	28.88	420	265
Unit 7	7.70	29.73	400	282
Unit 8	8.27	33.43	413	280
Unit 9	1.46	27.66	277	0
Total	38.02	173.09		
Paras				
Unit 3	5.32	21.35	251	149
Unit 4	5.42	21.85	256	149
Total	10.74	43.19		
Khaparkheda				
Unit 1	3.50	14.44	180	115
Unit 2	4.00	16.07	202	121
Unit 3	3.76	14.89	175	127
Unit 4	3.70	16.07	191	122
Unit 5	10.89	45.61	495	370
Total	25.86	107.09		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.39	13.02	178	84
Unit 5	3.27	12.56	162	115
Total	6.66	25.59		
Uran				
All Units	7.23	25.22	311	289
Total	7.23	25.22		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.12	0.28	47	0
Total	0.12	0.28		
Koyna				
Stage 1-2	1.57	6.12	145	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	2.30	0	0
Stage 3	0.49	2.06	80	0
Total	2.06	10.49		
Hydro				
KDPH	0.86	3.46	36	36
VTRNA	0.53	2.49	60	0
TILLARI	0.50	1.95	65	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.33	8.87	111	79
GHATGHAR	0.00	0.14	0	0
Total	4.22	16.90		
Wind				
Total	6.67	59.95	0	0
Total	6.67	59.95		
CPP				
APML(Mus)	52.62	213.31	0	0
JSWEL(Mus)	25.64	98.38	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.21	123.29	0	0
SWPGPL-Mus	12.21	48.42	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.73	22.86	259	201
Other(Mus)	36.74	149.34	0	0
JPL	4.10	16.42	199	162
Total	168.24	672.03		
SOLAR				
Total	18.06	65.84	0	0
Total	18.06	65.84		
Tata				
Trombay 5	6.85	28.61	372	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.30	8.05	108	61
Trombay 7B	1.45	5.32	65	50
TATA Hydro	3.21	11.77	363	14
Trombay 8	3.32	14.33	170	128
Total	17.11	68.08		
AEML				
DTPS U-1&2	8.07	32.99	455	282
Total	8.07	32.99		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	152.74	642.29	MSPGCL Total	166.36	695.19
			MSPGCL Thml+Gas	159.97	667.52	Koyna 1,2 & 4 Total	1.57	8.43
			MSPGCL Hydro	6.39	27.67	State Total	384.52	1594.08

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6202	160	308	6670	583	6568	0	0	7121	6807	-1068	19150	0	0	19150	1964	410	21524	50.05
2	5994	161	309	6464	666	6572	0	0	7069	6893	-983	19244	0	0	19244	1845	368	21457	50.00
3	5948	172	310	6430	554	6544	0	0	7004	6986	-933	19219	0	0	19219	1755	362	21336	49.97
4	6003	272	310	6585	413	6569	0	0	6944	7188	-877	19519	0	0	19519	1712	359	21590	50.01
5	6714	179	311	7204	303	6788	0	0	6935	6914	-762	20078	0	0	20078	1715	369	22162	50.03
6	6981	171	311	7463	319	7155	0	0	7507	7213	-913	20857	0	0	20857	1827	380	23064	50.04
7	7224	223	311	7758	364	7377	0	12	7938	7752	-951	21901	0	1	21901	2022	411	24334	49.98
8	7111	335	311	7757	240	7474	0	335	8199	8245	-1112	22496	0	0	22496	2223	443	25162	50.03
9	6525	306	307	7138	149	7270	0	1110	8998	8712	-1352	22550	0	0	22550	2529	477	25556	50.06
10	6136	307	299	6742	131	6971	0	1775	9602	9405	-1589	22951	0	0	22951	2760	484	26195	49.98
11	6106	304	296	6706	128	6811	0	2250	9956	9813	-1817	23410	0	3	23410	2927	481	26818	49.97
12	6065	397	291	6753	129	6982	0	2395	9612	10062	-1929	23905	0	7	23905	2972	487	27364	49.98
13	5924	299	293	6516	131	6888	0	2456	9482	9560	-2013	23065	0	7	23065	2927	473	26465	50.00
14	5744	243	291	6278	171	6604	0	2406	9391	9180	-1833	22334	0	6	22334	2787	472	25593	50.11
15	5478	298	289	6065	207	6560	0	2143	9712	9763	-1797	22472	0	4	22472	2788	469	25729	49.96
16	6165	268	289	6722	238	6755	0	1652	9519	9350	-1790	22445	0	5	22445	2808	482	25735	49.96
17	6250	317	290	6857	275	6900	0	1092	9336	9167	-1762	22023	0	6	22023	2778	506	25307	49.97
18	6527	314	294	7135	288	7118	0	409	8786	8439	-1468	21417	0	3	21417	2752	504	24673	50.04
19	6851	420	296	7567	199	7312	0	22	8106	8140	-1383	21360	0	0	21360	2694	497	24551	50.01
20	7248	435	298	7981	232	7807	0	0	8262	8088	-1332	22268	0	0	22268	2680	508	25456	50.03
21	6631	249	303	7183	174	7584	0	0	8217	7717	-1316	20853	0	0	20853	2519	489	23861	50.04
22	6407	188	301	6896	179	7315	0	0	7735	7517	-1214	20187	0	0	20187	2374	506	23067	49.97
23	6385	187	303	6875	264	7328	0	0	7896	7360	-1165	20183	0	0	20183	2220	479	22882	49.98
24	6123	188	305	6616	337	6991	0	0	7836	7620	-1126	19986	0	0	19986	2092	452	22530	50.02
MUs	152.74	6.39	7.23	166.36	6.67	168.24	0.00	18.06	201.16	197.89	-32.49	513.87	0.00	0.04	513.87	57.67	10.87	582.41	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

- 1) ELR Carried out due to 132 kV BBLR To Rahuri Line over Load Alarm 488 Amp/ 98.05 MW at 132kV Rahuri S/s
- 2) ELR carried out at 132kv Wadzire ss TF1/TF2 21MW.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Mar/2024

Position as on 6.30 Hrs of 05/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	08/03/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Chandrapur Unit 9	500	04/03/2024	05:46	05/03/2024	03:28	Air heater problem	06/03/2024
MSPGCL	Bhusawal Unit 3	210	04/03/2024	06:21	04/03/2024	11:32	ID Fan Problem	05/03/2024
MSPGCL	Bhusawal Unit 3	210	04/03/2024	12.02	04/03/2024	13:20	Drum level high	
MSPGCL	Bhusawal Unit 5	500	04/03/2024	19:54	04/03/2024	22:42	PA Fan problem	
Total Capacity MSPGCL		1648						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1968						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 04/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
TIRODA - KORADI 3 CKT - 2	IntraState	04/03/2024	12:54	04/03/2024	18:01	PO	For main bay CT secondary cable connection and testing
400 KV MAINBAY Outages/Tripping							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42	04/03/2024	19:56	PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
MAIN BAY (404) OF TAPTITANDA CKT - 1 @ EKTUNI	IntraState	04/03/2024	11:24	04/03/2024	17:19	PO	Diagnostic Testing and Routine Maintenance Works
400 KV LINE Outages/Tripping							
AKOLA - WARDHA(PG) CKT - 1	InterState	04/03/2024	11:26	04/03/2024	14:00	T	Teed Differential Protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa-Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
PADGHE - NAGOTHANE CKT - 2	IntraState	29/02/2024	15:34	04/03/2024	18:26	PO	1)Replacement of 29 A Bus All Phase PG Isolator under LES Scheme. 2) Line will be in service on TBC. 3) CB Maintenance work.
JAIGAD - KARAD CKT - 1	IntraState	04/03/2024	00:12	04/03/2024	08:54	HT	To Control grid over Voltage.
NEW KOYNA-KARAD CKT - 1	IntraState	04/03/2024	05:34	04/03/2024	12:25	T	Line tripped on distance protection.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	04/03/2024	12:07	04/03/2024	19:36	PO	At loc no -843 more than 12 nos discs of string found broken. Hence in order avoid future unwanted tripping of said EHV grid connected line outage is required on urgent basis
JAIGAD - KARAD CKT - 2	IntraState	05/03/2024	00:39			HT	For voltage management
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	05/03/2024	06:25			PO	At loc no-843 80% string of R ph is damaged hence in order to avoid futures unwanted tripping of said line outgae is required on urgent basis
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400 KV BR Outages/Tripping							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS & Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
TATA BORIVLI MSETCL BORIVLI - 5	IntraState	02/03/2024	10:30	04/03/2024	17:20	PO	CB Pole & Mechanism overhauling.
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	04/03/2024	01:39	04/03/2024	06:18	PO	METRO-4 PROJECT WORK BY MMRDA IN VICINITY
ANTOP HILL - DHARAVI-1	IntraState	04/03/2024	01:45	04/03/2024	06:11	PO	METRO-4 PROJECT WORK BY MMRDA IN VICINITY
WAGHIVALI - DHARAVI 7	IntraState	04/03/2024	01:54	04/03/2024	06:11	PO	METRO-4 PROJECT WORK BY MMRDA IN VICINITY
PALGHAR - NALASOPARA	IntraState	04/03/2024	05:13	04/03/2024	09:33	PO	Faulty Insulator replacement work identified in PID.
132 KV BHANDARA - KARDHA CKT - II	IntraState	04/03/2024	07:00	04/03/2024	07:50	HT	Shifting the conductors of 132kv tap to tekepar line from ers towers to newly erected towers from loc. no. 04, 05, 06 & 07.
KARAD - MUDSHINGI CKT- 4	IntraState	04/03/2024	10:31	04/03/2024	17:31	PO	For repairing damaged conductor strands by fixing armouring at tower loc no. 133 (Rph), 165-166 (B ph), 191-192 (B ph)
KARAD - MUDSHINGI CKT- 4	IntraState	04/03/2024	10:31	04/03/2024	17:31	PO	Repairing of damaged conductor at various locations by using repair sleeve and armoring.
KARAD - MUDSHINGI CKT- 4	IntraState	04/03/2024	10:31	04/03/2024	17:31	PO	Quarterly Maint work
NEW KOYNA - PEDAMBE	IntraState	04/03/2024	14:35	04/03/2024	19:33	PO	Back up relay commissioning work
132 KV JALNA (220 KV) RAJUR CKT - I	IntraState	04/03/2024	15:02	04/03/2024	17:48	HT	Providing arcing horn, vibration damper of b- phase at loc. no. 57 and 59.
ANTOP HILL - DHARAVI-1	IntraState	05/03/2024	01:58	05/03/2024	05:55	PO	METRO-4 PROJECT WORK BY MMRDA IN VICINITY
WAGHIVALI - DHARAVI 7	IntraState	05/03/2024	01:58	05/03/2024	05:55	PO	METRO-4 PROJECT WORK BY MMRDA IN VICINITY
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	05/03/2024	02:05	05/03/2024	06:12	PO	METRO-4 PROJECT WORK BY MMRDA IN VICINITY
SADAWAGHAPUR KARAD CKT 1	IntraState	05/03/2024	07:03			PO	For replacement work of Main Distance Relay.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	04/03/2024	09:28	04/03/2024	16:51	PO	Quarterly Maintainance works.
220/33kv 50MVA TF-3 @ 5 STAR MIDC	IntraState	04/03/2024	10:18	04/03/2024	16:40	PO	for TF3 LV CT oil leakage attending work on dt. 04.03.2024
220 MVA 220/132 KV ICT 3 @ JALNA	IntraState	04/03/2024	13:25	04/03/2024	14:25	HT	Diagnostic testing work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 05/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33-33KV 100MVA TF- 2 @ ICHALKARANJI - II	IntraState	04/03/2024	15:31	04/03/2024	18:04	PO	1) Quaterly bay maintenace work 2) Hot spot attending work 3)Jump replacement work
132 KV LINE Outages/Trippings							
132 KV KANHAN (220 KV) - PENCH CKT	InterState	04/03/2024	09:16	04/03/2024	15:29	HT	Earthwire replacement & other routine maint. work.
KANHAN-PENCH	IntraState	04/03/2024	09:16	04/03/2024	15:29	PO	For earthwire replacement & other Routine Maint. Work
JALNA (OLD) - JAFRABAD	IntraState	04/03/2024	13:25	04/03/2024	14:25	HT	Outage proposed for replacement of flashover suspension string r phase at loc. no. 102.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	06/02/2024	19:55			PO	PROJECT WORK-Conductor replacement
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage