

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Apr/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	60.744	252.197	1) Gujrat	10.415	41.257
2) Hydro	21.149	71.970	2) Madhya Pradesh	17.038	69.220
3) Gas	6.795	27.250	3) Chattisgarh	8.590	32.290
Total MSPGCL	88.688	351.417	4) Maharashtra	115.020	440.161
B) 1) APLM	63.888	250.110	5) Goa (Amona)	0.000	0.000
2) JSWEL	13.031	44.243	Total	151.063	582.928
3) VIPL	0.000	0.000	a) Mumbai Schedule	17.657	66.780
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	11.445	47.142
5) WPCL	5.468	21.881	c) MSEDCL Bilateral *	49.918	184.526
6) Other IPP	7.888	31.882	Include PX	31.476	116.514
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	17.657	66.780
C) 1) TPCL Thermal	15.447	58.526	Include PX	10.678	41.183
2) TPCL Hydro	2.583	10.267	Standby	0.000	0.000
3) TPCL Gas	2.546	10.230	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.450	44.257	1) MSEDCL	334.511	1306.680
D) STATE			2) Mumbai Discoms	43.471	170.422
1) Thermal	177.916	703.096	TOTAL STATE	377.982	1477.102
(A1+C1+C4+(B1-B6))					
2) Hydro	23.732	82.237			
(A2+C2)					
3) Gas	9.341	37.480			
(A3+B7+C3)					
4) Wind	8.850	42.132			
6) SOLAR	7.080	29.229			
TOTAL STATE	226.919	894.174			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 14 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2678	2565	2442	2684
MSPGCL Hydro	293	357	1041	949
MSPGCL Gas	276	266	286	302
MSPGCL Total Generation	3247	3188	3769	3935
Central Sector Receipt	7688	7999	5302	5280
WIND	260	223	240	468
CPP / IPP Thermal	3824	3795	3768	3685
CPP / IPP Gas	0	0	0	0
SOLAR	1004	948	0	0
Exchange with Mumbai	-481	-701	-559	-407
MSEDCL DEMAND MET	15542	15452	12520	12961
Load Shedding	0	0	0	0
MSEDCL DEMAND	15542	15452	12520	12961
TPCL GENERATION	887	696	851	828
AEML GENERATION	451	371	475	497
MUMBAI DEMAND	1819	1768	1885	1732
STATE DEMAND MET	17361	17220	14405	14693
STATE DEMAND	17361	17220	14405	14693
Frequency (Hz)	49.99	50.02	50.02	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.27 Hz at 18.01 Hrs	49.79 Hz at 22.34 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 04/Apr/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.88	43.55	495	405
Unit 9	11.60	44.18	560	420
Unit 10	10.55	41.87	481	405
Total	33.02	129.60		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.35	39.44	460	0
Unit 9	10.60	41.50	480	400
Total	17.95	80.93		
Paras				
Unit 3	4.95	20.94	243	173
Unit 4	4.83	20.72	229	183
Total	9.78	41.66		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	6.80	27.25	305	265
Total	6.80	27.25		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	0.40	50	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.16	0.40		
Koyna				
Stage 1-2	8.58	26.00	585	40
Stage 4	5.88	23.97	750	0
Stage 3	3.81	11.17	240	0
Total	18.28	61.14		
Hydro				
KDPH	0.89	2.90	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.48	1.93	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.06	0.32	60	0
RNGR+BHTSA	0.33	1.03	14	13
BHANDARDRA	0.47	1.87	20	19
ELDARY	0.00	0.58	0	0
SMLHY_PTN	0.64	2.21	37	24
GHATGHAR	0.00	0.00	0	0
Total	2.87	10.83		
Wind				
Total	8.85	42.13	0	0
Total	8.85	42.13		
CPP				
APML(Mus)	63.89	250.11	0	0
JSWEL(Mus)	13.03	44.24	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	5.47	21.88	0	0
Other(Mus)	7.89	31.88	0	0
Total	90.28	348.12		
SOLAR				
Total	7.08	29.23	0	0
Total	7.08	29.23		
Tata				
Trombay 5	10.18	37.74	468	310
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.42	5.69	61	58
Trombay 7B	1.13	4.54	49	46
Trombay 8	5.26	20.79	234	155
TATA Hydro	2.58	10.27	198	21
Total	20.58	79.02		
AEML				
DTPS U-1&2	11.45	44.26	500	371
Total	11.45	44.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	60.74	252.20	MSPGCL Total	88.69	351.42
			MSPGCL Thml+Gas	67.54	279.45	Koyna 1,2 & 4 Total	14.46	49.97
			MSPGCL Hydro	21.15	71.97	State Total	226.92	894.17

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Apr/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2709	1036	288	4033	590	3687	0	0	5346	5513	-603	13220	0	13220	1989	15209	50.00
2	2682	994	278	3954	557	3710	0	0	5539	5564	-520	13265	0	13265	1880	15145	49.99
3	2708	804	292	3804	552	3689	0	0	5514	5436	-446	13035	0	13035	1798	14833	49.97
4	2684	949	302	3935	468	3685	0	0	5333	5280	-407	12961	0	12961	1732	14693	49.97
5	2623	1352	284	4259	376	3694	0	0	5275	5319	-361	13287	0	13287	1688	14975	49.95
6	2628	1374	305	4307	360	3686	0	0	5899	6192	-350	14195	0	14195	1686	15881	49.94
7	2636	1534	295	4465	355	3713	0	24	6716	7006	-296	15267	0	15267	1654	16921	49.97
8	2609	1604	284	4497	322	3797	0	161	6588	6792	-331	15238	0	15238	1651	16889	50.05
9	2661	1132	301	4094	294	3821	0	427	6311	6324	-381	14579	0	14579	1702	16281	50.01
10	2661	1028	283	3972	386	3814	0	691	6368	6421	-379	14905	0	14905	1762	16667	50.01
11	2649	301	271	3221	344	3822	0	900	6797	6775	-378	14684	0	14684	1809	16493	50.00
12	2678	293	276	3247	260	3824	0	1004	7629	7688	-481	15542	0	15542	1819	17361	49.99
13	2568	231	266	3065	210	3801	0	1029	8052	7788	-675	15218	0	15218	1779	16997	50.02
14	2565	357	266	3188	223	3795	0	948	7831	7999	-701	15452	0	15452	1768	17220	50.02
15	2259	597	276	3132	296	3783	0	801	7865	7803	-630	15185	0	15185	1770	16955	50.00
16	2254	545	265	3064	302	3798	0	580	7950	7797	-407	15134	0	15134	1779	16913	49.95
17	2204	951	278	3433	320	3794	0	349	7027	7068	-361	14603	0	14603	1750	16353	49.96
18	2159	1115	270	3544	294	3776	0	146	6087	6055	-345	13470	0	13470	1728	15198	50.01
19	2374	326	283	2983	305	3787	0	20	5486	5679	-545	12229	0	12229	1721	13950	50.02
20	2442	1041	286	3769	240	3768	0	0	4976	5302	-559	12520	0	12520	1885	14405	50.02
21	2479	726	287	3492	403	3737	0	0	4900	5040	-495	12177	0	12177	1979	14156	50.03
22	2546	650	289	3485	486	3767	0	0	5103	5196	-540	12394	0	12394	2003	14397	50.01
23	2492	939	288	3719	453	3756	0	0	5203	5437	-603	12762	0	12762	2049	14811	49.92
24	2474	1270	282	4026	454	3771	0	0	5425	5589	-651	13189	0	13189	2090	15279	50.00
MUs	60.74	21.15	6.79	88.69	8.85	90.27	0.00	7.08	149.22	151.06	-11.45	334.51	0.00	334.51	43.47	377.98	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Apr/2020

Position as on 6.30 Hrs of 05/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 6	500	23/03/2020	21.59		Continued.	Clinker Removal Work.	
MSPGCL	Khaparkheda Unit 2	210	25/03/2020	18.02		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 1	210	25/03/2020	18.03		Continued.	Reserve Shut Down.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 3	210	25/03/2020	23.55		Continued.	Reserve Shut Down.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Apr/2020

Position as on 6.30 Hrs of 05/Apr/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 4	210	25/03/2020	23.58		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 3	210	26/03/2020	14.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 5	108	27/03/2020	05.53	05/04/2020	11.23	Mal Function	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56		Continued.	Zero Schedule.	
MSPGCL	Khaparkheda Unit 5	500	30/03/2020	17.42	05/04/2020	22.04	Zero schedule.	
IPP	JSW (J) U3	300	31/03/2020	22.46		Continued.	No schedule.	
MSPGCL	Chandrapur Unit-8	500	04/04/2020	14.02	04/04/2020	18.00	PA Fan problem	
MSPGCL	Koyana Unit 6	80	04/04/2020	23.30		Continued.	PLC Problem	
MSPGCL	Chandrapur Unit-8	500	05/04/2020	00.00		Continued.	PA Fan problem	
MSPGCL	Koyana Unit 12	80	05/04/2020	03.10		Continued.	R Phase Pole remains closed during withdrawing of Unit	
MSPGCL	Paras Unit 4	250	05/04/2020	11.31		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Padgha - Boisar (PG)	InterState	25/03/2020	18.00		Continued.	T	Over Voltage
Dhule Sar'Sarovar I	InterState	30/03/2020	17.32		Continued.	HT	Over Voltage
Chandrapur Bhadravati Ckt-IV	InterState	04/04/2020	12.56	05/04/2020	03.14	HT	Isolator Sparking
Chandrapur Bhadravati IV	InterState	05/04/2020	10.06	05/04/2020	17.30	EO	Sparking On R PH Bus 1 Isolator.
Padghe - Kalwa-II	IntraState	22/03/2020	16.57	05/04/2020	10.36	HT	Over Voltage
Karad - Jaigad - II	IntraState	23/03/2020	18.12		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	23/03/2020	20:37	05/04/2020	06.05	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	24/03/2020	20.20		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	25/03/2020	15.38	05/04/2020	06.34	HT	Over Voltage
Padghe - Nagothane - I	IntraState	25/03/2020	16.10		Continued.	T	Over Voltage
New Koyna - Dabhol-I	IntraState	25/03/2020	18.01		Continued.	T	Over Voltage
Koradi-Khaperkhedda I	IntraState	25/03/2020	20.21		Continued.	T	Over Voltage
Kalwa - Talegaon(PG)	IntraState	28/03/2020	16.47		Continued.	HT	Over Voltage
New Koyna - Koyna Stage IV-II	IntraState	01/04/2020	19.46	04/04/2020	08.56	T	Over Voltage
Babhaleshtar - Padghe-I	IntraState	02/04/2020	13.58		Continued.	T	Distance Protection (RFC at 18.38)
Lonikand I - Koyna stage-IV	IntraState	03/04/2020	18.53	04/04/2020	06.16	HT	Over Voltage
New Koyna -Koyna Stage IV-I	IntraState	04/04/2020	11.07	04/04/2020	14.08	EO	To attend Hot Spot
karad -kolhapur-II	IntraState	04/04/2020	19.06		Continued.	T	Over Voltage
New Koyna - Koyna Stage IV-II	IntraState	04/04/2020	20.02	05/04/2020	09.56	T	Over Voltage
Padghe - Kalwa- I	IntraState	05/04/2020	10.38		Continued.	EO	Attending Hot Spot
Karad - Lonikand 1	IntraState	05/04/2020	11.09	05/04/2020	13.13	T	Distance Protection
Bhusawal-Aurangabad	IntraState	05/04/2020	17.39		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	05/04/2020	18.25		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57		Continued.	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	22/03/2020	10.13		Continued.	HT	Hand tripped from LV end to control Over Voltage.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59		Continued.	EO	CT Tan Delta High.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	25/03/2020	22.00		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01		Continued.	HT	LV Side CB Hand Tripped For Voltage.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07		Continued.	HT	Over Voltage
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Mahalakshmi Amona	InterState	04/04/2020	09.50	04/04/2020	12.08	EO	Emergency outage at Goa
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2020

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Lonand-Baramati	IntraState	16/02/2020	09.37		Continued.	PO	Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	02/03/2020	11.12		Continued.	PO	Stringing Of New Earth Wire at loc no.112 to 132.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20		Continued.	HT	Over Voltage
Butibori-Indorama	IntraState	02/04/2020	21.18		Continued.	T	B PH PT Burst At Indorama End.
MALEGAON - KALWAN CKT-2	IntraState	04/04/2020	18.56	04/04/2020	20.47	EO	B phase CT leakage
Deepnagar Khadaka 2	IntraState	04/04/2020	19.54	05/04/2020	04.48	T	Distance Protection
Jejuri (400 Kv)-Jejuri ckt-I	IntraState	05/04/2020	19.29		Continued.	T	Distance Protection
220 KV ICT Outages/Trippings							
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage