

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Apr/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.012	622.614	1) Gujrat	-2.843	-7.558
2) Hydro	27.913	60.071	2) Madhya Pradesh	9.934	36.442
3) Gas	2.719	10.886	3) Chattisgarh	4.570	19.540
Total MSPGCL	189.644	693.571	4) Maharashtra	181.708	708.827
B) 1) APLM	73.111	291.805	5) Goa (Amona)	-1.275	-4.883
2) JSWEL	23.620	87.069	Total	192.094	752.368
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.059	124.405
4) RPL(AMT)	31.204	117.063	b) Mumbai Drawl	35.433	136.823
5) SWPGPL	12.310	48.822	c) MSEDCL Bilateral *	96.804	400.016
6) Other IPP	23.127	96.562	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.059	124.405
C) 1) TPCL Thermal	10.053	38.987	Include PX	0.000	0.000
2) TPCL Hydro	4.320	15.505	Standby	0.000	0.000
3) TPCL Gas	2.002	8.030	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.097	39.915	1) MSEDCL	529.679	2040.667
D) STATE			2) Mumbai Discoms	62.905	239.260
1) Thermal	343.534	1342.837	3) Other Discoms	10.235	40.177
(A1+C1+C4+(B1-B6))			TOTAL STATE	602.819	2320.104
2) Hydro	32.233	75.576			
(A2+C2)					
3) Gas	4.721	18.916			
(A3+B7+C3)					
4) Wind	13.461	61.694			
6) SOLAR	16.776	68.713			
TOTAL STATE	410.725	1567.736			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6671	6627	6584	6700
MSPGCL Hydro	711	467	2103	1143
MSPGCL Gas	112	112	115	112
MSPGCL Total Generation	7494	7206	8802	7955
Central Sector Receipt	9845	9559	7217	6760
WIND	174	203	800	729
CPP / IPP Thermal	6766	6713	6912	6857
CPP / IPP Gas	0	0	0	0
SOLAR	2161	2188	0	0
Exchange with Mumbai	-1838	-1820	-1441	-1076
MSEDCL DEMAND MET	24140	23616	21823	20883
Load Shedding	0	0	0	0
MSEDCL DEMAND	24140	23616	21823	20883
TPCL GENERATION	774	762	936	493
AEML GENERATION	494	496	487	493
MUMBAI DEMAND	3106	3078	2864	2062
OTHER DISCOM DEMAND	462	434	467	342
STATE DEMAND MET	27708	27127	25154	23287
STATE DEMAND	27708	27127	25154	23287
Frequency (Hz)	49.98	50.00	49.99	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 00.09 Hrs	49.78 Hz at 13.01 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.50	18.62	205	130
Unit 8	13.18	53.04	590	512
Unit 9	0.00	0.00	0	0
Unit 10	13.78	53.20	595	540
Total	31.45	124.86		
Bhusawal				
Unit 3	3.44	13.04	160	120
Unit 4	0.00	25.99	0	0
Unit 5	11.49	41.68	500	450
Total	14.92	80.72		
Parli				
Unit 6	5.04	18.16	250	135
Unit 7	5.44	18.04	248	147
Unit 8	3.83	14.23	167	145
Total	14.30	50.42		
Chandrapur				
Unit 3	3.98	14.74	170	150
Unit 4	3.48	13.47	147	142
Unit 5	9.40	34.09	415	345
Unit 6	9.55	33.11	405	370
Unit 7	9.87	35.74	428	342
Unit 8	11.63	40.79	493	472
Unit 9	11.68	44.78	498	472
Total	59.59	216.72		
Paras				
Unit 3	5.37	9.89	242	197
Unit 4	0.00	15.92	0	0
Total	5.37	25.81		
Khaparkheda				
Unit 1	2.82	11.26	125	105
Unit 2	2.62	6.24	125	83
Unit 3	4.33	16.45	184	176
Unit 4	4.31	16.47	190	145
Unit 5	11.36	43.77	495	393
Total	25.45	94.20		
Nasik				
Unit 3	4.09	15.49	176	162
Unit 4	0.00	0.00	0	0
Unit 5	3.83	14.39	171	145
Total	7.92	29.88		
Uran				
All Units	2.72	10.89	115	112
Total	2.72	10.89		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	0.63	23	0
Total	0.13	0.63		
Koyna				
Stage 1-2	5.94	13.69	520	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	13.51	22.04	1006	202
Stage 3	4.19	7.40	320	0
Total	23.64	43.13		
Hydro				
KDPH	0.86	3.46	36	36
VTRNA	1.19	4.76	61	0
TILLARI	0.42	1.82	58	0
BHIRA T.R.	0.24	0.82	77	0
SMLHY_PTN	1.43	5.46	71	53
GHATGHAR	0.00	0.00	0	0
Total	4.14	16.32		
Wind				
Total	13.46	61.69	0	0
Total	13.46	61.69		
CPP				
APML(Mus)	73.11	291.80	0	0
JSWEL(Mus)	23.62	87.07	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.20	117.06	0	0
SWPGPL-Mus	12.31	48.82	0	0
Dhariwal	5.84	22.65	269	177
IEPL	4.76	19.12	224	196
Other(Mus)	12.52	54.78	0	0
Total	163.37	641.32		
SOLAR				
Total	16.78	68.71	0	0
Total	16.78	68.71		
Tata				
Trombay 5	6.66	26.02	370	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.08	4.29	46	43
Trombay 7B	0.93	3.74	40	37
TATA Hydro	4.32	15.50	411	6
Trombay 8	3.39	12.96	186	128
Total	16.38	62.52		
AEML				
DTPS U-1&2	11.10	39.92	499	318
Total	11.10	39.92		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.01	622.61	MSPGCL Total	189.64	693.57
			MSPGCL Thml+Gas	161.73	633.50	Koyna 1,2 & 4 Total	19.45	35.73
			MSPGCL Hydro	27.91	60.07	State Total	410.72	1567.74

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	6673	1327	112	8112	600	6859	0	0	6953	6830	-1254	20763	0	0	20763	2361	384	23508	49.94
2	6700	1307	113	8120	625	6854	0	0	6942	6999	-1160	21080	0	0	21080	2199	358	23637	49.98
3	6700	1143	112	7955	729	6857	0	0	6925	6760	-1076	20883	0	0	20883	2062	342	23287	49.93
4	6674	876	112	7662	696	6852	0	0	7340	7251	-1008	21125	0	0	21125	1978	328	23431	50.00
5	6623	917	114	7654	704	6904	0	0	7520	7608	-928	21594	0	0	21594	1961	349	23903	50.03
6	6606	1306	113	8025	729	6933	0	1	7053	7292	-912	21686	0	0	21686	2044	382	24112	49.98
7	6685	1649	113	8447	720	6888	0	52	7372	7366	-984	22095	0	0	22095	2120	394	24609	50.00
8	6762	1342	113	8217	575	6911	0	510	7465	7474	-1168	22105	0	0	22105	2271	414	24790	50.00
9	6695	565	113	7373	443	6848	0	1108	8070	8366	-1484	22206	0	0	22206	2552	447	25206	49.91
10	6666	554	115	7335	278	6742	0	1677	8729	8943	-1761	22752	0	0	22752	2844	462	26058	49.96
11	6686	539	113	7338	187	6796	0	2051	9436	9671	-1810	23776	0	0	23776	3037	456	27270	50.01
12	6671	711	112	7494	174	6766	0	2161	9753	9845	-1838	24140	0	0	24140	3106	462	27708	49.98
13	6627	467	112	7206	203	6713	0	2188	9548	9559	-1820	23616	0	0	23616	3078	434	27127	50.00
14	6439	341	112	6892	319	6534	0	2103	9658	9673	-1928	23153	0	0	23153	2958	440	26551	50.01
15	6539	545	113	7197	461	6690	0	1947	9833	9591	-2078	23366	0	0	23366	3011	442	26819	49.90
16	6575	1002	114	7691	491	6812	0	1535	9449	9355	-2065	23348	0	0	23348	3030	471	26849	49.92
17	6573	1306	114	7993	580	6805	0	979	9058	9062	-1980	22959	0	0	22959	3011	480	26450	49.97
18	6543	1643	115	8301	641	6712	0	428	8242	7975	-1883	21695	0	0	21695	2956	479	25130	49.99
19	6576	1566	113	8255	708	6819	0	36	7480	7237	-1546	21029	0	0	21029	2869	481	24378	50.00
20	6584	2103	115	8802	800	6912	0	0	6908	7217	-1441	21823	0	0	21823	2864	467	25154	49.99
21	6612	1793	114	8519	749	6823	0	0	6980	7066	-1460	21230	0	0	21230	2785	466	24482	50.01
22	6582	1456	114	8152	711	6775	0	0	6859	6930	-1356	20762	0	0	20762	2668	451	23880	49.98
23	6594	1591	114	8299	723	6862	0	0	6547	6878	-1216	21106	0	0	21106	2596	440	24142	49.98
24	6627	1864	114	8605	615	6705	0	0	6755	7146	-1277	21388	0	0	21388	2544	406	24338	50.00
MUs	159.01	27.91	2.72	189.64	13.46	163.37	0.00	16.78	190.88	192.09	-35.43	529.68	0.00	0.00	529.68	62.91	10.24	602.82	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Apr/2023

Position as on 6.30 Hrs of 05/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 4	210	29/03/2023	04:36		Continued.	Boiler Tube Leakage (Under tolling from 00:00 hrs. from 04.04.23)	
MSPGCL	Uran Unit 6	108	29/03/2023	08:33		Continued.	Zero Schedule	
MSPGCL	Koradi Unit 9	660	31/03/2023	23:45		Continued.	Boiler Tube Leakage	05/04/2023
MSPGCL	Bhusawal Unit 4	500	03/04/2023	17:08	05/04/2023	22:43	Boiler Tube Leakage	
MSPGCL	Paras Unit 4	250	03/04/2023	20:13		Continued.	Boiler Tube Leakage	06/04/2023
MSPGCL	Koyana Unit 3	70	04/04/2023	08:30	04/04/2023	17:00	Preventive Maintenance Work	
MSPGCL	Koradi Unit-10	660	05/04/2023	02:05	05/04/2023	05:28	Condenser vacuum very low.	
MSPGCL	Koradi Unit 6	210	05/04/2023	06:36	05/04/2023	10:24	Bus Bar Protection operated	
IPP	SWPGPL U-1	135	05/04/2023	10:31		Continued.	ID Fan Problem	08/04/2023
MSPGCL	Chandrapur Unit 9	500	05/04/2023	13:28		Continued.	Generator rotor earth fault	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (707) OF KORADI CKT - 1 @ TIRORA	IntraState	05/04/2023	09:45	05/04/2023	18:10	PO	For bay(707) equipment maintenance and testing work.
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/04/2023	00:45	05/04/2023	03:07	EO	For Grass cutting in Pole-2 base filter area
400 KV MAINBAY Outages/Trippings							
400KV BUS BAR PROTECTION SCHEME @ CHANDRAPUR SWITCHING SS	InterState	05/04/2023	12:59	05/04/2023	17:52	PO	Busbar relay testing
MAIN BUS - 1 @ KORADI	IntraState	05/04/2023	06:36	05/04/2023	07:42	T	Bus Fault
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AKOLA - WARDHA(PG) CKT - 2	InterState	04/04/2023	09:38	04/04/2023	19:22	PO	Insulator Replacement Work
CHAKAN - TALEGAON(PG)	InterState	04/04/2023	22:15	05/04/2023	00:25	EO	For attending Hotspot at 400kV Talegaon line bay Y Phase CT of WT side .
KORADI - BHILAI	InterState	05/04/2023	06:36	05/04/2023	08:07	T	Bus Fault
KORADI - SATPUR	InterState	05/04/2023	06:36	05/04/2023	08:13	T	Bus Fault
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
KORADI - KHADKA	IntraState	05/04/2023	06:36	05/04/2023	08:19	T	Bus Fault
KORADI - KHAPERKHEDA CKT - 1	IntraState	05/04/2023	06:36	05/04/2023	12:55	T	Bus Fault
PADGHE - NAGOTHANE CKT - 1	IntraState	05/04/2023	12:37	05/04/2023	19:47	PO	for earth wire restringing work
LONIKAND - JEJURI CKT - 2	IntraState	05/04/2023	12:55	05/04/2023	18:14	HT	For load management
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	04/04/2023	06:27	04/04/2023	14:14	PO	Tan delta & capacitance measurement of Bushing & winding. Testing of CTR make NIFPS by M/s CTR Ltd,Pune for healthiness of NIFPS
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	04/04/2023	08:27	04/04/2023	19:40	PO	1) Erection of tertiary side IPS tube for RRS project work . 2) Routine Bay maintenance work.
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	05/04/2023	06:36	05/04/2023	08:26	T	Bus Fault
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	05/04/2023	09:35			PO	1) Erection of tertiary side IPS tube for RRS project work . 2) Routine Bay maintenance work.
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	05/04/2023	09:35	05/04/2023	17:56	PO	RTV Coating work & routine maintenance work
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	05/04/2023	16:12	05/04/2023	19:20	EO	Attending hot spot at B ph 220 kV LV side Tower jumpcone nutbolts Temp-376 degree
400 KV BUSBAR Outages/Trippings							
400 KV AUX BUS @ CHANDRAPUR	IntraState	04/04/2023	09:54	04/04/2023	14:34	EO	"Replacement of Faulty disc Insulator string at Gantry Loc No. 04 of 400KV Auxiliary Bus. (Section-1) by hot line technique."
400 KV BR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS REACTOR (125 MVar) @ LAMBOTI	IntraState	05/04/2023	17:43	05/04/2023	18:39	PO	CSD Trails for 409-52 Tie CB and commissioning of 409-52 CB
220 KV MAINBAY Outages/Trippings							
220/132KV 100MVA ICT 3	IntraState	05/04/2023	12:55	05/04/2023	18:40	PO	FOR SCADA TESTING WORK(FINAL)
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AEML BORIVALI - TPC BORIVALI LINE	IntraState	20/03/2023	00:14			T	Tripped due to cable joint failure.
RANJANGAON - U TECH SUGAR CKT	IntraState	30/03/2023	13:30			PO	1) Bunching of 220kV Lonikand-Kathapur at 321 opening the jump 2) Bunching of 220kV Utech-Ranjangaon at 303 opening the jump3) after opening jump at 321 & 303 line will be dead. after bunching circuit become 220kV Lonikand2-Ranjangaon & 220kV Kathapur-Utech 4) Tower erection work L.No-16 (inline tower) of 220kV Kathapur-lonikad line (for making LILO of 220kV Lonikand2-Kathapur line at 220kV Khedcity SS)
PARGAON(KATHAPUR)-LONIKAND	IntraState	30/03/2023	13:43			PO	1) Bunching of 220kV Lonikand-Kathapur at 321 opening the jump 2) Bunching of 220kV Utech-Ranjangaon at 303 opening the jump3) after opening jump at 321 & 303 line will be dead. after bunching circuit become 220kV Lonikand2-Ranjangaon & 220kV Kathapur-Utech 4) Tower erection work L.No-16 (inline tower) of 220kV Kathapur-lonikad line (for making LILO of 220kV Lonikand2-Kathapur line at 220kV Khedcity SS)
APTA - KALWA	IntraState	03/04/2023	22:56		Continued.	PO	Erection of Cable Termination kit on newly erected 2 nos. of CTT Monopole with fixing of Cross arm in between loc no. 686 to 687 in r/o newly proposed 220KV GIS substation of M/s. Print House (India) Pvt. Ltd.
CHIKHALI-JALNA II	IntraState	04/04/2023	03:47	04/04/2023	07:57	HT	To control loading on Akola ICT3
CHIKHALI-JALNA I	IntraState	04/04/2023	03:47	04/04/2023	07:57	HT	To control loading on Akola ICT 3
CHEMBUR (AEML) - NERUL (M)	IntraState	04/04/2023	08:01	05/04/2023	06:25	PO	Dimension measurement of conductor and shield inside main bus -1 chamber. Work to be executed under MERC Approved BKC Project Scheme.
MAIN BUS - 1 @ CHEMBUR	IntraState	04/04/2023	08:53	05/04/2023	05:39	PO	Dimension measurement of conductor and shield inside main bus -1 chamber. Work to be executed under MERC Approved BKC Project Scheme.
NIWALI - PAWAS LINE	IntraState	04/04/2023	09:03	04/04/2023	19:10	PO	Outage for cold washing of insulator strings.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	04/04/2023	09:20	04/04/2023	19:09	HT	Load management
NERLE - DASGAON	IntraState	04/04/2023	10:10	04/04/2023	19:22	PO	B Ph CT replacement Work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHIKHALI-JALNA I	IntraState	04/04/2023	16:56	04/04/2023	18:30	EO	Removal of Polythene
CHIKHALI-JALNA I	IntraState	05/04/2023	01:24	05/04/2023	08:22	HT	FOR ICT LOADING AT AKOLA
CHIKHALI-JALNA II	IntraState	05/04/2023	01:24	05/04/2023	08:22	HT	FOR ICT LOADING AT AKOLA
220 KV AMRAVATI - KARANJA CKT	IntraState	05/04/2023	08:12	05/04/2023	11:32	PO	REPLACEMENT OF FLASHOVER DISC AT LOC. NO.313 R PHASE AMRAVATI SIDE APPROVED SUBJECT TO LOAD MANAGEMENT MSETCL DAILY A BALAPUR 220/132KV 100MVA ICT 3 05-APR-23 11:00 05-APR-23 18:00 FOR SCADA TESTING WORK(FINAL)
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	05/04/2023	08:44	05/04/2023	21:53	HT	Load management
KORADI-KHAPERKHEDA	IntraState	05/04/2023	11:07	05/04/2023	16:16	PO	FOR REPLACEMENT OF FLASHOVER STRING INSULATORS AND FIXING OF VIBRATION DAMPER
LAMBOTI - PANDHARPUR	IntraState	05/04/2023	12:47	05/04/2023	13:20	EO	Emergency Tree Trimming removing between loc no.446-447 on immediately basis.
BORIVALI - TARAPUR	IntraState	05/04/2023	12:51			PO	Replacement of Rusted Hardware work under scheme at Loc No.28 To 50, by M/s.BNC Power Project.
PUSAD - HINGOLI	IntraState	05/04/2023	14:02	05/04/2023	17:33	HT	FOR AVAILING EMERGENCY OUTAGE ON 220KV PUSAD-WARDHA (PG) CKT.
PUSAD-GHATODI	IntraState	05/04/2023	14:05	05/04/2023	17:31	HT	FOR AVAILING EMERGENCY OUTAGE ON 220KV PUSAD-WARDHA (PG) CKT.
PUSAD - WARDHA (PG)	IntraState	05/04/2023	14:42	05/04/2023	17:30	EO	Removal of Saree (Cloths) at loc no 192 (At loc 192 Saree Cloth connecting on Y-ph & B-ph & wound up on Arcing Horn of B-ph conductor)
MIRAJ - ICHALKARANJI	IntraState	05/04/2023	15:04	05/04/2023	20:32	EO	1) CB CRM results on higher side required emergency outage to attend 2) Hot spot attending work - CB top plate
KADEGAON-MIRAJ	IntraState	05/04/2023	16:20	05/04/2023	18:36	PO	Quarterly maintenance & Diagnostic testing work
TALANDGE - MUDSHINGI CKT - 1	IntraState	05/04/2023	17:51	05/04/2023	23:20	PO	To attend hot spot observed in thermoscaning at loc no. 1 , 2A, 2, MC-22, 305 & cold line cleaning at loc no. 1 to 7, 293 to 295.
BHUGAON - WARDHA (PG)	IntraState	05/04/2023	19:31	05/04/2023	20:53	HT	To Control State Over Drawl.
KHAREPATAN -PAWAS LINE	IntraState	05/04/2023	19:47	05/04/2023	22:03	EO	Replacement of damaged insulator strings at Loc no 17 Bph.
MUDSHINGI - CHIKODI	IntraState	05/04/2023	20:39	05/04/2023	23:36	EO	For safety purpose for replacement of weak STN string of 220kV Talandge-Mudshingi ckt- 1 on tower loc. no. M/C-11 as per PID testing report. On M/C tower upper circuit is 220kV Talandge-Mudshingi ckt-1 & lower circuit is 220kV Mudshingi-Chikodi, So for work on upper circuit outage required on lower circuit also.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 25 MVA PTR 2 @ NAGOTHANE	IntraState	27/03/2023	09:40			PO	CB replacement work
220/33 KV 50MVA T/F - 2 @ MIRAJ	IntraState	04/04/2023	10:03	04/04/2023	16:52	PO	Y ph CT & Radiator oil leakage attending work.
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	04/04/2023	11:02	04/04/2023	13:23	PO	Hot spot attending and Bay maintenance work
220/132KV 200MVA ICT 1 @ JEUR	IntraState	05/04/2023	10:45	05/04/2023	13:30	PO	Outage is required for Quarterly Maintenance
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	05/04/2023	10:48	05/04/2023	12:42	PO	Outage is required for Quarterly Maintenance
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	04/04/2023	21:59			PO	FOR 400 KV KVPTL WORK
WAGHIVALI - MANKHURD	IntraState	04/04/2023	23:57			PO	FOR 400 KV KVPTL WORK

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage