

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Apr/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	189.249	741.109	1) Gujrat	4.794	22.164
2) Hydro	11.649	42.896	2) Madhya Pradesh	12.161	45.294
3) Gas	7.187	24.580	3) Chattisgarh	2.980	13.620
Total MSPGCL	208.085	808.585	4) Maharashtra	179.168	711.648
B) 1) APMIL	66.354	283.552	5) Goa (Amona)	-2.440	-10.693
2) JSWEL	21.386	84.310	Total	196.663	782.033
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.874	141.551
4) RPL(AMT)	31.770	126.110	b) Mumbai Drawl	37.568	156.184
5) SWPGPL	12.411	49.108	c) MSEDCL Bilateral *	90.926	353.671
6) Other IPP	30.815	124.031	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.874	141.551
C) 1) TPCL Thermal	13.143	49.347	Include PX	0.000	0.000
2) TPCL Hydro	4.469	17.531	Standby	0.000	0.000
3) TPCL Gas	4.125	16.375	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.664	44.562	1) MSEDCL	552.154	2183.106
D) STATE			2) Mumbai Discoms	70.969	283.999
1) Thermal	376.792	1502.129	3) Other Discoms	10.944	43.941
(A1+C1+C4+(B1-B6))			TOTAL STATE	634.067	2511.046
2) Hydro	16.118	60.427			
(A2+C2)					
3) Gas	11.312	40.955			
(A3+B7+C3)					
4) Wind	16.644	59.266			
6) SOLAR	16.538	66.236			
TOTAL STATE	437.404	1729.013			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7164	7997	8033	8263
MSPGCL Hydro	236	506	1112	200
MSPGCL Gas	278	281	373	295
MSPGCL Total Generation	7678	8784	9518	8758
Central Sector Receipt	9750	9127	7629	7542
WIND	285	468	636	911
CPP / IPP Thermal	6603	7080	7247	6521
CPP / IPP Gas	0	0	0	0
SOLAR	2260	1469	7	0
Exchange with Mumbai	-2177	-2150	-1377	-1139
MSEDCL DEMAND MET	23887	24286	23167	22249
Load Shedding	0	0	0	0
MSEDCL DEMAND	23887	24286	23167	22249
TPCL GENERATION	815	861	1273	636
AEML GENERATION	502	503	484	462
MUMBAI DEMAND	3494	3514	3134	2237
OTHER DISCOM DEMAND	512	492	493	344
STATE DEMAND MET	27893	28292	26794	24830
STATE DEMAND	27893	28292	26794	24830
Frequency (Hz)	50.02	49.91	49.97	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 18:02 Hrs	49.72 Hz at 15:27 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Apr/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.44	12.12	195	145
Unit 8	14.24	56.77	608	543
Unit 9	13.48	53.53	625	527
Unit 10	13.48	54.96	595	480
Total	45.65	177.38		
Bhusawal				
Unit 3	3.80	14.60	175	120
Unit 4	11.48	43.71	500	365
Unit 5	10.62	40.46	490	305
Total	25.92	98.78		
Parli				
Unit 6	2.40	15.79	250	0
Unit 7	4.82	18.27	248	137
Unit 8	4.35	18.46	250	110
Total	11.57	52.52		
Chandrapur				
Unit 3	3.59	13.70	160	130
Unit 4	3.82	14.98	170	122
Unit 5	8.73	35.08	420	275
Unit 6	9.23	36.05	445	285
Unit 7	10.42	39.25	467	292
Unit 8	10.07	39.75	425	409
Unit 9	11.48	44.77	493	400
Total	57.34	223.59		
Paras				
Unit 3	4.76	14.15	240	0
Unit 4	5.79	22.17	256	181
Total	10.55	36.32		
Khaparkheda				
Unit 1	3.24	15.02	170	100
Unit 2	4.20	16.20	193	140
Unit 3	4.00	16.13	176	151
Unit 4	4.61	17.34	197	189
Unit 5	10.59	44.10	490	400
Total	26.64	108.77		
Nasik				
Unit 3	3.90	15.02	180	120
Unit 4	3.97	15.26	184	124
Unit 5	3.72	13.46	166	120
Total	11.58	43.74		
Uran				
All Units	7.19	24.58	379	277
Total	7.19	24.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.21	0.66	50	0
Total	0.21	0.66		
Koyna				
Stage 1-2	3.71	11.56	525	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.61	7.41	836	0
Stage 3	1.32	4.30	240	0
Total	7.64	23.26		
Hydro				
KDPH	0.84	3.41	36	12
VTRNA	0.76	3.08	61	0
TILLARI	0.00	1.62	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.27	9.56	100	89
GHATGHAR	0.14	1.96	141	0
Total	4.01	19.63		
Wind				
Total	16.64	59.27	0	0
Total	16.64	59.27		
CPP				
APML(Mus)	66.35	283.55	0	0
JSWEL(Mus)	21.39	84.31	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.77	126.11	0	0
SWPGPL-Mus	12.41	49.11	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.25	24.71	268	248
Other(Mus)	18.68	77.04	0	0
JPL	5.88	22.27	273	203
Total	162.74	667.11		
SOLAR				
Total	16.54	66.24	0	0
Total	16.54	66.24		
Tata				
Trombay 5	8.64	32.17	460	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.58	10.24	108	107
Trombay 7B	1.54	6.14	65	64
TATA Hydro	4.47	17.53	427	40
Trombay 8	4.50	17.18	219	131
Total	21.74	83.25		
AEML				
DTPS U-1&2	11.66	44.56	503	453
Total	11.66	44.56		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	189.25	741.11	MSPGCL Total	208.08	808.58
			MSPGCL Thml+Gas	196.44	765.69	Koyna 1,2 & 4 Total	6.32	18.96
			MSPGCL Hydro	11.65	42.90	State Total	437.40	1729.01

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Apr/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	8247	319	293	8859	1094	7158	0	0	6984	7122	-1126	22703	0	0	22703	2721	404	25828	50.00
2	8329	212	293	8834	1043	6675	0	0	6999	7390	-1056	22517	0	0	22517	2505	369	25391	49.99
3	8335	270	295	8900	1059	6602	0	0	7388	7475	-1201	22489	0	0	22489	2341	346	25176	49.98
4	8263	200	295	8758	911	6521	0	0	7374	7542	-1139	22249	0	0	22249	2237	344	24830	49.96
5	8247	414	297	8958	878	6591	0	0	7410	7618	-1080	22596	0	0	22596	2210	369	25175	49.99
6	8140	749	298	9187	847	6437	0	0	7792	8167	-1064	23184	0	0	23184	2305	390	25879	49.98
7	7940	1392	297	9629	734	6441	0	53	7917	8186	-986	23643	0	0	23643	2433	414	26490	50.02
8	7719	477	296	8492	541	6399	0	448	8398	8573	-1357	22631	0	18	22631	2568	465	25664	50.04
9	7845	339	298	8482	346	6390	0	1063	8296	8250	-1660	22383	0	2	22383	2863	488	25734	49.99
10	7604	289	284	8177	256	6387	0	1633	8796	8929	-1871	23009	0	8	23009	3169	502	26680	49.95
11	7424	236	281	7941	226	6573	0	2056	9703	9520	-2071	23745	0	13	23745	3389	500	27634	49.96
12	7164	236	278	7678	285	6603	0	2260	9874	9750	-2177	23887	0	13	23887	3494	512	27893	50.02
13	7153	238	280	7671	289	6304	0	2313	9641	9457	-2184	23368	0	11	23368	3484	482	27334	50.00
14	6813	241	278	7332	350	6238	0	2148	9756	9532	-2181	22946	0	2	22946	3403	473	26822	49.98
15	7399	422	277	8098	452	6488	0	1872	9440	9609	-2269	23771	0	0	23771	3480	479	27730	49.97
16	7997	506	281	8784	468	7080	0	1469	9165	9127	-2150	24286	0	0	24286	3514	492	28292	49.91
17	7970	734	280	8984	514	7197	0	857	8848	8692	-2011	23733	0	16	23733	3440	500	27673	49.88
18	7980	806	282	9068	524	7189	0	335	8128	8132	-1878	22841	0	5	22841	3324	529	26694	49.99
19	8058	496	323	8877	572	7215	0	24	8112	7800	-1689	22275	0	0	22275	3219	524	26018	50.00
20	8033	1112	373	9518	636	7247	0	7	7796	7629	-1377	23167	0	0	23167	3134	493	26794	49.97
21	8121	320	379	8820	921	7235	0	0	7470	7416	-1318	22581	0	0	22581	3041	493	26115	49.91
22	8125	208	343	8676	1073	7253	0	0	7093	7075	-1260	22341	0	0	22341	2937	476	25754	49.97
23	8183	552	292	9027	1262	7241	0	0	6864	6917	-1226	22764	0	0	22764	2892	457	26113	49.99
24	8160	881	294	9335	1363	7272	0	0	6834	6755	-1237	23043	0	0	23043	2866	445	26354	50.02
MUs	189.25	11.65	7.19	208.09	16.64	162.74	0.00	16.54	196.08	196.66	-37.57	552.15	0.00	0.09	552.15	70.97	10.94	634.07	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132 kV BBLR TO Rahuri Line Over Load Alarm 488 Amp/104 MW

2)DLS carried out in Pune and Karad zone in order to control overloading of 400kV Chakan Talegaon line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Apr/2024

Position as on 6.30 Hrs of 05/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	10/04/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
Total Capacity MSPGCL		188						
Total Capacity PLANNED OUTAGE		188						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	29/03/2024	20:16	04/04/2024	18:30	Zero schedule (Due open cycle can be taken on bar as per MSEDCL requirement)	
MSPGCL	Paras Unit 3	250	04/04/2024	06:50	04/04/2024	09:18	Furnace Pressure High	
MSPGCL	Parli Unit 6	250	04/04/2024	09:50	04/04/2024	22:07	Bus Bar Protection	
MSPGCL	Uran Unit 6	108	04/04/2024	21:37		Continued.	Zero schedule (Due open cycle can be taken on bar as per MSEDCL requirement)	
MSPGCL	Parli Unit 8	250	05/04/2024	05:20		Continued.	clinker formation	06/04/2024
MSPGCL	Koyna STG-IV Unit-3	250	05/04/2024	05:25		Continued.	CB Closing block air pressure fault	05/04/2024
MSPGCL	Nasik Unit 3	210	05/04/2024	07:59		Continued.	Boiler Tube Leakage	
Total Capacity MSPGCL		1546						
IPP								
IPP	JSW (J) U1	300	24/03/2024	00:06		Continued.	CW duct leakage.	06/04/2024
IPP	Adani U-2	660	04/04/2024	00:47	04/04/2024	09:51	Boiler Furnace pressure High	
Total Capacity IPP		960						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2826						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Apr/2024

Position as on 6.30 Hrs of 05/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (705) OF ICT - 2 & BUS REACTOR @ KORADI 3	IntraState	04/04/2024	15:24	04/04/2024	17:39	PO	DGA Test of Current Transformer at Koradi-III SS.
765 KV MAINBAY Outages/Trippings							
MAIN BAY (704) OF ICT - 2 @ KORADI 3	IntraState	04/04/2024	11:36	04/04/2024	14:13	PO	DGA Test of Current Transformer at Koradi-III SS.
400 KV TIEBAY Outages/Trippings							
TIE BAY (423) OF STATION TF - 1 @ KORADI 2	IntraState	03/04/2024	11:26			PO	Overhauling of Circuit breaker
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	28/03/2024	23:52			HT	For load management of Talegaon Chakan line
DABHOL - NAGOTHANE CKT - 2	IntraState	04/04/2024	12:17	04/04/2024	18:48	PO	Cold Washing Work
CHANDRAPUR 2 - KUMBHARGAON(NANDED) CKT - 2	IntraState	04/04/2024	23:07	05/04/2024	04:51	HT	Attained broken conductor strands at loc.44-45.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	04/04/2024	10:19			PO	Stringing of conductor from spare ICT bay to CS type gantry and from CS type gantry to narrow base tower for RRS Scheme of ICTs
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	04/04/2024	14:32	04/04/2024	18:21	PO	For additional water cooling arrangement.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped For Load management
KARAD -MUDSHINGI CKT- 4	IntraState	02/04/2024	08:44			PO	1.Relay retrofitting Work 2.TC2 Circuit Configuration Work 3.DC bifurcation & Panel Rewiring work
BOISAR II - BOISAR (PG) CKT - 1	IntraState	04/04/2024	05:44	04/04/2024	09:48	PO	AMP WORKS
BOISAR II - BOISAR (PG) CKT - 1	IntraState	04/04/2024	05:44	04/04/2024	09:48	PO	Work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
220 KV WARORA - CHANDRAPUR (400 KV) CKT	IntraState	04/04/2024	08:13	04/04/2024	14:55	HT	Fixing of bird diverter on r, y & b-ph conductor between loc no. 02 - 18 by agency m/s. trafotech system pvt. ltd. mumbai.
KORADI-AMBAZARI-I	IntraState	04/04/2024	09:15	04/04/2024	13:08	HT	Diagnostic testing works at amb ss.
220 PARLI U-8 - NEW GCR PARLI CKT II	IntraState	04/04/2024	09:50	04/04/2024	10:33	T	Bus 2 tripped (LBB).

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PARLI NEW TPS - BEED CKT 1	IntraState	04/04/2024	09:50	04/04/2024	18:40	HT	D/P ar opted soft LBB optd 86optd.
MAIN BUS - 2 @ VERSOVA	IntraState	04/04/2024	10:42	04/04/2024	21:48	PO	Attending Main Bus-2 side isolator 189B contact issue of 220kV Versova-MSETCL Boisar Line
220 KV GIRWALI (400 KV) -PARLI U -8 CKT	IntraState	04/04/2024	11:14			HT	ABB make cb overhauling work.
CHIKHALI-JALNA I	IntraState	04/04/2024	11:24	04/04/2024	16:55	HT	Balance work of a/r closing trials of newly commissioned distance relay.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	04/04/2024	13:05	04/04/2024	20:50	PO	For stringing work (construction works) afterwards in 400kV S/C Sugan-Vapi line. Simultaneous outages of both the lines is required.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	04/04/2024	13:32	04/04/2024	21:14	PO	For stringing work (construction works) afterwards in 400kV S/C Sugan-Vapi line. Simultaneous outages of both the lines is required.
MALEGAON - KALWAN CKT-2	IntraState	04/04/2024	15:47	04/04/2024	18:32	PO	1. Old 220kV B Ph PT commissioning work with new 0.2 metering class PT & 220kV Bus PT-2 Isolator alignments work. 2. Bus Isolator Maintenance work
AKOT - BALAPUR	IntraState	04/04/2024	18:23	04/04/2024	19:16	HT	isolator maitanace.
BORIVALI - CTRLS CKT	IntraState	04/04/2024	22:50	05/04/2024	07:11	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KHARGHAR - BORIVALI CKT - 2	IntraState	04/04/2024	22:52	05/04/2024	07:27	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
GIS BHANDUP - BORIVALI	IntraState	04/04/2024	22:55	05/04/2024	07:23	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KALWA - BORIVALI	IntraState	04/04/2024	22:57	05/04/2024	07:35	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KALWA - TFIPL	IntraState	05/04/2024	08:12			PO	1) At 220kV Pawane S/stn: (i) Kalwa line GIS Bay CB CRM, (ii) Insulation Resistance of Kalwa-Pawane line Cable (iii) Partial Discharge Test & iv) 220kV Bay Testing (D08). 2) At 400kV RS Kalwa: All 3 no. 220kV CT replacement work due to heavy leakage.
GHODBUNDER - GORAI	IntraState	05/04/2024	09:07			PO	Preventive maintenance of circuit breaker
220 KV ICT Outages/Trippings							
220/33 KV 50MVA PTR 2	IntraState	27/03/2024	10:27			HT	Overhauling of hv gis hybrid pass (abb make) at 220kV Jalna S/S
220/33 KV 50 MVA PTR 3 @ KHARGHAR	IntraState	04/04/2024	08:15	04/04/2024	17:27	PO	For Replacement of CT secondary side cable upto CT MK box, Diagnostic and R&M Work
220/33 KV 50 MVA 1 PTR @ SHIRSUPHAL	IntraState	04/04/2024	10:10	04/04/2024	13:40	PO	Outage is proposed to carry out diagnostic testing of equipment & quarterly maintenance work.
220/132KV 100MVA ICT 2 @ KATHAPUR	IntraState	04/04/2024	10:30			PO	Attending of Oil leakage on 220 kV R phase bushing
220/33 KV 50 MVA 2 PTR @ SHIRSUPHAL	IntraState	04/04/2024	14:20	04/04/2024	17:30	PO	Outage is proposed to carry out diagnostic testing of equipment & quarterly maintenance work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 05/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132kV 100MVA ICT - 2 @ KALWAN	IntraState	04/04/2024	15:44	04/04/2024	18:17	PO	1. Old 220kV B Ph PT commissioning work with new 0.2 metering class PT & 220kV Bus PT-2 Bus Isolator alignments work. 2. Bus Isolator Maintenance work
220/33 KV 50MVA PTR - 2 @ KALWAN	IntraState	04/04/2024	15:45	04/04/2024	18:20	PO	1. Old 220kV B Ph PT commissioning work with new 0.2 metering class PT & 220kV Buus PT-2 Bus Isolator alignments work.
220/22 KV 50 MVA PTR 1 @ ANANDNAGAR	IntraState	05/04/2024	08:04			PO	1) IR and PI of Transformer 2) Winding tan delta
220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II	IntraState	05/04/2024	09:00			PO	1) Quarterly bay maintenance work 2) Diag Testing Work 3) Attending Hotspot work.
220 KV BUSBAR Outages/Trippings							
BUS SECTION @ KALWAN (BHENDI)	IntraState	04/04/2024	15:48	04/04/2024	18:12	PO	1. old 220kV B Ph PT commissioning work with new 0.2 metering class PT & 220kV Bus PT-2 Bus Isolaotr alignments work. 2. Bus Isolator Maintenance work.
132 KV LINE Outages/Trippings							
NANDURBAR - RAILWAY TSS	IntraState	04/04/2024	14:00	04/04/2024	19:25	HT	Attending oil leakage in ct at railway tss.
132 KV ICT Outages/Trippings							
132/33 KV 50 MVA PTR 1	IntraState	04/04/2024	08:01			HT	Dismantling of existing 132/33kv 25mva tf and erection of new nucon make 132/33kv,50mva,tf.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
110 KV BUSBAR Outages/Trippings							
BUS-3 @ KHOPOLI	IntraState	04/04/2024	01:00	04/04/2024	03:05	PO	110 KV Khopoli-Bokarpada Bkr Main Bus III side jumper removal to facilitated breaker O/H at Khopoli

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage