

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Apr/2025 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 151.840        | 637.858         | 1) Gujrat                      | -0.735         | 0.274           |
| 2) Hydro            | 15.785         | 69.546          | 2) Madhya Pradesh              | 12.346         | 54.856          |
| 3) Gas              | 6.281          | 24.117          | 3) Chattisgarh                 | 5.620          | 17.870          |
| <b>Total MSPGCL</b> | <b>173.906</b> | <b>731.521</b>  | 4) Maharashtra                 | 210.520        | 878.535         |
| B) 1) APLM          | 62.292         | 254.940         | 5) Goa (Amona)                 | -2.720         | -11.331         |
| 2) JSWEL            | 25.594         | 100.938         | <b>Total</b>                   | <b>225.031</b> | <b>940.204</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 43.554         | 174.101         |
| 4) RPL(AMT)         | 31.443         | 125.952         | b) Mumbai Drawl                | 49.587         | 194.014         |
| 5) SWPGPL           | 12.425         | 50.042          | c) MSEDCL Bilateral *          | 113.919        | 494.047         |
| 6) Other IPP        | 18.635         | 75.186          | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 43.554         | 174.101         |
| C) 1) TPCL Thermal  | 10.801         | 43.197          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 5.338          | 19.868          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.123          | 15.799          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.801          | 38.982          | 1) MSEDCL                      | 520.417        | 2152.870        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 79.650         | 311.860         |
| 1) Thermal          | 322.831        | 1327.095        | 3) Other Discoms               | 13.093         | 53.600          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>613.160</b> | <b>2518.330</b> |
| 2) Hydro (A2+C2)    | 21.123         | 89.414          |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 10.404         | 39.916          |                                |                |                 |
| 4) Wind             | 8.419          | 44.210          |                                |                |                 |
| 6) SOLAR            | 25.352         | 77.491          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>388.129</b> | <b>1578.126</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 16 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5096                      | 6071                  | 7230                      | 6595                      |
| MSPGCL Hydro               | 309                       | 903                   | 2005                      | 160                       |
| MSPGCL Gas                 | 257                       | 249                   | 265                       | 266                       |
| MSPGCL Total Generation    | 5662                      | 7223                  | 9500                      | 7021                      |
| Central Sector Receipt     | 10536                     | 10075                 | 8886                      | 8367                      |
| WIND                       | 218                       | 414                   | 367                       | 412                       |
| CPP / IPP Thermal          | 5293                      | 6050                  | 6987                      | 6471                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 3396                      | 2219                  | 0                         | 0                         |
| Exchange with Mumbai       | -2871                     | -2694                 | -1707                     | -1486                     |
| <b>MSEDCL DEMAND MET</b>   | <b>21649</b>              | <b>22699</b>          | <b>23443</b>              | <b>20353</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 21649                     | 22699                 | 23443                     | 20353                     |
| TPCL GENERATION            | 702                       | 720                   | 1212                      | 790                       |
| AEML GENERATION            | 327                       | 481                   | 423                       | 386                       |
| <b>MUMBAI DEMAND</b>       | <b>3900</b>               | <b>3895</b>           | <b>3342</b>               | <b>2662</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>585</b>                | <b>588</b>            | <b>590</b>                | <b>432</b>                |
| STATE DEMAND MET           | 26134                     | 27182                 | 27375                     | 23447                     |
| <b>STATE DEMAND</b>        | <b>26134</b>              | <b>27182</b>          | <b>27375</b>              | <b>23447</b>              |
| Frequency (Hz)             | 49.97                     | 50.01                 | 49.92                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.17 Hz at 14.01 Hrs | 49.64 Hz at 06.15 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 04/Apr/2025

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.93         | 15.59         | 177      | 120      |
| Unit 8             | 12.56        | 51.08         | 555      | 394      |
| Unit 9             | 13.07        | 54.67         | 576      | 391      |
| Unit 10            | 6.47         | 46.24         | 580      | 0        |
| <b>Total</b>       | <b>36.02</b> | <b>167.58</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.14         | 12.66         | 150      | 120      |
| Unit 4             | 9.40         | 36.78         | 495      | 280      |
| Unit 5             | 8.67         | 34.56         | 430      | 285      |
| Unit 6             | 8.00         | 8.00          | 631      | 0        |
| <b>Total</b>       | <b>29.21</b> | <b>92.00</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.26         | 16.91         | 250      | 143      |
| Unit 7             | 4.11         | 7.15          | 241      | 119      |
| Unit 8             | 4.14         | 16.53         | 219      | 147      |
| <b>Total</b>       | <b>12.51</b> | <b>40.59</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.94         | 15.62         | 190      | 119      |
| Unit 4             | 3.27         | 12.87         | 150      | 116      |
| Unit 5             | 8.19         | 33.51         | 400      | 275      |
| Unit 6             | 9.24         | 36.92         | 455      | 280      |
| Unit 7             | 9.13         | 35.56         | 444      | 285      |
| Unit 8             | 9.35         | 37.28         | 445      | 282      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>43.12</b> | <b>171.75</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.36         | 17.60         | 214      | 150      |
| Unit 4             | 4.55         | 18.32         | 218      | 146      |
| <b>Total</b>       | <b>8.90</b>  | <b>35.91</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.56         | 15.14         | 170      | 120      |
| Unit 2             | 2.46         | 14.91         | 183      | 0        |
| Unit 3             | 4.03         | 16.65         | 189      | 126      |
| Unit 4             | 2.58         | 12.77         | 178      | 0        |
| Unit 5             | 0.00         | 30.93         | 0        | 0        |
| <b>Total</b>       | <b>12.63</b> | <b>90.40</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 2.96         | 11.78         | 130      | 117      |
| Unit 4             | 3.33         | 14.46         | 177      | 120      |
| Unit 5             | 3.16         | 13.40         | 162      | 114      |
| <b>Total</b>       | <b>9.45</b>  | <b>39.63</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.28         | 24.12         | 268      | 249      |
| <b>Total</b>       | <b>6.28</b>  | <b>24.12</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.07         | 0.34          | 22       | 0        |
| <b>Total</b>       | <b>0.07</b>  | <b>0.34</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.58          | 9.64          | 465      | 40       |
| Stage 4         | 6.38          | 28.65         | 987      | 0        |
| Stage 3         | 1.96          | 8.76          | 240      | 0        |
| <b>Total</b>    | <b>10.92</b>  | <b>47.05</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.82          | 3.36          | 34       | 34       |
| VTRNA           | 0.83          | 3.33          | 60       | 0        |
| TILLARI         | 0.55          | 2.23          | 61       | 0        |
| BHIRA T.R.      | 0.32          | 1.14          | 40       | 0        |
| SMLHY_PTN       | 2.15          | 11.70         | 94       | 84       |
| GHATGHAR        | 0.20          | 0.72          | 100      | 0        |
| <b>Total</b>    | <b>4.86</b>   | <b>22.49</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 8.42          | 44.21         | 0        | 0        |
| <b>Total</b>    | <b>8.42</b>   | <b>44.21</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 62.29         | 254.94        | 0        | 0        |
| JSWEL(Mus)      | 25.59         | 100.94        | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 31.44         | 125.95        | 0        | 0        |
| SWPGPL-Mus      | 12.42         | 50.04         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00          | 0        | 0        |
| IEPL            | 5.86          | 24.37         | 269      | 180      |
| Other(Mus)      | 6.70          | 26.28         | 0        | 0        |
| JPL             | 6.07          | 24.54         | 274      | 198      |
| <b>Total</b>    | <b>150.39</b> | <b>607.06</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 25.35         | 77.49         | 0        | 0        |
| <b>Total</b>    | <b>25.35</b>  | <b>77.49</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 7.18          | 28.72         | 454      | 264      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 2.59          | 9.82          | 110      | 106      |
| Trombay 7B      | 1.54          | 5.98          | 65       | 63       |
| TATA Hydro      | 5.34          | 19.87         | 370      | 107      |
| Trombay 8       | 3.62          | 14.47         | 226      | 126      |
| <b>Total</b>    | <b>20.26</b>  | <b>78.86</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 9.80          | 38.98         | 500      | 287      |
| <b>Total</b>    | <b>9.80</b>   | <b>38.98</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 151.84      | 637.86        | MSPGCL Total        | 173.91      | 731.52        |
|                |             |         | MSPGCL Thml+Gas | 158.12      | 661.98        | Koyna 1,2 & 4 Total | 8.96        | 38.29         |
|                |             |         | MSPGCL Hydro    | 15.78       | 69.55         | State Total         | 388.13      | 1578.13       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 04/Apr/2025

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | Load Shedding |                          | MSEDC L DEM. WITH LS | MUMBAI DEMAND | OTHER DISCOM DEMAND | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|---------------|--------------------------|----------------------|---------------|---------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |      | THM       | GAS  |       |          |          |                |                  | Planned       | *Transmission Constraint |                      |               |                     |              |            |
| 1            | 6591        | 366   | 264  | 7221   | 537  | 6706      | 0    | 0     | 9189     | 8555     | -1966          | 20555            | 0             | 0                        | 20555                | 3296          | 498                 | 24349        | 49.99      |
| 2            | 6273        | 463   | 265  | 7001   | 492  | 6359      | 0    | 0     | 8643     | 8880     | -1638          | 20621            | 0             | 0                        | 20621                | 3019          | 473                 | 24113        | 49.97      |
| 3            | 6652        | 455   | 266  | 7373   | 390  | 6483      | 0    | 0     | 8391     | 8507     | -1546          | 20759            | 0             | 0                        | 20759                | 2814          | 448                 | 24021        | 50.00      |
| 4            | 6595        | 160   | 266  | 7021   | 412  | 6471      | 0    | 0     | 8687     | 8367     | -1486          | 20353            | 0             | 0                        | 20353                | 2662          | 432                 | 23447        | 50.01      |
| 5            | 6529        | 163   | 266  | 6958   | 341  | 6465      | 0    | 0     | 8756     | 8670     | -1432          | 20565            | 0             | 0                        | 20565                | 2604          | 437                 | 23606        | 50.03      |
| 6            | 6642        | 325   | 266  | 7233   | 224  | 6529      | 0    | 0     | 8972     | 9179     | -1399          | 21298            | 0             | 0                        | 21298                | 2646          | 468                 | 24412        | 49.97      |
| 7            | 6995        | 1087  | 267  | 8349   | 227  | 7014      | 0    | 74    | 8444     | 8682     | -1398          | 22429            | 0             | 0                        | 22429                | 2738          | 519                 | 25686        | 49.92      |
| 8            | 6883        | 643   | 268  | 7794   | 100  | 6926      | 0    | 681   | 8513     | 8669     | -1716          | 21913            | 0             | 0                        | 21913                | 2890          | 541                 | 25344        | 50.04      |
| 9            | 5685        | 417   | 266  | 6368   | 88   | 5985      | 0    | 1648  | 9791     | 9507     | -2185          | 20852            | 0             | 0                        | 20852                | 3217          | 559                 | 24628        | 50.03      |
| 10           | 5456        | 354   | 261  | 6071   | 135  | 5318      | 0    | 2554  | 10219    | 10246    | -2520          | 21224            | 0             | 31                       | 21224                | 3523          | 580                 | 25327        | 49.99      |
| 11           | 5494        | 344   | 259  | 6097   | 165  | 5209      | 0    | 3064  | 10508    | 10563    | -2807          | 21704            | 0             | 10                       | 21704                | 3775          | 587                 | 26066        | 50.01      |
| 12           | 5096        | 309   | 257  | 5662   | 218  | 5293      | 0    | 3396  | 10607    | 10536    | -2871          | 21649            | 0             | 30                       | 21649                | 3900          | 585                 | 26134        | 49.97      |
| 13           | 5135        | 236   | 252  | 5623   | 250  | 5136      | 0    | 3488  | 10668    | 10428    | -2772          | 21582            | 0             | 9                        | 21582                | 3957          | 571                 | 26110        | 49.94      |
| 14           | 4919        | 229   | 255  | 5403   | 354  | 5054      | 0    | 3331  | 10803    | 10641    | -2805          | 21401            | 0             | 0                        | 21401                | 3861          | 577                 | 25839        | 50.06      |
| 15           | 5437        | 363   | 252  | 6052   | 393  | 5464      | 0    | 2981  | 10752    | 10671    | -2925          | 22049            | 0             | 37                       | 22049                | 3945          | 587                 | 26581        | 50.00      |
| 16           | 6071        | 903   | 249  | 7223   | 414  | 6050      | 0    | 2219  | 10793    | 10075    | -2694          | 22699            | 0             | 19                       | 22699                | 3895          | 588                 | 27182        | 50.01      |
| 17           | 6174        | 1191  | 253  | 7618   | 432  | 6024      | 0    | 1409  | 10422    | 9742     | -2570          | 22047            | 0             | 33                       | 22047                | 3877          | 608                 | 26532        | 49.91      |
| 18           | 6629        | 1110  | 259  | 7998   | 409  | 6212      | 0    | 487   | 9620     | 9445     | -2283          | 21672            | 0             | 59                       | 21672                | 3582          | 596                 | 25850        | 49.99      |
| 19           | 7100        | 921   | 263  | 8284   | 352  | 6645      | 0    | 20    | 9096     | 9001     | -1974          | 21732            | 0             | 0                        | 21732                | 3371          | 596                 | 25699        | 49.94      |
| 20           | 7230        | 2005  | 265  | 9500   | 367  | 6987      | 0    | 0     | 8821     | 8886     | -1707          | 23443            | 0             | 0                        | 23443                | 3342          | 590                 | 27375        | 49.92      |
| 21           | 7052        | 1235  | 265  | 8552   | 458  | 7036      | 0    | 0     | 8644     | 8788     | -1613          | 22641            | 0             | 0                        | 22641                | 3207          | 580                 | 26428        | 49.99      |
| 22           | 7094        | 396   | 265  | 7755   | 580  | 7011      | 0    | 0     | 9199     | 9253     | -1821          | 22205            | 0             | 0                        | 22205                | 3116          | 573                 | 25894        | 50.00      |
| 23           | 7086        | 807   | 265  | 8158   | 586  | 7016      | 0    | 0     | 8929     | 9107     | -1801          | 22503            | 0             | 0                        | 22503                | 3155          | 563                 | 26221        | 49.98      |
| 24           | 7022        | 1303  | 267  | 8592   | 495  | 6996      | 0    | 0     | 8396     | 8633     | -1658          | 22520            | 0             | 0                        | 22520                | 3258          | 538                 | 26316        | 49.97      |
| MUs          | 151.84      | 15.79 | 6.28 | 173.91 | 8.42 | 150.39    | 0.00 | 25.35 | 226.86   | 225.03   | -49.59         | 520.42           | 0.00          | 0.23                     | 520.42               | 79.65         | 13.09               | 613.16       | 49.99      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

- 1)LTS Operated at 132kV Dindori S/S due to 132kV Satana-Dindori line overload
- 2)LTS Operatd & ELR carried out at 132kV MIDC A'Nagar S/S due to 132kV Sonewadi to MIDC line overload.
- 3)Due to LTS operated on 220kV Kondhawa-Jejuri line

| Maximum Demand scenario for the date 04/Apr/2025 |                                    |                                   |
|--------------------------------------------------|------------------------------------|-----------------------------------|
| State Demand                                     | MSEDC L Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 27375 MW                                         | 23443 MW                           | 3957 MW                           |
| 20 Hrs                                           | 20 Hrs                             | 13 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW                 | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Apr/2025**

Position as on 6.30 Hrs of 05/Apr/2025

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| FORCED OUTAGE                                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 20/04/2025    |
| MSPGCL                                        | Chandrapur Unit 9       | 500      | 11/01/2025   | 18:55        |            | Continued. | Generator Protection operated                                                                                                                           | 01/05/2025    |
| MSPGCL                                        | Uran Unit 7             | 108      | 04/03/2025   | 14:15        |            | Continued. | Turbine bearing vibration high                                                                                                                          | 20/04/2025    |
| MSPGCL                                        | Uran Unit 5             | 108      | 21/03/2025   | 17:30        | 04/04/2025 | 22:00      | DUE TO A1 BOILER RLA TESTING WORK                                                                                                                       | 06/04/2025    |
| MSPGCL                                        | Bhusawal Unit 6         | 660      | 30/03/2025   | 11:35        | 04/04/2025 | 05:22      | Clinker formation                                                                                                                                       | 03/04/2025    |
| MSPGCL                                        | Khaparkhedha Unit 5     | 500      | 03/04/2025   | 21:43        | 05/04/2025 | 16:12      | Boiler Tube Leakage                                                                                                                                     | 06/04/2025    |
| MSPGCL                                        | Khaparkhedha Unit 2     | 210      | 04/04/2025   | 03:28        | 04/04/2025 | 12:36      | Class A Protection                                                                                                                                      | 04/04/2025    |
| MSPGCL                                        | Koradi Unit-10          | 660      | 04/04/2025   | 10:58        | 04/04/2025 | 16:19      | BOILER MFT OPERATED ON BOTH AIR CYCLE TRIPPED                                                                                                           |               |
| MSPGCL                                        | Khaparkhedha Unit 4     | 210      | 04/04/2025   | 16:26        | 05/04/2025 | 18:49      | High furnace pressure                                                                                                                                   | 06/04/2025    |
| MSPGCL                                        | Koradi Unit-10          | 660      | 04/04/2025   | 19:25        | 04/04/2025 | 23:58      | Due to Electrical Fault.                                                                                                                                |               |
| MSPGCL                                        | Uran Unit A0            | 120      | 05/04/2025   | 06:43        | 05/04/2025 | 20:50      | I & C Problem.                                                                                                                                          | 06/04/2025    |
| MSPGCL                                        | Uran Unit 6             | 108      | 05/04/2025   | 06:44        | 05/04/2025 | 12:28      | Boiler Protection operated                                                                                                                              | 06/04/2025    |
| MSPGCL                                        | Koyna STG-IV Unit-1     | 250      | 05/04/2025   | 15:15        | 05/04/2025 | 17:50      | BUTTERFLY VALVE MAJOR FAULT                                                                                                                             |               |
| Total Capacity MSPGCL                         |                         | 4219     |              |              |            |            |                                                                                                                                                         |               |
| IPP                                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                                           | JPL Unit 1              | 150      | 04/04/2025   | 23:32        | 05/04/2025 | 10:51      | Generator Elect. Fault                                                                                                                                  | 06/04/2025    |
| Total Capacity IPP                            |                         | 150      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/06/2025    |
| CENT.SECTOR                                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/09/2025    |
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE                  |                         | 4689     |              |              |            |            |                                                                                                                                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 04/04/2025   | 22:00        |            | Continued. | Due to No Schedule by MSEDCL (open cycle)                                                                                                               |               |
| Total Capacity MSPGCL                         |                         | 108      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 108      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                                                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Apr/2025**

**Position as on 6.30 Hrs of 05/Apr/2025**

| Generating Company                                | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                        | Expected Date |
|---------------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-----------------------------------------|---------------|
| <b>IPP</b>                                        |                         |          |              |              |           |            |                                         |               |
| IPP                                               | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                    |               |
| IPP                                               | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                    |               |
| IPP                                               | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019) |               |
| IPP                                               | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)  |               |
| <b>Total Capacity IPP</b>                         |                         | 988      |              |              |           |            |                                         |               |
| <b>Total Capacity FORCED OUTAGE DUE TO NO PPA</b> |                         | 988      |              |              |           |            |                                         |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Apr/2025

| Name of Line                                                                       | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                 |
|------------------------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV ICT Outages/Trippings</b>                                                |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                  |
| 765/400 KV 1500MVA ICT - 2 @ PUNE (GIS)                                            | InterState                | 04/04/2025   | 08:42        | 05/04/2025 | 22:16      | PO          | Aux bus extension works (W/o internal conductor fixing)                                                                                                                                                                                                          |
| <b>500 KV LINE Outages/Trippings</b>                                               |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                  |
| CHANDRAPUR - PADGHE HVDC POLE 2                                                    | IntraState                | 04/04/2025   | 15:54        | 04/04/2025 | 18:48      | T           | Moisture ingress                                                                                                                                                                                                                                                 |
| <b>400 KV MAINBAY Outages/Trippings</b>                                            |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                  |
| MAIN BAY 415 REACTOR @ NANDGAONPETH                                                | InterState                | 04/04/2025   | 11:15        | 05/04/2025 | 21:07      | PO          | Outage required for Main Bay-415 of Reactor Transformer for Breaker Maintenance and testing.                                                                                                                                                                     |
| MAIN BAY - 400KV-TARAPUR 3&4-BOISAR-2 AND BOISAR - 400KV - BUS 2 at BOISAR - 400KV | IntraState                | 05/04/2025   | 07:10        | 05/04/2025 | 18:21      | PO          | 410-Bay Amp Work                                                                                                                                                                                                                                                 |
| <b>400 KV LR Outages/Trippings</b>                                                 |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                  |
| 50 MVAR LINE REACTOR OF 400KV KUMBHARGAON(NANDED) CKT 1 AT 400KV PARLI             | IntraState                | 05/03/2025   | 20:45        |            |            | HT          | Due to Voltage constraint LR kept out at Parly ss.                                                                                                                                                                                                               |
| <b>400 KV LINE Outages/Trippings</b>                                               |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                  |
| DHULE - SSNNL CKT - 2                                                              | InterState                | 04/12/2024   | 12:04        |            |            | EO          | 400kV Dhule SSNNL-2 line CB as hydraulic operated CB mechanism oil pressure is 310bar & not building up so it is requested to give permission for shifting of 400KV Dhule SSNNL-2 line load shifting to 400KV TBC urgently & attending same.                     |
| Boisar (PG) - Aurangabad (PG) ckt -1                                               | InterState                | 04/04/2025   | 11:09        |            |            | PO          | Repairing of a damaged sub-conductor that snapped on 12.03.2025. (Non-auto of Ckt#2 is also required.) A simultaneous outage of the 220 kV Tarapur-Boisar line is also necessary, as this line passes underneath the 400 kV Aurangabad-Boisar transmission line. |
| BUS - 2 @ SOLAPUR (PG)                                                             | InterState                | 05/04/2025   | 12:15        | 05/04/2025 | 23:25      | PO          | Replacement of R.Ph CVT due to voltage drift                                                                                                                                                                                                                     |
| DHULE - SSNNL CKT - 2                                                              | InterState                | 05/04/2025   | 12:36        | 05/04/2025 | 19:40      | EO          | 400 kV Dhule - SSNNL Ckt 2 for attending Red Hotspot on Aux. PG isolator of Y-Phase found during thermo-vision.                                                                                                                                                  |
| LONIKAND I - TALEGAON (PGCIL)                                                      | InterState                | 05/04/2025   | 13:08        | 05/04/2025 | 14:30      | T           | Tripped on distance protection                                                                                                                                                                                                                                   |
| LONIKAND I - TALEGAON (PGCIL)                                                      | InterState                | 05/04/2025   | 17:15        |            | Continued. | T           | Tripped on distance protection                                                                                                                                                                                                                                   |
| 220KV KORADI II (400KV)-BUTIBORI 3 CKT I                                           | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                                          |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                                                | IntraState                | 21/03/2025   | 00:53        |            |            | HT          | IN VIEW OF 400KV TALEGAON - CHAKAN LINE LOADING                                                                                                                                                                                                                  |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                                                | IntraState                | 26/03/2025   | 21:30        |            | Continued. | HT          | IN VIEW OF 400KV TALEGAON - CHAKAN LINE LOADING                                                                                                                                                                                                                  |
| PARLI - KARJAT CKT - 2                                                             | IntraState                | 03/04/2025   | 18:59        | 04/04/2025 | 04:59      | T           | Dist. Protection                                                                                                                                                                                                                                                 |
| NEW KOYNA-KARAD CKT - 2                                                            | IntraState                | 04/04/2025   | 09:07        | 04/04/2025 | 14:26      | PO          | Diagnostic testing & Relay testing work , Routine maint. Work                                                                                                                                                                                                    |
| KHADKA-AURANGABAD (WALUJ)                                                          | IntraState                | 04/04/2025   | 11:38        | 04/04/2025 | 18:44      | PO          | 1) Diagnostic Testing and Routine Maintenance work.<br>2) Nut Bolt Tightening and Line Maintenance Work.                                                                                                                                                         |
| CHANDRAPUR-PARLI CKT-3                                                             | IntraState                | 05/04/2025   | 00:53        | 05/04/2025 | 02:31      | T           | Overvoltage                                                                                                                                                                                                                                                      |
| 220 KV CHANDRAPUR GCR (400 KV) - WANI CKT                                          | IntraState                | 05/04/2025   | 10:39        | 05/04/2025 | 17:25      | PO          | Diagnostic testing work.                                                                                                                                                                                                                                         |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Apr/2025

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                             |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|
| JEJURI- KOYNA STAGE-IV                        | IntraState                | 05/04/2025   | 12:32        | 05/04/2025 | 14:50      | T           | Tripped on distance protection.                                                                                                                              |
| PADGHE - NAGOTHANE CKT - 2                    | IntraState                | 05/04/2025   | 15:28        | 05/04/2025 | 19:36      | EO          | for removing of broken Earth wire between loc no 324-325                                                                                                     |
| PARLI - KARJAT CKT - 2                        | IntraState                | 05/04/2025   | 16:07        | 05/04/2025 | 18:59      | EO          | To replacement of 29A B-ph(RYB) main bus-1 horizontal rod by hot line method.                                                                                |
| <b>400 KV ICT Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                                              |
| STATION TF No 3 @ CHANDRAPUR GCR              | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                               |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA           | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                      |
| 105 MVA SPARE ICT @ CHAKAN                    | IntraState                | 26/02/2025   | 10:59        |            |            | PO          | Long Duration outage required for Rapid restoration scheme work of ICT at 400kV Chakan s/sn                                                                  |
| 400/220/33 KV 315 MVA ICT - 3 @ KHARGHAR      | IntraState                | 31/03/2025   | 13:33        |            |            | EO          | For<br>1) Shifting of ICT3 LV bay to ICT4 LV side.<br>2) Building of incomplete firewall between ICT3 & ICT4.                                                |
| 400/220 KV 3X105 MVA ICT - 1 @ PADGHE         | IntraState                | 04/04/2025   | 16:03        | 04/04/2025 | 22:50      | T           | Tripped on NDR                                                                                                                                               |
| 400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR       | IntraState                | 04/04/2025   | 22:56        | 05/04/2025 | 07:26      | EO          | For connecting New 220kV bay to ICT1 LV Bay                                                                                                                  |
| 400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR      | IntraState                | 05/04/2025   | 08:22        | 05/04/2025 | 13:20      | PO          | For Diagnostic Testing of ICT with Routine Pre-Monsoon Maintenance Work on Both HV & LV Bay                                                                  |
| 400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR   | IntraState                | 05/04/2025   | 09:44        | 05/04/2025 | 16:17      | EO          | 400/220KV 315MVA ICT-2 HV Trip circuit -1 faulty indication displayed. Trip circuit fuse is blowing for respective trip circuit after replacement of fuse.   |
| <b>220 KV TIEBAY Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                              |
| 220 KV TBC @ AMBAZARI                         | IntraState                | 04/04/2025   | 15:09        | 04/04/2025 | 16:59      | PO          | Diagnostic testing work                                                                                                                                      |
| <b>220 KV MAINBAY Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                              |
| 220KV BUS SECTION BAY @ PEDAMBE               | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                 |
| 220 KV BUS SECTION II                         | IntraState                | 04/04/2025   | 10:41        | 04/04/2025 | 12:36      | PO          | Bus isolator maintenance work of 220kV Nagewadi Bhokardan line 2.                                                                                            |
| 220KV PADEGAON WALUJ CKT 3                    | IntraState                | 04/04/2025   | 11:15        | 04/04/2025 | 19:21      | PO          | Replacement of NIT switch at 220kV Padegaon end.                                                                                                             |
| 220 KV BUS SECTION I                          | IntraState                | 04/04/2025   | 14:54        | 04/04/2025 | 18:28      | PO          | Bus isolator maintenance work of 220kV Nagewadi Bhokardan line 1.                                                                                            |
| <b>220 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                              |
| PRINT HOUSE - NAVI MUMBAI (PG)                | InterState                | 05/12/2024   | 23:09        |            |            | EO          | 1) For bunching at TL no 678/1 with 220kV Kalwa-Panchanand line to provide 2nd source to Panchanand & Taloja s/stn.<br>2)For opening jumpers at TL no 678/1. |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2         | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                          |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II    | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                        |
| KALWA - PANCHANAND                            | IntraState                | 17/10/2024   | 12:10        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.                                        |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                         |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Apr/2025

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                     |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 30/12/2024   | 10:44        |            |            | HT          | Hand tripped only at Waghivali (TATA ) End only For load management on 220kV Ulwe - Waghivali ckt -1                                                                                                                                                                 |
| SAKI (AEML) - SAKI (TATA) CKT - 2             | IntraState                | 21/01/2025   | 15:26        |            |            | HT          | Fire Caught near Marve Bridge                                                                                                                                                                                                                                        |
| SAKI (AEML) - SAKI (TATA) CKT - 1             | IntraState                | 21/01/2025   | 15:26        |            |            | HT          | fire caught near Marve bridge                                                                                                                                                                                                                                        |
| 220kV REL Life Science (GIS) - NASIK-1        | IntraState                | 13/03/2025   | 09:38        | 05/04/2025 | 10:35      | HT          | H/T for load management.                                                                                                                                                                                                                                             |
| EKLAHARE (OCR) - NAVASARI CKT - 2             | IntraState                | 25/03/2025   | 18:45        | 05/04/2025 | 09:55      | HT          | H/T for load management.                                                                                                                                                                                                                                             |
| PETH- MUDSHINGI 1 LINE                        | IntraState                | 28/03/2025   | 07:55        |            |            | PO          | For D/C suspension tower replacement at loc no. 167 & 168 by D/C tension towers ( 6 meter & 9 meter extension) for height raising at new NH-166 Ratnagiri-Nagpur highway crossing at Nagaon Village, Kolhapur.                                                       |
| SALSETTE BORIVLI - 2                          | IntraState                | 03/04/2025   | 09:18        |            |            | EO          | Work on Salsette Borivali-2 cable sealing end in vicinity of O/H line                                                                                                                                                                                                |
| 220 KV GIRWALI (400 KV) -MURUD CKT            | IntraState                | 03/04/2025   | 21:29        | 04/04/2025 | 13:17      | T           | Distance protection                                                                                                                                                                                                                                                  |
| PALGHAR - NALASOPARA                          | IntraState                | 04/04/2025   | 00:24        | 04/04/2025 | 07:45      | EO          | For attending damaged conductor between Loc no. 203-24.                                                                                                                                                                                                              |
| PALGHAR - PANCHALI TSS                        | IntraState                | 04/04/2025   | 00:38        | 04/04/2025 | 07:55      | EO          | For attending damaged conductor between Loc no. 203-24.                                                                                                                                                                                                              |
| HINJAWADI I- CHINCHWAD                        | IntraState                | 04/04/2025   | 07:05        | 04/04/2025 | 19:35      | HT          | Load management                                                                                                                                                                                                                                                      |
| ALEPHATA-PARGAON(KATHAPUR)                    | IntraState                | 04/04/2025   | 07:17        | 04/04/2025 | 21:56      | HT          | Load management                                                                                                                                                                                                                                                      |
| PUSAD - HINGOLI                               | IntraState                | 04/04/2025   | 07:38        | 04/04/2025 | 19:38      | PO          | Replacement of faulty string                                                                                                                                                                                                                                         |
| DAHANU - VERSOVA                              | IntraState                | 04/04/2025   | 08:08        | 04/04/2025 | 22:47      | PO          | Relocation / Modification of lines infringing NHAI route-Shifting of lines on permanent towers from ERS at SS 158 & SS 163                                                                                                                                           |
| LOTEPARSHURAM- DASTURI LINE                   | IntraState                | 04/04/2025   | 08:49        | 04/04/2025 | 13:52      | PO          | Replacement of damaged bottom jumpers of R & Y ph Wavetrap of 220KV Dasturi Lote line at 220KV Dasturi S/s.                                                                                                                                                          |
| NERLE - DASGAON                               | IntraState                | 04/04/2025   | 10:29        | 04/04/2025 | 16:46      | PO          | Replacement work of B Ph CT                                                                                                                                                                                                                                          |
| AMBAZARI - KARANJA CKT                        | IntraState                | 04/04/2025   | 10:45        | 04/04/2025 | 14:25      | PO          | Y Diagnostic testing work                                                                                                                                                                                                                                            |
| ALKUD - MENDHEGIRI CKT - 2                    | IntraState                | 04/04/2025   | 10:55        | 04/04/2025 | 16:07      | PO          | Annual Diagnostic Testing Work                                                                                                                                                                                                                                       |
| BOISAR II - TARAPUR                           | IntraState                | 04/04/2025   | 11:11        |            |            | PO          | A simultaneous outage of the 220 kV Tarapur-Boisar line and 400KV -AURANGABAD-BOISAR-1 are required, as 220 kV Tarapur-Boisar line passes underneath the 400 kV Aurangabad-Boisar transmission line in the section where the damaged sub-conductor is to be repaired |
| TALANDGE - SAWANTWADI                         | IntraState                | 04/04/2025   | 12:15        | 04/04/2025 | 15:34      | T           | Tripped on distance protection                                                                                                                                                                                                                                       |
| KHAREPATAN -PAWAS LINE                        | IntraState                | 04/04/2025   | 14:08        | 04/04/2025 | 16:36      | EO          | For replacement string having broken disc insulator.                                                                                                                                                                                                                 |
| PHURSUNGI-PARVATI                             | IntraState                | 04/04/2025   | 17:45        | 04/04/2025 | 22:02      | T           | Conductor Decapping                                                                                                                                                                                                                                                  |
| BHOSARI- BHOSARI 2                            | IntraState                | 04/04/2025   | 22:36        | 05/04/2025 | 00:49      | EO          | 1) 29 C Isolator Jumpering work .(Due to occurrence on dtd.29.03.2025 B Phase 220kV CT burst causing damaged to 29 C & 29 D Isolator)<br>2) Half yearly Maintenance work<br>3) DT work                                                                               |
| HINJAWADI I- CHINCHWAD                        | IntraState                | 04/04/2025   | 22:50        |            | Continued. | HT          | Load management                                                                                                                                                                                                                                                      |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Apr/2025

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                         |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------|
| PALGHAR - PANCHALI TSS                 | IntraState                | 04/04/2025   | 23:25        | 05/04/2025 | 07:12      | PO          | For Replacement of existing 0.4 ACSR by HPC (high performance conductor) at TL No. 204 A-204 D and TL No. 204 D to Palghar S/Stn Gantry. |
| PALGHAR - NALASOPARA                   | IntraState                | 04/04/2025   | 23:27        | 05/04/2025 | 07:16      | PO          | For Replacement of existing 0.4 ACSR by HPC (high performance conductor) at TL No. 204 A-204 D and TL No. 204 D to Palghar S/Stn Gantry. |
| MAIN BUS - 1 @ BHIRA                   | IntraState                | 05/04/2025   | 05:55        | 05/04/2025 | 19:17      | PO          | R/M & Testing                                                                                                                            |
| ALEPHATA-PARGAON(KATHAPUR)             | IntraState                | 05/04/2025   | 07:10        | 05/04/2025 | 21:00      | HT          | Due To Load control.                                                                                                                     |
| BOISAR - VERSOVA                       | IntraState                | 05/04/2025   | 07:41        |            |            | PO          | Relocation / Modification of lines infringing NHAI route-Shifting of lines on permanent towers from ERS at SS 158 & SS 163               |
| NERLE - PEDAMBE                        | IntraState                | 05/04/2025   | 09:30        | 05/04/2025 | 12:30      | PO          | Replacement Work of R Ph wave Trap jump                                                                                                  |
| TILLARI - AMONA LINE                   | IntraState                | 05/04/2025   | 09:34        | 05/04/2025 | 17:59      | PO          | Insulator replacement & SSN to DSN conversion                                                                                            |
| NANDGAON PETH-AMRAVATI                 | IntraState                | 05/04/2025   | 09:50        | 05/04/2025 | 17:20      | PO          | Replacement of disc at suspension location no. 20B phase.                                                                                |
| NIWALI - PAWAS LINE                    | IntraState                | 05/04/2025   | 10:00        | 05/04/2025 | 13:06      | PO          | For LMU replacement work.                                                                                                                |
| BUS - A @ PADGHE                       | IntraState                | 05/04/2025   | 10:58        | 05/04/2025 | 13:06      | EO          | FOR CONNECTION OF 220KV A-BUS GANTRY JUMPER BETWEEN NEW ICT-6 AND EXISTING ICT-5 BY HOTLINE METHOD.                                      |
| MAIN BUS SECTION - 1 @ EKLAHARE (GCR)  | IntraState                | 05/04/2025   | 11:29        | 05/04/2025 | 16:05      | PO          | GCR side isolator of B/S-1 B ph hot spot attending,bypass removing,isloator jaw & blade replacement work.                                |
| KHAPARKHEDA- SURYALAKSHMI              | IntraState                | 05/04/2025   | 14:03        | 05/04/2025 | 15:16      | T           | Distance protection.                                                                                                                     |
| NERLE- POPHALI                         | IntraState                | 05/04/2025   | 15:05        | 05/04/2025 | 18:45      | PO          | 220 KV BAY BY BAY EQUIPMENTS PM WORK & R PHASE CT CHECKING WORK                                                                          |
| NERLE- POPHALI                         | IntraState                | 05/04/2025   | 15:05        | 05/04/2025 | 18:45      | PO          | Maintenance work                                                                                                                         |
| TROMBAY (M) - CHEMBUR CKT - 3          | IntraState                | 05/04/2025   | 16:23        | 05/04/2025 | 18:26      | PO          | For safety purpose for measurement of old rusted cross arms at TL No. 735 in BARC premises.                                              |
| BUS SECTION-6 @ TROMBAY                | IntraState                | 05/04/2025   | 23:42        |            | Continued. | PO          | MAIN BUS-6 CVT TESTING, BUS SECTION-4 CT TESTING                                                                                         |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                          |
| 220/132 KV 80 MVA ICT 1 @ HINGANGHAT   | IntraState                | 19/02/2025   | 12:45        |            |            | HT          | H/T Due to end of expected life of paper insulation of ICT                                                                               |
| 220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA  | IntraState                | 02/04/2025   | 15:43        | 04/04/2025 | 12:20      | PO          | TF oil filtration work                                                                                                                   |
| 220/100 KV 200 MVA ICT 1 @ APTA        | IntraState                | 04/04/2025   | 05:57        | 04/04/2025 | 12:17      | PO          | 1. Diagnostic testing work<br>2. Bay maintenance work                                                                                    |
| 220/132 KV 100 MVA ICT - I @ MALKAPUR  | IntraState                | 04/04/2025   | 08:49        | 04/04/2025 | 18:05      | PO          | Tan delta and Pre monsoon maintenance activity at 220kV substation Malkapur                                                              |
| 220/33 KV 25 MVA T/F 1 @ JATH          | IntraState                | 04/04/2025   | 09:25        | 04/04/2025 | 16:25      | PO          | Transformer painting work                                                                                                                |
| 220/100 KV 100 MVA ICT 2 @ VASAI II    | IntraState                | 04/04/2025   | 11:00        | 04/04/2025 | 20:58      | PO          | For SCADA Point to Point testing at 220kV Vasai S/S by agency under the supervision of Testing team Kalwa.                               |
| 220/33KV 50MVA TF NO.1 @ SAYNE         | IntraState                | 04/04/2025   | 13:45        | 04/04/2025 | 18:55      | PO          | For diagnostic testing work such as CT C-Tann Delta & Bay Maint. work.                                                                   |
| <b>220 KV BUSBAR Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                                          |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Apr/2025**

**Statement-VII**

Position as on 6.30 Hrs of 05/Apr/2025

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                           |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------|
| BUS - B @ PADGHE                          | IntraState                | 05/04/2025   | 08:56        | 05/04/2025 | 10:50      | EO          | FOR CONNECTION OF 220KV B-BUS GANTRY JUMPER BETWEEN NEW ICT-6 AND EXISTING ICT-5 BY HOTLINE METHOD.                        |
| <b>132 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                            |
| MANSAR-PENCH                              | InterState                | 12/02/2025   | 19:12        |            |            | HT          | System Constraints H/T at Pench End.                                                                                       |
| CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP  | IntraState                | 16/10/2024   | 07:02        |            |            | HT          | For Load Management                                                                                                        |
| 132 KV PATHRI-MAJALGAON CKT               | IntraState                | 06/01/2025   | 13:05        |            |            | HT          | After completion of outage on 132kv patri parbhani ckt                                                                     |
| 132 KV BADNAPUR - HYOSUNG (STERLIGHT) CKT | IntraState                | 14/02/2025   | 17:01        |            |            | T           | B - R PH, Z2, 2.56 KA, 26 KM. H - R PH, 3 KA, 700 MTR.                                                                     |
| 132 KV UJANI - BASSK                      | IntraState                | 18/03/2025   | 13:10        |            |            | T           | Distance protection.                                                                                                       |
| 132 KV GANGAKHED - SAIKHEDA - PARLY CKT   | IntraState                | 04/04/2025   | 11:12        | 04/04/2025 | 11:35      | T           | Trip on LTS                                                                                                                |
| GANGAKHED - KANDHAR                       | IntraState                | 04/04/2025   | 11:12        | 04/04/2025 | 11:35      | T           | Trip on LTS                                                                                                                |
| PARLI -GANGAKHED CKT                      | IntraState                | 04/04/2025   | 11:12        | 04/04/2025 | 11:35      | T           | On backup relay                                                                                                            |
| SOLAPUR 2(BALE)-NALDURG                   | IntraState                | 05/04/2025   | 16:48        | 05/04/2025 | 22:17      | EO          | Fixing of Mid span Joint at Loc. No 182 for attaneding damaged conductor. Fixing Vibration Damper from Loc. No 177 to 202. |
| <b>132 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                            |
| 132/33 KV 50 MVA PTR 2 @ DONDAICHA        | IntraState                | 15/11/2024   | 11:40        |            |            | T           | Tripped on Buchholz alarm                                                                                                  |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                            |
| TATA BORIVLI MSETCL BORIVLI 2             | IntraState                | 24/03/2025   | 09:18        |            |            | PO          | Line to be shift on TBC for Overhauling of Pole and Mechanism of 145 kV Circuit Breaker.                                   |
| KHOPOLI - KARANJADE                       | IntraState                | 04/04/2025   | 08:26        | 04/04/2025 | 17:32      | PO          | INSULATOR REPLACEMENT                                                                                                      |
| <b>110 KV BUSBAR Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                            |
| BUS-1 @ KHOPOLI                           | IntraState                | 03/04/2025   | 23:15        | 04/04/2025 | 04:47      | PO          | ATEENDING HOT SPOT                                                                                                         |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage