

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Jun/2016 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	137.703	550.285	1) Gujrat	-7.711	-26.997
2) Hydro	3.101	27.760	2) Madhya Pradesh	8.061	38.450
3) Gas	5.961	24.887	3) Chattisgarh	7.480	27.830
Total MSPGCL	146.765	602.932	4) Maharashtra Net	114.492	474.984
B) 1) APLM	12.733	53.182	5) Goa (Amona)	-0.832	-3.714
2) JSWEL	20.167	81.736	6) TAPS 1&2 Injection	3.584	14.248
3) VIPL	9.975	49.312	7) RGPPL Injection	11.592	45.619
4) RPL(AMT)	19.414	74.368	8) Pench (MS)	0.160	0.327
5) WPCL	4.209	13.791	9) Pench (Excess)	-0.160	-0.327
6) Other IPP	4.998	18.369	Total	136.506	570.093
C) 1) TPCL Thermal	15.862	67.264	a) Mumbai Schedule	28.652	116.851
2) TPCL Hydro	2.362	14.743	b) Mumbai Drawl	36.632	143.477
3) TPCL Gas	2.116	8.484	c) MSEDCL Bilateral *	44.265	167.315
4) R-INFRA Thermal	10.945	46.750	Include PX	5.940	24.439
D) STATE			d) Mumbai Bilateral *	28.652	116.851
1) Thermal	236.006	955.057	Include PX	6.458	24.544
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	5.463	42.503	H) ENERGY CATERED (MUs)		
3) Gas	8.077	33.371	1) MSEDCL	343.291	1410.172
4) Wind	23.966	85.043	2) Mumbai Discoms	67.916	280.719
6) SOLAR	1.190	4.823	TOTAL STATE	411.207	1690.891
TOTAL STATE	274.702	1120.797			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	5973	6118	5634	5709
MSPGCL Hydro	208	373	118	62
MSPGCL Gas	237	248	271	241
MSPGCL Total Generation	6418	6739	6023	6012
Central Sector Receipt	6116	6506	5584	5210
WIND	888	586	1498	828
CPP / IPP	2823	3374	2991	2875
SOLAR	164	113	0	0
Exchange with Mumbai	-1573	-1591	-1501	-1333
MSEDCL DEMAND MET	14836	15727	14595	13592
Load Shedding	0	0	0	0
MSEDCL DEMAND	14836	15727	14595	13592
TPCL GENERATION	1132	1190	885	606
R-INFRA GENERATION	497	488	510	402
MUMBAI DEMAND	3202	3269	2896	2341
STATE DEMAND MET	18038	18996	17491	15933
STATE DEMAND	18038	18996	17491	15933
Frequency (Hz)	49.98	49.91	49.92	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.1 Hz at 05:02 Hrs	49.72 Hz at 22:12 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 04/Jun/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	3.25	13.33	145	130
Unit 6	0.00	0.00	0	0
Unit 7	3.61	15.16	165	133
Unit 8	12.33	52.17	630	410
Total	19.19	80.66		
Bhusawal				
Unit 2	3.30	9.99	150	130
Unit 3	3.91	15.62	165	160
Unit 4	9.39	42.29	500	350
Unit 5	9.37	42.64	500	350
Total	25.97	110.54		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	4.16	14.80	192	163
Unit 4	4.09	16.92	189	160
Unit 5	9.55	17.86	450	354
Unit 6	9.61	38.97	455	360
Unit 7	9.42	40.11	450	347
Unit 8	2.64	9.26	218	0
Total	39.46	137.93		
Paras				
Unit 3	5.09	22.02	240	160
Unit 4	5.20	22.68	250	190
Total	10.29	44.70		
Khaparkheda				
Unit 1	3.46	12.74	160	125
Unit 2	3.85	15.08	175	145
Unit 3	4.11	16.86	190	160
Unit 4	4.27	17.46	190	166
Unit 5	10.26	43.95	505	370
Total	25.95	106.09		
Nasik				
Unit 3	4.14	17.25	185	165
Unit 4	4.05	17.32	195	162
Unit 5	4.18	17.45	194	164
Total	12.36	52.01		
Uran				
All Units	5.96	24.89	282	229
Total	5.96	24.89		
PENCH (MS)				
Pench (MS)	0.16	0.33	24	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.16	0.33		
Koyna				
Stage 1-2	1.34	8.88	230	40
Stage 4	0.00	8.41	0	0
Stage 3	0.00	3.87	0	0
Total	1.34	21.16		
Hydro				
KDPH	0.10	1.21	8	0
VTRNA	0.00	0.16	0	0
TILLARI	0.37	1.26	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.22	1.01	80	0
RNGR+BHTSA	0.20	0.60	9	8
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.00	0.15	0	0
GHATGHAR	0.87	2.22	235	0
Total	1.76	6.60		
Wind				
Total	23.97	85.04	0	0
Total	23.97	85.04		
CPP				
APML(Mus)	12.73	53.18	0	0
JSWEL(Mus)	20.17	81.74	0	0
VIPL(Mus)	9.98	49.31	0	0
RPLAMT(Mus)	19.41	74.37	0	0
WPCL(Mus)	4.21	13.79	0	0
Other(Mus)	5.00	18.37	0	0
Total	71.50	290.76		
SOLAR				
Total	1.19	4.82	0	0
Total	1.19	4.82		
Tata				
Trombay 5	10.30	44.21	488	315
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.17	4.68	49	48
Trombay 7B	0.95	3.80	40	39
Trombay 8	5.56	23.05	246	201
TATA Hydro	2.36	14.74	371	7
Total	20.34	90.49		
R-INFRA				
1-2	10.94	46.75	511	401
Total	10.94	46.75		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
Chandrapur 9	0.00	0.00	MSPGCL Thermal	137.70	550.28	MSPGCL Total	146.76	602.93
Koradi 9	4.48	18.36	MSPGCL Thml+Gas	143.66	575.17	Koyna 1,2 & 4 Total	1.34	17.29
Parli 8	0.00	0.00	MSPGCL Hydro	3.10	27.76	State Total	274.70	1120.80

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Jun/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	5764	122	239	6125	1223	2861	0	5829	5698	-1635	14272	0	14272	2924	17196	49.92
2	5761	62	239	6062	1157	2868	0	5514	5640	-1569	14158	0	14158	2716	16874	49.94
3	5748	62	239	6049	1176	2870	0	5439	5064	-1510	13649	0	13649	2544	16193	49.95
4	5734	62	241	6037	977	2872	0	5284	5218	-1416	13688	0	13688	2424	16112	49.96
5	5709	62	241	6012	828	2875	0	5129	5210	-1333	13592	0	13592	2341	15933	49.95
6	5694	57	251	6002	826	2872	0	5253	5509	-1332	13877	0	13877	2342	16219	49.98
7	5711	66	242	6019	788	2898	2	5518	5361	-1258	13810	0	13810	2267	16077	49.94
8	5709	56	240	6005	658	3018	27	5681	5276	-1283	13701	0	13701	2289	15990	49.97
9	5651	66	254	5971	863	3039	64	5870	5640	-1453	14124	0	14124	2472	16596	49.96
10	5849	167	250	6266	910	3041	103	5912	6087	-1613	14794	0	14794	2821	17615	49.96
11	6065	197	229	6491	810	3017	140	5953	5992	-1580	14870	0	14870	3129	17999	50.00
12	5973	208	237	6418	888	2823	164	6081	6116	-1573	14836	0	14836	3202	18038	49.98
13	6270	115	238	6623	663	2871	179	6119	6231	-1603	14964	0	14964	3214	18178	49.96
14	6200	178	238	6616	556	2963	160	6108	6209	-1558	14946	0	14946	3129	18075	49.94
15	6215	183	238	6636	570	3217	145	6237	6494	-1638	15424	0	15424	3255	18679	49.90
16	6118	373	248	6739	586	3374	113	6257	6506	-1591	15727	0	15727	3269	18996	49.91
17	6076	378	238	6692	795	3432	63	6105	6119	-1554	15547	0	15547	3193	18740	49.97
18	5931	183	237	6351	1025	3157	26	6024	5605	-1648	14516	0	14516	3023	17539	49.99
19	5252	113	250	5615	1388	2967	4	5995	5727	-1530	14171	0	14171	2881	17052	49.96
20	5634	118	271	6023	1498	2991	0	6092	5584	-1501	14595	0	14595	2896	17491	49.92
21	5303	114	277	5694	1825	2963	0	6060	5197	-1648	14031	0	14031	2985	17016	49.95
22	5149	58	282	5489	1568	2818	0	5659	5141	-1539	13477	0	13477	2864	16341	49.96
23	5117	48	270	5435	1365	2812	0	5279	5280	-1573	13319	0	13319	2801	16120	49.87
24	5070	53	272	5395	1023	2876	0	5088	5602	-1694	13202	0	13202	2936	16138	49.91
MUs	137.7 0	3.10	5.96	146.76	23.97	71.50	1.19	138.49	136.51	-36.63	343.29	0.00	343.29	67.92	411.21	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Jun/2016

Position as on 6.30 Hrs of 05/Jun/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
CENT.SECTOR	Tarapur 2	160	10/09/2015	12.55		Continued.	Refuelling work	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
CENT.SECTOR	TARAPUR-3	540	23/05/2016	20.30		Continued.	Annual Maintenance Work.	
IPP	JSW (J) U2	300	01/06/2016	00.30		Continued.	Annual Maintenance Work.	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	No Schedule	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
IPP	Adani U-3	660	20/04/2016	03.33		Continued.	Furnace Pressure High	
IPP	Adani U-5	660	05/05/2016	23.09		Continued.	Due to Unavailblity of Water.	
RGPL	Dabhol 3A	230	07/05/2016	18.44		Continued.	Low Vaccum	
MSPGCL	Chandrapur Unit 9	500	08/05/2016	23:16		Continued.	Turbine Problem	
IPP	Adani U-1	660	13/05/2016	22.53		Continued.	Water Shortage	
IPP	RPL(AMT) U-5	270	24/05/2016	00.05		Continued.	Zero Schedule From MSEDCL	
MSPGCL	Uran Unit 7	108	24/05/2016	17.42		Continued.	Generation Bearing Vibration High.	
IPP	Adani U-2	660	25/05/2016	21.22		Continued.	Water Shortage.	
MSPGCL	Uran Unit B0	120	29/05/2016	23.17	05/06/2016	21.22	Gas shortage	
MSPGCL	Uran Unit 8	108	29/05/2016	23.19	05/06/2016	14.30	Gas shortage	
IPP	VIPL U-1	300	04/06/2016	10.56	04/06/2016	13.26	Furnace Pressure High	
MSPGCL	Chandrapur Unit-8	500	04/06/2016	13.00		Continued.	Due To Main Steam Temperature Very Low.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2016

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Raichur(PG)-Solapur(PG)- II	InterState	04/06/2016	22.28	04/06/2016	23.02	T	Distance Protection
Akola II- Ektuni (A'bad)	IntraState	05/06/2016	16.12	05/06/2016	17.47	T	Tripped Akola End.
Ektuni - Akola II Ckt I	IntraState	05/06/2016	17.10		Continued.	T	Directional Earth Fault.
765 KV ICT Outages/Trippings							
765/400kv 1500 MVA ICT - I @ Aurangabad	IntraState	05/06/2016	21.48		Continued.	T	Tripped on PRV
400 KV LINE Outages/Trippings							
Kolhapur Solapur (PG) II	InterState	03/06/2016	18.01	04/06/2016	09.01	T	Over Voltage
Dabhol Nagothane II	InterState	04/06/2016	10.17	04/06/2016	17.22	EO	Attending Hot Spot
Talegaon PG-Aurangabad-I	InterState	04/06/2016	11.18	04/06/2016	11.37	PO	OutLR For Oil Sampling Collection Line Charged Without LR.
Talegaon PG-Aurangabad-I	InterState	04/06/2016	13.17	04/06/2016	13.30	PO	To Charge Line With LR Out
Talegaon PG - Aurangabad - II	InterState	04/06/2016	18.36	04/06/2016	18.39	PO	To Take Line Reactor Out.
Lamboti - Solapur (PG)	InterState	04/06/2016	20.47	05/06/2016	14.40	T	Distance Protection
Kolhapur Solapur (PG) II	InterState	05/06/2016	00.02		Continued.	T	Over Voltage
Dabhol Nagothane II	InterState	05/06/2016	00.12	05/06/2016	00.50	T	Heavy Rain.
Dabhol Nagothane II	InterState	05/06/2016	03.03	05/06/2016	15.41	T	Distance Protection
Dhule Sar'Sarovar I	InterState	05/06/2016	17.40		Continued.	HT	Over Voltage
Ektuni-Bableshtar ckt II	IntraState	19/05/2016	09.44		Continued.	HT	To Control BBLR Padghe Loading.
Ektuni-Taptitanda II	IntraState	28/05/2016	10.30		Continued.	PO	Dismantalling of Tower.
Chandrapu II - Chandrapur SW Ckt II	IntraState	03/06/2016	15.58	04/06/2016	04.21	EO	Attending Oil Leakage
karad -kolhapur-I	IntraState	03/06/2016	16.23	04/06/2016	09.48	HT	Over Voltage
Karad - Jaigad - II	IntraState	03/06/2016	17.09	04/06/2016	10.07	HT	Over Voltage
Karad - Lonikand 1	IntraState	03/06/2016	17.49	04/06/2016	09.33	T	Distance Protection
Khadka-Aurangabad (Waluj)	IntraState	03/06/2016	21.15	04/06/2016	06.12	HT	Over Voltage
Jejuri- Koynastage-IV	IntraState	03/06/2016	22.03	04/06/2016	12.19	T	Distance Protection
Deepnagar - Aurangabad	IntraState	04/06/2016	06.42	04/06/2016	14.06	PO	Jumper Tightening and Fixing of Nut Bolts
Jaigad-New Koyna Ckt-I	IntraState	04/06/2016	11.25	04/06/2016	18.28	EO	Replace Insulator String.
Koradi-Bhusawal	IntraState	04/06/2016	13.49	04/06/2016	15.12	PO	Shifting Of PMU.
karad -kolhapur-II	IntraState	04/06/2016	16.06		Continued.	HT	Over Voltage
Chandrapur-II - Nanded	IntraState	04/06/2016	16.23	05/06/2016	07.45	T	Distance Protection
Khadka-Aurangabad (Waluj)	IntraState	04/06/2016	17.34		Continued.	HT	Over Voltage
Chandrapu II - Chandrapur SW Ckt II	IntraState	04/06/2016	18.03	04/06/2016	21.09	EO	Attending Hot Spot
Girwali-Solapur (Lamboti)	IntraState	04/06/2016	20.47	04/06/2016	23.06	T	Over Voltage
Girwali-Solapur (Lamboti)	IntraState	04/06/2016	23.58	05/06/2016	07.34	T	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	05/06/2016	00.06		Continued.	HT	Over Voltage
Parly(MS)- Nanded	IntraState	05/06/2016	02.02	05/06/2016	07.22	T	Over Voltage
Karad-Jaigad - I	IntraState	05/06/2016	17.06		Continued.	HT	Over Voltage
Warora-Tirora-II	IntraState	05/06/2016	20.04	05/06/2016	23.10	T	Distance Protection
Chandrapur-Parali III	IntraState	05/06/2016	20.28		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220kv 315 Mva ICT I @Karad	IntraState	03/06/2016	22.23	04/06/2016	00.26	T	NDR Operated
400/220/33 Kv 315 Mva Ict 2 @Dhule	IntraState	04/06/2016	09.42	04/06/2016	13.44	PO	Maintenance And Testing Work With TAP Changing.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2016

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 Kv 315 Mva Ict 1 @Dhule	IntraState	04/06/2016	14.17	04/06/2016	17.18	PO	Maintenace And Testing Work With TAP Changing
400/220KV 500MVA ICT-I @Nanded	IntraState	04/06/2016	16.23	04/06/2016	16.39	T	ICT Load Zero.
400/220/33 Kv 500 Mva Ict 3 @Dhule	IntraState	04/06/2016	17.35	04/06/2016	18.36	PO	Maintenace And Testing Work With TAP Changing.
400/220kv 315 Mva ICT I @Karad	IntraState	04/06/2016	23.07	05/06/2016	01.39	T	Heavy Rain.
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	04/06/2016	23.52	05/06/2016	02.33	T	Haavy Rain
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	05/06/2016	03.03	05/06/2016	05.34	T	Heavy Rain.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	05/06/2016	03.03	05/06/2016	04.19	T	Heavy Rain.
400/220 KV 500 MVA ICT- III @ Aurangabad	IntraState	05/06/2016	21.26		Continued.	T	NDR
220 KV LINE Outages/Trippings							
Nasik Navsari I	InterState	16/05/2016	18.32		Continued.	HT	O/L of Interconnector betn. Nsk OCR & GCR
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Padghe - Vasai	IntraState	24/01/2016	08.32		Continued.	PO	For Formation of Temp. Padgha-Borivali (Charge upto 51/1).
Osmanabad - Solapur (Bale)	IntraState	03/06/2016	20.17	04/06/2016	17.10	T	Distance Protection
Karad -Mudshingi Ckt- IV	IntraState	03/06/2016	23.08	04/06/2016	00.09	T	Distance Protection
Jejuri-Phursungi 1	IntraState	04/06/2016	16.17	04/06/2016	18.19	EO	Remove Bird Nest.
Mururd - Tuljapur	IntraState	04/06/2016	20.37	04/06/2016	20.55	T	Distance Protection
Tembhurni - Jeur	IntraState	04/06/2016	21.05	05/06/2016	07.58	T	Distance Protection
Nagar-Bose I	IntraState	04/06/2016	21.50	05/06/2016	13.48	T	Distance Protection
Gadchandur - Grace	IntraState	04/06/2016	22.36	04/06/2016	22.59	T	Distance Protection
Adlabs - Pedambe	IntraState	05/06/2016	00.15	05/06/2016	01.10	T	Heavy Rain.
Salsette Borivli 1	IntraState	05/06/2016	08.43	05/06/2016	14.12	PO	Maintenance And Testing Work.
Eklahare (Gcr) - Ghatghar	IntraState	05/06/2016	11.33	05/06/2016	19.41	PO	Erection of Monopole.
Kalwa - Borivali	IntraState	05/06/2016	14.15	05/06/2016	22.09	HT	As CT Jumper open at Borivali end.
Nashik-Airoli Knowledge Park	IntraState	05/06/2016	14.25	05/06/2016	18.17	PO	Erection Of Monopole.
Miraj - Ichalkaranji II	IntraState	05/06/2016	20.06		Continued.	EO	Attend Sparkling On Line.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 150 MVA ICT @Boisar-II	IntraState	04/06/2016	08.16	04/06/2016	13.05	PO	Filtration Work.
220/33kv 50mva Ptr 2 @Kathapur	IntraState	04/06/2016	10.35	04/06/2016	10.55	PO	To Remove Large Bird Nest Load Affected.
220/132 kv 200 Mva ICT-II @Boisar -II	IntraState	04/06/2016	11.02	04/06/2016	11.39	T	Overcurrent Tripping.
220/132 KV 200 Mva ICT-II @Boisar -II	IntraState	05/06/2016	06.23	05/06/2016	08.33	PO	HV CT Ratio Modification.
220/132 Kv 150 MVA ICT @Boisar-II	IntraState	05/06/2016	08.53		Continued.	PO	Oil Filtration and repl.of LV Bushing(charged and kept on Humming 19.41Hrs/13-6-16)
100 KV LINE Outages/Trippings							
Kandalgaon - Roha II	IntraState	05/06/2016	03.05		Continued.	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage