

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Jun/2019 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	161.236	666.506	1) Gujrat	-1.026	-5.970
2) Hydro	4.379	16.862	2) Madhya Pradesh	10.080	32.367
3) Gas	6.703	27.015	3) Chattisgarh	3.740	13.160
Total MSPGCL	172.318	710.383	4) Maharashtra	116.255	448.631
B) 1) APMIL	67.906	280.939	5) Goa (Amona)	-0.462	-1.408
2) JSWEL	23.119	94.799	Total	128.587	486.780
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.451	122.638
4) RPL(AMT)	23.684	97.337	b) Mumbai Drawl	41.099	154.941
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	12.623	47.493
6) Other IPP	6.680	28.520	Include PX	-2.128	-7.063
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.451	122.638
C) 1) TPCL Thermal	13.452	52.433	Include PX	16.067	53.343
2) TPCL Hydro	3.366	10.178	Standby	0.000	0.000
3) TPCL Gas	4.342	17.235	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.508	37.894	1) MSEDCL	423.616	1713.235
D) STATE			2) Mumbai Discoms	71.767	272.682
1) Thermal	305.585	1258.428	TOTAL STATE	495.383	1985.917
(A1+C1+C4+(B1-B6))					
2) Hydro	7.745	27.040			
(A2+C2)					
3) Gas	11.045	44.250			
(A3+B7+C3)					
4) Wind	36.078	143.774			
6) SOLAR	6.343	25.644			
TOTAL STATE	366.796	1499.136			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6853	7454	6400	6495
MSPGCL Hydro	281	302	121	80
MSPGCL Gas	280	268	272	278
MSPGCL Total Generation	7414	8024	6793	6853
Central Sector Receipt	5962	5895	5116	4535
WIND	1340	1384	1964	1965
CPP / IPP Thermal	4978	5538	4953	4866
CPP / IPP Gas	0	0	0	0
SOLAR	815	549	0	0
Exchange with Mumbai	-2089	-1977	-1642	-1332
MSEDCL DEMAND MET	18420	19413	17184	16887
Load Shedding	0	0	0	0
MSEDCL DEMAND	18420	19413	17184	16887
TPCL GENERATION	966	1144	980	686
AEML GENERATION	449	375	375	376
MUMBAI DEMAND	3504	3496	2997	2394
STATE DEMAND MET	21924	22909	20181	19281
STATE DEMAND	21924	22909	20181	19281
Frequency (Hz)	49.90	49.94	49.86	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.12 Hz at 08.00 Hrs	49.67 Hz at 22.26 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 04/Jun/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.22	16.22	200	140
Unit 7	3.30	8.75	170	0
Unit 8	8.05	34.23	361	234
Unit 9	11.22	44.63	550	460
Unit 10	10.97	43.09	470	430
Total	37.76	146.93		
Bhusawal				
Unit 3	3.24	12.44	165	0
Unit 4	9.04	38.53	500	350
Unit 5	9.02	38.45	500	355
Total	21.29	89.42		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	11.77	0	0
Total	0.00	11.77		
Chandrapur				
Unit 3	4.23	16.61	195	163
Unit 4	3.92	15.49	175	155
Unit 5	9.20	37.57	420	365
Unit 6	9.54	39.32	460	360
Unit 7	9.38	37.58	440	362
Unit 8	10.90	44.32	500	360
Unit 9	8.38	41.14	495	0
Total	55.56	232.03		
Paras				
Unit 3	5.48	22.82	258	200
Unit 4	5.42	22.62	256	200
Total	10.90	45.45		
Khaparkheda				
Unit 1	3.36	13.16	150	130
Unit 2	2.90	12.18	140	100
Unit 3	3.36	13.36	150	135
Unit 4	3.38	13.24	145	135
Unit 5	10.73	42.50	500	380
Total	23.72	94.44		
Nasik				
Unit 3	3.99	16.33	193	159
Unit 4	4.03	13.94	202	154
Unit 5	3.98	16.20	194	159
Total	12.00	46.47		
Uran				
All Units	6.70	27.02	288	267
Total	6.70	27.02		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.00	0.00		
Koyna				
Stage 1-2	1.24	4.89	125	40
Stage 4	0.00	0.00	0	0
Stage 3	0.75	1.58	140	0
Total	1.99	6.47		
Hydro				
KDPH	0.46	1.75	19	19
VTRNA	0.71	3.81	61	0
TILLARI	0.46	0.64	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.09	0.68	40	0
RNGR+BHTSA	0.21	0.87	9	5
BHANDARDRA	0.17	0.73	34	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.16	0.89	7	6
GHATGHAR	0.13	1.03	70	0
Total	2.39	10.39		
Wind				
Total	36.08	143.77	0	0
Total	36.08	143.77		
CPP				
APML(Mus)	67.91	280.94	0	0
JSWEL(Mus)	23.12	94.80	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	23.68	97.34	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	6.68	28.52	0	0
Total	121.39	501.60		
SOLAR				
Total	6.34	25.64	0	0
Total	6.34	25.64		
Tata				
Trombay 5	8.49	32.80	482	306
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	11.03	117	115
Trombay 7B	1.56	6.20	66	64
Trombay 8	4.96	19.63	234	198
TATA Hydro	3.37	10.18	328	35
Total	21.16	79.85		
AEML				
DTPS U-1&2	9.51	37.89	498	374
Total	9.51	37.89		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	161.24	666.51	MSPGCL Total	172.32	710.38
			MSPGCL Thml+Gas	167.94	693.52	Koyna 1,2 & 4 Total	1.24	4.89
			MSPGCL Hydro	4.38	16.86	State Total	366.80	1499.14

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Jun/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6669	105	276	7050	1280	5285	0	0	5558	5577	-1844	17348	0	17348	2974	20322	50.03
2	6661	75	285	7021	1309	5278	0	0	5396	5060	-1677	16991	0	16991	2773	19764	50.05
3	6686	85	286	7057	1293	5016	0	0	5188	4952	-1537	16781	0	16781	2598	19379	50.04
4	6803	90	285	7178	1436	4834	0	0	5093	4921	-1401	16968	0	16968	2460	19428	49.99
5	6495	80	278	6853	1965	4866	0	0	5062	4535	-1332	16887	0	16887	2394	19281	50.03
6	6689	75	288	7052	2125	4826	0	0	4939	4799	-1309	17493	0	17493	2414	19907	50.02
7	6611	104	288	7003	1740	4816	0	48	5288	4829	-1070	17366	0	17366	2387	19753	50.03
8	6478	165	287	6930	1393	4611	0	205	4832	5078	-1203	17014	0	17014	2505	19519	50.07
9	6451	193	283	6927	1498	4602	0	384	4769	5302	-1666	17047	0	17047	2782	19829	49.97
10	6616	225	273	7114	1146	4662	0	568	5176	5462	-1969	16983	0	16983	3129	20112	49.95
11	7040	368	282	7690	1133	4950	0	816	5689	5964	-2151	18402	0	18402	3377	21779	50.00
12	6853	281	280	7414	1340	4978	0	815	6048	5962	-2089	18420	0	18420	3504	21924	49.90
13	7040	276	270	7586	1218	5046	0	860	5808	5674	-1855	18529	0	18529	3480	22009	49.88
14	6990	254	267	7511	1430	4951	0	824	5717	5779	-1857	18638	0	18638	3404	22042	49.88
15	7264	366	278	7908	1232	5147	0	724	5853	6035	-1925	19121	0	19121	3482	22603	49.90
16	7454	302	268	8024	1384	5538	0	549	6184	5895	-1977	19413	0	19413	3496	22909	49.94
17	7119	200	280	7599	1524	5358	0	374	6107	5934	-2051	18738	0	18738	3414	22152	49.99
18	6283	220	271	6774	1927	4944	0	141	5665	6195	-1922	18059	0	18059	3258	21317	49.98
19	6108	141	282	6531	2216	4857	0	35	5346	5047	-1748	16938	0	16938	3064	20002	49.97
20	6400	121	272	6793	1964	4953	0	0	4991	5116	-1642	17184	0	17184	2997	20181	49.86
21	6397	154	282	6833	1791	5310	0	0	4921	4639	-1637	16936	0	16936	2961	19897	49.90
22	6263	169	274	6706	1619	5174	0	0	4851	5155	-1661	16993	0	16993	2910	19903	49.86
23	6677	239	284	7200	1115	5620	0	0	4681	5465	-1769	17631	0	17631	2962	20593	49.86
24	7189	91	284	7564	1000	5767	0	0	5438	5212	-1807	17736	0	17736	3042	20778	49.94
MUs	161.24	4.38	6.70	172.32	36.08	121.39	0.00	6.34	128.60	128.59	-41.10	423.62	0.00	423.62	71.77	495.38	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Jun/2019

Position as on 6.30 Hrs of 05/Jun/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	Zero Schedule. (From Dt-27/01/2019 Converted Zero sch to AOH) and (from dt-15/02/2019 Converted AOH to Zero sch by MSEDCL)	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit B0	120	08/09/2018	12.19		Continued.	T/F Shifting Work.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	20/05/2019	16.01		Continued.	Gas shortage	
MSPGCL	Koradi Unit 7	210	03/06/2019	16.55	04/06/2019	01.05	Coal Mill Tripped	
MSPGCL	Parli Unit 8	250	04/06/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Chandrapur Unit 9	500	04/06/2019	17.07	04/06/2019	21.19	GTR Y Phase PRV Operated	
MSPGCL	Bhusawal Unit 3	210	04/06/2019	20.15		Continued.	Zero Schedule	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	03/06/2019	11.17	04/06/2019	09.04	PO	Maintenance Work
Boisar (PG)- Aurangabad (PG)-I	InterState	04/06/2019	11.58	05/06/2019	08.43	HT	Load Management.
Akola Wardha li	InterState	04/06/2019	16.54	05/06/2019	21.01	T	Zone 1, B-Phase, 2.53KA.
Wardha (Pg) Warora I	InterState	04/06/2019	16.54	04/06/2019	19.20	T	Zone 1, B Phase
Dhule Sar'Sarovar II	InterState	04/06/2019	18.55		Continued.	HT	Over Voltage
Chandrapur Bhadravati IV	InterState	04/06/2019	20.53	05/06/2019	15.18	T	Tripped on Z-2, B-phase, 34KM, 4.5KA.
Akola Wardha I	InterState	05/06/2019	15.57	05/06/2019	19.01	T	Distance Protection, 13.5KM, 7.6KA, Y-PH. To E/F.
Khadka-Aurangabad (Waluj)	IntraState	03/06/2019	18.56	04/06/2019	07.56	HT	Over Voltage
Padghe - Kalwa- I	IntraState	04/06/2019	05.53	04/06/2019	07.43	PO	Attending Hot Spot
Bableshtar- Aurangabad (Waluj)	IntraState	04/06/2019	08.00	04/06/2019	11.10	PO	Chemical Washing
Karad - Talandge Ckt 1	IntraState	04/06/2019	08.02	04/06/2019	19.13	PO	Cold Line Cleaning
New Koyna -Koyna Stage IV-I	IntraState	04/06/2019	08.07	04/06/2019	19.24	PO	Cold Washing
Nagothane - Dabhol-II	IntraState	04/06/2019	09.36	04/06/2019	19.45	PO	Cold Washing
Warora -IEPL	IntraState	04/06/2019	16.54	04/06/2019	17.53	T	Zone1, B Phase
koaradi II - Wardha(PG)	IntraState	04/06/2019	16.54	04/06/2019	20.00	T	Zone 2, R Phase
Khadka-Aurangabad (Waluj)	IntraState	04/06/2019	20.58		Continued.	HT	Over Voltage
Chandrapur-II - Nanded ckt II	IntraState	05/06/2019	06.44	05/06/2019	13.48	PO	Pid Work.
N.Koyna-Karad -Ckt I	IntraState	05/06/2019	08.01	05/06/2019	19.06	PO	Replacement of Insulator String.
Akola-Nandgaonpeth (RPL)	IntraState	05/06/2019	16.26	05/06/2019	17.37	T	Distance Protection, 17.3KM, 2.8KA, B-Ph. To E/F.
Akola-Nandgaonpeth (RPL)	IntraState	05/06/2019	20.39	05/06/2019	21.04	HT	Charging Wardha Akola PG-2.
N.Koyna-Karad -Ckt I	IntraState	05/06/2019	22.51		Continued.	T	AR Lockout, Y-Ph, Z1, 15.07KM, 12.84KA.
Lonikand I - Koyna stage-IV	IntraState	05/06/2019	23:06	05/06/2019	23:57	T	Distance Protection, Z2, R-Ph, 188.7KM From Lonikand.
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 Are Damaged.
400/220 kV 500MVA ICT-I @ Alkud	IntraState	04/06/2019	10.47	04/06/2019	17.49	PO	Quarterly Maintenance Work
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	05/06/2019	05.57	05/06/2019	08.11	PO	Pre Monsoon Plastic Paper Wrapping
400/220KV 500MVA ICT-II@Taptitanda	IntraState	05/06/2019	09.10	05/06/2019	19.01	T	R-Ph OLTC Bucchohz Trip.
400/220/33 Kv 500 Mva Ict-3 @Nagothane	IntraState	05/06/2019	10.03	05/06/2019	16.35	PO	Painting Work.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of Conductor Loc No 86 Disconnecting of Jumper At Loc No 86 & 107 And De-energising The Line Bet.86 To 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching of Conductor At Loc No.86 Disconnecting of Jumper At Loc No.86 To 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2019

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Koradi-Ambazari-I	IntraState	01/06/2019	17.12		Continued.	T	D/C Tower Collapse At LOC.NO.51.
Koradi-Butibori Rly Tss	IntraState	01/06/2019	17.12		Continued.	T	D/C Tower Collapse At LOC.NO.51
Ambazari-Abhijeet	IntraState	01/06/2019	23:28		Continued.	EO	Making Dropper arrangement from 220kv Ambazari-Abhijeet ckt to 220kv Koradi-Butibori TSS ckt.
Midc Chandrapur-Gadchandur	IntraState	03/06/2019	18.05	04/06/2019	09.12	T	Distance Protection
Trombay MSETCL Tie 2	IntraState	03/06/2019	23.00	04/06/2019	04.59	EO	Attend Hot spot at A-ph line isolator
Eklahare (Gcr)(Nashik) - Airoli Know Park	IntraState	04/06/2019	04.19	04/06/2019	04.55	T	Y-PH CT BURST T/F-2
Kalwa1- Airoli Knowledge Park	IntraState	04/06/2019	04.19	04/06/2019	05.50	T	Y-PH CT BURST T/F-2
satara MIDC- Malharpeth	IntraState	04/06/2019	08.08	04/06/2019	19.04	PO	Cold Line Cleaning
Chalisgaon -Babhaleshwar	IntraState	04/06/2019	08.33	04/06/2019	10.23	PO	Tan Delta Measurement work
Mahad - Pedambe	IntraState	04/06/2019	09.32	04/06/2019	12.33	PO	CT Leakage
Chalisgaon - Deepnagar	IntraState	04/06/2019	10.37	04/06/2019	12.16	PO	Tan Delta Measurement work
Vita - Ghatnandre	IntraState	04/06/2019	11.00	04/06/2019	14.40	PO	Line Maintenance work
Niwali - Pawas Line	IntraState	04/06/2019	12.16	04/06/2019	18.01	PO	Chemical Washing
Kadegaon-Miraj	IntraState	04/06/2019	12.38	04/06/2019	14.35	EO	To attend Hot Spot
Nanded-Parbhani	IntraState	04/06/2019	21.24	04/06/2019	21.43	T	Distance Protection
Trombay - Kalwa	IntraState	05/06/2019	08.16	05/06/2019	12.07	EO	Hot Spot At LOC 27 & 31.
Dasturi-Kandalgaon Line	IntraState	05/06/2019	09.10	05/06/2019	18.05	EO	Hot Spot At LOC 3,6,9.
MALEGAON - KALWAN CKT-2	IntraState	05/06/2019	10.03	05/06/2019	19.32	PO	Restrining of Conductor.
Nagothane - Ipcl	IntraState	05/06/2019	11.07		Continued.	PO	Load Management On ICT-3 Outage.
Nashik-Padgha	IntraState	05/06/2019	15.14	05/06/2019	18.00	HT	OCR End To Control Bus Coupler Loading (1450A) At GCR OCR.
Pusad - Hingoli	IntraState	05/06/2019	21.25	05/06/2019	21.52	T	Pusad- Z1, 17.6KM, 2.84KA, Hingoli- R-E, IF-2.18KA, D-45KM.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/03/2019	22.48		Continued.	T	Bucholz Trip.
220/100 Kv 100 MVA ICT II @Kandalgaon	IntraState	01/06/2019	11.30		Continued.	PO	Oil Filtration Work.(Charged On Humming).
220/22 Kv 50 Mva Imp Ptr 2 @Airoli Knowledge Park	IntraState	04/06/2019	04.19	04/06/2019	23.10	T	Y-PH CT BURST T/F-2
220/22 Kv 50 Mva Imp Ptr 1 @Airoli Knowledge Park	IntraState	04/06/2019	04.19	04/06/2019	04.57	T	Y-PH CT BURST T/F-2
220/33kv 125 MVA Transformer 3 @Saki R/S	IntraState	04/06/2019	09.46	04/06/2019	11.47	PO	Pre Monsoon Maint.Work
200/100KV 100MVA ICT-1@Satara MIDC	IntraState	04/06/2019	11.15	04/06/2019	13.35	PO	Quarterly Maintenance Work
220/132kv 100MVA ICT II @Satara Midc	IntraState	04/06/2019	15.05	04/06/2019	17.53	PO	Quarterly Maintenance Work
220/33 Kv 50 Mva Imp Ptr 1 @Sonkar	IntraState	05/06/2019	08.33	05/06/2019	14.40	PO	REPLACEMENT ON TBC.
132 KV LINE Outages/Trippings							
Lalkhedi-Durgwada	IntraState	05/06/2019	20.39	05/06/2019	21.35	T	Z1, SOFT, 9KM, 2.9KA, B-E. Durgwada- Z2, 2.0KA, B-E, 29.05KM.
Jintur - Yeldari	IntraState	05/06/2019	22.20	05/06/2019	22.45	T	Distance Protection, D-4.64KM, IF -2.5KA.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage