

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Jun/2020 THURSDAY**

| I GENERATION (MUs)  |                |                | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly        | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 69.457         | 371.267        | 1) Gujrat                      | 1.122          | 10.917          |
| 2) Hydro            | 7.110          | 24.884         | 2) Madhya Pradesh              | 1.014          | 17.257          |
| 3) Gas              | 0.044          | 5.691          | 3) Chattisgarh                 | 4.160          | 18.550          |
| <b>Total MSPGCL</b> | <b>76.611</b>  | <b>401.842</b> | 4) Maharashtra                 | 74.924         | 352.536         |
| B) 1) APLM          | 41.046         | 213.984        | 5) Goa (Amona)                 | 0.000          | -0.022          |
| 2) JSWEL            | 15.583         | 59.848         | <b>Total</b>                   | <b>81.220</b>  | <b>399.238</b>  |
| 3) VIPL             | 0.000          | 0.000          | a) Mumbai Schedule             | 19.576         | 86.151          |
| 4) RPL(AMT)         | 0.000          | 0.000          | b) Mumbai Drawl                | 16.688         | 82.559          |
| 5) WPCL             | 2.322          | 9.349          | c) MSEDCL Bilateral *          | 22.546         | 117.748         |
| 6) Other IPP        | 7.671          | 30.077         | Include PX                     | -1.193         | 22.618          |
| 7) PGPL             | 0.000          | 0.000          | d) Mumbai Bilateral *          | 19.576         | 86.151          |
| C) 1) TPCL Thermal  | 7.354          | 29.674         | Include PX                     | 11.952         | 58.885          |
| 2) TPCL Hydro       | 2.730          | 14.403         | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.411          | 17.602         | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.845          | 36.213         | 1) MSEDCL                      | 243.659        | 1153.896        |
| D) STATE            |                |                | 2) Mumbai Discoms              | 40.028         | 180.451         |
| 1) Thermal          | 152.278        | 750.412        | <b>TOTAL STATE</b>             | <b>283.687</b> | <b>1334.347</b> |
| (A1+C1+C4+(B1-B6))  |                |                |                                |                |                 |
| 2) Hydro            | 9.840          | 39.287         |                                |                |                 |
| (A2+C2)             |                |                |                                |                |                 |
| 3) Gas              | 4.455          | 23.293         |                                |                |                 |
| (A3+B7+C3)          |                |                |                                |                |                 |
| 4) Wind             | 30.013         | 103.597        |                                |                |                 |
| 6) SOLAR            | 5.881          | 18.520         |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>202.467</b> | <b>935.109</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 10 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 6 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 2836                      | 3013                  | 3243                      | 2812                      |
| MSPGCL Hydro             | 238                       | 1352                  | 306                       | 133                       |
| MSPGCL Gas               | 0                         | 0                     | 0                         | 0                         |
| MSPGCL Total Generation  | 3074                      | 4364                  | 3548                      | 2945                      |
| Central Sector Receipt   | 3284                      | 3963                  | 5012                      | 2239                      |
| WIND                     | 1412                      | 831                   | 1278                      | 915                       |
| CPP / IPP Thermal        | 2896                      | 2659                  | 3011                      | 2849                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 603                       | 140                   | 0                         | 0                         |
| Exchange with Mumbai     | -863                      | -673                  | -755                      | -612                      |
| <b>MSEDCL DEMAND MET</b> | <b>10406</b>              | <b>11284</b>          | <b>12094</b>              | <b>8336</b>               |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 10406                     | 11284                 | 12094                     | 8336                      |
| TPCL GENERATION          | 565                       | 519                   | 543                       | 570                       |
| AEML GENERATION          | 372                       | 369                   | 373                       | 372                       |
| <b>MUMBAI DEMAND</b>     | <b>1800</b>               | <b>1561</b>           | <b>1671</b>               | <b>1554</b>               |
| STATE DEMAND MET         | 12206                     | 12846                 | 13766                     | 9890                      |
| <b>STATE DEMAND</b>      | <b>12206</b>              | <b>12846</b>          | <b>13766</b>              | <b>9890</b>               |
| Frequency (Hz)           | 49.97                     | 50.02                 | 50.04                     | 49.94                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.19 Hz at 19.04 Hrs | 49.82 Hz at 08.36 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 04/Jun/2020

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 0.00         | 18.14         | 0        | 0        |
| Unit 10            | 0.00         | 18.21         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>36.35</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 2.50          | 0        | 0        |
| Unit 5             | 0.00         | 4.40          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>6.91</b>   |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 2.61          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>2.61</b>   |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 9.95          | 0        | 0        |
| Unit 4             | 0.00         | 9.39          | 0        | 0        |
| Unit 5             | 0.00         | 23.58         | 0        | 0        |
| Unit 6             | 8.74         | 35.40         | 425      | 355      |
| Unit 7             | 8.27         | 34.98         | 363      | 310      |
| Unit 8             | 9.10         | 36.51         | 480      | 360      |
| Unit 9             | 9.04         | 36.24         | 455      | 360      |
| <b>Total</b>       | <b>35.16</b> | <b>186.04</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.60         | 18.65         | 203      | 187      |
| Unit 4             | 4.78         | 19.84         | 240      | 187      |
| <b>Total</b>       | <b>9.37</b>  | <b>38.49</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.86         | 15.56         | 170      | 150      |
| Unit 2             | 3.94         | 15.94         | 185      | 160      |
| Unit 3             | 3.97         | 16.00         | 190      | 158      |
| Unit 4             | 3.99         | 15.90         | 190      | 161      |
| Unit 5             | 9.15         | 37.48         | 490      | 360      |
| <b>Total</b>       | <b>24.92</b> | <b>100.88</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 0.04         | 5.69          | 29       | 0        |
| <b>Total</b>       | <b>0.04</b>  | <b>5.69</b>   |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.05         | 0.51          | 24       | 0        |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.05</b>  | <b>0.51</b>   |          |          |
| <b>Koyna</b>    |              |               |          |          |
| Stage 1-2       | 2.44         | 10.26         | 410      | 35       |
| Stage 4         | 1.62         | 2.81          | 719      | 0        |
| Stage 3         | 1.25         | 3.34          | 176      | 0        |
| <b>Total</b>    | <b>5.31</b>  | <b>16.41</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.45         | 2.54          | 29       | 15       |
| VTRNA           | 0.00         | 0.00          | 0        | 0        |
| TILLARI         | 0.73         | 2.06          | 62       | 0        |
| BHTGR/VEER      | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.00         | 0.53          | 0        | 0        |
| RNGR+BHTSA      | 0.13         | 0.91          | 11       | 0        |
| BHANDARDRA      | 0.43         | 1.72          | 35       | 10       |
| ELDARY          | 0.00         | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.05         | 0.72          | 3        | 2        |
| GHATGHAR        | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>1.80</b>  | <b>8.47</b>   |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 30.01        | 103.60        | 0        | 0        |
| <b>Total</b>    | <b>30.01</b> | <b>103.60</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 41.05        | 213.98        | 0        | 0        |
| JSWEL(Mus)      | 15.58        | 59.85         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00          | 0        | 0        |
| RPLAMT(Mus)     | 0.00         | 0.00          | 0        | 0        |
| WPCL(Mus)       | 2.32         | 9.35          | 0        | 0        |
| Other(Mus)      | 7.67         | 30.08         | 0        | 0        |
| <b>Total</b>    | <b>66.62</b> | <b>313.26</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 5.88         | 18.52         | 0        | 0        |
| <b>Total</b>    | <b>5.88</b>  | <b>18.52</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 7.35         | 29.67         | 311      | 300      |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.81         | 11.23         | 118      | 116      |
| Trombay 7B      | 1.60         | 6.37          | 68       | 66       |
| Trombay 8       | 0.00         | 0.00          | 0        | 0        |
| TATA Hydro      | 2.73         | 14.40         | 309      | 29       |
| <b>Total</b>    | <b>14.50</b> | <b>61.68</b>  |          |          |
| <b>AEML</b>     |              |               |          |          |
| DTPS U-1&2      | 8.84         | 36.21         | 374      | 332      |
| <b>Total</b>    | <b>8.84</b>  | <b>36.21</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 69.46       | 371.27        | MSPGCL Total        | 76.61       | 401.84        |
|                |             |         | MSPGCL Thml+Gas | 69.50       | 376.96        | Koyna 1,2 & 4 Total | 4.06        | 13.07         |
|                |             |         | MSPGCL Hydro    | 7.11        | 24.88         | State Total         | 202.47      | 935.11        |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 04/Jun/2020

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|-------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |       |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 2829        | 104  | 0    | 2933  | 1601  | 2844      | 0    | 0     | 2224        | 2166        | -745                 | 8799                  | 0                    | 8799                      | 1720             | 10519           | 49.99         |
| 2                  | 2818        | 89   | 0    | 2907  | 1528  | 2876      | 0    | 0     | 2308        | 1951        | -655                 | 8607                  | 0                    | 8607                      | 1663             | 10270           | 50.03         |
| 3                  | 2818        | 89   | 0    | 2907  | 1525  | 2881      | 0    | 0     | 1913        | 1801        | -618                 | 8496                  | 0                    | 8496                      | 1600             | 10096           | 49.97         |
| 4                  | 2804        | 99   | 0    | 2903  | 1343  | 2865      | 0    | 0     | 1834        | 1864        | -596                 | 8379                  | 0                    | 8379                      | 1557             | 9936            | 49.99         |
| 5                  | 2787        | 94   | 0    | 2881  | 1233  | 2846      | 0    | 0     | 1874        | 2021        | -606                 | 8375                  | 0                    | 8375                      | 1539             | 9914            | 49.97         |
| 6                  | 2812        | 133  | 0    | 2945  | 915   | 2849      | 0    | 0     | 2092        | 2239        | -612                 | 8336                  | 0                    | 8336                      | 1554             | 9890            | 49.94         |
| 7                  | 2812        | 566  | 0    | 3378  | 1015  | 2838      | 0    | 52    | 2270        | 2527        | -597                 | 9213                  | 0                    | 9213                      | 1552             | 10765           | 49.98         |
| 8                  | 2833        | 414  | 0    | 3246  | 1161  | 2842      | 0    | 193   | 2999        | 2955        | -661                 | 9736                  | 0                    | 9736                      | 1610             | 11346           | 49.99         |
| 9                  | 2835        | 224  | 0    | 3058  | 1217  | 2895      | 0    | 419   | 3492        | 3455        | -752                 | 10292                 | 0                    | 10292                     | 1724             | 12016           | 49.96         |
| 10                 | 2836        | 238  | 0    | 3074  | 1412  | 2896      | 0    | 603   | 3508        | 3284        | -863                 | 10406                 | 0                    | 10406                     | 1800             | 12206           | 49.97         |
| 11                 | 2845        | 178  | 0    | 3022  | 1389  | 2860      | 0    | 722   | 3717        | 3197        | -883                 | 10308                 | 0                    | 10308                     | 1805             | 12112           | 50.04         |
| 12                 | 2845        | 166  | 0    | 3012  | 1208  | 2751      | 0    | 789   | 3430        | 3314        | -869                 | 10204                 | 0                    | 10204                     | 1801             | 12006           | 50.03         |
| 13                 | 2840        | 182  | 0    | 3022  | 1413  | 2432      | 0    | 760   | 3193        | 3309        | -882                 | 10054                 | 0                    | 10054                     | 1789             | 11844           | 50.01         |
| 14                 | 2849        | 118  | 0    | 2966  | 1336  | 2397      | 0    | 751   | 3515        | 3526        | -814                 | 10162                 | 0                    | 10162                     | 1750             | 11912           | 50.03         |
| 15                 | 2841        | 124  | 0    | 2966  | 1502  | 2409      | 0    | 672   | 3760        | 3819        | -774                 | 10594                 | 0                    | 10594                     | 1704             | 12298           | 49.99         |
| 16                 | 2788        | 400  | 0    | 3188  | 1122  | 2453      | 0    | 453   | 3726        | 3900        | -730                 | 10386                 | 0                    | 10386                     | 1629             | 12014           | 49.98         |
| 17                 | 2811        | 954  | 0    | 3764  | 1074  | 2445      | 0    | 299   | 3668        | 3889        | -650                 | 10822                 | 0                    | 10822                     | 1585             | 12406           | 49.96         |
| 18                 | 3013        | 1352 | 0    | 4364  | 831   | 2659      | 0    | 140   | 3475        | 3963        | -673                 | 11284                 | 0                    | 11284                     | 1561             | 12846           | 50.02         |
| 19                 | 3230        | 308  | 0    | 3538  | 1020  | 2966      | 0    | 28    | 4425        | 4479        | -663                 | 11368                 | 0                    | 11368                     | 1571             | 12938           | 49.99         |
| 20                 | 3243        | 306  | 0    | 3548  | 1278  | 3011      | 0    | 0     | 4817        | 5012        | -755                 | 12094                 | 0                    | 12094                     | 1671             | 13766           | 50.04         |
| 21                 | 3335        | 294  | 0    | 3630  | 1196  | 2993      | 0    | 0     | 4853        | 4671        | -627                 | 11862                 | 0                    | 11862                     | 1726             | 13588           | 50.00         |
| 22                 | 3008        | 266  | 0    | 3274  | 1331  | 2988      | 0    | 0     | 4962        | 4469        | -553                 | 11510                 | 0                    | 11510                     | 1724             | 13234           | 49.98         |
| 23                 | 2821        | 196  | 15   | 3032  | 1120  | 2937      | 0    | 0     | 4903        | 4712        | -556                 | 11244                 | 0                    | 11244                     | 1706             | 12950           | 50.00         |
| 24                 | 2804        | 218  | 29   | 3052  | 1243  | 2689      | 0    | 0     | 4841        | 4697        | -554                 | 11126                 | 0                    | 11126                     | 1687             | 12814           | 50.01         |
| MUs                | 69.46       | 7.11 | 0.04 | 76.61 | 30.01 | 66.62     | 0.00 | 5.88  | 81.80       | 81.22       | -16.69               | 243.66                | 0.00                 | 243.66                    | 40.03            | 283.69          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Jun/2020**

Position as on 6.30 Hrs of 05/Jun/2020

| Generating Company   | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                            | Expected Date |
|----------------------|-------------------------|----------|--------------|--------------|-----------|------------|---------------------------------------------------------------------------------------------|---------------|
| <b>FORCED OUTAGE</b> |                         |          |              |              |           |            |                                                                                             |               |
| IPP                  | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                     |               |
| PGPL                 | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| PGPL                 | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |           | Continued. | No PPA                                                                                      |               |
| CPP                  | SWPGL U-4               | 135      | 15/12/2018   | 00.00        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage                                                                               |               |
| IPP                  | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal Shortage                                                                               |               |
| MSPGCL               | Koradi Unit 7           | 210      | 27/08/2019   | 09.52        |           | Continued. | Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs) |               |
| MSPGCL               | Bhusawal Unit 3         | 210      | 01/09/2019   | 17.56        |           | Continued. | Zero Schedule from 18:00hrs of 28/09/2019                                                   |               |
| MSPGCL               | Koradi Unit 6           | 210      | 06/09/2019   | 15.41        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| IPP                  | RPL(AMT) U-4            | 270      | 12/11/2019   | 00.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |           | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)                          |               |
| IPP                  | RPL(AMT) U-3            | 270      | 11/02/2020   | 18.00        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| IPP                  | RPL(AMT) U-5            | 270      | 11/02/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL.                                                                    |               |
| MSPGCL               | Nasik Unit 3            | 210      | 17/02/2020   | 00:00        |           | Continued. | C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)             |               |
| MSPGCL               | Ghatghar Unit-1         | 125      | 18/02/2020   | 00.25        |           | Continued. | Severe Hunting In Hydro Conduit Across MIV                                                  |               |
| MSPGCL               | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |           | Continued. | Gas shortage                                                                                |               |
| IPP                  | RPL(AMT) U-1            | 270      | 04/03/2020   | 19.30        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Ghatghar Unit-2         | 125      | 09/03/2020   | 10:50        |           | Continued. | Expansion joint leakage.                                                                    |               |
| IPP                  | RPL(AMT) U-2            | 270      | 09/03/2020   | 20.15        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Parli Unit 6            | 250      | 21/03/2020   | 17.31        |           | Continued. | Zero Schedule By MSEDCL                                                                     |               |
| MSPGCL               | Nasik Unit 4            | 210      | 25/03/2020   | 19.45        |           | Continued. | Reserve Shut Down.                                                                          |               |
| MSPGCL               | Uran Unit 5             | 108      | 06/04/2020   | 13.23        |           | Continued. | Gas shortage                                                                                |               |
| TPC_G                | Trombay 8               | 250      | 11/04/2020   | 16.55        |           | Continued. | Zero Schedule.                                                                              |               |
| CPP                  | SWPGL U-3               | 135      | 25/04/2020   | 00.08        |           | Continued. | No Schedule                                                                                 |               |
| IPP                  | JSW (J) U3              | 300      | 30/04/2020   | 15.13        |           | Continued. | No Schedule                                                                                 |               |
| MSPGCL               | Parli Unit 7            | 250      | 12/05/2020   | 19.34        |           | Continued. | Zero Schedule.                                                                              |               |
| MSPGCL               | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |           | Continued. | Shaft Position                                                                              |               |
| MSPGCL               | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |           | Continued. | Shaft position                                                                              |               |
| MSPGCL               | Koradi Unit-8           | 660      | 31/05/2020   | 22.56        |           | Continued. | Heavy steam Leakage in super heater.(Converted in To Zero schedule w.e.f                    |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Jun/2020**

Position as on 6.30 Hrs of 05/Jun/2020

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage         | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------|---------------|
|                    |                         |          |              |              |            |            | 03.06.2020 01.28)        |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 01/06/2020   | 07.16        |            | Continued. | Zero Schedule By MSEDCL  |               |
| MSPGCL             | Bhusawal Unit 5         | 500      | 01/06/2020   | 12.21        |            | Continued. | Zero schedule By MSEDCL  |               |
| MSPGCL             | Parli Unit 8            | 250      | 01/06/2020   | 13.13        |            | Continued. | Zero schedule By MSEDCL  |               |
| MSPGCL             | Koradi Unit 9           | 660      | 02/06/2020   | 15.42        |            | Continued. | Flame Failure            |               |
| MSPGCL             | Uran Unit A0            | 120      | 02/06/2020   | 17.07        | 05/06/2020 | 04.27      | Jerk In the Grid.        |               |
| MSPGCL             | Uran Unit 6             | 108      | 02/06/2020   | 17.07        | 04/06/2020 | 22.19      | Jerk In the Grid.        |               |
| MSPGCL             | Koradi Unit 10          | 660      | 03/06/2020   | 02.20        |            | Continued. | Zero Schedule By MSEDCL. |               |
| MSPGCL             | Chandrapur Unit 3       | 210      | 03/06/2020   | 13.07        |            | Continued. | RSD                      |               |
| MSPGCL             | Chandrapur Unit 4       | 210      | 03/06/2020   | 13.15        |            | Continued. | RSD                      |               |
| MSPGCL             | Chandrapur Unit 5       | 500      | 03/06/2020   | 15.00        |            | Continued. | RSD                      |               |
| IPP                | Adani U-1               | 660      | 03/06/2020   | 15.02        |            | Continued. | RSD                      |               |
| IPP                | Adani U-5               | 660      | 04/06/2020   | 12.29        |            | Continued. | Zero Schedule.           |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jun/2020**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jun/2020

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                 |
| Karad Solapur (PG)                         | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                        |
| Dhule Sar'Sarovar I                        | InterState                | 02/06/2020   | 12.39        |            | Continued. | PO          | REPLACEMENT OF PID SUSPICIOUS DISC INSULATOR AND MAINTENANCE WORK RFC AT 18:40. |
| Chandrapur Bhadravati I                    | InterState                | 02/06/2020   | 20.53        |            | Continued. | HT          | Over Voltage                                                                    |
| Chandrapur Bhadravati II                   | InterState                | 02/06/2020   | 20.53        |            | Continued. | HT          | Over Voltage                                                                    |
| Dhule Khandwa II                           | InterState                | 02/06/2020   | 21.23        |            | Continued. | HT          | Over Voltage                                                                    |
| Dabhol Nagothane II                        | InterState                | 03/06/2020   | 10.50        | 04/06/2020 | 15.56      | T           | Distance Protection                                                             |
| Dabhol Nagothane I                         | InterState                | 03/06/2020   | 11.03        |            | Continued. | T           | Distance Protection                                                             |
| Padgha Tarapur I                           | InterState                | 04/06/2020   | 08.37        | 04/06/2020 | 16.31      | T           | Distance Protection                                                             |
| Akola Aurangabad(PG) I                     | InterState                | 04/06/2020   | 13.38        | 04/06/2020 | 21.42      | T           | Distance Protection                                                             |
| Waluj Aurangabad(PG) II                    | InterState                | 04/06/2020   | 17.52        | 04/06/2020 | 21.40      | HT          | HT For Safety Permit For Akola-Aurangabad.                                      |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 31/05/2020   | 17.29        |            | Continued. | HT          | Over Voltage                                                                    |
| Karad - Jaigad - II                        | IntraState                | 02/06/2020   | 18.39        |            | Continued. | HT          | Over Voltage                                                                    |
| Dhule- Bableshwar - I                      | IntraState                | 02/06/2020   | 18.42        |            | Continued. | HT          | Over Voltage                                                                    |
| Koradi-Bhusawal                            | IntraState                | 03/06/2020   | 02.00        | 04/06/2020 | 19.37      | T           | Over Voltage                                                                    |
| Padghe - Kalwa- I                          | IntraState                | 03/06/2020   | 02.40        |            | Continued. | T           | Over Voltage                                                                    |
| Deepnagar Waluj 1                          | IntraState                | 03/06/2020   | 12.38        | 04/06/2020 | 07.30      | T           | Distance Protection                                                             |
| Padghe - Kalwa-II                          | IntraState                | 03/06/2020   | 14.23        | 04/06/2020 | 07.49      | HT          | Over Voltage                                                                    |
| Babhaleshwar - Padghe-I                    | IntraState                | 03/06/2020   | 15.23        |            | Continued. | T           | Distance Protection                                                             |
| Kalwa - Kharghar                           | IntraState                | 03/06/2020   | 15.53        | 04/06/2020 | 10.17      | T           | Over Voltage                                                                    |
| Ektuni-Bableshwar ckt I                    | IntraState                | 03/06/2020   | 23.29        | 04/06/2020 | 06.27      | HT          | Over Voltage                                                                    |
| Dhule - Bableshwar - II                    | IntraState                | 04/06/2020   | 01.48        | 04/06/2020 | 06.35      | HT          | Over Voltage                                                                    |
| BABHALESHWAR - RPL(NASHIK) CKT - 2         | IntraState                | 04/06/2020   | 03.01        | 04/06/2020 | 07.03      | T           | Over Voltage                                                                    |
| Deepnagar Taptitanda                       | IntraState                | 04/06/2020   | 03.51        | 04/06/2020 | 09.41      | T           | Over Voltage                                                                    |
| Khadka- Deepnagar Ckt 1                    | IntraState                | 04/06/2020   | 04.22        | 04/06/2020 | 06.44      | T           | Over Voltage                                                                    |
| Babhaleshwar - Bhusawal II                 | IntraState                | 04/06/2020   | 06.27        |            | Continued. | T           | Over Voltage                                                                    |
| Akola II - RPL(Rattanindia) Ckt I          | IntraState                | 04/06/2020   | 12.19        | 04/06/2020 | 15.25      | T           | Over Voltage                                                                    |
| Kharghar-Talegaon(PG)                      | IntraState                | 04/06/2020   | 14.52        | 04/06/2020 | 18.52      | T           | Distance Protection                                                             |
| Kalwa - Talegaon(PG)                       | IntraState                | 04/06/2020   | 14.52        | 04/06/2020 | 16.25      | T           | Over Voltage                                                                    |
| Lonikand I - Koyna stage-IV                | IntraState                | 05/06/2020   | 00.04        |            | Continued. | HT          | Over Voltage                                                                    |
| Padghe - Nagothane - I                     | IntraState                | 05/06/2020   | 00.25        |            | Continued. | HT          | Over Voltage                                                                    |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                 |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe        | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential Protection,Declared Faulty.                                        |
| 400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2 | IntraState                | 09/03/2020   | 12.57        | 04/06/2020 | 23.48      | EO          | Testing work (Bushing Tan Delta problem hence kept out.)                        |
| 400/220 Kv 600 MVA ICT-II @Kalwa           | IntraState                | 03/06/2020   | 08.28        |            | Continued. | HT          | Over Voltage                                                                    |
| 400/220 Kv 500 MVA ICT-III @Kalwa          | IntraState                | 03/06/2020   | 13.20        | 04/06/2020 | 12.43      | HT          | Over Voltage                                                                    |
| 400/220/33 Kv 315 MVA ICT -I @Nagothane    | IntraState                | 03/06/2020   | 15.30        |            | Continued. | T           | Oil Level low                                                                   |
| 400/220/33 Kv 315 MVA ICT- 2 @Nagothane    | IntraState                | 03/06/2020   | 16.22        | 04/06/2020 | 11.03      | T           | Tripped during Rain.                                                            |
| 400/220/33 Kv 600 MVA ICT 4 @Padghe        | IntraState                | 03/06/2020   | 17.32        | 04/06/2020 | 14.36      | HT          | Low On Oil Level.                                                               |
| 400/220kv, 500 MVA ICT-III                 | IntraState                | 03/06/2020   | 17.37        |            | Continued. | HT          | Over Voltage                                                                    |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Jun/2020**

**Statement-VII**

Position as on 6.30 Hrs of 05/Jun/2020

| Name of Line                                     | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                       |
|--------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|------------------------------------------------------------------------------------------------------------------------|
| @Babhleshwar                                     |                           |              |              |            |            |             |                                                                                                                        |
| 400/220 KV 500 MVA ICT I @ Kudus                 | IntraState                | 04/06/2020   | 12.44        | 04/06/2020 | 15.50      | T           | B PH Alarm Attending.                                                                                                  |
| <b>220 KV LINE Outages/Trippings</b>             |                           |              |              |            |            |             |                                                                                                                        |
| Mudshingi Chikodi                                | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule.                                                                                                           |
| Talandage - Chikodi                              | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule.(close at Chikodi end only)                                                                                |
| Tillari Amona                                    | InterState                | 03/06/2020   | 22.20        |            | Continued. | T           | LA blast at Amona end.                                                                                                 |
| BOISAR BORIVALI                                  | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To Control Line Loading(H/T from Boisar end)                                                                           |
| Borivali - Ghodbunder                            | IntraState                | 30/01/2020   | 12.05        |            | Continued. | PO          | Isolation of 220KV Cables on MSETCL Tower NO.240                                                                       |
| Pusad-Ghatodi                                    | IntraState                | 02/06/2020   | 08.35        |            | Continued. | HT          | In view Of outage On 220Kv Pusad wardha PG CKT.                                                                        |
| Pusad-WardhaPG(Deoli)                            | IntraState                | 02/06/2020   | 08.50        | 04/06/2020 | 15.41      | PO          | Removing From ERS & Shifting OF Line on new Tower 166 & 169B.                                                          |
| Kandalgaon - Bhira                               | IntraState                | 02/06/2020   | 19.39        |            | Continued. | T           | Backup Protection                                                                                                      |
| Chandrapur GCR - Warora - I                      | IntraState                | 03/06/2020   | 09.07        | 04/06/2020 | 13.29      | PO          | For replacement/fixing Of 59 NO's of arcing horn betn loc no.01 to 56 & providing repair sleeve. betn loc no.12 to 15. |
| Niwali - Pawas Line                              | IntraState                | 03/06/2020   | 09.14        |            | Continued. | T           | Distance Protection                                                                                                    |
| Koyna (Pophali) - Kdph                           | IntraState                | 03/06/2020   | 10.55        | 04/06/2020 | 17.15      | T           | Distance Protection                                                                                                    |
| Bombay Dyeing - Sahara                           | IntraState                | 03/06/2020   | 12.00        |            | Continued. | T           | Backup Protection                                                                                                      |
| Mahad-Kandalgaon                                 | IntraState                | 03/06/2020   | 13.04        |            | Continued. | T           | Distance Protection                                                                                                    |
| Nagothane - Posco                                | IntraState                | 03/06/2020   | 13.18        |            | Continued. | T           | Distance Protection                                                                                                    |
| Adlabs - Pedambe                                 | IntraState                | 03/06/2020   | 13.18        |            | Continued. | T           | Distance Protection                                                                                                    |
| Uran - Apta II                                   | IntraState                | 03/06/2020   | 13.58        |            | Continued. | T           | Distance Protection                                                                                                    |
| NERUL - SEAWOOD CABLE CKT - 2                    | IntraState                | 03/06/2020   | 14.18        | 04/06/2020 | 14.54      | T           | Distance Protection                                                                                                    |
| Apta - Hoc                                       | IntraState                | 03/06/2020   | 15.14        |            | Continued. | T           | Distance Protection                                                                                                    |
| Kharghar-Borivali ckt I                          | IntraState                | 03/06/2020   | 15.53        |            | Continued. | T           | Distance Protection                                                                                                    |
| Kandalgaon - ONGC Panvel                         | IntraState                | 03/06/2020   | 16.00        | 04/06/2020 | 00.07      | T           | Distance Protection                                                                                                    |
| Pigasus-Hinjewadi-II                             | IntraState                | 03/06/2020   | 16.03        |            | Continued. | T           | Distance Protection                                                                                                    |
| Kandalgaon - Koyna (Pophali)                     | IntraState                | 03/06/2020   | 16.25        |            | Continued. | T           | Distance Protection                                                                                                    |
| Babhleshwar - Alephata ckt I                     | IntraState                | 03/06/2020   | 18.46        | 04/06/2020 | 00.08      | T           | Distance Protection                                                                                                    |
| Satana-Gangapur                                  | IntraState                | 03/06/2020   | 21.17        | 04/06/2020 | 17.27      | T           | Y Phase LA Burst At Gangapur End.                                                                                      |
| Warora - Wardha                                  | IntraState                | 04/06/2020   | 10.24        | 04/06/2020 | 13.36      | PO          | Disc Insulator Replacement Work                                                                                        |
| Khaparkheda-Kanhan                               | IntraState                | 04/06/2020   | 10.49        | 04/06/2020 | 14.35      | PO          | LA replacement Work.                                                                                                   |
| Butibori-Abhijeet                                | IntraState                | 04/06/2020   | 13.40        | 05/06/2020 | 00.18      | EO          | Relay Replacement work.                                                                                                |
| Hinganghat - Bhugaon                             | IntraState                | 04/06/2020   | 13.55        | 04/06/2020 | 15.39      | PO          | Disc Insulator Replacement Work                                                                                        |
| Trombay - Mulund                                 | IntraState                | 04/06/2020   | 14.34        | 04/06/2020 | 19.54      | T           | D.C Leakage Attending At Trombay.                                                                                      |
| Wardha-Yeotmal                                   | IntraState                | 04/06/2020   | 16.06        |            | Continued. | PO          | Construction Work.                                                                                                     |
| Chakan-Mahindra Vehicle                          | IntraState                | 04/06/2020   | 19.30        |            | Continued. | EO          | R PH wave trap jump hanging.                                                                                           |
| Pedambe-Nerle                                    | IntraState                | 05/06/2020   | 04.42        |            | Continued. | T           | Distance Protection                                                                                                    |
| <b>220 KV ICT Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                        |
| 220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2) | IntraState                | 03/06/2020   | 19.50        | 04/06/2020 | 06.55      | HT          | Over Voltage                                                                                                           |
| 220/132 KV ICT II @ Kopergaon                    | IntraState                | 03/06/2020   | 19.50        | 04/06/2020 | 06.55      | HT          | To Control Over voltage                                                                                                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage