

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Jun/2021 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	110.453	435.538	1) Gujrat	-4.310	-0.204
2) Hydro	27.488	81.719	2) Madhya Pradesh	8.503	45.457
3) Gas	6.691	26.602	3) Chattisgarh	4.950	23.550
Total MSPGCL	144.632	543.859	4) Maharashtra	153.117	627.914
B) 1) APML	30.600	121.638	5) Goa (Amona)	-1.345	-5.218
2) JSWEL	20.817	84.475	Total	160.915	691.499
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.579	122.017
4) RPL(AMT)	25.576	111.546	b) Mumbai Drawl	27.155	107.415
5) SWPGPL	9.023	35.065	c) MSEDCL Bilateral *	39.108	208.437
6) Other IPP	9.326	37.271	Include PX	7.573	58.727
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.579	121.978
C) 1) TPCL Thermal	14.764	59.078	Include PX	16.023	70.407
2) TPCL Hydro	5.399	21.679	Standby	0.000	0.039
3) TPCL Gas	4.055	16.156	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.762	23.662	1) MSEDCL	387.476	1583.714
D) STATE			2) Mumbai Discoms	57.135	227.990
1) Thermal	226.321	908.273	TOTAL STATE	444.611	1811.704
(A1+C1+C4+(B1-B6))					
2) Hydro	32.887	103.398			
(A2+C2)					
3) Gas	10.746	42.758			
(A3+B7+C3)					
4) Wind	7.062	39.412			
6) SOLAR	6.680	26.364			
TOTAL STATE	283.696	1120.205			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	4707	4683	4550	4623
MSPGCL Hydro	1622	707	693	1169
MSPGCL Gas	271	283	300	279
MSPGCL Total Generation	6600	5673	5543	6071
Central Sector Receipt	7433	7311	6071	5652
WIND	85	172	658	197
CPP / IPP Thermal	3975	3954	3913	4010
CPP / IPP Gas	0	0	0	0
SOLAR	622	912	0	0
Exchange with Mumbai	-1299	-1453	-918	-977
MSEDCL DEMAND MET	17416	16569	15267	14953
Load Shedding	0	0	0	0
MSEDCL DEMAND	17416	16569	15267	14953
TPCL GENERATION	894	1051	1198	1238
AEML GENERATION	250	251	251	250
MUMBAI DEMAND	2443	2755	2367	2465
STATE DEMAND MET	19859	19324	17634	17418
STATE DEMAND	19859	19324	17634	17418
Frequency (Hz)	50.00	50.01	49.95	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.27 Hz at 18.03 Hrs	49.78 Hz at 19.42 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 04/Jun/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	12.15	47.82	540	435
Total	12.15	47.82		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.48	46.67	500	435
Unit 5	11.06	16.91	495	420
Total	22.55	63.58		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.04	13.07	139	108
Unit 4	0.00	12.03	0	0
Unit 5	9.56	37.64	419	390
Unit 6	9.74	38.14	410	385
Unit 7	0.00	0.00	0	0
Unit 8	11.79	47.10	495	483
Unit 9	0.00	10.05	0	0
Total	34.13	158.03		
Paras				
Unit 3	5.39	21.15	228	220
Unit 4	5.36	22.58	233	162
Total	10.75	43.73		
Khaparkheda				
Unit 1	2.62	10.34	145	90
Unit 2	4.27	16.27	180	165
Unit 3	4.34	17.28	190	165
Unit 4	3.94	15.60	180	140
Unit 5	11.43	45.90	500	450
Total	26.60	105.38		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.28	17.00	198	127
Unit 5	0.00	0.00	0	0
Total	4.28	17.00		
Uran				
All Units	6.69	26.60	300	267
Total	6.69	26.60		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.22	1.25	24	0
Total	0.22	1.25		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.22	17.06	425	35
Stage 4	12.50	27.56	1000	0
Stage 3	3.95	10.24	320	0
Total	20.67	54.86		
Hydro				
KDPH	0.34	1.34	14	14
VTRNA	0.77	2.84	60	0
TILLARI	0.46	2.09	58	0
BHIRA T.R.	0.34	1.21	80	0
SMLHY_PTN	4.59	18.48	207	162
GHATGHAR	0.32	0.91	250	0
Total	6.82	26.86		
Wind				
Total	7.06	39.41	0	0
Total	7.06	39.41		
CPP				
APML(Mus)	30.60	121.64	0	0
JSWEL(Mus)	20.82	84.48	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.58	111.55	0	0
SWPGPL-Mus	9.02	35.06	0	0
Other(Mus)	9.33	37.27	0	0
Total	95.34	390.00		
SOLAR				
Total	6.68	26.36	0	0
Total	6.68	26.36		
Tata				
Trombay 5	9.56	38.02	452	292
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.53	10.08	117	102
Trombay 7B	1.52	6.08	67	62
Trombay 8	5.20	21.06	231	148
TATA Hydro	5.40	21.68	443	0
Total	24.22	96.91		
AEML				
DTPS U-1&2	5.76	23.66	252	169
Total	5.76	23.66		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	110.45	435.54	MSPGCL Total	144.63	543.86
			MSPGCL Thml+Gas	117.14	462.14	Koyna 1,2 & 4 Total	16.72	44.62
			MSPGCL Hydro	27.49	81.72	State Total	283.70	1120.20

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Jun/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4525	2193	285	7003	337	4086	0	0	6079	5946	-1038	16334	0	16334	2411	18745	50.00
2	4523	2009	276	6808	315	4043	0	0	6062	6428	-1021	16573	0	16573	2239	18812	50.01
3	4588	1629	277	6494	321	4016	0	0	6000	6047	-866	16012	0	16012	2101	18113	49.99
4	4607	1287	277	6171	223	4007	0	0	6125	6209	-906	15704	0	15704	1990	17694	50.04
5	4579	1556	287	6422	214	4047	0	0	6125	6278	-862	16099	0	16099	1939	18038	50.00
6	4593	1483	288	6364	232	4080	0	0	7152	7185	-876	16985	0	16985	1944	18929	49.96
7	4647	1786	277	6710	257	3996	0	39	7487	7496	-848	17650	0	17650	1908	19558	50.02
8	4663	1498	287	6448	121	3964	0	186	7458	7468	-925	17262	0	17262	1952	19214	50.02
9	4695	1412	274	6381	106	3946	0	409	7343	7626	-1104	17364	0	17364	2176	19540	49.99
10	4707	1622	271	6600	85	3975	0	622	7406	7433	-1299	17416	0	17416	2443	19859	50.00
11	4702	1047	270	6019	105	3942	0	852	7463	7062	-1399	16581	0	16581	2656	19237	49.97
12	4692	865	278	5835	92	3925	0	910	7701	7757	-1460	17059	0	17059	2734	19793	49.97
13	4683	707	283	5673	172	3954	0	912	7592	7311	-1453	16569	0	16569	2755	19324	50.01
14	4651	565	268	5484	138	3911	0	845	7607	7581	-1533	16426	0	16426	2708	19134	50.00
15	4564	805	267	5636	253	3944	0	730	7427	7336	-1638	16261	0	16261	2786	19047	50.03
16	4490	478	280	5248	580	3932	0	596	7630	7319	-1507	16168	0	16168	2833	19001	50.09
17	4511	437	271	5219	421	3891	0	386	7292	7066	-1564	15419	0	15419	2734	18153	50.04
18	4523	566	270	5359	532	3891	0	166	6327	6461	-1377	15032	0	15032	2560	17592	50.06
19	4506	414	277	5197	767	3943	0	27	6016	6049	-1005	14978	0	14978	2385	17363	50.09
20	4550	693	300	5543	658	3913	0	0	6085	6071	-918	15267	0	15267	2367	17634	49.95
21	4614	913	280	5807	423	3926	0	0	5903	5809	-862	15103	0	15103	2345	17448	50.00
22	4636	1237	280	6153	256	4009	0	0	5510	5579	-822	15175	0	15175	2324	17499	49.99
23	4581	1117	289	5987	257	3991	0	0	5720	5746	-895	15086	0	15086	2380	17466	49.99
24	4623	1169	279	6071	197	4010	0	0	5794	5652	-977	14953	0	14953	2465	17418	49.98
MUs	110.45	27.49	6.69	144.63	7.06	95.34	0.00	6.68	161.30	160.92	-27.15	387.48	0.00	387.48	57.14	444.61	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 04/Jun/2021

Position as on 6.30 Hrs of 05/Jun/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 6	80	22/04/2021	12.00		Continued.	UGC Oil Cooler Leakage.(Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021)	25/06/2021
AEML	AEML Unit 1	250	19/05/2021	09.52		Continued.	HP turbine replacement.	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	
MSPGCL	Chandrapur Unit 7	500	20/02/2021	23.43		Continued.	Generator Earth Fault.	
MSPGCL	Koradi Unit 6	210	27/04/2021	19.59		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Bhusawal Unit 3	210	04/05/2021	20.00	05/06/2021	00.05	Zero Schedule.	
MSPGCL	Parli Unit 6	250	04/05/2021	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	05/05/2021	19.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	06/05/2021	19.45	05/06/2021	09.28	Zero Schedule	
IPP	Adani U-4	660	16/05/2021	10.01		Continued.	Zero Schedule.	
IPP	Adani U-1	660	16/05/2021	17.57		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-5	660	17/05/2021	12.05		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 5	210	17/05/2021	12.50		Continued.	Zero schedule.	
MSPGCL	Uran Unit 6	108	17/05/2021	22.59		Continued.	Gas shortage.	
MSPGCL	Koradi Unit-8	660	25/05/2021	03.52		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	31/05/2021	21.59		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	01/06/2021	23.57	05/06/2021	00.58	Boiler Validity Renevoation	
IPP	RPL(AMT) U-5	270	02/06/2021	14.29	05/06/2021	09.13	Bottom ash problem	
MSPGCL	Chandrapur Unit 4	210	03/06/2021	23.20	05/06/2021	13.37	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2021

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Alkud-Solapur(PG)	InterState	05/06/2021	10.50	05/06/2021	14.57	PO	Outage required for replacement of polymer insulator at tower No: 24 & 142
Babhleshwar - RIPL(Nashik)	IntraState	18/03/2021	15.48		Continued.	PO	Hot spot attending.
karad -kolhapur-II	IntraState	03/06/2021	21.03	04/06/2021	09.18	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	04/06/2021	08.44	04/06/2021	17.27	PO	PID Faulty string replacement work.
Jaigad-New Koyna Ckt-I	IntraState	05/06/2021	08.56	05/06/2021	18.14	PO	Routine Maintenance Work
Chandrapur-Parali III	IntraState	05/06/2021	10.10	05/06/2021	18.28	PO	Pre-monsoon maintenance work.
Koradi-Bhusawal	IntraState	05/06/2021	14.09	05/06/2021	14.44	T	DT received at khadka end. koradi=line reactor back up impedance prot optd.
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.(FTC DT 16/08/2021 At 14.42)
400/220kv 315MVA ICT 2 @ Chandrapur GCR	IntraState	03/06/2021	09.30		Continued.	PO	Testing Work
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	04/06/2021	10.22	04/06/2021	14.40	PO	Routine Maintenance Work
400/220/33kv, 500 Mva Ict-2 @Khaparkheda	IntraState	04/06/2021	11.27	04/06/2021	16.50	EO	Attending oil leakage from neutral bushing of R phase unit.
400/220 Kv 500 MVA ICT II @Lamboti	IntraState	04/06/2021	22.06	05/06/2021	00.43	T	PRV
400/220 kv 167 MVA Spare ICT @Deepnagar	IntraState	05/06/2021	11.58	05/06/2021	16.19	PO	Premonsoon Maintenance work & HV LV bushing winding tan delta testing work
400/220/33 Kv 315 MVA ICT -I @Kharghar	IntraState	05/06/2021	12.41	05/06/2021	18.08	PO	Painting work of 400/220kv 3X105MVA ICT-I
400/220/33 Kv 315 MVA ICT I @Babhleshwar	IntraState	05/06/2021	13.15	05/06/2021	17.46	PO	CB diagnostic testing work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
Kharghar-Sonkhar	IntraState	04/06/2021	06.54	04/06/2021	08.31	PO	Removing Bird nest at Loc. No. 686 & Emergency Tree Cutting at Loc. No. 683 to 684 and other R&M work.
Koradi-Khaperkheda	IntraState	04/06/2021	09.37	04/06/2021	15.59	PO	Replacement of flashover string at various location.
Apta - Taloja	IntraState	04/06/2021	09.58	04/06/2021	14.09	EO	To attend Hot Spot
Parli 2 (Girwali)- Parbhani	IntraState	04/06/2021	10.56	04/06/2021	14.28	PO	R PH CT leakage attending work.
Vita - Ghatnandre	IntraState	04/06/2021	11.00	04/06/2021	17.00	PO	Line Maintenance work
Abhijeet-Wardha-I	IntraState	04/06/2021	11.10	04/06/2021	18.08	PO	Replacement of flashover string
Dondaicha(220)-Amalner(220)	IntraState	04/06/2021	11.19	04/06/2021	16.43	T	Distance Protection
Vasai Kamba	IntraState	04/06/2021	11.55	05/06/2021	03.38	T	Distance Protection
Nalasopara-Boisar	IntraState	04/06/2021	12.05	04/06/2021	13.27	EO	Replacement of de-capped pilot insulator at loc. No. 187, and replacement of PID faulty insulator string at loc. No. 189, 196, 173.
Kandalgaon - Koyna (Pophali)	IntraState	04/06/2021	13.30	04/06/2021	14.15	T	Distance Protection
Chandrapur(MIDC)-Ballarshah II	IntraState	04/06/2021	13.45	04/06/2021	15.47	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2021

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Warora - I	IntraState	04/06/2021	13.47	04/06/2021	16.18	T	R PH jump open from CT stude line side at Warora end.
Apta - Hoc	IntraState	04/06/2021	14.38	04/06/2021	20.15	PO	Relay Testing Work.
Kandalgaon - Bhira	IntraState	04/06/2021	14.50	04/06/2021	18.15	EO	To attend Hot Spot
Dhule - Dondaicha Ckt	IntraState	04/06/2021	17.01	04/06/2021	20.11	T	Distance Protection
Jamde-Dondaicha 2	IntraState	04/06/2021	17.01	04/06/2021	17.43	T	220 KV LBB operated.
Jamde-Dondaicha 1	IntraState	04/06/2021	17.01	04/06/2021	17.43	T	220 KV LBB operated.
Dondaicha- Shahada	IntraState	04/06/2021	17.01	04/06/2021	17.39	T	220 KV LBB operated.
Dondaicha(220)-Amalner(220)	IntraState	04/06/2021	17.01	04/06/2021	17.32	T	220 KV LBB operated.
Satana-Gangapur	IntraState	05/06/2021	06.13	05/06/2021	09.05	T	R PH jumper open at Gangapur end.
Deepnagar Bambhori	IntraState	05/06/2021	08.47	05/06/2021	16.56	PO	Replacement of antifog disc insulator string at T.L.no.25,41,47,49,89.
Nalasopara-Boisar	IntraState	05/06/2021	09.10	05/06/2021	12.12	PO	Replacement of decapped and hanging pilot insulator string at loc. No. 187
Trombay Carnac 5	IntraState	05/06/2021	09.58	05/06/2021	19.14	PO	Resagging of conductor
Osmanabad - Solapur (Bale)	IntraState	05/06/2021	10.29	05/06/2021	15.47	PO	"1) Refixing of arcing horn at loc.140 B phase. 2) Armouring work at loc.140 Y-phase."
TOPWORTH VILEBHAGAD	IntraState	05/06/2021	12.30	05/06/2021	17.56	PO	Lightening arrester replacement at 220kV EHV MSL consumer .
Bapgaon - Kalwa	IntraState	05/06/2021	12.31	05/06/2021	15.08	EO	Hot spot attending work at Y-phase CT (Temp.99 deg Cel)
Dahanu-Viraj	IntraState	05/06/2021	12.38	05/06/2021	15.39	PO	Pre-monsoon maintenance work.
TALEGAON - TALEGAON ambi (PG) -I	IntraState	05/06/2021	13.40	05/06/2021	18.22	PO	Half yearly maintenance work
Sonkhar - Trombay	IntraState	05/06/2021	13.50	05/06/2021	19.48	PO	Bus section outage.
Boisar-Viraj	IntraState	05/06/2021	15.45	05/06/2021	18.27	PO	Pre-monsoon maintenance work.
220 KV ICT Outages/Trippings							
220/132 KV 150MVA ICT I @ Boisar	IntraState	17/05/2021	11.19		Continued.	T	ICT Failed due to internal fault.
220/132 kv 100MVA ICT @ Bhandara	IntraState	04/06/2021	08.31	04/06/2021	17.00	PO	Repairing and testing of healthiness of nitrogen (N2) injection fire prevention and protection system.
220/132 Kv 200 Mva Emco Ict 2 @Ambazari	IntraState	04/06/2021	08.54	04/06/2021	12.05	PO	Pre-monsoon maintenance work.
220/132kv 200MVA ICT-III @ Nanded	IntraState	04/06/2021	14.27	04/06/2021	18.05	PO	Pre-monsoon maintenance work.
220/132 KV 100MVA ICT-II @ Bhokar	IntraState	04/06/2021	14.50	04/06/2021	16.20	PO	Pre-monsoon maintenance work.
220/132 Kv 100 Mva Emco Ict 2 @Dondaicha	IntraState	04/06/2021	17.01	04/06/2021	17.40	T	220 KV LBB operated.
220/132 Kv 100 Mva Cgl Ict 1 @Dondaicha	IntraState	04/06/2021	17.01	04/06/2021	17.44	T	220 KV LBB operated.
220/132kv 200mva Vijai Ptr 1 @Lonand	IntraState	05/06/2021	09.17	05/06/2021	11.32	T	Pre-monsoon maintenance work.
220/100 Kv 200 Mva Vijai Ict 3 @Trombay	IntraState	05/06/2021	13.52	05/06/2021	21.02	PO	Bus section outage.
220/132kv 100mva Ptr 2 @Kharepatan	IntraState	05/06/2021	14.16	05/06/2021	17.30	T	Oil top up in ICT.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage