

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Jun/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	177.967	679.144	1) Gujrat	-5.106	-19.483
2) Hydro	18.258	59.689	2) Madhya Pradesh	4.744	17.114
3) Gas	3.152	12.576	3) Chattisgarh	2.040	8.570
Total MSPGCL	199.377	751.409	4) Maharashtra	169.921	691.636
B) 1) APML	76.278	289.496	5) Goa (Amona)	-1.089	-4.442
2) JSWEL	18.912	70.082	Total	170.510	693.395
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.560	141.902
4) RPL(AMT)	24.541	94.832	b) Mumbai Drawl	37.670	154.236
5) SWPGPL	6.390	33.926	c) MSEDCL Bilateral *	72.740	308.358
6) Other IPP	16.291	64.558	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.503	141.771
C) 1) TPCL Thermal	15.545	61.219	Include PX	0.000	0.000
2) TPCL Hydro	5.776	23.303	Standby	0.058	0.131
3) TPCL Gas	0.337	3.544	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.783	45.615	1) MSEDCL	499.937	1958.990
D) STATE			2) Mumbai Discoms	70.111	287.918
1) Thermal	346.707	1338.872	3) Other Discoms	9.438	38.291
(A1+C1+C4+(B1-B6))			TOTAL STATE	579.486	2285.199
2) Hydro (A2+C2)	24.034	82.992			
3) Gas (A3+B7+C3)	3.489	16.120			
4) Wind	24.571	114.555			
6) SOLAR	10.175	39.264			
TOTAL STATE	408.976	1591.803			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7339	7485	7564	7361
MSPGCL Hydro	345	1383	1517	387
MSPGCL Gas	123	124	128	126
MSPGCL Total Generation	7807	8992	9209	7874
Central Sector Receipt	8105	8036	6248	6458
WIND	644	707	849	1411
CPP / IPP Thermal	5563	5754	6094	6046
CPP / IPP Gas	0	0	0	0
SOLAR	1312	905	0	0
Exchange with Mumbai	-2025	-1979	-1402	-1137
MSEDCL DEMAND MET	20989	21986	20565	20356
Load Shedding	0	0	0	0
MSEDCL DEMAND	20989	21986	20565	20356
TPCL GENERATION	781	883	1087	945
AEML GENERATION	454	457	494	431
MUMBAI DEMAND	3260	3319	2983	2513
OTHER DISCOM DEMAND	417	429	433	296
STATE DEMAND MET	24666	25734	23981	23165
STATE DEMAND	24666	25734	23981	23165
Frequency (Hz)	49.99	49.95	49.91	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 07.43 Hrs	49.64 Hz at 19.30 Hrs	49.94	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.32	17.21	190	170
Unit 7	0.00	0.00	0	0
Unit 8	13.04	53.29	595	390
Unit 9	11.98	50.25	532	432
Unit 10	12.43	50.80	536	476
Total	41.78	171.55		
Bhusawal				
Unit 3	3.48	13.75	160	125
Unit 4	10.80	41.22	465	410
Unit 5	10.13	24.89	455	380
Total	24.40	79.87		
Parli				
Unit 6	5.20	20.40	243	173
Unit 7	4.61	16.74	220	148
Unit 8	3.11	12.47	139	123
Total	12.92	49.62		
Chandrapur				
Unit 3	3.17	9.93	149	122
Unit 4	3.01	12.72	130	120
Unit 5	8.90	34.70	380	365
Unit 6	8.64	35.98	417	310
Unit 7	9.10	34.74	405	310
Unit 8	10.87	43.25	472	410
Unit 9	10.15	41.07	440	375
Total	53.84	212.38		
Paras				
Unit 3	5.31	20.17	238	204
Unit 4	5.15	15.26	236	195
Total	10.46	35.44		
Khaparkheda				
Unit 1	2.98	12.43	150	85
Unit 2	3.64	14.50	155	150
Unit 3	4.29	16.98	182	173
Unit 4	3.20	13.15	141	123
Unit 5	11.20	43.55	475	440
Total	25.31	100.60		
Nasik				
Unit 3	4.00	15.31	183	152
Unit 4	1.58	1.58	166	0
Unit 5	3.67	12.80	160	130
Total	9.25	29.69		
Uran				
All Units	3.15	12.58	138	123
Total	3.15	12.58		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.53	1.34	27	7
Total	0.53	1.34		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.87	14.38	500	40
Stage 4	4.87	13.24	725	0
Stage 3	1.89	6.85	240	0
Total	11.63	34.46		
Hydro				
KDPH	0.53	2.12	22	22
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.54	0	0
BHIRA T.R.	0.36	1.32	80	0
SMLHY_PTN	5.21	19.54	224	207
GHATGHAR	0.00	0.36	0	0
Total	6.10	23.89		
Wind				
Total	24.57	114.56	0	0
Total	24.57	114.56		
CPP				
APML(Mus)	76.28	289.50	0	0
JSWEL(Mus)	18.91	70.08	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.54	94.83	0	0
SWPGPL-Mus	6.39	33.93	0	0
Other(Mus)	16.29	64.56	0	0
Total	142.41	552.89		
SOLAR				
Total	10.18	39.26	0	0
Total	10.18	39.26		
Tata				
Trombay 5	10.26	40.04	458	301
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.34	3.54	113	0
Trombay 7B	0.00	0.00	0	0
TATA Hydro	5.78	23.30	443	0
Trombay 8	5.28	21.18	238	161
Total	21.66	88.07		
AEMIL				
DTPS U-1&2	10.78	45.62	501	252
Total	10.78	45.62		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	177.97	679.14	MSPGCL Total	199.38	751.41
			MSPGCL Thml+Gas	181.12	691.72	Koyna 1,2 & 4 Total	9.74	27.62
			MSPGCL Hydro	18.26	59.69	State Total	408.98	1591.80

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 04/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7356	784	136	8276	1606	6130	0	0	6751	6387	-1491	20553	0	20553	2986	356	23894	49.86
2	7322	973	127	8422	1563	6057	0	0	6375	6107	-1308	20493	0	20493	2803	349	23644	49.84
3	7312	474	137	7923	1468	6064	0	0	6703	6547	-1131	20550	0	20550	2637	322	23508	49.91
4	7361	387	126	7874	1411	6046	0	0	6492	6458	-1137	20356	0	20356	2513	296	23165	49.95
5	7456	393	137	7986	1557	6102	0	0	6412	6465	-1113	20678	0	20678	2432	320	23429	49.89
6	7447	604	127	8178	1457	6117	0	0	6612	6403	-1209	20601	0	20601	2422	345	23368	49.86
7	7411	825	137	8373	1375	6110	0	170	6730	6368	-1227	20807	0	20807	2379	361	23548	49.92
8	7331	387	126	7844	1201	5907	0	264	6841	7464	-1432	20848	0	20848	2430	400	23678	50.02
9	7263	319	135	7717	1029	5790	0	601	7202	7117	-1760	20075	0	20075	2620	420	23114	50.02
10	7212	384	124	7720	811	5818	0	930	7537	7596	-1738	20723	0	20723	2915	414	24052	49.99
11	7219	376	133	7728	680	5752	0	1109	7934	7839	-1955	20752	0	20752	3151	402	24304	49.98
12	7339	345	123	7807	644	5563	0	1312	8210	8105	-2025	20989	0	20989	3260	417	24666	49.99
13	7428	350	134	7912	675	5569	0	1364	8699	8375	-2068	21411	0	21411	3290	416	25117	50.00
14	7393	304	124	7821	671	5565	0	1383	8469	8266	-1986	21303	0	21303	3224	416	24944	49.97
15	7499	724	134	8357	650	5546	0	1132	8568	8375	-1999	21639	0	21639	3294	422	25355	49.93
16	7485	1383	124	8992	707	5754	0	905	8264	8036	-1979	21986	0	21986	3319	429	25734	49.95
17	7455	1195	135	8785	778	5977	0	594	7896	7711	-1904	21505	0	21505	3297	436	25238	50.00
18	7495	922	127	8544	635	6096	0	317	7482	7484	-1705	20944	0	20944	3174	427	24545	50.01
19	7518	627	137	8282	592	6040	0	94	7009	6945	-1481	20017	0	20017	3028	456	23500	49.97
20	7595	1374	138	9107	720	6017	0	0	6842	6454	-1484	20400	0	20400	3062	414	23876	49.78
21	7564	1517	128	9209	849	6094	0	0	6628	6248	-1402	20565	0	20565	2983	433	23981	49.91
22	7580	797	138	8515	1071	6096	0	0	6678	6646	-1362	20557	0	20557	2938	409	23904	49.96
23	7512	1152	128	8792	1164	6095	0	0	6679	6672	-1355	20962	0	20962	2935	406	24303	49.85
24	7414	1662	137	9213	1257	6105	0	0	6623	6442	-1419	21226	0	21226	3019	372	24617	49.91
MUs	177.97	18.26	3.15	199.38	24.57	142.41	0.00	10.18	173.64	170.51	-37.67	499.94	0.00	499.94	70.11	9.44	579.49	49.94

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Jun/2022

Position as on 6.30 Hrs of 05/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 6	108	29/05/2022	00:32		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	29/05/2022	04:57		Continued.	Gas shortage	
IPP	RPL(AMT) U-4	270	31/05/2022	01:15		Continued.	Ash Conveyer problem	06/06/2022
MSPGCL	Nasik Unit 4	210	31/05/2022	15:00	04/06/2022	12:09	ID Fan Problem	04/06/2022
AEML	AEML Unit 2	250	04/06/2022	00:02	04/06/2022	02:38	Generator Elect. Fault	
IPP	SWPGPL U-3	135	04/06/2022	01:00		Continued.	Boiler Bottom Ash System problem	
TPC-G	Trombay 7A	120	04/06/2022	03:15	05/06/2022	17:48	Gas shortage	05/06/2022
IPP	RPL(AMT) U-3	270	04/06/2022	12:00	04/06/2022	15:21	CEP Recirculation valve leakage.	
MSPGCL	Khaparkheda Unit 3	210	05/06/2022	01:07	05/06/2022	03:57	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/06/2022	03:21	05/06/2022	06:46	EO	Premonsoon Work
400 KV LR Outages/Trippings							
400KV KORADI-BHILAI (Koradi end)	IntraState	05/06/2022	08:51	05/06/2022	19:40	HT	work at PG end
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	30/05/2022	15:15			HT	H/T for Load Management ie. to avoid the dumping of power in 400 kV Kharghar and Kalwa Lines.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	03/06/2022	09:14	04/06/2022	16:34	PO	Due to Twin Monopole Cross-Arm jointing plate rectification Works.
BABHALESHWAR - RPL(NSK) CKT - 2	IntraState	03/06/2022	09:15	04/06/2022	16:40	PO	Due to Twin Monopole Cross-Arm jointing plate Rectification Works.
KARAD - LONIKAND I	IntraState	03/06/2022	22:54	04/06/2022	03:16	HT	H/T for load management
KHARGHAR - TALEGAON (PG)	IntraState	03/06/2022	23:05	04/06/2022	03:16	HT	Emergency outage for disc replacement
AKOLA - KHADKA (BHUSAWAL)	IntraState	04/06/2022	06:10	04/06/2022	18:24	PO	String replacement work will be carried out on 400 kV Akola-Khadka (Bhusawal) line. Also work of tightening of Spacers cum Vibration Dampers, providing of corona ring & arcing horn will be carried out.
NAGOTHANE - DABHOL CKT - 2	IntraState	04/06/2022	12:57	04/06/2022	20:27	PO	Lightning Arrestor replacement
KHARGHAR - TALEGAON (PG)	IntraState	04/06/2022	22:26	05/06/2022	02:21	EO	Cold washing of insulator string from loc no 10 to 33 (DC portion)
KHARGHAR - TALEGAON (PG)	IntraState	04/06/2022	23:05	04/06/2022	03:16	EO	Replacement of Flash overed insulator string at loc no 30 Rph
LONIKAND I - JEJURI	IntraState	05/06/2022	17:41	05/06/2022	21:17	EO	Replacement of R phase L.A due to high LCM value (280 microamps) of 400kV Lonikand-Jejuri line bay at 400kV Lonikand-I.
PADGHE - KALWA CKT - 2	IntraState	05/06/2022	19:57	05/06/2022	22:16	EO	Hot Spot Attending work at loc. no. 1012 Y-Phase (145 Degree)
KARAD - LONIKAND I	IntraState	05/06/2022	22:56		Continued.	HT	For Load Management
400 KV BR Outages/Trippings							
400KV 125 MVAR BUS REACTOR@400KV DHULE SS	InterState	04/06/2022	08:43	04/06/2022	19:55	PO	FOR MAINTENANCE OF PG ISOLATOR OF 400KV,125 MVAR Bus Reactor
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	CABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
KANDALGAON - KOYNA (POPHALI)	IntraState	04/06/2022	06:33	04/06/2022	11:18	PO	For replacement of damaged tower at loc no. 95&99 of 220kV Lote-Dasturi line &:220kV Pophali-Kandalgaon line.
GHODBUNDER - GORAI	IntraState	04/06/2022	09:43	04/06/2022	14:47	PO	Checking and Refilling of CB compressor oil and premonsoon maintenance of CB
KARAD - DASGAON	IntraState	04/06/2022	10:45	04/06/2022	17:28	PO	Insulator cleaning & jumper tightening
BOMBAY DYEING - SAHARA	IntraState	04/06/2022	14:41	04/06/2022	19:15	EO	1) Replacement of F/O string R-ph loc-102 2)Cold Washing loc 92-115 3) Earthwire removal loc. 89-105
LONIDEOKAR TAP ON WALCHANDNAGAR- BHIGWAN CKT	IntraState	04/06/2022	15:10	04/06/2022	20:05	PO	REPLACEMENT OF FLASHOVER STRING AT LOC NO.10 B-PH

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHAKAN-BHOSARI 1	IntraState	04/06/2022	21:59	05/06/2022	00:41	HT	R-ph CC abnormal sound & hotspot at Bhosari end
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	05/06/2022	01:21	05/06/2022	02:17	T	Distance Protection
LOTEPARSHURAM- DASTURI LINE	IntraState	05/06/2022	06:10	05/06/2022	11:50	PO	For replacement of damaged tower at loc no. 95&99 of 220kV Lote-Dasturi line & 220kV Pophali-Kandalgaon line.
KALWA - TFIPL	IntraState	05/06/2022	07:00	05/06/2022	12:38	PO	Outage required for safety purpose for removing of jumpers of 220KV Kharghar-Borivali-1 for CTRLS at Loc no.47.
KHARGHAR - BORIVALI CKT - 1	IntraState	05/06/2022	07:08	05/06/2022	14:56	PO	The work of removing of jumpers for making LILO at 220KV CTRLS S/stn at Loc no.47
TROMBAY - ANTOP HILL CKT - 1	IntraState	05/06/2022	09:41	05/06/2022	20:05	PO	For CVT testing
CHAKAN-BHOSARI 1	IntraState	05/06/2022	10:47	05/06/2022	18:36	PO	Double Jumpering Work at location no 25 to 27 (M/C) 68,59,57,52,51, tap 1, Z1,Z3, 4A, 4,3,2,1. and cold washing of insulators at loc no, 1,2,34,Z1, Z3, loc no 31, to 22 (M/c) from Chakan end.
AAREY - AEML SAKI CKT - 2	IntraState	05/06/2022	14:22	05/06/2022	17:50	EO	Covering of damaged Sheath of 220 kV Cable with heat shrink sleeves to prevent ingress of moisture.
BABLESHWAR-BABLESHWAR(400KV)-II	IntraState	05/06/2022	17:16	05/06/2022	20:35	T	TRIPPED ON DISTANCE PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/33 KV 50 MVA PTR 1 @ SONKAR	IntraState	04/06/2022	07:58	04/06/2022	09:49	PO	Plastic paper wrapping to PRV, Buchloz relay & Auxiliary Trials.
220/33-22 KV 50 MVA PTR 4 @ NERUL	IntraState	04/06/2022	08:23	04/06/2022	11:50	PO	for replacement of R phase LA on EHV Side and polythene wrapping
220/22 KV 50 MVA PTR 3 @ COLOURCHEM	IntraState	04/06/2022	08:30	04/06/2022	10:57	PO	For pre monsoon maintenance work including plastic paper wrapping to transformer buccholz , PRV relay ,MK box.
220/33 KV 50 MVA PTR 2 @ SONKAR	IntraState	04/06/2022	09:53	04/06/2022	11:13	PO	Plastic paper wrapping to PRV, Buchloz relay & Auxiliary Trials.
220/100 KV 100MVA NO 4 @ CHINCHWAD	IntraState	04/06/2022	10:25	04/06/2022	18:52	PO	Premonsoon & half yearly Maint.work
220/33KV 125 MVA TF 1 @ GOREGAON	IntraState	04/06/2022	10:26	04/06/2022	20:31	PO	Annual Maintenance & Premonsoon Maintenance
220/132 KV 200 MVA ICT 2 @ SATANA	IntraState	04/06/2022	10:33	04/06/2022	17:15	PO	For OLTC overhauling work.
220/33KV 125 MVA TF 1 @ CHEMBUR	IntraState	04/06/2022	10:37	04/06/2022	16:27	PO	Annual and Premonsoon maintenance of Transformer
220/22-22 KV 100 MVA PTR 1 @ COLOURCHEM	IntraState	04/06/2022	12:05	04/06/2022	17:28	PO	For premonsoon maintenance work including transformer buccholz , PRV relay ,MB plastic paper wrapping work.
220/22-22 KV 50 MVA PTR 2 @ COLOURCHEM	IntraState	05/06/2022	07:15	05/06/2022	13:30	PO	For premonsoon maintenance work including transformer buccholz , PRV relay ,MB plastic paper wrapping work .
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	05/06/2022	09:25	05/06/2022	11:26	PO	Plastic wrapping of auxiliaries of ICT-1 & 2 alternately
220/110/33KV 250 MVA ICT-4 @ MAHALAXMI GIS (T)	IntraState	05/06/2022	10:02	05/06/2022	16:59	PO	R/M AND PROTECTION TESTING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 05/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	05/06/2022	11:38	05/06/2022	12:44	PO	Plastic wrapping of auxiliaries of ICT-1 & 2 alternately
220/22 KV 80 MVA PTR 2 @ NALASOPARA	IntraState	05/06/2022	13:30	05/06/2022	20:09	PO	Pre monsoon maintenance and LV Bushing oil leakage attending work by M/s Mahati Industries.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage