

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Jul/2020 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	92.398	381.789	1) Gujrat	2.055	20.114
2) Hydro	7.251	31.696	2) Madhya Pradesh	8.828	39.617
3) Gas	2.959	12.408	3) Chattisgarh	4.930	20.640
Total MSPGCL	102.608	425.893	4) Maharashtra	116.405	490.444
B) 1) APMIL	30.307	117.657	5) Goa (Amona)	0.000	-1.056
2) JSWEL	17.853	71.387	Total	132.218	569.759
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.333	103.948
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	21.865	99.007
5) WPCL	2.753	10.855	c) MSEDCL Bilateral *	24.458	115.278
6) Other IPP	6.798	28.769	Include PX	4.739	28.334
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.333	103.948
C) 1) TPCL Thermal	7.880	31.779	Include PX	16.323	74.611
2) TPCL Hydro	5.070	19.002	Standby	0.000	0.000
3) TPCL Gas	3.916	16.950	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.865	19.636	1) MSEDCL	321.716	1296.426
D) STATE			2) Mumbai Discoms	43.596	186.374
1) Thermal	162.854	661.872	TOTAL STATE	365.312	1482.800
(A1+C1+C4+(B1-B6))					
2) Hydro	12.321	50.698			
(A2+C2)					
3) Gas	6.875	29.358			
(A3+B7+C3)					
4) Wind	45.780	147.266			
6) SOLAR	5.264	23.847			
TOTAL STATE	233.094	913.041			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4206	3818	3708	3982
MSPGCL Hydro	356	445	354	78
MSPGCL Gas	133	122	118	124
MSPGCL Total Generation	4695	4385	4180	4184
Central Sector Receipt	5987	6005	5446	4983
WIND	2032	2102	2419	1357
CPP / IPP Thermal	2397	2187	2460	2425
CPP / IPP Gas	0	0	0	0
SOLAR	665	641	0	0
Exchange with Mumbai	-1170	-1139	-805	-861
MSEDCL DEMAND MET	14606	14181	13700	12088
Load Shedding	0	0	0	0
MSEDCL DEMAND	14606	14181	13700	12088
TPCL GENERATION	690	736	845	567
AEML GENERATION	190	190	219	191
MUMBAI DEMAND	2050	2065	1869	1619
STATE DEMAND MET	16656	16246	15569	13707
STATE DEMAND	16656	16246	15569	13707
Frequency (Hz)	50.06	49.95	50.02	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.15 Hz at 21.32 Hrs	49.8 Hz at 06.14 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 04/Jul/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	9.90	39.52	515	265
Unit 10	9.31	40.29	435	315
Total	19.22	79.81		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.36	15.79	180	0
Unit 4	3.50	15.08	165	110
Unit 5	9.37	37.09	430	350
Unit 6	0.00	16.50	0	0
Unit 7	9.42	38.06	428	359
Unit 8	10.23	39.95	450	365
Unit 9	6.03	36.13	470	0
Total	41.91	198.59		
Paras				
Unit 3	4.79	19.00	235	155
Unit 4	5.23	19.90	250	162
Total	10.02	38.90		
Khaparkheda				
Unit 1	3.66	14.39	170	125
Unit 2	0.00	0.00	0	0
Unit 3	4.07	15.40	178	158
Unit 4	4.24	16.82	190	162
Unit 5	9.29	17.88	470	340
Total	21.26	64.49		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	2.96	12.41	135	118
Total	2.96	12.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	0.30	26	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.10	0.30		
Koyna				
Stage 1-2	2.86	12.56	365	40
Stage 4	0.84	5.19	258	0
Stage 3	1.71	6.01	160	0
Total	5.42	23.75		
Hydro				
KDPH	0.67	2.69	28	28
VTRNA	0.00	0.00	0	0
TILLARI	0.80	2.92	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.20	1.05	40	0
RNGR+BHTSA	0.00	0.63	0	0
BHANDARDRA	0.00	0.20	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.17	0.46	16	4
GHATGHAR	0.00	0.00	0	0
Total	1.84	7.94		
Wind				
Total	45.78	147.27	0	0
Total	45.78	147.27		
CPP				
APML(Mus)	30.31	117.66	0	0
JSWEL(Mus)	17.85	71.39	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.75	10.86	0	0
Other(Mus)	6.80	28.77	0	0
Total	57.71	228.67		
SOLAR				
Total	5.26	23.85	0	0
Total	5.26	23.85		
Tata				
Trombay 5	7.88	31.78	404	292
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.46	10.81	117	96
Trombay 7B	1.46	6.14	65	59
Trombay 8	0.00	0.00	0	0
TATA Hydro	5.07	19.00	459	43
Total	16.87	67.73		
AEML				
DTPS U-1&2	4.86	19.64	252	189
Total	4.86	19.64		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	92.40	381.79	MSPGCL Total	102.61	425.89
			MSPGCL Thml+Gas	95.36	394.20	Koyna 1,2 & 4 Total	3.70	17.75
			MSPGCL Hydro	7.25	31.70	State Total	233.09	913.04

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Jul/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4244	158	134	4536	1430	2543	0	0	5015	5055	-955	12609	0	12609	1875	14484	50.00
2	4171	111	125	4407	1367	2420	0	0	4997	5195	-942	12447	0	12447	1772	14219	50.02
3	4106	78	125	4309	1386	2437	0	0	4991	5010	-912	12230	0	12230	1684	13914	49.99
4	3982	78	124	4184	1357	2425	0	0	5012	4983	-861	12088	0	12088	1619	13707	50.02
5	3979	78	125	4182	1535	2437	0	0	5078	5069	-775	12448	0	12448	1588	14036	49.99
6	3995	263	135	4393	1614	2443	0	0	5536	5724	-720	13454	0	13454	1597	15051	50.00
7	4105	776	125	5006	1480	2426	0	32	5846	5853	-658	14139	0	14139	1582	15721	49.97
8	4148	878	125	5151	1530	2454	0	168	5985	6022	-693	14632	0	14632	1636	16268	49.99
9	4210	693	125	5028	1862	2435	0	429	5863	5908	-823	14839	0	14839	1762	16601	49.99
10	4223	406	125	4754	1922	2427	0	580	6027	6028	-1040	14671	0	14671	1922	16593	49.98
11	4206	356	133	4695	2032	2397	0	665	6069	5987	-1170	14606	0	14606	2050	16656	50.06
12	3828	258	122	4208	2000	2226	0	740	6419	6291	-1196	14269	0	14269	2082	16351	50.02
13	3818	445	122	4385	2102	2187	0	641	5858	6005	-1139	14181	0	14181	2065	16246	49.95
14	3690	234	120	4044	2144	2176	0	680	5873	5809	-1143	13710	0	13710	2006	15716	49.98
15	3545	284	120	3949	2240	2221	0	593	5774	5930	-975	13958	0	13958	1928	15886	49.95
16	3547	249	120	3916	2418	2347	0	331	5506	5362	-826	13548	0	13548	1858	15406	50.01
17	3428	299	120	3847	2502	2361	0	276	5319	5239	-830	13395	0	13395	1774	15169	50.04
18	3414	265	120	3799	2386	2371	0	101	5230	5266	-936	12987	0	12987	1754	14741	50.03
19	3473	215	119	3807	2370	2385	0	28	5293	5571	-1020	13141	0	13141	1825	14966	50.04
20	3708	354	118	4180	2419	2460	0	0	5292	5446	-805	13700	0	13700	1869	15569	50.02
21	3743	262	118	4123	2246	2546	0	0	4938	4981	-732	13164	0	13164	1887	15051	50.03
22	3693	172	119	3984	2130	2541	0	0	5131	4980	-884	12751	0	12751	1841	14592	50.04
23	3561	157	120	3838	1749	2491	0	0	4922	5289	-915	12452	0	12452	1823	14275	50.07
24	3581	182	120	3883	1559	2555	0	0	4794	5215	-915	12297	0	12297	1797	14094	50.07
MUs	92.40	7.25	2.96	102.61	45.78	57.71	0.00	5.26	130.77	132.22	-21.86	321.72	0.00	321.72	43.60	365.31	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Jul/2020

Position as on 6.30 Hrs of 05/Jul/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-2	250	02/07/2020	09.00		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.(Converted zero schedule from 25.03.2020)	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
CPP	SWPGL U-3	135	25/04/2020	00.08	04/07/2020	23.31	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Jul/2020

Position as on 6.30 Hrs of 05/Jul/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit-8	660	31/05/2020	22.56		Continued.	Heavy steam Leakage in super heater.(Converted in To Zero schedule w.e.f 03.06.2020 01.28)	
MSPGCL	Bhusawal Unit 4	500	01/06/2020	07.16		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 5	500	01/06/2020	12.21		Continued.	Zero schedule By MSEDCL	
MSPGCL	Parli Unit 8	250	01/06/2020	13.13		Continued.	Zero schedule By MSEDCL	
IPP	Adani U-1	660	03/06/2020	15.02		Continued.	Converted zero schedule from 03.06.2020	
IPP	Adani U-5	660	04/06/2020	12.29		Continued.	Zero Schedule.	
IPP	Adani U-4	660	12/06/2020	10.30		Continued.	Zero Schedule	
MSPGCL	Khaparkheda Unit 2	210	24/06/2020	11.34		Continued.	Generator Earth Fault	
AEML	AEML Unit 1	250	27/06/2020	23.55		Continued.	Zero schedule.	
IPP	SWPGL U-2	135	29/06/2020	12.00	05/07/2020	00.12	ID Fan Problem	
MSPGCL	Chandrapur Unit 6	500	02/07/2020	18.30	05/07/2020	01.11	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	04/07/2020	13.31		Continued.	Water valve Circulation not.	
MSPGCL	Chandrapur Unit 3	210	04/07/2020	14.48	04/07/2020	18.36	Low furnace pressure	
MSPGCL	Chandrapur Unit 6	500	05/07/2020	11.08	05/07/2020	14.14	HP CV Closed.	
MSPGCL	Chandrapur Unit 6	500	05/07/2020	14.25	05/07/2020	16.15	HP CV Closed.	
MSPGCL	Chandrapur Unit 3	210	05/07/2020	20.43		Continued.	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jul/2020

Statement-VII

Position as on 6.30 Hrs of 05/Jul/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	03/07/2020	13.54		Continued.	T	Distance Protection (RFC 23.10).
Chandrapur-II - Warora - I	InterState	04/07/2020	09.24	04/07/2020	16.38	PO	Routine Maintenance Work & diagnostic Testing Work,relay Testing Work.
Chandrapur Bhadravati II	InterState	04/07/2020	21.02		Continued.	HT	Over Voltage
Parli(MS)-Parli (PG) II	InterState	05/07/2020	01.39	05/07/2020	07.11	T	Over Voltage
Dabhol New koyna I	InterState	05/07/2020	03.28	05/07/2020	11.07	T	Over Voltage
Parli(MS)-Parli (PG) II	InterState	05/07/2020	12.59	05/07/2020	22.39	PO	Attending Hot Spot
BABHALESHWAR - RPL(NASHIK) CKT - 1	IntraState	11/06/2020	10.40		Continued.	HT	Over Voltage
Babhaleshwar - Padghe-II	IntraState	18/06/2020	20.48		Continued.	HT	Over Voltage
Padghe - Nagothane - I	IntraState	25/06/2020	19.20		Continued.	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	26/06/2020	16.47		Continued.	HT	Over Voltage
Dhule - Bableshtar - II	IntraState	29/06/2020	19.38		Continued.	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	02/07/2020	10.28		Continued.	EO	SF6 Gas Leakage.
Deepnagar Taptitanda	IntraState	03/07/2020	17.12	04/07/2020	07.22	T	Over Voltage
Karad - Jaigad - II	IntraState	03/07/2020	20.35		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	04/07/2020	01.46	04/07/2020	09.33	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	04/07/2020	02.19	04/07/2020	08.25	HT	Over Voltage
Koradi-Bhusawal	IntraState	04/07/2020	20.04		Continued.	T	Over Voltage
Padghe - Kalwa- I	IntraState	04/07/2020	20.51		Continued.	T	Over Voltage
Karad - Talandge Ckt 2	IntraState	04/07/2020	22.17		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	04/07/2020	22.17		Continued.	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	05/07/2020	03.28	05/07/2020	13.45	T	Over Voltage
Jejuri- Koynastage-IV	IntraState	05/07/2020	03.28	05/07/2020	06.50	T	Over Voltage
Lonikand 1 -Jejuri	IntraState	05/07/2020	03.28	05/07/2020	06.33	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	04/07/2020	02.12		Continued.	HT	LV Side, Over Voltage.
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	04/07/2020	10.15	04/07/2020	12.00	T	OLTC Bucholz relay alarm.
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	05/07/2020	00.03		Continued.	PO	LV Side Over Voltage.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Borivali - Tarapur	InterState	05/07/2020	13.53		Continued.	T	Distance Protection
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
EKLAHRE (GCR)Nashik-Airoli Knowledge Park	IntraState	02/07/2020	08.19		Continued.	PO	Stringing of conductor between olt Tower to new CTT tower at both ends and connection of jumper to cable termination kit
Sawantwadi-Bidri	IntraState	03/07/2020	22.05	04/07/2020	10.05	HT	Over Voltage
Lonikand-VSNL	IntraState	04/07/2020	09.20	04/07/2020	18.48	PO	Work of putting OPGW in place of existing 7/3.15 mm sq normal earth wire in r/o MTCIL.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jul/2020

Statement-VII

Position as on 6.30 Hrs of 05/Jul/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
512 Khadki- Century Enka	IntraState	04/07/2020	09.20	04/07/2020	18.48	PO	Work of putting OPGW in place of existing 7/3.15 mm sq normal.
Pargaon(Kathapur)-Lonikand	IntraState	04/07/2020	09.29	04/07/2020	10.58	PO	Half yearly maintenance & Diagnostic testing work.
Gadchandur-Ultratech II	IntraState	04/07/2020	12.02	04/07/2020	15.02	PO	For Repairing/servicing & alignment of 220kv line bus & auxiliary isolators by agency.
Chandrapur(MIDC)-Ballarshah II	IntraState	04/07/2020	15.22	05/07/2020	17.33	T	Distance Protection
Chandrapur(MIDC)-Ballarshah I	IntraState	04/07/2020	15.22	04/07/2020	20.57	T	Distance Protection
Salsette Borivli 2	IntraState	05/07/2020	09.45	05/07/2020	15.37	PO	ARR Scheme Commissioning.
Pandharpur - Malinagar	IntraState	05/07/2020	10.18	05/07/2020	17.50	PO	Outage Is Required For Making LILO Arrangment For 220KV Bhalwani Line.
220 KV ICT Outages/Trippings							
220/132 kV 100MVA ICT-I @ Shivajinagar	IntraState	13/06/2020	01.24		Continued.	T	Differential protection & main Buchholz trip.
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	04/07/2020	07.19	04/07/2020	19.27	PO	OLTC Overhauling work.
220/132kv 100mva Ict 1 @Peth	IntraState	04/07/2020	10.00	04/07/2020	11.54	PO	Quarterly Maintenance Work & Attending Oil Leakage.
220/132 Kv 150 Mva Cgl Ict 3 @Eklahre (Ocr)	IntraState	04/07/2020	11.48	04/07/2020	13.21	EO	Testing Work
220/132 kV 200MVA ICT-V @ Nashik	IntraState	04/07/2020	11.48	04/07/2020	13.21	EO	Testing Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage