

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Jul/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.424	551.941	1) Gujrat	-9.543	-38.766
2) Hydro	8.650	43.041	2) Madhya Pradesh	3.608	22.081
3) Gas	6.210	21.431	3) Chattisgarh	4.050	14.760
Total MSPGCL	163.284	616.413	4) Maharashtra	165.890	638.512
B) 1) APLM	49.700	195.822	5) Goa (Amona)	-0.984	-4.263
2) JSWEL	14.322	57.263	Total	163.021	632.324
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.281	131.801
4) RPL(AMT)	19.096	73.207	b) Mumbai Drawl	38.006	144.920
5) SWPGPL	8.461	29.638	c) MSEDCL Bilateral *	75.669	323.860
6) Other IPP	7.595	31.208	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.281	131.801
C) 1) TPCL Thermal	10.170	41.482	Include PX	0.000	0.000
2) TPCL Hydro	2.352	6.734	Standby	0.000	0.000
3) TPCL Gas	1.545	1.952	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.563	40.566	1) MSEDCL	416.828	1646.595
D) STATE			2) Mumbai Discoms	62.636	235.653
1) Thermal	268.331	1021.127	3) Other Discoms	8.838	35.683
(A1+C1+C4+(B1-B6))			TOTAL STATE	488.302	1917.931
2) Hydro (A2+C2)	11.002	49.775			
3) Gas (A3+B7+C3)	7.755	23.383			
4) Wind	30.936	157.076			
6) SOLAR	7.257	34.247			
TOTAL STATE	325.281	1285.608			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6469	6357	6051	6249
MSPGCL Hydro	646	430	384	290
MSPGCL Gas	271	259	256	261
MSPGCL Total Generation	7386	7046	6692	6800
Central Sector Receipt	8517	8587	6273	5640
WIND	396	496	2372	701
CPP / IPP Thermal	4543	4000	4291	4347
CPP / IPP Gas	0	0	0	0
SOLAR	647	977	0	0
Exchange with Mumbai	-1928	-2250	-1470	-1093
MSEDCL DEMAND MET	19157	18481	17766	16105
Load Shedding	0	0	0	0
MSEDCL DEMAND	19157	18481	17766	16105
TPCL GENERATION	567	515	824	429
AEML GENERATION	483	424	472	409
MUMBAI DEMAND	2978	3189	2766	1931
OTHER DISCOM DEMAND	404	376	392	291
STATE DEMAND MET	22540	22046	20924	18326
STATE DEMAND	22540	22046	20924	18326
Frequency (Hz)	50.02	50.03	49.85	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.17 Hz at 10.19 Hrs	49.63 Hz at 19.13 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.44	6.27	140	25
Unit 7	0.00	0.00	0	0
Unit 8	9.25	43.27	490	0
Unit 9	11.66	18.10	542	401
Unit 10	12.05	47.66	525	455
Total	35.39	115.30		
Bhusawal				
Unit 3	2.98	12.62	135	115
Unit 4	9.97	37.54	455	315
Unit 5	10.06	25.29	470	315
Total	23.02	75.46		
Parli				
Unit 6	5.07	20.18	249	155
Unit 7	3.82	16.94	208	108
Unit 8	0.00	0.00	0	0
Total	8.89	37.12		
Chandrapur				
Unit 3	2.83	9.93	125	108
Unit 4	2.99	11.52	138	113
Unit 5	7.45	30.35	325	290
Unit 6	6.89	30.20	350	225
Unit 7	0.00	0.00	0	0
Unit 8	10.62	42.43	457	406
Unit 9	10.30	40.52	458	398
Total	41.07	164.94		
Paras				
Unit 3	4.42	17.96	205	139
Unit 4	4.66	17.12	213	140
Total	9.07	35.08		
Khaparkheda				
Unit 1	2.92	12.96	135	100
Unit 2	3.10	13.54	155	100
Unit 3	3.68	15.36	166	134
Unit 4	0.00	0.00	0	0
Unit 5	11.10	43.58	475	405
Total	20.80	85.45		
Nasik				
Unit 3	3.71	14.91	179	127
Unit 4	3.38	13.62	157	126
Unit 5	3.08	10.06	155	110
Total	10.17	38.59		
Uran				
All Units	6.21	21.43	271	220
Total	6.21	21.43		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.25	0.34	14	0
Total	0.25	0.34		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.32	9.94	135	40
Stage 4	0.28	4.50	217	0
Stage 3	0.39	4.15	80	0
Total	1.99	18.58		
Hydro				
KDPH	0.23	0.50	10	10
VTRNA	0.76	2.87	60	0
TILLARI	0.00	0.47	0	0
BHIRA T.R.	0.24	0.57	77	0
SMLHY_PTN	5.18	19.71	226	205
GHATGHAR	0.00	0.00	0	0
Total	6.41	24.12		
Wind				
Total	30.94	157.08	0	0
Total	30.94	157.08		
CPP				
APML(Mus)	49.70	195.82	0	0
JSWEL(Mus)	14.32	57.26	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.10	73.21	0	0
SWPGPL-Mus	8.46	29.64	0	0
Other(Mus)	7.60	31.21	0	0
Total	99.17	387.14		
SOLAR				
Total	7.26	34.25	0	0
Total	7.26	34.25		
Tata				
Trombay 5	5.88	25.97	253	217
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.15	1.38	115	0
Trombay 7B	0.39	0.57	67	0
TATA Hydro	2.35	6.73	237	2
Trombay 8	4.30	15.51	226	134
Total	14.07	50.17		
AEML				
DTPS U-1&2	10.56	40.57	501	342
Total	10.56	40.57		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.42	551.94	MSPGCL Total	163.28	616.41
			MSPGCL Thml+Gas	154.63	573.37	Koyna 1,2 & 4 Total	1.60	14.43
			MSPGCL Hydro	8.65	43.04	State Total	325.28	1285.61

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 04/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6334	286	261	6880	1345	3945	0	0	5749	5947	-1384	16398	0	16398	2288	335	19022	49.99
2	6252	338	261	6850	1121	3815	0	0	5879	5931	-1263	16157	0	16157	2144	298	18598	49.95
3	6229	342	261	6832	883	4152	0	0	5585	5639	-1161	16074	0	16074	2013	272	18358	49.96
4	6249	290	261	6800	701	4347	0	0	5880	5640	-1093	16105	0	16105	1931	291	18326	49.95
5	6288	284	261	6832	659	4247	0	0	6350	6252	-1068	16607	0	16607	1918	315	18840	49.98
6	6292	288	261	6840	570	4329	0	0	7197	6722	-1167	16969	0	16969	2033	325	19328	49.87
7	6400	282	269	6950	511	4537	0	49	7585	7479	-1245	17917	0	17917	2169	364	20450	49.89
8	6502	260	261	7024	412	4525	0	194	7890	7817	-1411	18177	0	18177	2343	384	20904	49.91
9	6561	352	260	7172	364	4516	0	412	7654	7987	-1693	18358	0	18358	2652	400	21410	50.04
10	6469	646	271	7386	396	4543	0	647	7901	8517	-1928	19157	0	19157	2978	404	22540	50.02
11	6457	550	261	7268	329	4323	0	798	8597	8534	-2088	18777	0	18777	3192	386	22356	50.06
12	6426	466	268	7160	404	4117	0	924	8783	8734	-2121	18820	0	18820	3239	398	22458	49.98
13	6357	430	259	7046	496	4000	0	977	8891	8587	-2250	18481	0	18481	3189	376	22046	50.03
14	5940	414	261	6616	912	3631	0	916	8999	8449	-2106	18037	0	18037	3071	381	21488	50.01
15	5886	374	267	6526	1780	3512	0	895	8640	8007	-2047	18276	0	18276	3062	398	21736	49.99
16	5936	338	262	6536	2064	3526	0	744	7497	7137	-2069	17534	0	17534	3018	404	20956	49.92
17	5933	340	220	6494	2354	3520	0	442	6489	6919	-2045	17278	0	17278	2953	406	20636	49.91
18	6192	350	243	6786	2355	3687	0	218	6259	6191	-1889	16947	0	16947	2903	401	20250	50.00
19	5954	348	253	6554	2590	3619	0	41	6433	6590	-1749	17228	0	17228	2869	417	20514	50.00
20	6051	384	256	6692	2372	4291	0	0	6060	6273	-1470	17766	0	17766	2766	392	20924	49.85
21	6167	396	257	6820	2264	4568	0	0	5870	5095	-1352	17008	0	17008	2619	386	20014	49.94
22	5970	318	257	6544	2125	4204	0	0	5490	5340	-1276	16559	0	16559	2510	379	19448	49.90
23	5837	288	267	6392	2014	4539	0	0	4756	4699	-1061	16219	0	16219	2419	364	19002	49.77
24	5742	286	252	6280	1915	4681	0	0	4710	4535	-1070	15978	0	15978	2357	362	18698	49.90
MUs	148.42	8.65	6.21	163.28	30.94	99.17	0.00	7.26	165.14	163.02	-38.01	416.83	0.00	416.83	62.64	8.84	488.30	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 04/Jul/2022

Position as on 6.30 Hrs of 05/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkhedha Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna STG-IV Unit-2	250	13/06/2022	00:00		Continued.	Commissioning and installation of New TSLG governor	07/07/2022
IPP	RPL(AMT) U-5	270	15/06/2022	00:00		Continued.	Annual Overhaul	25/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Parli Unit 8	250	25/06/2022	00:00		Continued.	Short overhauling	10/07/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Stator Earth Fault (Converted into AOH from 00:00Hrs dt.01/07/2022.	22/07/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	RPL(AMT) U-1	270	01/05/2018	00.00		Continued.	Coal Shortage(Zero schedule on 30.06.2018)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Turbine Gland steam temperature not maintained	18/07/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	07/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	07/07/2022
TPC-G	Trombay 7B	60	01/07/2022	04:53	04/07/2022	17:31	Gas shortage	
TPC-G	Trombay 7A	120	01/07/2022	05:14	04/07/2022	13:07	Gas shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	10/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Jul/2022

Position as on 6.30 Hrs of 05/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	SWPGPL U-1	135	03/07/2022	21:58	04/07/2022	00:36	PA Fan problem	03/07/2022
IPP	SWPGPL U-1	135	04/07/2022	02:38		Continued.	PA Fan problem	08/07/2022
TPC-G	Trombay 5	500	05/07/2022	02:25		Continued.	condenser cooling water inlet line leakage	09/07/2022
MSPGCL	Khaparkheda Unit 5	500	05/07/2022	04:16	05/07/2022	11:36	ID Fan Problem	05/07/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 05/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
MAIN BAY (403) of 500 MVA ICT @ ALKUD	IntraState	05/07/2022	10:47	05/07/2022	19:03	PO	Quarterly Maintenance & Diagnostic testing Work
400 KV LINE Outages/Trippings							
WARORA - WARDHA (PG)	InterState	20/06/2022	10:10	05/07/2022	12:16	PO	1. Tower Erection of loc. No. 01 under 400 kV Wardha-Warora line. 2. Connecting 400kV Warora (MSETCL) to 400kV Warora (PGCIL)
KALWA - TALEGAON (PG)	InterState	04/07/2022	22:12	05/07/2022	01:13	EO	Hot spot attending work of: 1) Wavetrap jumper Top & bottom pad R & Y-phase (Temp 191 deg C) 2) CB R-ph, 29 B Isolator side (Temp 161 deg C)
DHULE - SSNNL CKT - 1	InterState	05/07/2022	07:27	05/07/2022	20:30	PO	SF6 to air bushing gas leakage checking work & Relay testing work with M/s HEIL, Bangalore
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
400 KV ICT Outages/Trippings							
400kv Stn. TF No 3 @ C'pur GCR	IntraState	05/07/2022	10:37			PO	1) Measurement of R, Y & B-ph CTs Tan delta & capacitance 2) Measurement of CB timing, CRM, DCRM. 3) Maintenance and alignment of Isolators
400/220 KV 500 MVA ICT @ ALKUD	IntraState	05/07/2022	10:47	05/07/2022	19:03	PO	Quarterly Maintenance & Diagnostic testing Work
400/220/33KV 315MVA ICT - 2 @ LONIKAND	IntraState	05/07/2022	11:06	05/07/2022	11:06	PO	ICT-2 LV (220kV Side) CB Mechanism O/H work
400/220 KV SPARE 167 MVA ICT @ ALKUD	IntraState	05/07/2022	11:38	05/07/2022	19:03	PO	Quarterly Maintenance & Diagnostic testing Work
220 KV TBC Outages/Trippings							
TBC @ JEJURI	IntraState	04/07/2022	10:05	05/07/2022	18:52	PO	220 KV TBC BREAKER MECHANISM OVERHAULING WORK
220 KV MAINBAY Outages/Trippings							
MAIN BUS @ NIWALI	IntraState	04/07/2022	10:38	04/07/2022	18:44	PO	Charging of newly erected 220KV and 110KV Bus extension and ICT2 HV LV Bays (not at ICT).
BUS COUPLER @ BABHALESHWAR	IntraState	05/07/2022	11:56	05/07/2022	16:19	PO	CT testing
220 KV LINE Outages/Trippings							
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
TAMBATI - ADLABS	IntraState	03/07/2022	20:30	04/07/2022	01:55	T	wave trap jumper broken at Adlab end
POPHALI - KDPH	IntraState	04/07/2022	03:53	05/07/2022	10:01	T	Distance protection
CHEMBUR (AEML) - NERUL (M)	IntraState	04/07/2022	08:33	04/07/2022	11:31	PO	Outage required for safety purpose for erection of tower no.49 of 400KV Kharghar-Vikroli line by Kharghar-Vikroli Transmission Ltd. as the loc no.49 is close to 220KV Nerul-Chembur
TALANDAGE - FIVE STAR MIDC 2	IntraState	04/07/2022	09:40	04/07/2022	18:19	PO	1. Annual relay testing work 2. Back Up relay retrofitting work 3. QM work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 05/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KARAD -MUDSHINGI CKT 2-TAK	IntraState	04/07/2022	09:50	04/07/2022	14:23	PO	For Replacement of TSR
WARDHA - WARDHA (PG)	IntraState	04/07/2022	10:35	04/07/2022	15:41	PO	Routine line maintainance work
ALEPHATA-PARGAON(KATHAPUR)	IntraState	04/07/2022	10:50	04/07/2022	17:23	HT	H/T for to control line loading.
WARDHA - WARDHA (PG)	IntraState	04/07/2022	12:01	04/07/2022	15:41	PO	For following diagnostic testing work 1) For measurement of tan delta & IR of CT. 2) For measurement of CB Timing CRM of breaker. 3) For other bay maintenance activities.
MALEGAON - KALWAN CKT-2	IntraState	04/07/2022	13:38	04/07/2022	16:57	PO	Relay testing and SCADA Upgrading work
PEDAMBE-KALAMBANI(TSS)	IntraState	04/07/2022	14:33	05/07/2022	11:55	T	DP
TALANDGE - ICHALKARANJI 2	IntraState	04/07/2022	14:43	04/07/2022	16:36	PO	1) For Quarterly bay maintenance work. 2) Bay Diagnostic testing work 3) Hot spot attending work
URAN - APTA 2	IntraState	04/07/2022	15:45	04/07/2022	19:21	T	DP
SADAWAGHAPUR KARAD CKT 1	IntraState	04/07/2022	19:29	04/07/2022	20:15	T	DP
SADAWAGHAPUR KARAD CKT 2	IntraState	04/07/2022	19:29	05/07/2022	00:29	T	DP
KARAD - OGALEWADI CKT 1	IntraState	05/07/2022	09:49	05/07/2022	16:50	PO	For Relay Testing work.
THEUR-JEJURI	IntraState	05/07/2022	10:31	05/07/2022	19:19	PO	RELAY TESTING & MAINTENANCE WORK.
URAN - KHARGHAR 1	IntraState	05/07/2022	11:20	05/07/2022	19:56	EO	Attending red Hotspot Loc. No. 51
BHUGAON - WARDHA (PG)	IntraState	05/07/2022	19:23		Continued.	HT	H/T by WRLDC due to Over Drawal.
WALUJ - CHITEGAON II	IntraState	05/07/2022	19:50		Continued.	HT	H/T by WRLDC due to Over Drawal.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	05/07/2022	11:10	05/07/2022	18:37	PO	FITTING OF AIR CELL TO ICT
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 05/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage