

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Sep/2022 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 126.786        | 517.610         | 1) Gujrat                      | 11.416         | 35.745          |
| 2) Hydro            | 10.483         | 56.190          | 2) Madhya Pradesh              | 4.710          | 14.857          |
| 3) Gas              | 4.978          | 16.528          | 3) Chattisgarh                 | 2.570          | 13.330          |
| <b>Total MSPGCL</b> | <b>142.247</b> | <b>590.328</b>  | 4) Maharashtra                 | 163.814        | 676.192         |
| B) 1) APLM          | 66.548         | 250.691         | 5) Goa (Amona)                 | -0.816         | -2.975          |
| 2) JSWEL            | 19.541         | 79.559          | <b>Total</b>                   | <b>181.694</b> | <b>737.149</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 33.743         | 129.867         |
| 4) RPL(AMT)         | 12.841         | 47.174          | b) Mumbai Drawl                | 37.153         | 145.388         |
| 5) SWPGPL           | 5.334          | 21.642          | c) MSEDCL Bilateral *          | 45.224         | 202.525         |
| 6) Other IPP        | 5.515          | 24.034          | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 33.743         | 129.834         |
| C) 1) TPCL Thermal  | 9.828          | 46.095          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 2.993          | 22.000          | Standby                        | 0.000          | 0.033           |
| 3) TPCL Gas         | 0.181          | 5.477           | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 8.312          | 38.144          | 1) MSEDCL                      | 403.582        | 1633.343        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 58.467         | 257.103         |
| 1) Thermal          | 254.705        | 1024.949        | 3) Other Discoms               | 8.577          | 36.096          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>470.626</b> | <b>1926.542</b> |
| 2) Hydro (A2+C2)    | 13.476         | 78.190          |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 5.159          | 22.005          |                                |                |                 |
| 4) Wind             | 8.639          | 25.743          |                                |                |                 |
| 6) SOLAR            | 6.953          | 38.507          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>288.932</b> | <b>1189.394</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 24 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal             | 5365                      | 5181                  | 5243                      | 5313                       |
| MSPGCL Hydro               | 432                       | 385                   | 591                       | 255                        |
| MSPGCL Gas                 | 248                       | 217                   | 134                       | 196                        |
| MSPGCL Total Generation    | 6045                      | 5783                  | 5968                      | 5764                       |
| Central Sector Receipt     | 8066                      | 8196                  | 7585                      | 6689                       |
| WIND                       | 393                       | 381                   | 313                       | 110                        |
| CPP / IPP Thermal          | 4388                      | 4168                  | 5020                      | 4972                       |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                          |
| SOLAR                      | 949                       | 997                   | 0                         | 0                          |
| Exchange with Mumbai       | -1751                     | -1849                 | -1456                     | -1561                      |
| <b>MSEDCL DEMAND MET</b>   | <b>17726</b>              | <b>17306</b>          | <b>17046</b>              | <b>15615</b>               |
| Load Shedding              | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND              | 17726                     | 17306                 | 17046                     | 15615                      |
| TPCL GENERATION            | 456                       | 448                   | 677                       | 611                        |
| AEML GENERATION            | 318                       | 311                   | 457                       | 365                        |
| <b>MUMBAI DEMAND</b>       | <b>2525</b>               | <b>2608</b>           | <b>2590</b>               | <b>2537</b>                |
| <b>OTHER DISCOM DEMAND</b> | <b>364</b>                | <b>370</b>            | <b>384</b>                | <b>359</b>                 |
| STATE DEMAND MET           | 20615                     | 20284                 | 20020                     | 18511                      |
| <b>STATE DEMAND</b>        | <b>20615</b>              | <b>20284</b>          | <b>20020</b>              | <b>18511</b>               |
| Frequency (Hz)             | 50.00                     | 49.96                 | 50.02                     | 49.99                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.2 Hz at 10.01 Hrs | 49.73 Hz at 16.55 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 04/Sep/2022

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.22         | 13.88         | 170      | 105      |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.42        | 46.18         | 497      | 447      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| Unit 10            | 10.66        | 44.33         | 460      | 416      |
| <b>Total</b>       | <b>25.30</b> | <b>104.39</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 2.62         | 11.32         | 125      | 90       |
| Unit 4             | 8.04         | 35.19         | 395      | 5        |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>10.65</b> | <b>46.50</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.58         | 18.06         | 199      | 181      |
| Unit 7             | 4.38         | 17.36         | 202      | 148      |
| Unit 8             | 4.10         | 16.56         | 187      | 148      |
| <b>Total</b>       | <b>13.06</b> | <b>51.98</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.47         | 14.05         | 160      | 125      |
| Unit 4             | 3.46         | 13.86         | 157      | 120      |
| Unit 5             | 0.00         | 0.52          | 0        | 0        |
| Unit 6             | 7.98         | 32.10         | 415      | 243      |
| Unit 7             | 8.58         | 31.41         | 412      | 288      |
| Unit 8             | 9.48         | 39.95         | 420      | 354      |
| Unit 9             | 9.37         | 39.96         | 416      | 335      |
| <b>Total</b>       | <b>42.35</b> | <b>171.85</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.39         | 18.25         | 198      | 170      |
| Unit 4             | 4.48         | 17.70         | 212      | 169      |
| <b>Total</b>       | <b>8.88</b>  | <b>35.95</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.57         | 10.55         | 115      | 90       |
| Unit 2             | 2.48         | 10.36         | 125      | 80       |
| Unit 3             | 3.47         | 14.02         | 162      | 130      |
| Unit 4             | 3.58         | 14.94         | 158      | 129      |
| Unit 5             | 8.84         | 34.28         | 400      | 280      |
| <b>Total</b>       | <b>20.95</b> | <b>84.15</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 2.93         | 12.15         | 134      | 109      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 2.67         | 10.63         | 120      | 101      |
| <b>Total</b>       | <b>5.60</b>  | <b>22.78</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 4.98         | 16.53         | 260      | 134      |
| <b>Total</b>       | <b>4.98</b>  | <b>16.53</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.59         | 2.38          | 25       | 25       |
| <b>Total</b>       | <b>0.59</b>  | <b>2.38</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.10          | 11.76         | 250      | 35       |
| Stage 4         | 0.35          | 9.00          | 187      | 0        |
| Stage 3         | 0.86          | 4.74          | 240      | 0        |
| <b>Total</b>    | <b>3.32</b>   | <b>25.50</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.00          | 0.00          | 0        | 0        |
| VTRNA           | 0.73          | 2.97          | 61       | 0        |
| TILLARI         | 0.52          | 2.09          | 58       | 0        |
| BHIRA T.R.      | 0.37          | 1.74          | 77       | 0        |
| SMLHY_PTN       | 4.95          | 20.38         | 226      | 193      |
| GHATGHAR        | 0.00          | 1.13          | 0        | 0        |
| <b>Total</b>    | <b>6.57</b>   | <b>28.31</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 8.64          | 25.74         | 0        | 0        |
| <b>Total</b>    | <b>8.64</b>   | <b>25.74</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 66.55         | 250.69        | 0        | 0        |
| JSWEL(Mus)      | 19.54         | 79.56         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 12.84         | 47.17         | 0        | 0        |
| SWPGPL-Mus      | 5.33          | 21.64         | 0        | 0        |
| Other(Mus)      | 5.52          | 24.03         | 0        | 0        |
| <b>Total</b>    | <b>109.78</b> | <b>423.10</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 6.95          | 38.51         | 0        | 0        |
| <b>Total</b>    | <b>6.95</b>   | <b>38.51</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 6.58          | 30.98         | 322      | 267      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 0.10          | 3.24          | 39       | 0        |
| Trombay 7B      | 0.08          | 2.24          | 34       | 0        |
| TATA Hydro      | 2.99          | 22.00         | 307      | 24       |
| Trombay 8       | 3.25          | 15.12         | 169      | 131      |
| <b>Total</b>    | <b>13.00</b>  | <b>73.57</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 8.31          | 38.14         | 457      | 287      |
| <b>Total</b>    | <b>8.31</b>   | <b>38.14</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 126.79      | 517.61        | MSPGCL Total        | 142.25      | 590.33        |
|                |             |         | MSPGCL Thml+Gas | 131.76      | 534.14        | Koyna 1,2 & 4 Total | 2.45        | 20.76         |
|                |             |         | MSPGCL Hydro    | 10.48       | 56.19         | State Total         | 288.93      | 1189.39       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 04/Sep/2022

### Annexure-2

| TIME SR. NO. | MSPGCL GEN. |       |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | LOAD SHED DING | MSEDC L DEM. WITH LS | MUMBAI DEMAN D | OTHER DISCOM DEMAN D | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|-------|------|--------|------|-----------|------|-------|----------|----------|----------------|------------------|----------------|----------------------|----------------|----------------------|--------------|------------|
|              | THM         | HY    | GAS  |        |      | THM       | GAS  |       |          |          |                |                  |                |                      |                |                      |              |            |
| 1            | 4972        | 643   | 248  | 5863   | 531  | 4996      | 0    | 0     | 7128     | 7240     | -1394          | 16886            | 0              | 16886                | 2622           | 350                  | 19858        | 50.04      |
| 2            | 5132        | 339   | 259  | 5730   | 565  | 4836      | 0    | 0     | 7372     | 7068     | -1439          | 16433            | 0              | 16433                | 2463           | 327                  | 19223        | 50.03      |
| 3            | 5315        | 278   | 248  | 5841   | 565  | 4677      | 0    | 0     | 7224     | 6830     | -1472          | 16142            | 0              | 16142                | 2312           | 299                  | 18753        | 50.01      |
| 4            | 5433        | 282   | 260  | 5975   | 401  | 4287      | 0    | 0     | 7233     | 7156     | -1439          | 16090            | 0              | 16090                | 2214           | 290                  | 18594        | 49.99      |
| 5            | 5462        | 448   | 248  | 6158   | 339  | 4244      | 0    | 0     | 7259     | 7551     | -1405          | 16576            | 0              | 16576                | 2172           | 311                  | 19059        | 49.98      |
| 6            | 5473        | 359   | 259  | 6091   | 318  | 4811      | 0    | 0     | 7653     | 7456     | -1393          | 16947            | 0              | 16947                | 2212           | 336                  | 19495        | 49.99      |
| 7            | 5487        | 494   | 247  | 6228   | 290  | 5067      | 0    | 16    | 7450     | 7424     | -1222          | 17452            | 0              | 17452                | 2209           | 351                  | 20012        | 50.01      |
| 8            | 5532        | 498   | 260  | 6290   | 236  | 4621      | 0    | 145   | 7926     | 7906     | -1134          | 17691            | 0              | 17691                | 2235           | 373                  | 20299        | 49.99      |
| 9            | 5575        | 678   | 250  | 6503   | 259  | 4642      | 0    | 388   | 7859     | 7742     | -1461          | 17705            | 0              | 17705                | 2276           | 368                  | 20349        | 50.00      |
| 10           | 5494        | 486   | 258  | 6238   | 299  | 4600      | 0    | 680   | 8351     | 7929     | -1585          | 17804            | 0              | 17804                | 2397           | 357                  | 20558        | 50.06      |
| 11           | 5365        | 432   | 248  | 6045   | 393  | 4388      | 0    | 949   | 8517     | 8066     | -1751          | 17726            | 0              | 17726                | 2525           | 364                  | 20615        | 50.00      |
| 12           | 5371        | 422   | 257  | 6050   | 385  | 4231      | 0    | 970   | 8399     | 8063     | -1825          | 17500            | 0              | 17500                | 2602           | 374                  | 20476        | 49.88      |
| 13           | 5181        | 385   | 217  | 5783   | 381  | 4168      | 0    | 997   | 8392     | 8196     | -1849          | 17306            | 0              | 17306                | 2608           | 370                  | 20284        | 49.96      |
| 14           | 5088        | 382   | 161  | 5631   | 448  | 4177      | 0    | 904   | 8100     | 8068     | -1787          | 17077            | 0              | 17077                | 2558           | 364                  | 19999        | 50.03      |
| 15           | 5347        | 379   | 157  | 5883   | 450  | 4284      | 0    | 779   | 8159     | 7644     | -1769          | 16903            | 0              | 16903                | 2509           | 368                  | 19780        | 50.07      |
| 16           | 5100        | 375   | 156  | 5631   | 500  | 4173      | 0    | 598   | 8229     | 7876     | -1719          | 16700            | 0              | 16700                | 2460           | 359                  | 19519        | 50.04      |
| 17           | 4848        | 389   | 155  | 5392   | 620  | 4161      | 0    | 387   | 8217     | 7932     | -1673          | 16437            | 0              | 16437                | 2407           | 382                  | 19226        | 49.97      |
| 18           | 5012        | 553   | 136  | 5701   | 491  | 4216      | 0    | 132   | 7717     | 7854     | -1612          | 16402            | 0              | 16402                | 2390           | 380                  | 19172        | 50.00      |
| 19           | 5273        | 649   | 137  | 6059   | 420  | 4717      | 0    | 8     | 7458     | 7564     | -1624          | 16759            | 0              | 16759                | 2497           | 385                  | 19641        | 50.01      |
| 20           | 5243        | 591   | 134  | 5968   | 313  | 5020      | 0    | 0     | 7829     | 7585     | -1456          | 17046            | 0              | 17046                | 2590           | 384                  | 20020        | 50.02      |
| 21           | 5207        | 451   | 149  | 5807   | 160  | 4723      | 0    | 0     | 7484     | 7343     | -1520          | 16132            | 0              | 16132                | 2582           | 381                  | 19095        | 50.03      |
| 22           | 5249        | 457   | 166  | 5872   | 102  | 4752      | 0    | 0     | 7389     | 7510     | -1560          | 16300            | 0              | 16300                | 2551           | 376                  | 19227        | 50.02      |
| 23           | 5314        | 264   | 172  | 5750   | 63   | 5016      | 0    | 0     | 6816     | 6996     | -1503          | 15953            | 0              | 15953                | 2539           | 369                  | 18861        | 49.96      |
| 24           | 5313        | 255   | 196  | 5764   | 110  | 4972      | 0    | 0     | 6885     | 6689     | -1561          | 15615            | 0              | 15615                | 2537           | 359                  | 18511        | 49.99      |
| MUs          | 126.79      | 10.48 | 4.98 | 142.25 | 8.64 | 109.78    | 0.00 | 6.95  | 185.05   | 181.69   | -37.15         | 403.58           | 0.00           | 403.58               | 58.47          | 8.58                 | 470.63       | 50.00      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Sep/2022**

**Position as on 6.30 Hrs of 05/Sep/2022**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                | Koyna Unit 9            | 80       | 15/06/2022   | 08:00        |            | Continued. | Capital Overhaul                                                                                                                                        | 30/09/2022    |
| MSPGCL                | Koyna Unit 4            | 70       | 05/08/2022   | 17:20        |            | Continued. | Generator winding differential protection                                                                                                               | 20/09/2022    |
| MSPGCL                | Koradi Unit 9           | 660      | 07/08/2022   | 14:53        |            | Continued. | Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)                                                                          | 26/09/2022    |
| MSPGCL                | Bhusawal Unit 5         | 500      | 08/08/2022   | 12:31        |            | Continued. | Bottom ash Hopper damaged due to felling of clinker in the boiler ( Converted into Annual Overhaul for 33 Days.)                                        | 10/09/2022    |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                                                                                  |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 31/03/2023    |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                                                                                   | 22/10/2022    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 31/03/2023    |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                                                                                           |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      | 30/09/2022    |
| IPP                   | RPL(AMT) U-3            | 270      | 30/06/2022   | 15:00        |            | Continued. | Coal Shortage                                                                                                                                           |               |
| IPP                   | JSW (J) U4              | 300      | 01/07/2022   | 13:03        |            | Continued. | Turbine bearing Vabration high                                                                                                                          | 05/09/2022    |
| MSPGCL                | Nasik Unit 4            | 210      | 14/07/2022   | 19:55        |            | Continued. | Wet Coal Problem.                                                                                                                                       |               |
| IPP                   | SWPGPL U-4              | 135      | 16/08/2022   | 00:45        |            | Continued. | Coal Shortage                                                                                                                                           |               |
| IPP                   | RPL(AMT) U-5            | 270      | 19/08/2022   | 11:00        | 05/09/2022 | 13:19      | Coal Shortage                                                                                                                                           |               |
| MSPGCL                | Uran Unit B0            | 120      | 27/08/2022   | 15:26        |            | Continued. | Gas shortage                                                                                                                                            |               |
| IPP                   | SWPGPL U-3              | 135      | 28/08/2022   | 19:04        |            | Continued. | Boiler SSC chain broken problem.                                                                                                                        |               |
| IPP                   | RPL(AMT) U-4            | 270      | 31/08/2022   | 00:00        |            | Continued. | Coal Shortage                                                                                                                                           |               |
| MSPGCL                | Uran Unit 8             | 108      | 01/09/2022   | 00:00        |            | Continued. | Gas shortage                                                                                                                                            |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 03/09/2022   | 18:00        | 05/09/2022 | 09:36      | Poor Coal Receipt                                                                                                                                       |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 03/09/2022   | 21:45        | 04/09/2022 | 00:53      | Flame Failure                                                                                                                                           |               |
| TPC-G                 | Trombay 7B              | 60       | 04/09/2022   | 02:24        |            | Continued. | Gas shortage                                                                                                                                            |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Sep/2022**

Position as on 6.30 Hrs of 05/Sep/2022

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------|---------------|
| TPC-G              | Trombay 7A              | 120      | 04/09/2022   | 02:38        | 05/09/2022 | 18:00      | Gas shortage     |               |
| TPC-G              | Bhira PSU               | 150      | 04/09/2022   | 18:35        | 04/09/2022 | 19:01      | starting trouble |               |
| MSPGCL             | Uran Unit 5             | 108      | 05/09/2022   | 09:20        |            | Continued. | Gas shortage     |               |
| TPC-G              | Trombay 7A              | 120      | 05/09/2022   | 22:00        |            | Continued. | Gas shortage     |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 04/Sep/2022**

**Statement-VII**

**Position as on 6.30 Hrs of 05/Sep/2022**

| Name of Line                                             | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                            |
|----------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV MAINBAY Outages/Tripping</b>                   |                           |              |              |            |            |             |                                                                                                                                                                                             |
| 400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2           | InterState                | 23/06/2022   | 20:33        |            |            | EO          | for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425                                                                             |
| <b>400 KV LINE Outages/Tripping</b>                      |                           |              |              |            |            |             |                                                                                                                                                                                             |
| KUDUS - KALA CKT - 2                                     | InterState                | 04/09/2022   | 00:40        | 04/09/2022 | 06:09      | EO          | For Bay No 401 Line isolator Y-phase Hotspot attending work (Temp 297 &#8451;.)                                                                                                             |
| WARORA - IEPL                                            | IntraState                | 01/09/2022   | 07:36        |            |            | PO          | 1. Dis-Connecting Horizontal Jumper and covert 400kv IEPL-PGCIL Deoli Ckt ( Temporary Arrangemet for 10 Days) 400kv IEPL-Warora Ckt.<br>2. Connecting 400kv IEPL-Warora through new towers. |
| KHADKA-AURANGABAD (WALUJ)                                | IntraState                | 03/09/2022   | 21:57        | 05/09/2022 | 10:19      | HT          | H/T FOR O/V                                                                                                                                                                                 |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                      | IntraState                | 04/09/2022   | 18:38        |            |            | T           | Y Phase Ground Fault                                                                                                                                                                        |
| <b>400 KV ICT Outages/Tripping</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                             |
| MAIN BAY (419) OF 400/220/33kV 500MVA ICT-I @ LONIKAND 2 | IntraState                | 05/09/2022   | 09:54        | 05/09/2022 | 11:58      | PO          | Diagnostic testing and Maintenance                                                                                                                                                          |
| <b>220 KV TBC Outages/Tripping</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                             |
| AUXILIARY BUS @ MALEGAON                                 | IntraState                | 29/08/2022   | 16:50        |            |            | PO          | Shifting of TBC Bay new 50MVA 220/33kV PTR 3                                                                                                                                                |
| <b>220 KV LINE Outages/Tripping</b>                      |                           |              |              |            |            |             |                                                                                                                                                                                             |
| KANDALGAON - KOYNA (POPHALI)                             | IntraState                | 04/09/2022   | 04:15        |            |            | T           | TRIPPED ON DISTANCE PROTECTION                                                                                                                                                              |
| TROMBAY - KALWA                                          | IntraState                | 04/09/2022   | 06:19        | 04/09/2022 | 16:34      | T           | TRIPPED ON DISTANCE PROTECTION                                                                                                                                                              |
| EKLAHARE (OCR) - PADGHE                                  | IntraState                | 04/09/2022   | 10:30        | 04/09/2022 | 14:40      | HT          | HT for Load Management                                                                                                                                                                      |
| EKLAHARA(GCR)(NASIK)-BABLESHWAR 2                        | IntraState                | 04/09/2022   | 11:04        | 04/09/2022 | 14:14      | HT          | HT due to Sparking at Nasik end                                                                                                                                                             |
| PUSAD - WARDHA (PG)                                      | IntraState                | 04/09/2022   | 15:22        | 04/09/2022 | 19:49      | EO          | Attending hotspot on Y ph wavetrap                                                                                                                                                          |
| GHATGHAR - JINDAL                                        | IntraState                | 05/09/2022   | 08:12        | 05/09/2022 | 14:42      | EO          | flashover disc Insulator replacement work at loc no 43. (B and Y ph) of 220kv Ghat-jindal line.                                                                                             |
| WASHALA - GHATGHAR                                       | IntraState                | 05/09/2022   | 08:12        | 05/09/2022 | 14:49      | EO          | flashover disc Insulator replacement work at loc no 43. (B and Y ph) of 220kv Ghat-jindal line. [For Safety purpose]                                                                        |
| EKLAHARE (OCR) - PADGHE                                  | IntraState                | 05/09/2022   | 09:49        |            |            | HT          | HT for Load Management                                                                                                                                                                      |
| PHALTAN MIDC - CSSK BHAVANI NAGAR                        | IntraState                | 05/09/2022   | 10:05        | 05/09/2022 | 18:48      | PO          | Fixing of missing nut bolts at cut point loc no.4,9,11                                                                                                                                      |
| KADEGAON-MIRAJ                                           | IntraState                | 05/09/2022   | 11:50        | 05/09/2022 | 13:40      | PO          | Diagnostic Testing Work                                                                                                                                                                     |
| KHARGHAR - BORIVALI CKT - 2                              | IntraState                | 05/09/2022   | 13:15        | 05/09/2022 | 17:50      | EO          | For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.                                                    |
| BORIVALI - CTRLS CKT                                     | IntraState                | 05/09/2022   | 13:32        | 05/09/2022 | 17:34      | EO          | For safety purpose during replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line between loc no. 1118 to 1119.                                                    |
| ADLABS - PEDAMBE                                         | IntraState                | 05/09/2022   | 13:39        | 05/09/2022 | 14:23      | T           | TRIPPED ON DISTANCE PROTECTION                                                                                                                                                              |
| BORIVALI - BOISAR (PG)                                   | IntraState                | 05/09/2022   | 16:45        |            | Continued. | T           | LINE TRIPPED ON DISTANCE PROTECTION.                                                                                                                                                        |
| <b>220 KV ICT Outages/Tripping</b>                       |                           |              |              |            |            |             |                                                                                                                                                                                             |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Sep/2022**

**Statement-VII**

Position as on 6.30 Hrs of 05/Sep/2022

| Name of Line                                 | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                  |
|----------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220 / 110 / 22kV 250 MVA ICT 1 @<br>SALSETTE | IntraState                   | 12/10/2020      | 11:35           |            |               | T              | Tripped due to Grid disturbance.                                                                                                                                                                                                                                                                                                                  |
| 220/100 KV 200 MVA ICT 2 @<br>KALWA          | IntraState                   | 04/09/2022      | 00:46           | 04/09/2022 | 02:57         | HT             | Attending Hot spot of R Ph LV<br>(100 KV) Bushing.                                                                                                                                                                                                                                                                                                |
| <b>110 KV LINE Outages/Trippings</b>         |                              |                 |                 |            |               |                |                                                                                                                                                                                                                                                                                                                                                   |
| DHARAVI POWAI                                | IntraState                   | 30/08/2021      | 00:03           |            |               | PO             | Shifting of OPGW and stringing of<br>conductor of 220 kV Trombay-<br>Dharavi- Salsette line and<br>replacement and shifting of<br>conductor of Dharavi Powai and<br>Dharavi Vikhroli line on new tower<br>and dismantling old towers in<br>section 32 to 38. 110 KV Vikhroli<br>Powai line will be formed for dual<br>feed to Vikhroli and Powai. |
| DHARAVI VIKHROLI                             | IntraState                   | 30/08/2021      | 00:03           |            |               | PO             | Shifting of OPGW and stringing of<br>conductor of 220 kV Trombay-<br>Dharavi- Salsette line and<br>replacement and shifting of<br>conductor of Dharavi Powai and<br>Dharavi Vikhroli line on new tower<br>and dismantling old towers in<br>section 32 to 38. 110 KV Vikhroli<br>Powai line will be formed for dual<br>feed to Vikhroli and Powai. |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage