

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Oct/2015 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 102.113        | 432.186         | 1) Gujrat                      | 4.176          | 23.202          |
| 2) Hydro            | 5.296          | 21.322          | 2) Madhya Pradesh              | 12.791         | 53.203          |
| 3) Gas              | 7.108          | 28.150          | 3) Chattisgarh                 | 4.150          | 17.080          |
| <b>Total MSPGCL</b> | <b>114.517</b> | <b>481.658</b>  | 4) Maharashtra Net             | 90.299         | 387.771         |
| B) 1) APMIL         | 54.690         | 216.490         | 5) Goa                         | -6.658         | -29.355         |
| 2) JSWEL            | 26.514         | 102.375         | 6) TAPS 1&2 Injection          | 3.513          | 14.037          |
| 3) VIPL             | 10.005         | 42.997          | 7) RGPPL Injection             | 0.000          | 0.000           |
| 4) RPL(AMT)         | 22.490         | 78.320          | 8) Pench (MS)                  | 0.434          | 1.992           |
| 5) WPCL             | 4.219          | 17.708          | 9) Pench (Excess)              | -0.434         | -1.992          |
| 6) Other IPP        | 3.033          | 12.162          | <b>Total</b>                   | <b>107.837</b> | <b>463.946</b>  |
| C) 1) TPCL Thermal  | 12.327         | 62.402          | a) Mumbai Schedule             | 19.155         | 92.635          |
| 2) TPCL Hydro       | 0.235          | 4.393           | b) Mumbai Drawl                | 24.677         | 111.529         |
| 3) TPCL Gas         | 4.714          | 18.303          | c) MSEDCL Bilateral *          | 26.609         | 113.632         |
| 4) R-INFRA Thermal  | 10.529         | 45.592          | Include PX                     | -1.609         | 1.968           |
| <b>D) STATE</b>     |                |                 | d) Mumbai Bilateral *          | 19.155         | 92.635          |
| 1) Thermal          | 245.920        | 1010.232        | Include PX                     | 2.727          | 18.404          |
| (A1+C1+C4+(B1-B6))  |                |                 | Include Standby                | 0.000          | 0.000           |
| 2) Hydro            | 5.531          | 25.715          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 3) Gas              | 11.822         | 46.453          | 1) MSEDCL                      | 324.112        | 1333.605        |
| 4) Wind             | 4.453          | 25.137          | 2) Mumbai Discoms              | 52.480         | 242.214         |
| 6) SOLAR            | 1.031          | 4.341           | <b>TOTAL STATE</b>             | <b>376.592</b> | <b>1575.819</b> |
| <b>TOTAL STATE</b>  | <b>268.757</b> | <b>1111.878</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4308                      | 4256                  | 4243                      | 4301                      |
| MSPGCL Hydro             | 449                       | 430                   | 485                       | 104                       |
| MSPGCL Gas               | 292                       | 291                   | 294                       | 299                       |
| MSPGCL Total Generation  | 5049                      | 4977                  | 5022                      | 4704                      |
| Central Sector Receipt   | 5277                      | 5061                  | 4721                      | 3368                      |
| WIND                     | 94                        | 124                   | 121                       | 321                       |
| CPP / IPP                | 5134                      | 5175                  | 5125                      | 4892                      |
| SOLAR                    | 159                       | 154                   | 0                         | 0                         |
| Exchange with Mumbai     | -1220                     | -1272                 | -1115                     | -716                      |
| <b>MSEDCL DEMAND MET</b> | <b>14493</b>              | <b>14219</b>          | <b>13874</b>              | <b>12569</b>              |
| Load Shedding            | 28                        | 28                    | 24                        | 18                        |
| MSEDCL DEMAND            | 14521                     | 14247                 | 13898                     | 12587                     |
| TPCL GENERATION          | 657                       | 654                   | 821                       | 650                       |
| R-INFRA GENERATION       | 395                       | 394                   | 514                       | 511                       |
| <b>MUMBAI DEMAND</b>     | <b>2272</b>               | <b>2320</b>           | <b>2450</b>               | <b>1877</b>               |
| STATE DEMAND MET         | 16765                     | 16539                 | 16324                     | 14446                     |
| <b>STATE DEMAND</b>      | <b>16793</b>              | <b>16567</b>          | <b>16348</b>              | <b>14464</b>              |
| Frequency (Hz)           | 49.95                     | 50.00                 | 50.00                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.19 Hz at 06.02 Hrs | 49.8 Hz at 18.26 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 04/Oct/2015

| Generating unit     | Generation   |               |          |          |
|---------------------|--------------|---------------|----------|----------|
|                     | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>       |              |               |          |          |
| Unit 5              | 3.49         | 10.64         | 151      | 135      |
| Unit 6              | 0.00         | 0.00          | 0        | 0        |
| Unit 7              | 3.44         | 13.99         | 165      | 120      |
| <b>Total</b>        | <b>6.93</b>  | <b>24.63</b>  |          |          |
| <b>Bhusawal</b>     |              |               |          |          |
| Unit 2              | 0.00         | 0.00          | 0        | 0        |
| Unit 3              | 4.10         | 15.63         | 180      | 160      |
| Unit 4              | 10.70        | 43.62         | 500      | 370      |
| Unit 5              | 11.05        | 44.91         | 500      | 355      |
| <b>Total</b>        | <b>25.85</b> | <b>104.16</b> |          |          |
| <b>Parli</b>        |              |               |          |          |
| Unit 3              | 0.00         | 0.00          | 0        | 0        |
| Unit 4              | 0.00         | 0.00          | 0        | 0        |
| Unit 5              | 0.00         | 0.00          | 0        | 0        |
| Unit 6              | 0.00         | 0.00          | 0        | 0        |
| Unit 7              | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>        | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>Chandrapur</b>   |              |               |          |          |
| Unit 1              | 0.00         | 0.00          | 0        | 0        |
| Unit 2              | 3.34         | 13.51         | 144      | 124      |
| Unit 3              | 4.34         | 17.66         | 202      | 170      |
| Unit 4              | 4.11         | 17.01         | 199      | 157      |
| Unit 5              | 0.00         | 0.00          | 0        | 0        |
| Unit 6              | 9.62         | 38.65         | 427      | 380      |
| Unit 7              | 9.55         | 38.19         | 427      | 370      |
| <b>Total</b>        | <b>30.96</b> | <b>125.03</b> |          |          |
| <b>Paras</b>        |              |               |          |          |
| Unit 3              | 4.91         | 20.04         | 212      | 195      |
| Unit 4              | 4.38         | 18.91         | 196      | 158      |
| <b>Total</b>        | <b>9.29</b>  | <b>38.95</b>  |          |          |
| <b>Khaparkhedha</b> |              |               |          |          |
| Unit 1              | 3.38         | 6.38          | 170      | 115      |
| Unit 2              | 3.20         | 12.96         | 170      | 105      |
| Unit 3              | 3.89         | 15.68         | 182      | 150      |
| Unit 4              | 0.00         | 7.15          | 0        | 0        |
| Unit 5              | 7.75         | 35.38         | 380      | 270      |
| <b>Total</b>        | <b>18.22</b> | <b>77.54</b>  |          |          |
| <b>Nasik</b>        |              |               |          |          |
| Unit 3              | 4.41         | 17.74         | 190      | 170      |
| Unit 4              | 2.04         | 15.40         | 187      | 0        |
| Unit 5              | 4.41         | 17.85         | 190      | 175      |
| <b>Total</b>        | <b>10.87</b> | <b>50.98</b>  |          |          |
| <b>Uran</b>         |              |               |          |          |
| All Units           | 7.11         | 28.15         | 305      | 290      |
| <b>Total</b>        | <b>7.11</b>  | <b>28.15</b>  |          |          |
| <b>PENCH (MS)</b>   |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Pench (MS)      | 0.43          | 1.99          | 24       | 11       |
| <b>Total</b>    | <b>0.43</b>   | <b>1.99</b>   |          |          |
| <b>Koyna</b>    |               |               |          |          |
| Stage 1-2       | 1.66          | 7.88          | 350      | 40       |
| Stage 4         | 0.00          | 1.18          | 0        | 0        |
| Stage 3         | 1.35          | 2.26          | 160      | 0        |
| <b>Total</b>    | <b>3.02</b>   | <b>11.32</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.44          | 2.08          | 19       | 18       |
| VTRNA           | 0.05          | 0.28          | 46       | 0        |
| TILLARI         | 0.00          | 0.00          | 0        | 0        |
| BHTGR/VEER      | 0.00          | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.18          | 0.78          | 44       | 0        |
| RNGR+BHTSA      | 0.00          | 0.21          | 0        | 0        |
| BHANDARDRA      | 0.52          | 1.98          | 36       | 13       |
| ELDARY          | 0.00          | 0.00          | 0        | 0        |
| SMLHY_PTN       | 0.21          | 0.95          | 16       | 6        |
| GHATGHAR        | 0.88          | 3.72          | 125      | 0        |
| <b>Total</b>    | <b>2.28</b>   | <b>10.00</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 4.45          | 25.14         | 0        | 0        |
| <b>Total</b>    | <b>4.45</b>   | <b>25.14</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 54.69         | 216.49        | 0        | 0        |
| JSWEL(Mus)      | 26.51         | 102.38        | 0        | 0        |
| VIPL(Mus)       | 10.00         | 43.00         | 0        | 0        |
| RPLAMT(Mus)     | 22.49         | 78.32         | 0        | 0        |
| WPCL(Mus)       | 4.22          | 17.71         | 0        | 0        |
| Other(Mus)      | 3.03          | 12.16         | 0        | 0        |
| <b>Total</b>    | <b>120.95</b> | <b>470.05</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 1.03          | 4.34          | 0        | 0        |
| <b>Total</b>    | <b>1.03</b>   | <b>4.34</b>   |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 6.53          | 39.16         | 487      | 205      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 3.03          | 11.69         | 130      | 115      |
| Trombay 7B      | 1.69          | 6.61          | 72       | 66       |
| Trombay 8       | 5.80          | 23.24         | 246      | 238      |
| TATA Hydro      | 0.24          | 4.39          | 92       | 0        |
| <b>Total</b>    | <b>17.28</b>  | <b>85.10</b>  |          |          |
| <b>R-INFRA</b>  |               |               |          |          |
| 1-2             | 10.53         | 45.59         | 517      | 393      |
| <b>Total</b>    | <b>10.53</b>  | <b>45.59</b>  |          |          |

|                     |                    |                      |
|---------------------|--------------------|----------------------|
| <b>Infirm Power</b> | Chandrapur 8       | 0.00                 |
| <b>Summary</b>      |                    |                      |
| <b>Particulars</b>  | <b>Daily (Mus)</b> | <b>Monthly (Mus)</b> |
| MSPGCL Thermal      | 102.11             | 432.19               |
| MSPGCL Thml+Gas     | 109.22             | 460.34               |

|              |             |               |
|--------------|-------------|---------------|
| Koradi 8     | 0.00        |               |
| Summary      |             |               |
| Particulars  | Daily (Mus) | Monthly (Mus) |
| MSPGCL Hydro | 5.30        | 21.32         |
| MSPGCL Total | 114.52      | 481.66        |

|                     |                    |                      |
|---------------------|--------------------|----------------------|
| <b>Summary</b>      |                    |                      |
| <b>Particulars</b>  | <b>Daily (Mus)</b> | <b>Monthly (Mus)</b> |
| Koyna 1,2 & 4 Total | 1.66               | 9.06                 |
| State Total         | 268.76             | 1111.88              |

**State Load Despatch Center,Airoli (MSETCL)**  
**Hourly Load Data As on 04/Oct/2015**

**Annexure-2**

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP /<br>IPP | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|--------------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      |              |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4147        | 123  | 299  | 4569   | 339  | 4699         | 0     | 4283        | 4304        | -1017                | 12894                 | 30                   | 12924                     | 2221             | 15145           | 49.98         |
| 2                  | 4222        | 103  | 299  | 4624   | 297  | 4713         | 0     | 4088        | 4151        | -975                 | 12810                 | 18                   | 12828                     | 2055             | 14883           | 49.97         |
| 3                  | 4194        | 99   | 299  | 4592   | 289  | 4777         | 0     | 3792        | 3918        | -895                 | 12681                 | 18                   | 12699                     | 1943             | 14642           | 49.95         |
| 4                  | 4301        | 104  | 299  | 4704   | 321  | 4892         | 0     | 3717        | 3368        | -716                 | 12569                 | 18                   | 12587                     | 1877             | 14464           | 49.98         |
| 5                  | 4322        | 104  | 301  | 4727   | 351  | 4895         | 0     | 3846        | 3647        | -693                 | 12927                 | 18                   | 12945                     | 1862             | 14807           | 49.95         |
| 6                  | 4344        | 107  | 300  | 4751   | 296  | 4940         | 0     | 4366        | 4061        | -771                 | 13277                 | 27                   | 13304                     | 1896             | 15200           | 49.96         |
| 7                  | 4379        | 160  | 302  | 4841   | 273  | 4993         | 0     | 4561        | 4328        | -841                 | 13594                 | 30                   | 13624                     | 1890             | 15514           | 50.01         |
| 8                  | 4379        | 156  | 301  | 4836   | 209  | 4922         | 22    | 4914        | 4877        | -854                 | 14012                 | 32                   | 14044                     | 1908             | 15952           | 50.01         |
| 9                  | 4381        | 166  | 297  | 4844   | 114  | 4973         | 67    | 5040        | 5145        | -937                 | 14206                 | 28                   | 14234                     | 1989             | 16223           | 49.98         |
| 10                 | 4404        | 161  | 298  | 4863   | 153  | 4954         | 118   | 5052        | 5151        | -1079                | 14160                 | 23                   | 14183                     | 2129             | 16312           | 49.97         |
| 11                 | 4401        | 332  | 291  | 5024   | 85   | 5084         | 148   | 5066        | 5327        | -1208                | 14460                 | 23                   | 14483                     | 2258             | 16741           | 49.95         |
| 12                 | 4308        | 449  | 292  | 5049   | 94   | 5134         | 159   | 5019        | 5277        | -1220                | 14493                 | 28                   | 14521                     | 2272             | 16793           | 49.95         |
| 13                 | 4256        | 430  | 291  | 4977   | 124  | 5175         | 154   | 4955        | 5061        | -1272                | 14219                 | 28                   | 14247                     | 2320             | 16567           | 50.00         |
| 14                 | 4269        | 367  | 292  | 4928   | 135  | 5156         | 149   | 4848        | 4835        | -1245                | 13958                 | 31                   | 13989                     | 2293             | 16282           | 50.01         |
| 15                 | 4255        | 317  | 290  | 4862   | 139  | 5175         | 112   | 4834        | 4840        | -1175                | 13953                 | 21                   | 13974                     | 2283             | 16257           | 49.99         |
| 16                 | 4250        | 285  | 290  | 4825   | 218  | 5108         | 64    | 4845        | 4840        | -1240                | 13815                 | 21                   | 13836                     | 2285             | 16121           | 49.96         |
| 17                 | 4272        | 211  | 290  | 4773   | 137  | 5074         | 30    | 4617        | 4625        | -1096                | 13543                 | 20                   | 13563                     | 2236             | 15799           | 49.98         |
| 18                 | 4210        | 185  | 293  | 4688   | 74   | 4956         | 8     | 4315        | 4391        | -1145                | 12972                 | 20                   | 12992                     | 2213             | 15205           | 50.00         |
| 19                 | 4246        | 479  | 294  | 5019   | 89   | 5043         | 0     | 4469        | 4573        | -1097                | 13627                 | 20                   | 13647                     | 2320             | 15967           | 49.94         |
| 20                 | 4243        | 485  | 294  | 5022   | 121  | 5125         | 0     | 4768        | 4721        | -1115                | 13874                 | 24                   | 13898                     | 2450             | 16348           | 50.00         |
| 21                 | 4175        | 181  | 293  | 4649   | 142  | 5368         | 0     | 4622        | 4385        | -1081                | 13463                 | 24                   | 13487                     | 2490             | 15977           | 49.98         |
| 22                 | 4110        | 86   | 296  | 4492   | 145  | 5266         | 0     | 4423        | 4044        | -1045                | 12902                 | 24                   | 12926                     | 2481             | 15407           | 49.97         |
| 23                 | 4036        | 94   | 302  | 4432   | 179  | 5306         | 0     | 4168        | 3906        | -1029                | 12794                 | 24                   | 12818                     | 2454             | 15272           | 49.97         |
| 24                 | 4009        | 112  | 305  | 4426   | 129  | 5223         | 0     | 4164        | 4069        | -931                 | 12916                 | 24                   | 12940                     | 2357             | 15297           | 50.00         |
| MUs                | 102.11      | 5.30 | 7.11 | 114.52 | 4.45 | 120.95       | 1.03  | 108.77      | 107.84      | -24.68               | 324.12                | 0.57                 | 324.69                    | 52.48            | 377.17          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

# State Load Despatch Center,Airoli (MSETCL)      Statement-VI

## Details of Generating Unit Outages/Trippings for 04/Oct/2015

Position as on 6.30 Hrs of 05/Oct/2015

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                    | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                     |               |
| CENT.SECTOR           | Tarapur 2               | 160      | 10/09/2015   | 12.55        |            | Continued. | Refuelling work                     |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                     |               |
| RGPPL                 | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |            | Continued. | Gas Shortage.                       |               |
| RGPPL                 | Dabhol 3A               | 230      | 06/06/2013   | 08.28        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 2A               | 230      | 06/06/2013   | 09.10        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 2X               | 290      | 15/07/2013   | 15.09        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 2B               | 230      | 08/08/2013   | 15.03        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 3X               | 290      | 29/12/2013   | 05.47        |            | Continued. | Gas Shortage                        |               |
| RGPPL                 | Dabhol 3B               | 230      | 29/12/2013   | 06.14        |            | Continued. | Gas Shortage                        |               |
| IPP                   | Dhariwal                | 300      | 28/05/2014   | 02.27        |            | Continued. | No schedule                         |               |
| MSPGCL                | Chandrapur Unit 1       | 210      | 28/08/2014   | 07:15        |            | Continued. | Economic Shutdown.                  |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 13/09/2014   | 12.43        |            | Continued. | Economic shutdown                   |               |
| MSPGCL                | Koradi Unit 6           | 210      | 20/03/2015   | 01.02        |            | Continued. | Economic shutdown                   |               |
| IPP                   | RPL(AMT) U-5            | 270      | 03/04/2015   | 14.22        |            | Continued. | turbine Shaft Vibration high.       |               |
| MSPGCL                | Uran Unit 7             | 108      | 17/04/2015   | 00.07        |            | Continued. | Gas turbine problem                 |               |
| MSPGCL                | Parli Unit 3            | 210      | 14/06/2015   | 12.58        |            | Continued. | Water Shortage                      |               |
| IPP                   | WPCL U-2                | 135      | 16/06/2015   | 00.00        |            | Continued. | No Schdule                          |               |
| MSPGCL                | Parli Unit 6            | 250      | 25/06/2015   | 15.03        |            | Continued. | Water Shortage                      |               |
| MSPGCL                | Parli Unit 4            | 210      | 05/07/2015   | 18.45        |            | Continued. | Water Shortage                      |               |
| MSPGCL                | Parli Unit 5            | 210      | 06/07/2015   | 14.55        |            | Continued. | Water Shortage.                     |               |
| MSPGCL                | Parli Unit 7            | 250      | 08/07/2015   | 12.08        |            | Continued. | Water Shortage                      |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |            | Continued. | Economic shutdown                   |               |
| CPP                   | WPCL U-1                | 135      | 25/08/2015   | 19.18        |            | Continued. | Maintenance work                    |               |
| IPP                   | Adani U-4               | 660      | 11/09/2015   | 20.49        |            | Continued. | Abnormal sound in generator bearing |               |
| MSPGCL                | Koradi Unit-8           | 660      | 18/09/2015   | 18.08        | 05/10/2015 | 04.32      | ESP Problem                         |               |
| MSPGCL                | Uran Unit B0            | 120      | 28/09/2015   | 23.06        |            | Continued. | Gas shortage                        |               |
| MSPGCL                | Uran Unit 8             | 108      | 28/09/2015   | 23.11        |            | Continued. | Gas shortage                        |               |
| MSPGCL                | Chandrapur Unit 5       | 500      | 30/09/2015   | 17.34        | 05/10/2015 | 05.08      | Boiler Tube Leakage                 |               |
| MSPGCL                | Khaparkheda Unit 4      | 210      | 02/10/2015   | 21.12        |            | Continued. | Turbine Problem.                    |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 03/10/2015   | 09.31        |            | Continued. | High Drum level                     |               |
| MSPGCL                | Nasik Unit 4            | 210      | 04/10/2015   | 11.32        |            | Continued. | Boiler Tube Leakage                 |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Oct/2015**

**Statement-VII**

Position as on 6.30 Hrs of 05/Oct/2015

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| Chandrapur - Padghe Hvdc Pole 2        | IntraState                | 02/10/2015   | 12.18        | 04/10/2015 | 17.19      | PO          | OPGW Jointing & Other Hardware Tightening Work(2 Days).                                                             |
| Chandrapur - Padghe Hvdc Pole 1        | IntraState                | 04/10/2015   | 09.25        | 04/10/2015 | 10.05      | PO          | power supply card faulty                                                                                            |
| <b>400 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| Dabhol Nagothane I                     | InterState                | 29/09/2015   | 08.52        | 04/10/2015 | 18.59      | PO          | Routine Maintenance Work                                                                                            |
| Kolhapur Mapusa I                      | InterState                | 03/10/2015   | 17.27        | 04/10/2015 | 08.42      | HT          | Over Voltage                                                                                                        |
| Dhule Sar'Sarovar I                    | InterState                | 03/10/2015   | 17.52        | 04/10/2015 | 08.53      | HT          | Over Voltage                                                                                                        |
| Talegaon PG-Aurangabad-I               | InterState                | 04/10/2015   | 12.29        | 04/10/2015 | 16.57      | HT          | Emergency outage                                                                                                    |
| Talegaon PG - Aurangabad - II          | InterState                | 04/10/2015   | 13.41        | 04/10/2015 | 16.39      | HT          | Emergency outage                                                                                                    |
| Kolhapur Mapusa I                      | InterState                | 04/10/2015   | 15.11        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Dhule Sar'Sarovar I                    | InterState                | 04/10/2015   | 18.10        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Akola II - Taptitanda ckt-I            | IntraState                | 05/09/2015   | 21.56        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Babhaleshwar-Taptitanda ckt-I          | IntraState                | 29/09/2015   | 17.35        |            | Continued. | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-II                     | IntraState                | 03/10/2015   | 16.04        | 04/10/2015 | 09.37      | HT          | Over Voltage                                                                                                        |
| Karad-Jaigad - I                       | IntraState                | 03/10/2015   | 16.06        | 04/10/2015 | 09.40      | HT          | Over Voltage                                                                                                        |
| Khadka-Aurangabad (Waluj)              | IntraState                | 03/10/2015   | 16.22        | 04/10/2015 | 09.05      | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV            | IntraState                | 03/10/2015   | 21.23        | 04/10/2015 | 08.57      | HT          | Over Voltage                                                                                                        |
| karad -kolhapur-II                     | IntraState                | 04/10/2015   | 10.38        |            | Continued. | HT          | Current found zero at karad end RFC 10.40                                                                           |
| Karad-Jaigad - I                       | IntraState                | 04/10/2015   | 16.15        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Lonikand I - Koyna stage-IV            | IntraState                | 04/10/2015   | 17.13        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Bhusawal-Aurangabad                    | IntraState                | 04/10/2015   | 17.15        |            | Continued. | HT          | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                     |
| 400/220/33 Kv 315 MVA ICT -I @Kharghar | IntraState                | 02/10/2015   | 09.34        |            | Continued. | PO          | Protection Wall Strengthening Work(3Days).                                                                          |
| <b>220 KV LINE Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                     |
| Chandrapur GCR - Warora - I            | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                  | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Padghe - Vasai                         | IntraState                | 15/08/2015   | 08:35        |            | Continued. | PO          | Removal of jumper & bunching work at Loc No. 51/1 & 35 ( charged up to Loc No. 51/1 from Padghe end only )          |
| Kalwa - Borivali                       | IntraState                | 16/08/2015   | 08.00        |            | Continued. | PO          | Erection of Loc.No.12 and shifting of conductor on NER M/C Tower                                                    |
| Kandalgaon - Sona Alloys               | IntraState                | 03/10/2015   | 15.47        | 04/10/2015 | 11.10      | T           | Distance Protection                                                                                                 |
| New Koyna - Niwali                     | IntraState                | 03/10/2015   | 16.00        |            | Continued. | T           | Distance Protection                                                                                                 |
| Karad - Kadegaon                       | IntraState                | 03/10/2015   | 16.52        |            | Continued. | PO          | Attending Hot Spot                                                                                                  |
| Kalwa - Mulund 1                       | IntraState                | 04/10/2015   | 06.12        | 04/10/2015 | 11.12      | EO          | Attending Hot Spot                                                                                                  |
| Kalwa-TIFIL                            | IntraState                | 04/10/2015   | 06.56        | 05/10/2015 | 00.08      | T           | Tifil bay strengthring work                                                                                         |
| Karad - Vita Ckt- II                   | IntraState                | 04/10/2015   | 12.49        | 04/10/2015 | 13.41      | T           | Distance Protection                                                                                                 |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali   | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Internal Fault                                                                                                      |
| 220/22KV 100MVA T/F 4 @Mulund          | IntraState                | 09/09/2015   | 12.20        |            | Continued. | PO          | Replacement of Control and Relay Panel                                                                              |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage