

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Oct/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	116.330	418.566	1) Gujrat	15.931	65.573
2) Hydro	3.973	28.456	2) Madhya Pradesh	12.990	41.835
3) Gas	9.584	38.372	3) Chattisgarh	2.820	10.660
Total MSPGCL	129.887	485.394	4) Maharashtra	141.066	575.259
B) 1) APML	21.059	94.919	5) Goa (Amona)	-0.220	-0.924
2) JSWEL	16.468	67.122	Total	172.587	692.403
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.770	112.257
4) RPL(AMT)	21.135	91.389	b) Mumbai Drawl	34.912	128.405
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	38.189	126.010
6) Other IPP	8.558	33.768	Include PX	19.337	51.725
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.770	112.257
C) 1) TPCL Thermal	12.563	53.667	Include PX	15.914	57.980
2) TPCL Hydro	4.526	15.430	Standby	0.000	0.000
3) TPCL Gas	4.211	13.613	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.488	41.422	1) MSEDCL	342.578	1392.515
D) STATE			2) Mumbai Discoms	65.700	252.535
1) Thermal	205.601	800.853	TOTAL STATE	408.278	1645.050
(A1+C1+C4+(B1-B6))					
2) Hydro	8.499	43.886			
(A2+C2)					
3) Gas	13.795	51.985			
(A3+B7+C3)					
4) Wind	3.319	32.206			
6) SOLAR	4.477	23.719			
TOTAL STATE	235.691	952.649			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	4965	4913	5278	4645
MSPGCL Hydro	108	98	222	76
MSPGCL Gas	395	403	400	400
MSPGCL Total Generation	5468	5414	5900	5121
Central Sector Receipt	8157	7545	7166	6351
WIND	134	184	234	108
CPP / IPP Thermal	2643	2674	3268	2617
CPP / IPP Gas	0	0	0	0
SOLAR	676	636	0	0
Exchange with Mumbai	-1972	-1961	-1466	-1204
MSEDCL DEMAND MET	15106	14492	15102	12993
Load Shedding	0	0	0	0
MSEDCL DEMAND	15106	14492	15102	12993
TPCL GENERATION	925	915	1144	630
AEML GENERATION	374	375	434	403
MUMBAI DEMAND	3271	3251	3044	2237
STATE DEMAND MET	18377	17743	18146	15230
STATE DEMAND	18377	17743	18146	15230
Frequency (Hz)	50.01	50.04	50.00	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 13.05 Hrs	49.8 Hz at 05.14 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 04/Oct/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	9.57	36.86	494	290
Unit 10	11.10	39.64	540	420
Total	20.67	76.50		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.53	40.07	450	350
Unit 5	0.00	0.00	0	0
Total	9.53	40.07		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	4.02	19.87	223	130
Unit 8	4.86	19.40	223	189
Total	8.88	39.26		
Chandrapur				
Unit 3	0.17	0.17	50	0
Unit 4	3.19	13.52	147	115
Unit 5	7.68	26.90	340	289
Unit 6	8.14	27.61	390	283
Unit 7	0.00	0.00	0	0
Unit 8	8.63	32.17	400	340
Unit 9	8.60	32.03	391	320
Total	36.41	132.40		
Paras				
Unit 3	3.89	5.08	237	0
Unit 4	0.00	0.00	0	0
Total	3.89	5.08		
Khaparkheda				
Unit 1	3.56	9.86	165	125
Unit 2	3.90	16.38	180	130
Unit 3	4.06	16.76	185	148
Unit 4	3.72	14.80	180	140
Unit 5	10.47	30.79	500	365
Total	25.71	88.59		
Nasik				
Unit 3	3.78	7.60	180	144
Unit 4	3.78	14.46	180	133
Unit 5	3.68	14.62	182	113
Total	11.23	36.67		
Uran				
All Units	9.58	38.37	411	380
Total	9.58	38.37		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.26	5.06	54	50

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	1.26	5.06		
Koyna				
Stage 1-2	1.85	13.94	265	40
Stage 4	0.95	6.73	454	0
Stage 3	0.67	5.20	126	0
Total	3.47	25.87		
Hydro				
KDPH	0.00	0.29	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.30	1.02	40	0
RNGR+BHTSA	0.00	0.00	0	0
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.20	0.64	18	5
GHATGHAR	0.00	0.63	0	0
Total	0.50	2.58		
Wind				
Total	3.32	32.21	0	0
Total	3.32	32.21		
CPP				
APML(Mus)	21.06	94.92	0	0
JSWEL(Mus)	16.47	67.12	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	21.14	91.39	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	8.56	33.77	0	0
Total	67.22	287.20		
SOLAR				
Total	4.48	23.72	0	0
Total	4.48	23.72		
Tata				
Trombay 5	7.83	34.15	463	290
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.66	8.51	116	84
Trombay 7B	1.55	5.10	67	56
Trombay 8	4.73	19.52	209	185
TATA Hydro	4.53	15.43	459	0
Total	21.30	82.71		
AEML				
DTPS U-1&2	9.49	41.42	498	374
Total	9.49	41.42		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	116.33	418.57	MSPGCL Total	129.89	485.39
			MSPGCL Thml+Gas	125.91	456.94	Koyna 1,2 & 4 Total	2.80	20.68
			MSPGCL Hydro	3.97	28.46	State Total	235.69	952.65

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 04/Oct/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4599	99	409	5107	121	2936	0	0	6747	6767	-1446	13485	0	13485	2446	15931	49.98
2	4645	76	400	5121	108	2617	0	0	6601	6351	-1204	12993	0	12993	2237	15230	49.99
3	4598	71	402	5071	76	2979	0	0	6386	6495	-1046	13575	0	13575	2083	15658	50.03
4	4622	91	401	5114	126	2959	0	0	6346	6271	-997	13473	0	13473	2002	15475	50.04
5	4659	51	400	5110	108	2752	0	0	6802	6741	-984	13727	0	13727	1989	15716	50.00
6	4814	323	411	5548	142	3007	0	0	7000	7122	-877	14942	0	14942	2092	17034	49.95
7	4945	540	400	5885	194	3024	0	31	7805	7714	-889	15959	0	15959	2239	18198	49.97
8	4969	428	401	5798	101	3024	0	141	8168	8035	-986	16113	0	16113	2427	18540	50.01
9	4875	46	399	5320	52	2892	0	365	8076	8450	-1429	15650	0	15650	2724	18374	50.01
10	4920	100	407	5427	64	2819	0	604	8121	7890	-1755	15049	0	15049	3050	18099	50.02
11	4948	134	395	5477	79	2640	0	699	8369	8144	-1922	15117	0	15117	3240	18357	50.02
12	4965	108	395	5468	134	2643	0	676	8433	8157	-1972	15106	0	15106	3271	18377	50.01
13	4913	98	403	5414	184	2674	0	636	8118	7545	-1961	14492	0	14492	3251	17743	50.04
14	4767	107	380	5254	223	2626	0	533	7364	7395	-1855	14176	0	14176	3136	17312	50.07
15	4697	57	389	5143	197	2582	0	424	7418	7129	-1906	13569	0	13569	3194	16763	50.00
16	4720	56	400	5176	146	2581	0	231	7244	6969	-1930	13173	0	13173	3222	16395	50.03
17	4736	123	392	5251	117	2593	0	101	6826	6881	-1874	13069	0	13069	3195	16264	50.00
18	4711	131	384	5226	211	2606	0	33	6956	7036	-1610	13502	0	13502	3131	16633	50.04
19	4965	209	403	5577	214	3042	0	1	7408	7503	-1552	14785	0	14785	3093	17878	49.97
20	5278	222	400	5900	234	3268	0	0	7463	7166	-1466	15102	0	15102	3044	18146	50.00
21	5078	201	400	5679	217	2917	0	0	6828	7069	-1373	14509	0	14509	2868	17377	49.95
22	5078	229	409	5716	126	2713	0	0	6776	6680	-1256	13979	0	13979	2678	16657	49.96
23	4984	165	402	5551	92	2662	0	0	6619	6592	-1264	13633	0	13633	2564	16197	49.93
24	4844	308	402	5554	53	2664	0	0	6403	6485	-1358	13398	0	13398	2524	15922	49.99
MUs	116.33	3.97	9.58	129.89	3.32	67.22	0.00	4.48	174.28	172.59	-34.91	342.58	0.00	342.58	65.70	408.28	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Oct/2019

Position as on 6.30 Hrs of 05/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Koyna STG- IV Unit - 1	250	18/07/2019	14.30		Continued.	Breaker Air Pressure Problem(Converted for Capital Overhaul from DT.24-07-2019)	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Koradi Unit-8	660	25/08/2019	00.01		Continued.	Annual Overhaul	
MSPGCL	Bhusawal Unit 5	500	25/08/2019	00.13		Continued.	Capital Overhaul	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koyna Unit 10	80	05/08/2019	20.05		Continued.	Stator Earth Fault	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(converted to zero schedule from 12.09.2019 at 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule	
IPP	Adani U-1	660	19/09/2019	01.43		Continued.	Due to Low Coal Stock.	
MSPGCL	Parli Unit 6	250	19/09/2019	06.24		Continued.	Poor Coal Receipt.	
IPP	Adani U-2	660	30/09/2019	05.37		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 3	210	30/09/2019	11.00	04/10/2019	19.32	wet coal.	
IPP	JSW (J) U3	300	30/09/2019	23.53		Continued.	No schedule.	
MSPGCL	Paras Unit 3	250	01/10/2019	11.18	04/10/2019	03.10	Boiler Tube Leakage	
IPP	Adani U-5	660	01/10/2019	23.10		Continued.	Coal Shortage	
MSPGCL	Koyna STG-IV Unit-2	250	02/10/2019	19.19		Continued.	Down Stream Seal Leakage Problem.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Oct/2019

Position as on 6.30 Hrs of 05/Oct/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 1	210	05/10/2019	09.18		Continued.	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 05/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	24/09/2019	17.43		Continued.	PO	Tower Height Rise work
Chandrapur - Padghe Hvdc Pole 1	IntraState	24/09/2019	17.56		Continued.	PO	Tower Height Rise work
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Khandwa I	InterState	26/09/2019	22.49	04/10/2019	07.04	HT	Over Voltage
Dabhol Newkoyna li	InterState	04/10/2019	13.54	05/10/2019	18.54	PO	Replacement of Flashover String
Dabhol Nagothane I	InterState	04/10/2019	22.07	05/10/2019	01.01	T	Bus Bar Protection Operated
Chandrapur-II - Warora - I	InterState	04/10/2019	22.30	05/10/2019	16.55	PO	Attending Hot Spot
Dhule Khandwa II	InterState	05/10/2019	00.29		Continued.	HT	Over Voltage
Chandrapur Bhadravati I	InterState	05/10/2019	08.31		Continued.	PO	Work at Bhadravati end
Chandrapur-II - Nanded ckt II	IntraState	16/09/2019	08:57	05/10/2019	07.04	PO	Replacement of Broken Spacer cum Damper.
Khadka-Aurangabad (Waluj)	IntraState	24/09/2019	18.12	04/10/2019	08.39	HT	Over Voltage
Chandrapur - Khaperkheda	IntraState	26/09/2019	01.05		Continued.	T	O/V (Trial Taken At 08.10 But Trip Again O/V.)
New Koyna - Dabhol - II	IntraState	01/10/2019	08.54	04/10/2019	10.10	PO	Earth Wire Replacement Work (RFC:18.48 Dt.03.10.2019)
Khadka-Aurangabad (Waluj)	IntraState	04/10/2019	17.13		Continued.	HT	Over Voltage
Nagothane - Dabhol-II	IntraState	04/10/2019	20.48	05/10/2019	01.01	T	TRIPPED AT NAGOTHANE END ONLY AS DT RECIVED FROM DABHOL END.
New Koyna - Dabhol-I	IntraState	04/10/2019	22.07	04/10/2019	23.41	T	Bus Bar Protection Operated
Karad-Jaigad - I	IntraState	05/10/2019	20.52		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
400/220 KV 500 MVA ICT- I @Warora	IntraState	04/10/2019	09.21	04/10/2019	15.35	PO	Daignostic Testing Work
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	04/10/2019	15.17	04/10/2019	19.37	PO	Re-fix Nut bolt of SSN Hardware on LV side interconnecting line of ICT To change 29-LA Jaw
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	T	Distance Protection
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule
Tillari Amona	InterState	03/10/2019	03.43	04/10/2019	12.46	T	Distance Protection
Khaparkheda-Butibori 3	InterState	04/10/2019	10.52	04/10/2019	16.27	PO	Dignostic Testing Work
Mahalakshmi Amona	InterState	04/10/2019	14.40	04/10/2019	16.32	T	Tripped at Both end Mahalaxmi
Tillari Amona	InterState	05/10/2019	14.02	05/10/2019	16.10	HT	H/T due to tripping of Halkarni-Tillari line
Mahalakshmi Amona	InterState	05/10/2019	14.02	05/10/2019	16.15	T	Backup Protection
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Chandrapur GCR - Sicom I	IntraState	01/10/2019	07.45		Continued.	PO	Erection of Inline Tower.
Chandrapur GCR - Sicom II	IntraState	01/10/2019	07.50		Continued.	PO	Erection of Inline Tower.
Butibori-Indorama	IntraState	04/10/2019	06.42	04/10/2019	21.31	PO	Annual Maintenance Work
Apta - Taloja	IntraState	04/10/2019	08.29	04/10/2019	13.03	PO	Attending Hot Spot
Aarey Saki Line 1	IntraState	04/10/2019	09.05	05/10/2019	00.49	PO	MMRDA WORK
Dhamangaon New - Badnera	IntraState	04/10/2019	09.10	04/10/2019	18.07	PO	Outage for Measurement of C & TAN Delta of CTS

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 04/Oct/2019

Statement-VII

Position as on 6.30 Hrs of 05/Oct/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Miraj - Mhaishal	IntraState	04/10/2019	09.20	04/10/2019	17.13	PO	Faulty String Replacement work
Kalwa - Siemens	IntraState	04/10/2019	09.57	04/10/2019	16.43	PO	FOR CHECKING ALL THE DENSITY MONITORS ON THIS BAY AND Y-PHASE LA REPLACEMENT AND BAY MAINTENANCE WORK.
Ghatghar - Jindal	IntraState	04/10/2019	10.10	04/10/2019	19.41	PO	Line Maintenance work
Chinchwad-Hinjewadi I	IntraState	04/10/2019	10.29	04/10/2019	14.46	PO	control load of chinchwad-urse line
Bhandara-Ultratech	IntraState	04/10/2019	10.59	04/10/2019	15.12	PO	String Replacement work
New Koyana - Pedambe	IntraState	04/10/2019	12.07	04/10/2019	18.45	PO	Due to Bus section outage
Pedambe-Pophali	IntraState	04/10/2019	12.10	04/10/2019	18.05	PO	Due to Bus section outage
Mahad - Pedambe	IntraState	04/10/2019	12.14	04/10/2019	18.55	PO	Due to Bus section outage
Main Bus Section-I@ Pedambe	IntraState	04/10/2019	12.15	04/10/2019	17.25	PO	22kv pedambe -new koyana line cut and unwound conductor B phase main bus to main bus isolator
Apta - Kalwa1	IntraState	04/10/2019	13.21	04/10/2019	22.24	PO	Replacement of Damaged conductor at Loc no-638
Sawantwadi-Bidri	IntraState	04/10/2019	13.40	04/10/2019	16.20	T	Tripped at Bidri end
Pusad-Ghatodi	IntraState	05/10/2019	07.30	05/10/2019	15.20	EO	R Phase CT Heavy Leakage
Dahanu Versova	IntraState	05/10/2019	07.47	05/10/2019	20.10	PO	Line Maintenance work
Eklahara(Gcr)(Nasik)- Bableshtar-I	IntraState	05/10/2019	08.20		Continued.	PO	CT Replacement
Pophali - Nerale	IntraState	05/10/2019	08.45	05/10/2019	12.50	PO	Y Phase Line side Isolator Pad Hot Glow
Nanded-Parbhani	IntraState	05/10/2019	10.53	05/10/2019	15.57	PO	Jumper connecting work
Paras-Chikhali Ckt No-li	IntraState	05/10/2019	11.27	05/10/2019	18.28	PO	Tan Delta Measurment of CTs
Uran - Apta III	IntraState	05/10/2019	12.10	05/10/2019	16.50	PO	Tree Trimming work
220kv Halkarni- Tillary	IntraState	05/10/2019	14.02	05/10/2019	15.00	T	Distance Protection
Halkarni-Mahalaxmi line	IntraState	05/10/2019	14.02	05/10/2019	14.48	T	Distance Protection
Warora - Wardha	IntraState	05/10/2019	14.37	05/10/2019	16.52	EO	To attend Hot Spot
220 KV ICT Outages/Trippings							
220/22 Kv 50 Mva Cgl Ptr 4 @Kamba	IntraState	04/10/2019	09.40	04/10/2019	16.30	PO	wti(hv) meter installation work of 50 mva, 220/22kv tf no-4 and oltc mechanism oil leakage attending work. as well as other maintenance activity.
220/110 Kv 200 Mva Vel Ptr 2 @Kolhapur-li (Mudshingi)	IntraState	04/10/2019	10.18	04/10/2019	17.20	PO	ICT-II TAKEN INSTED OF ICT-1.
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	04/10/2019	10.25	04/10/2019	18.57	PO	Relay Testing Work
220/132 KV 200 MVA ICT - 2 @ CHINCHWAD 2	IntraState	04/10/2019	11.17	04/10/2019	15.27	PO	Dignostic Testing Work
220/100 Kv 100 MVA ICT II @Vasai-li	IntraState	04/10/2019	12.25	04/10/2019	17.15	PO	Resolving TBC issue of ICT-2
220/22 Kv 50 Mva Areva Ptr 2 @Anandnagar	IntraState	04/10/2019	12.40	04/10/2019	18.40	PO	Y-phase stub Bus conductor replacement
220/132kv 100mva lct 1 @Peth	IntraState	05/10/2019	10.18	05/10/2019	12.02	PO	Quarterly Maintenance Work
220/100 KV 200MVA ICT II @ Pal	IntraState	05/10/2019	12.12	05/10/2019	13.22	HT	To check trip supervision ckt

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage