

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Oct/2024 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 144.802        | 576.723         | 1) Gujrat                      | 10.360         | 40.480          |
| 2) Hydro            | 7.348          | 39.427          | 2) Madhya Pradesh              | 2.761          | 12.904          |
| 3) Gas              | 6.912          | 24.884          | 3) Chattisgarh                 | 2.490          | 9.940           |
| <b>Total MSPGCL</b> | <b>159.062</b> | <b>641.034</b>  | 4) Maharashtra                 | 196.051        | 755.906         |
| B) 1) APLM          | 65.618         | 254.442         | 5) Goa (Amona)                 | -2.341         | -8.881          |
| 2) JSWEL            | 23.710         | 97.296          | <b>Total</b>                   | <b>209.321</b> | <b>810.349</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 49.824         | 188.799         |
| 4) RPL(AMT)         | 18.274         | 73.225          | b) Mumbai Drawl                | 54.187         | 204.649         |
| 5) SWPGPL           | 9.154          | 36.749          | c) MSEDCL Bilateral *          | 87.192         | 327.065         |
| 6) Other IPP        | 11.396         | 45.722          | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 49.609         | 187.170         |
| C) 1) TPCL Thermal  | 4.397          | 18.707          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 4.490          | 20.488          | Standby                        | 0.215          | 1.630           |
| 3) TPCL Gas         | 4.208          | 16.882          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 7.612          | 34.357          | 1) MSEDCL                      | 460.772        | 1818.632        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 74.894         | 295.083         |
| 1) Thermal          | 284.963        | 1137.221        | 3) Other Discoms               | 12.125         | 48.756          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>547.791</b> | <b>2162.471</b> |
| 2) Hydro (A2+C2)    | 11.838         | 59.915          |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 11.120         | 41.766          |                                |                |                 |
| 4) Wind             | 11.063         | 34.826          |                                |                |                 |
| 6) SOLAR            | 19.486         | 78.394          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>338.470</b> | <b>1352.122</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 5004                      | 6507                  | 6802                      | 5905                      |
| MSPGCL Hydro               | 272                       | 243                   | 944                       | 251                       |
| MSPGCL Gas                 | 282                       | 283                   | 309                       | 285                       |
| MSPGCL Total Generation    | 5558                      | 7033                  | 8055                      | 6441                      |
| Central Sector Receipt     | 10182                     | 8774                  | 8911                      | 7318                      |
| WIND                       | 148                       | 808                   | 805                       | 537                       |
| CPP / IPP Thermal          | 4125                      | 5740                  | 6132                      | 5703                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2522                      | 339                   | 0                         | 0                         |
| Exchange with Mumbai       | -2803                     | -2564                 | -2149                     | -1663                     |
| <b>MSEDCL DEMAND MET</b>   | <b>19166</b>              | <b>19580</b>          | <b>21212</b>              | <b>17935</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 19166                     | 19580                 | 21212                     | 17935                     |
| TPCL GENERATION            | 521                       | 654                   | 798                       | 396                       |
| AEML GENERATION            | 289                       | 294                   | 459                       | 309                       |
| <b>MUMBAI DEMAND</b>       | <b>3613</b>               | <b>3512</b>           | <b>3406</b>               | <b>2368</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>566</b>                | <b>550</b>            | <b>542</b>                | <b>401</b>                |
| STATE DEMAND MET           | 23345                     | 23642                 | 25160                     | 20704                     |
| <b>STATE DEMAND</b>        | <b>23345</b>              | <b>23642</b>          | <b>25160</b>              | <b>20704</b>              |
| Frequency (Hz)             | 50.00                     | 50.01                 | 50.07                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.2 Hz at 13:02 Hrs | 49.87 Hz at 07:18 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 04/Oct/2024

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.49         | 14.48         | 175      | 0        |
| Unit 8             | 12.67        | 49.40         | 589      | 375      |
| Unit 9             | 11.97        | 45.95         | 564      | 367      |
| Unit 10            | 11.50        | 46.16         | 535      | 375      |
| <b>Total</b>       | <b>39.62</b> | <b>156.00</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.12         | 3.30          | 150      | 110      |
| Unit 4             | 9.16         | 37.43         | 495      | 280      |
| Unit 5             | 8.66         | 35.38         | 460      | 290      |
| <b>Total</b>       | <b>20.94</b> | <b>76.11</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 4.20         | 13.84         | 237      | 140      |
| Unit 7             | 3.22         | 13.62         | 169      | 115      |
| Unit 8             | 4.19         | 16.31         | 223      | 145      |
| <b>Total</b>       | <b>11.61</b> | <b>43.78</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.54         | 12.23         | 144      | 73       |
| Unit 4             | 3.21         | 13.16         | 153      | 110      |
| Unit 5             | 7.74         | 30.52         | 375      | 285      |
| Unit 6             | 1.52         | 19.44         | 150      | 0        |
| Unit 7             | 7.15         | 28.64         | 348      | 242      |
| Unit 8             | 10.42        | 38.64         | 470      | 370      |
| Unit 9             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>32.58</b> | <b>142.63</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.14         | 16.74         | 213      | 133      |
| Unit 4             | 2.04         | 9.44          | 225      | 0        |
| <b>Total</b>       | <b>6.18</b>  | <b>26.18</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.62         | 14.14         | 175      | 115      |
| Unit 2             | 4.08         | 15.88         | 195      | 117      |
| Unit 3             | 3.83         | 15.23         | 171      | 133      |
| Unit 4             | 4.18         | 16.22         | 190      | 128      |
| Unit 5             | 11.01        | 43.31         | 485      | 405      |
| <b>Total</b>       | <b>26.72</b> | <b>104.78</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.45         | 12.95         | 158      | 121      |
| Unit 4             | 3.70         | 14.29         | 170      | 117      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>7.15</b>  | <b>27.24</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.91         | 24.88         | 373      | 280      |
| <b>Total</b>       | <b>6.91</b>  | <b>24.88</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 1.10         | 4.13          | 46       | 45       |
| <b>Total</b>       | <b>1.10</b>  | <b>4.13</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 1.50         | 7.72          | 190      | 40       |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 4         | 0.37          | 6.96          | 310      | 0        |
| Stage 3         | 0.39          | 3.33          | 160      | 0        |
| <b>Total</b>    | <b>2.26</b>   | <b>18.01</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.76          | 3.35          | 36       | 0        |
| VTRNA           | 0.00          | 0.00          | 0        | 0        |
| TILLARI         | 0.00          | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.34          | 1.38          | 40       | 0        |
| SMLHY_PTN       | 3.79          | 15.56         | 166      | 147      |
| GHATGHAR        | 0.20          | 1.12          | 125      | 0        |
| <b>Total</b>    | <b>5.09</b>   | <b>21.42</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 11.06         | 34.83         | 0        | 0        |
| <b>Total</b>    | <b>11.06</b>  | <b>34.83</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 65.62         | 254.44        | 0        | 0        |
| JSWEL(Mus)      | 23.71         | 97.30         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 18.27         | 73.22         | 0        | 0        |
| SWPGPL-Mus      | 9.15          | 36.75         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00          | 0        | 0        |
| IEPL            | 5.79          | 23.10         | 268      | 194      |
| Other(Mus)      | 0.75          | 3.06          | 0        | 0        |
| JPL             | 4.85          | 19.56         | 270      | 169      |
| <b>Total</b>    | <b>128.15</b> | <b>507.43</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 19.49         | 78.39         | 0        | 0        |
| <b>Total</b>    | <b>19.49</b>  | <b>78.39</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 0.00          | 0.00          | 0        | 0        |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 2.66          | 10.68         | 111      | 111      |
| Trombay 7B      | 1.54          | 6.20          | 65       | 64       |
| TATA Hydro      | 4.49          | 20.49         | 404      | 47       |
| Trombay 8       | 4.40          | 18.71         | 223      | 158      |
| <b>Total</b>    | <b>13.10</b>  | <b>56.08</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 7.61          | 34.36         | 459      | 282      |
| <b>Total</b>    | <b>7.61</b>   | <b>34.36</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 144.80      | 576.72        | MSPGCL Total        | 159.06      | 641.03        |
|                |             |         | MSPGCL Thml+Gas | 151.71      | 601.61        | Koyna 1,2 & 4 Total | 1.87        | 14.68         |
|                |             |         | MSPGCL Hydro    | 7.35        | 39.43         | State Total         | 338.47      | 1352.12       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 04/Oct/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 6229        | 240  | 283  | 6752   | 579   | 5968      | 0    | 0     | 7702        | 7515        | -1989                | 18358                  | 0                | 0                           | 18358                         | 2927             | 467                       | 21752           | 49.99         |
| 2                  | 6066        | 242  | 284  | 6592   | 508   | 5890      | 0    | 0     | 7439        | 7308        | -1886                | 17985                  | 0                | 0                           | 17985                         | 2663             | 427                       | 21075           | 49.99         |
| 3                  | 5921        | 246  | 283  | 6450   | 528   | 5706      | 0    | 0     | 7275        | 7332        | -1752                | 17860                  | 0                | 0                           | 17860                         | 2477             | 404                       | 20741           | 49.95         |
| 4                  | 5905        | 251  | 285  | 6441   | 537   | 5703      | 0    | 0     | 7137        | 7318        | -1663                | 17935                  | 0                | 0                           | 17935                         | 2368             | 401                       | 20704           | 50.00         |
| 5                  | 6061        | 238  | 284  | 6583   | 436   | 5860      | 0    | 0     | 7316        | 7591        | -1613                | 18457                  | 0                | 0                           | 18457                         | 2319             | 400                       | 21176           | 49.99         |
| 6                  | 6064        | 241  | 284  | 6589   | 399   | 5767      | 0    | 0     | 8693        | 8780        | -1687                | 19412                  | 0                | 0                           | 19412                         | 2397             | 436                       | 22245           | 50.01         |
| 7                  | 6087        | 232  | 284  | 6603   | 342   | 5704      | 0    | 61    | 9657        | 9768        | -1802                | 20199                  | 0                | 0                           | 20199                         | 2534             | 477                       | 23210           | 50.04         |
| 8                  | 6140        | 272  | 285  | 6697   | 246   | 5680      | 0    | 610   | 9207        | 9420        | -1994                | 20145                  | 0                | 0                           | 20145                         | 2734             | 514                       | 23393           | 50.00         |
| 9                  | 5835        | 273  | 285  | 6393   | 179   | 5283      | 0    | 1422  | 9034        | 9190        | -2308                | 19617                  | 0                | 0                           | 19617                         | 3078             | 542                       | 23237           | 50.02         |
| 10                 | 5536        | 266  | 282  | 6084   | 173   | 4571      | 0    | 2016  | 9569        | 9642        | -2609                | 19312                  | 0                | 13                          | 19312                         | 3404             | 565                       | 23281           | 50.03         |
| 11                 | 5004        | 272  | 282  | 5558   | 148   | 4125      | 0    | 2522  | 10200       | 10182       | -2803                | 19166                  | 0                | 16                          | 19166                         | 3613             | 566                       | 23345           | 50.00         |
| 12                 | 5074        | 275  | 281  | 5630   | 183   | 4122      | 0    | 2576  | 9566        | 9761        | -2718                | 19007                  | 0                | 16                          | 19007                         | 3691             | 547                       | 23245           | 50.02         |
| 13                 | 5039        | 373  | 280  | 5692   | 192   | 4101      | 0    | 2607  | 9229        | 9452        | -2755                | 18770                  | 0                | 14                          | 18770                         | 3634             | 519                       | 22923           | 49.97         |
| 14                 | 5143        | 263  | 282  | 5688   | 200   | 4069      | 0    | 2462  | 9319        | 9444        | -2676                | 18658                  | 0                | 14                          | 18658                         | 3513             | 529                       | 22700           | 50.02         |
| 15                 | 5689        | 228  | 281  | 6198   | 340   | 4109      | 0    | 2227  | 9667        | 9201        | -2735                | 18821                  | 0                | 3                           | 18821                         | 3586             | 519                       | 22926           | 50.02         |
| 16                 | 5833        | 230  | 280  | 6343   | 434   | 4244      | 0    | 1681  | 9723        | 9538        | -2754                | 18956                  | 0                | 8                           | 18956                         | 3634             | 530                       | 23120           | 49.98         |
| 17                 | 6246        | 236  | 282  | 6764   | 563   | 5055      | 0    | 926   | 9360        | 9012        | -2715                | 19069                  | 0                | 8                           | 19069                         | 3596             | 536                       | 23201           | 50.05         |
| 18                 | 6507        | 243  | 283  | 7033   | 808   | 5740      | 0    | 339   | 9019        | 8774        | -2564                | 19580                  | 0                | 0                           | 19580                         | 3512             | 550                       | 23642           | 50.01         |
| 19                 | 6697        | 550  | 373  | 7620   | 729   | 5958      | 0    | 37    | 9441        | 9304        | -2405                | 20685                  | 0                | 0                           | 20685                         | 3429             | 558                       | 24672           | 50.02         |
| 20                 | 6802        | 944  | 309  | 8055   | 805   | 6132      | 0    | 0     | 8799        | 8911        | -2149                | 21212                  | 0                | 0                           | 21212                         | 3406             | 542                       | 25160           | 50.07         |
| 21                 | 6809        | 445  | 283  | 7537   | 833   | 6129      | 0    | 0     | 8348        | 8259        | -2089                | 20117                  | 0                | 0                           | 20117                         | 3246             | 552                       | 23915           | 50.03         |
| 22                 | 6862        | 258  | 285  | 7405   | 750   | 6112      | 0    | 0     | 7999        | 8042        | -2151                | 19610                  | 0                | 0                           | 19610                         | 3093             | 548                       | 23251           | 50.01         |
| 23                 | 6656        | 247  | 285  | 7188   | 617   | 6081      | 0    | 0     | 7728        | 7925        | -2180                | 19123                  | 0                | 0                           | 19123                         | 3014             | 508                       | 22645           | 49.97         |
| 24                 | 6597        | 283  | 287  | 7167   | 534   | 6043      | 0    | 0     | 7596        | 7652        | -2190                | 18717                  | 0                | 0                           | 18717                         | 3026             | 489                       | 22232           | 49.96         |
| MUs                | 144.80      | 7.35 | 6.91 | 159.06 | 11.06 | 128.15    | 0.00 | 19.49 | 209.02      | 209.32      | -54.19               | 460.77                 | 0.00             | 0.09                        | 460.77                        | 74.89            | 12.12                     | 547.79          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

due to overloading of 132kV Satana-Dindori line.

| Maximum Demand scenario for the date 04/Oct/2024 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25160 MW                                         | 21212 MW                         | 3691 MW                           |
| 20 Hrs                                           | 20 Hrs                           | 12 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Oct/2024**

Position as on 6.30 Hrs of 05/Oct/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        | Nasik Unit 5            | 210      | 27/08/2024   | 23:55        |            | Continued. | On Tolling(Under COH from 00.00 Hrs DT.05.09.2024)                                                              | 10/10/2024    |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 31/08/2024   | 23:45        |            | Continued. | Capital overhaul (COH) works.                                                                                   | 07/10/2024    |
| MSPGCL                        | Koyna Unit 6            | 80       | 12/09/2024   | 15:10        |            | Continued. | Refurbishment of governing system & Upgradation of PLC system & Excitation system.                              | 22/10/2024    |
| Total Capacity MSPGCL         |                         | 790      |              |              |            |            |                                                                                                                 |               |
| Total Capacity PLANNED OUTAGE |                         | 790      |              |              |            |            |                                                                                                                 |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                 |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                              | 31/10/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                              | 26/11/2024    |
| MSPGCL                        | Koyna Unit 5            | 80       | 18/08/2024   | 18:00        |            | Continued. | UGB Temperature High                                                                                            | 12/10/2024    |
| MSPGCL                        | Uran Unit 6             | 108      | 24/09/2024   | 10:30        |            | Continued. | Generator exciter end abnormal sound.                                                                           | 12/10/2024    |
| MSPGCL                        | Paras Unit 4            | 250      | 02/10/2024   | 16:54        | 04/10/2024 | 12:55      | generator electrical protection                                                                                 | 04/10/2024    |
| MSPGCL                        | Chandrapur Unit 6       | 500      | 04/10/2024   | 05:20        | 04/10/2024 | 17:21      | PA Fan problem                                                                                                  | 04/10/2024    |
| MSPGCL                        | Koradi Unit 6           | 210      | 04/10/2024   | 07:58        | 04/10/2024 | 10:20      | Flame Failure                                                                                                   |               |
| MSPGCL                        | Uran Unit 8             | 108      | 05/10/2024   | 00:15        |            | Continued. | For filters replacement & B2 boiler leakages attending work                                                     | 07/10/2024    |
| MSPGCL                        | Koyna STG-IV Unit-4     | 250      | 05/10/2024   | 18:50        | 05/10/2024 | 22:05      | LT Breaker Fault                                                                                                |               |
| MSPGCL                        | Chandrapur Unit 8       | 500      | 05/10/2024   | 19:32        | 05/10/2024 | 22:10      | Generator Elect. Fault                                                                                          |               |
| Total Capacity MSPGCL         |                         | 2251     |              |              |            |            |                                                                                                                 |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                 |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                 |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                 |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                 |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                          | 31/10/2024    |
| IPP                           | RPL(AMT) U-5            | 270      | 15/09/2024   | 15:21        |            | Continued. | Bottom Ash Evacuation Problem                                                                                   | 15/10/2024    |
| IPP                           | SWPGPL U-4              | 135      | 01/10/2024   | 01:00        |            | Continued. | Due to EHP DC High                                                                                              | 07/10/2024    |
| Total Capacity IPP            |                         | 675      |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                 |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling. | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket                                                                                  | 30/11/2024    |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Oct/2024**

Position as on 6.30 Hrs of 05/Oct/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                         | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------------------------------------------------------------------------------------------------|---------------|
|                                               |                         |          |              |              |            |            | strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. |               |
| Total Capacity CENT.SECTOR                    |                         | 320      |              |              |            |            |                                                                                                                          |               |
| Total Capacity FORCED OUTAGE                  |                         | 3746     |              |              |            |            |                                                                                                                          |               |
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |            |            |                                                                                                                          |               |
| MSPGCL                                        |                         |          |              |              |            |            |                                                                                                                          |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 03/10/2024   | 21:03        | 04/10/2024 | 17:58      | Due to no Schedule given by MSEDCL.                                                                                      |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 04/10/2024   | 19:30        | 05/10/2024 | 15:53      | Due to no schedule given by MSEDCL                                                                                       |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 05/10/2024   | 19:58        |            | Continued. | Due to no schedule given by MSEDCL                                                                                       |               |
| Total Capacity MSPGCL                         |                         | 324      |              |              |            |            |                                                                                                                          |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 324      |              |              |            |            |                                                                                                                          |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |            |            |                                                                                                                          |               |
| IPP                                           |                         |          |              |              |            |            |                                                                                                                          |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                     |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                     |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                  |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                   |               |
| Total Capacity IPP                            |                         | 988      |              |              |            |            |                                                                                                                          |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |            |            |                                                                                                                          |               |

\* Other generator generating power instead of contracted genertaoor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 05/Oct/2024

| Name of Line                                | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                 |
|---------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV MAINBAY Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| MAIN BAY (710) OF TIRORA CKT - 1 @ KORADI 3 | IntraState                | 04/10/2024   | 09:36        | 04/10/2024 | 18:05      | PO          | Annual Maintenance of Bay Equipment at Koradi-III SS.                                                                                                                                                                                                                            |
| <b>400 KV LINE Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| KALWA - TALEGAON (PG)                       | InterState                | 04/10/2024   | 07:08        |            | Continued. | PO          | 400KV-KALWA-PUNE-PG-1 for LILO at 400kv Vikhroli (GIS) ss                                                                                                                                                                                                                        |
| PADGHE - BOISAR (PG)                        | InterState                | 05/10/2024   | 15:15        | 05/10/2024 | 16:43      | T           | Tripped on distance protection.                                                                                                                                                                                                                                                  |
| BUS REACTOR (50MVAR) @ PARLI                | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                                                                                                                                                              |
| 220kv Koradi-2 - Uppalwadi ckt 2            | IntraState                | 28/08/2024   | 00:14        |            |            | T           | Distance protection                                                                                                                                                                                                                                                              |
| PARLI - KUMBHARGAON(NANDED) CKT - 2         | IntraState                | 03/10/2024   | 16:14        |            |            | PO          | (1) Bay equipments replacement work (CB, CT,CVT,LA,WT, PG & HCB isolators) under LES. (2)Distance M1 & M2 relays retrofitting work.3) Hardware tightening & fitting work                                                                                                         |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1         | IntraState                | 04/10/2024   | 08:31        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                                         |
| KORADI II - KORADI III CKT - 2              | IntraState                | 04/10/2024   | 11:33        | 04/10/2024 | 16:18      | EO          | Replacement of damaged cable connected between Bph CVT & CVT MB at bay 406                                                                                                                                                                                                       |
| <b>400 KV ICT Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| STATION TF No 3 @ CHANDRAPUR GCR            | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                   |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA         | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                                                          |
| 400/220kv 500MVA ICT-2 @ TAPTITANDA         | IntraState                | 04/10/2024   | 12:03        | 04/10/2024 | 14:58      | PO          | For CB diagnostic testing work after shifting the load on 220 kV TBC bay.                                                                                                                                                                                                        |
| <b>400 KV BR Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| KARAD - 400KV 80 MVAR B/R 2                 | IntraState                | 04/10/2024   | 10:05        | 04/10/2024 | 18:20      | PO          | Diagnostic testing work                                                                                                                                                                                                                                                          |
| <b>220 KV MAINBAY Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| 220KV BUS SECTION BAY @ PEDAMBE             | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                     |
| BUS SECTION - 2 @ TIFIL                     | IntraState                | 04/10/2024   | 13:00        | 04/10/2024 | 16:51      | PO          | 1)220kv Kalwa-Pawane-Nextra Line will be available in service for 220kv Nextra Substation.<br>2) 220kv Mahape-TFIPL line will be available in service for 220kv TFIPL Substation.                                                                                                |
| <b>220 KV LINE Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| BALE - SOLAPUR (PG)                         | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37) |
| 220 KV HARANGUL - PARLY (PG) CKT            | InterState                | 05/10/2024   | 09:36        | 05/10/2024 | 19:40      | EO          | Flashover string replacement work at loc.no. 132 R Ph                                                                                                                                                                                                                            |
| 220 KV HARANGUL - PARLY (PG) CKT            | InterState                | 05/10/2024   | 09:36        | 05/10/2024 | 19:40      | EO          | Testing,CRM Timing of CB                                                                                                                                                                                                                                                         |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 05/Oct/2024

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                              |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220 KV HARANGUL - PARLY (PG) CKT           | InterState                | 05/10/2024   | 19:40        |            |            | EO          | Testing, CRM, Timing of CB alongwith overhauling due to PDR operations of breaker of 220Kv Harangul-PGCIL line on Dtd. 02.10.2024                                                                                                                                             |
| OSMANABAD - SOLAPUR (BALE)                 | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37) |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2      | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                           |
| GHODBUNDER - GORAI                         | IntraState                | 29/07/2024   | 12:14        |            |            | PO          | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                           |
| EKLAHARE (OCR) - NAVASARI CKT - 2          | IntraState                | 20/09/2024   | 17:34        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                                      |
| EKLAHARE (OCR) - PADGHE                    | IntraState                | 24/09/2024   | 07:48        |            |            | HT          | For load mgmt                                                                                                                                                                                                                                                                 |
| AAREY - MSETCL BORIVALI CKT - 1            | IntraState                | 26/09/2024   | 23:58        |            |            | T           | Tripped on distance protection.                                                                                                                                                                                                                                               |
| EKLAHARE (OCR) - NAVASARI CKT - 1          | IntraState                | 30/09/2024   | 00:02        |            | Continued. | HT          | H/T for load management.                                                                                                                                                                                                                                                      |
| KALWA - GIGAPLEX (PDG) CKT                 | IntraState                | 30/09/2024   | 16:34        | 04/10/2024 | 16:27      | T           | Cable Burnt at PDG end                                                                                                                                                                                                                                                        |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I  | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                                                       |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                                                                                                                                         |
| 132 KV CHITEGAON - GARWARE CKT             | IntraState                | 03/10/2024   | 19:47        | 04/10/2024 | 18:10      | HT          | CB air pressure does not maintain during serval attempt and said CB goes into lockout at Garware end Hence CB HT at Garware end.                                                                                                                                              |
| HINJAWADI I- CHINCHWAD                     | IntraState                | 04/10/2024   | 06:58        | 04/10/2024 | 22:34      | HT          | control the loading of 400kV Chakan - Talegaon PG                                                                                                                                                                                                                             |
| PUSAD - HINGOLI                            | IntraState                | 04/10/2024   | 07:27        | 04/10/2024 | 10:52      | PO          | Line maintenance work                                                                                                                                                                                                                                                         |
| NEW KOYNA - NIWALI                         | IntraState                | 04/10/2024   | 10:32        | 04/10/2024 | 17:49      | PO          | For cold washing of insulator strings and other line maintenance work.                                                                                                                                                                                                        |
| KHAPARKHEDA-AMBAZARI-II                    | IntraState                | 04/10/2024   | 10:39        | 04/10/2024 | 16:23      | PO          | Retrofitting work of back up relay at 220kV SSTN ambazari                                                                                                                                                                                                                     |
| SAWANGI-BHOKARDAN CKT                      | IntraState                | 04/10/2024   | 10:49        | 04/10/2024 | 15:01      | PO          | Stringing work of 220kV Nagewadi Bhokardan line on existing M/C Loc 214-216                                                                                                                                                                                                   |
| JEJURI ( 400 KV)-JEJURI- I                 | IntraState                | 04/10/2024   | 10:56        | 04/10/2024 | 21:27      | PO          | Testing and maintenance work                                                                                                                                                                                                                                                  |
| AURANGABAD (WALUJ)-DEOGAON RANGARI         | IntraState                | 04/10/2024   | 11:05        | 04/10/2024 | 16:24      | PO          | Diagnostic testing and routine maintenance work.                                                                                                                                                                                                                              |
| 132 KV JINTUR - PARBHANI (220 KV ) CKT     | IntraState                | 04/10/2024   | 11:45        | 04/10/2024 | 12:30      | T           | Distance protection                                                                                                                                                                                                                                                           |
| AKOLA-PARAS CKT NO-II                      | IntraState                | 04/10/2024   | 11:55        | 04/10/2024 | 15:52      | PO          | Diagnostic testing and bay maintenance work.                                                                                                                                                                                                                                  |
| TIFIL - NEXTRA GIS                         | IntraState                | 04/10/2024   | 12:16        | 04/10/2024 | 17:19      | PO          | Replacement of B ph main bus drop jumper to Bus section isolator due to breaking of conductor strands.                                                                                                                                                                        |
| LONAND - KANDALGAON (SONA ALLOY TAP)       | IntraState                | 04/10/2024   | 12:35        | 04/10/2024 | 19:01      | PO          | Replacement of damaged conductor at Loc No.131,139,141,162,227                                                                                                                                                                                                                |
| 220kV Koradi-2 - Uppalwadi ckt 1           | IntraState                | 04/10/2024   | 13:06        | 04/10/2024 | 17:48      | PO          | Daily basis outage required and Restoration work.                                                                                                                                                                                                                             |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 05/Oct/2024

| Name of Line                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                              |
|------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| KARAD -NIGADE                                  | IntraState                | 04/10/2024   | 14:41        | 04/10/2024 | 14:41      | PO          | For Distance relay retrofitting and relay panel rewiring work at karad end.                                                                                                                                                                                   |
| 220 KV PHULAMBRI - BHOKARDHAN                  | IntraState                | 04/10/2024   | 15:14        | 04/10/2024 | 18:25      | PO          | Stringing work of 220kv Nagewadi Bhokardan line on existing M/C Loc 214-216                                                                                                                                                                                   |
| BABLESHWAR-BABLESHWAR(400KV)-II                | IntraState                | 04/10/2024   | 17:22        | 04/10/2024 | 22:50      | EO          | Outage is required for attending oil leakages of R,Y & B Phase CT of 220KV Babhaleshwar-Babhaleshwar-2 bay. Images attached.                                                                                                                                  |
| TAMBATI - ADLABS                               | IntraState                | 04/10/2024   | 17:43        | 04/10/2024 | 19:43      | PO          | 1) Retrofitting of O/C+E/F Backup protection relay by PAC Dn. Panvel at tambati end.<br>2) Diagnostic testing wok at both ends.<br>3) Bay maintenance work at both ends.                                                                                      |
| HINJAWADI I- CHINCHWAD                         | IntraState                | 05/10/2024   | 07:04        | 05/10/2024 | 22:12      | HT          | Load Management                                                                                                                                                                                                                                               |
| ALEPHATA-PARGAON(KATHAPUR)                     | IntraState                | 05/10/2024   | 07:39        | 05/10/2024 | 19:11      | HT          | Load Management                                                                                                                                                                                                                                               |
| HINJAWADI I- CHINCHWAD                         | IntraState                | 05/10/2024   | 09:56        | 05/10/2024 | 15:58      | PO          | Work to be carried out 220kv Hinjewadi I S/Stn:- CB MB to relay panel control cable replacement work due to DC leakage & annual relay testing work.<br>Work to be carried out 220kv Chinchwad I S/Stn :-Half yearly bay Maintenance & Diagnostic testing work |
| 220 KV PARTUR - NAGEWADI CKT 1                 | IntraState                | 05/10/2024   | 10:30        | 05/10/2024 | 13:27      | PO          | Replacement of Suspension strings                                                                                                                                                                                                                             |
| BOISAR II - BOISAR (PG) CKT - 2                | IntraState                | 05/10/2024   | 11:29        | 05/10/2024 | 16:47      | PO          | AMP WORK                                                                                                                                                                                                                                                      |
| LONAND - KANDALGAON (SONA ALLOY TAP)           | IntraState                | 05/10/2024   | 13:07        | 05/10/2024 | 18:09      | PO          | Replacement of damaged conductor at Loc No.131,139,141,162,227                                                                                                                                                                                                |
| BABLESHWAR -AHAMADNAGAR-I-JEUR TAP             | IntraState                | 05/10/2024   | 13:52        | 05/10/2024 | 17:00      | PO          | Diagnostic testing work, CT tan delta Measurement                                                                                                                                                                                                             |
| 220 KV PARTUR - NAGEWADI CKT 2                 | IntraState                | 05/10/2024   | 13:55        | 05/10/2024 | 16:48      | PO          | Replacement of Suspension strings                                                                                                                                                                                                                             |
| PURTI-BHUGAON                                  | IntraState                | 05/10/2024   | 17:09        | 05/10/2024 | 23:13      | T           | Distance Protection                                                                                                                                                                                                                                           |
| <b>220 KV ICT Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                                                                                                                                               |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR         | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kv 100MVA to 220/132kv 200MVA at Babheshwar.                                                                                                                                                                                           |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2               | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                                                                                                   |
| 220/132 KV 100 MVA ICT II @ UPPALWADI          | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                                                                                                   |
| 220/132 KV 100 MVA ICT I @ UPPALWADI           | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                                                                                                   |
| 220/33 KV 25 MVA TF - I @ PURTI                | IntraState                | 28/08/2024   | 23:05        | 04/10/2024 | 16:51      | T           | 33kv PT Burst and LA Burst, Bucholz protection operated                                                                                                                                                                                                       |
| 220/132 KV 100 MVA ICT - 1 @ ALEPHATA          | IntraState                | 23/09/2024   | 03:31        |            |            | T           | Tripped on internal fault and main Buchholz.                                                                                                                                                                                                                  |
| 220/110 KV 200 MVA ICT - 2 @ ICHALKARANJI - II | IntraState                | 23/09/2024   | 10:40        |            |            | PO          | 245 KV HV CB overhauling work (ABB Make)                                                                                                                                                                                                                      |
| 220/22-22 KV 100 MVA PTR 3 @ PAL-DOMBIVALI     | IntraState                | 25/09/2024   | 09:12        | 04/10/2024 | 12:28      | PO          | Dismantling of existing 50 MVA transformer and erection of 80 MVA Transformer.                                                                                                                                                                                |
| 220/22-22 KV 80 MVA PTR 2 @ COLOURCHEM         | IntraState                | 29/09/2024   | 09:43        | 04/10/2024 | 20:41      | T           | Buchholz alarm operated                                                                                                                                                                                                                                       |
| 100 MVA 220/132 KV ICT 1 @ PARTUR              | IntraState                | 04/10/2024   | 06:46        | 04/10/2024 | 11:25      | PO          | Erection of inline tower of 132kv Partur ckt-2 and removal of 132kv Partur TSS tapping jumper                                                                                                                                                                 |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 05/Oct/2024

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                               |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------|
| 220/132-110/11KV 200MVA VID ICT 1 @ MIRAJ | IntraState                | 04/10/2024   | 10:07        | 04/10/2024 | 18:58      | PO          | 1. Diagnostic Testing Work<br>2. Quarterly Maintenance Work<br>3. NIFPS Maintenance Work                       |
| 220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR    | IntraState                | 04/10/2024   | 11:00        | 04/10/2024 | 12:55      | PO          | Attending hot spots                                                                                            |
| 220/100 KV 200 MVA ICT 2 @ TROMBAY        | IntraState                | 04/10/2024   | 11:02        | 04/10/2024 | 17:11      | EO          | To attend the major oil leakage from the radiator block by replacement of faulty radiator block by the agency. |
| 200 MVA 220/132 KV ICT - III @ CHALISGAON | IntraState                | 04/10/2024   | 11:21        | 04/10/2024 | 12:24      | PO          | Removal of oil from OLTC conservator and to maintaining the oil level of said ict.                             |
| 220/132 KV 200 MVA ICT 1 @ BOISAR-II      | IntraState                | 04/10/2024   | 12:15        | 04/10/2024 | 16:48      | EO          | To check the SF6 Gas leakage issue from LV CB after shifting the LV of ICT on TBC..                            |
| 220/22 KV 50 MVA PTR 2 @ ANANDNAGAR       | IntraState                | 04/10/2024   | 13:06        | 04/10/2024 | 15:53      | PO          | Attending hot spots.                                                                                           |
| 220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE | IntraState                | 04/10/2024   | 14:43        | 04/10/2024 | 18:30      | PO          | OLTC OIL FILTRATION                                                                                            |
| 220/132 KV 200MVA ICT 2 @ DHULE           | IntraState                | 05/10/2024   | 09:22        | 05/10/2024 | 14:29      | PO          | Trip CKT Faulty rectification work                                                                             |
| 220/132-110KV 200MVA ICT 2 @ MIRAJ        | IntraState                | 05/10/2024   | 10:03        | 05/10/2024 | 16:47      | PO          | 1. Diagnostic Testing Work<br>2. Quarterly Maintenance Work<br>3. NIFPS Maintenance Work                       |
| 220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR     | IntraState                | 05/10/2024   | 10:56        | 05/10/2024 | 13:02      | PO          | PRV faulty micro switch replacement work                                                                       |
| <b>220 KV BUSBAR Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                |
| MAIN BUS-PT @TIFIL                        | IntraState                | 04/10/2024   | 12:59        | 04/10/2024 | 16:51      | PO          | Replacement of B ph main bus drop jumper to Bus section isolator due to breaking of conductor strands.         |
| <b>132 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                |
| MANSAR-PENCH                              | InterState                | 26/09/2024   | 14:40        |            |            | HT          | H/T at 132KV Pench end                                                                                         |
| <b>110 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                |
| BORIVLI (T) - BORIVLI (M) - BMC - KOLSHET | IntraState                | 05/10/2024   | 06:55        | 05/10/2024 | 10:25      | PO          | R/M & insulator replacement                                                                                    |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage