

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 04/Nov/2021 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 131.642        | 571.061         | 1) Gujrat                      | -5.987         | -25.060         |
| 2) Hydro            | 8.786          | 51.040          | 2) Madhya Pradesh              | 4.259          | 30.575          |
| 3) Gas              | 4.984          | 23.456          | 3) Chattisgarh                 | 5.390          | 24.840          |
| <b>Total MSPGCL</b> | <b>145.412</b> | <b>645.557</b>  | 4) Maharashtra                 | 138.322        | 624.315         |
| B) 1) APLM          | 53.282         | 222.055         | 5) Goa (Amona)                 | -0.958         | -5.093          |
| 2) JSWEL            | 13.799         | 54.880          | <b>Total</b>                   | <b>141.026</b> | <b>649.577</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 26.756         | 113.536         |
| 4) RPL(AMT)         | 14.280         | 69.859          | b) Mumbai Drawl                | 27.460         | 120.280         |
| 5) SWPGPL           | 6.201          | 17.046          | c) MSEDCL Bilateral *          | 42.472         | 187.315         |
| 6) Other IPP        | 24.712         | 93.307          | Include PX                     | 6.874          | 46.871          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 26.756         | 113.536         |
| C) 1) TPCL Thermal  | 10.869         | 46.533          | Include PX                     | 18.689         | 82.878          |
| 2) TPCL Hydro       | 3.047          | 16.503          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.830          | 12.737          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 9.240          | 38.296          | 1) MSEDCL                      | 387.102        | 1702.262        |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 53.445         | 234.348         |
| 1) Thermal          | 264.025        | 1113.037        | <b>TOTAL STATE</b>             | <b>440.547</b> | <b>1936.610</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                 |
| 2) Hydro            | 11.833         | 67.543          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 7.814          | 36.193          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 9.480          | 41.703          |                                |                |                 |
| 6) SOLAR            | 6.370          | 28.558          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>299.522</b> | <b>1287.034</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 15 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 24 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|----------------------------|
| MSPGCL Thermal           | 5304                      | 5753                  | 5472                      | 4650                       |
| MSPGCL Hydro             | 541                       | 260                   | 296                       | 250                        |
| MSPGCL Gas               | 199                       | 186                   | 240                       | 204                        |
| MSPGCL Total Generation  | 6044                      | 6199                  | 6008                      | 5104                       |
| Central Sector Receipt   | 7054                      | 6642                  | 5265                      | 5046                       |
| WIND                     | 401                       | 335                   | 355                       | 485                        |
| CPP / IPP Thermal        | 4599                      | 4904                  | 4641                      | 4253                       |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                          |
| SOLAR                    | 877                       | 733                   | 1                         | 0                          |
| Exchange with Mumbai     | -1208                     | -1228                 | -1213                     | -1317                      |
| <b>MSEDCL DEMAND MET</b> | <b>17767</b>              | <b>17585</b>          | <b>15057</b>              | <b>13571</b>               |
| Load Shedding            | 0                         | 0                     | 0                         | 0                          |
| MSEDCL DEMAND            | 17767                     | 17585                 | 15057                     | 13571                      |
| TPCL GENERATION          | 673                       | 674                   | 918                       | 671                        |
| AEML GENERATION          | 410                       | 384                   | 351                       | 358                        |
| <b>MUMBAI DEMAND</b>     | <b>2291</b>               | <b>2286</b>           | <b>2482</b>               | <b>2346</b>                |
| STATE DEMAND MET         | 20058                     | 19871                 | 17539                     | 15917                      |
| <b>STATE DEMAND</b>      | <b>20058</b>              | <b>19871</b>          | <b>17539</b>              | <b>15917</b>               |
| Frequency (Hz)           | 50.03                     | 50.03                 | 50.13                     | 50.00                      |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.26 Hz at 17.03 Hrs | 49.78 Hz at 02.12 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 04/Nov/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 2.92         | 13.20         | 150      | 90       |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 12.30        | 50.14         | 602      | 373      |
| Unit 9             | 12.29        | 49.60         | 598      | 368      |
| Unit 10            | 12.14        | 48.93         | 565      | 385      |
| <b>Total</b>       | <b>39.65</b> | <b>161.86</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 3.14         | 13.08         | 150      | 120      |
| Unit 4             | 8.60         | 39.58         | 455      | 280      |
| Unit 5             | 8.88         | 38.76         | 450      | 280      |
| <b>Total</b>       | <b>20.62</b> | <b>91.42</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 2.88         | 15.22         | 208      | 0        |
| Unit 7             | 3.79         | 16.53         | 212      | 148      |
| Unit 8             | 3.92         | 17.02         | 202      | 151      |
| <b>Total</b>       | <b>10.60</b> | <b>48.76</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 2.93         | 8.32          | 130      | 115      |
| Unit 4             | 2.89         | 13.10         | 128      | 112      |
| Unit 5             | 7.42         | 33.62         | 360      | 275      |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 3.43         | 30.06         | 364      | 0        |
| Unit 8             | 8.67         | 37.25         | 410      | 270      |
| Unit 9             | 8.51         | 38.36         | 402      | 272      |
| <b>Total</b>       | <b>33.83</b> | <b>160.72</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.79         | 10.45         | 212      | 145      |
| <b>Total</b>       | <b>3.79</b>  | <b>10.45</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.65         | 10.84         | 125      | 80       |
| Unit 2             | 3.06         | 13.75         | 170      | 115      |
| Unit 3             | 3.19         | 14.32         | 170      | 123      |
| Unit 4             | 3.10         | 13.74         | 156      | 120      |
| Unit 5             | 8.14         | 22.71         | 470      | 275      |
| <b>Total</b>       | <b>20.14</b> | <b>75.37</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 9.93          | 0        | 0        |
| Unit 5             | 3.01         | 12.55         | 184      | 112      |
| <b>Total</b>       | <b>3.01</b>  | <b>22.48</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 4.98         | 23.46         | 242      | 186      |
| <b>Total</b>       | <b>4.98</b>  | <b>23.46</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.77         | 2.78          | 33       | 31       |
| <b>Total</b>       | <b>0.77</b>  | <b>2.78</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.36          | 14.15         | 340      | 40       |
| Stage 4         | 0.29          | 7.77          | 200      | 0        |
| Stage 3         | 0.74          | 4.60          | 160      | 0        |
| <b>Total</b>    | <b>3.39</b>   | <b>26.52</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.29          | 1.58          | 18       | 0        |
| VTRNA           | 0.00          | 0.00          | 0        | 0        |
| TILLARI         | 0.00          | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.24          | 0.90          | 80       | 0        |
| SMLHY_PTN       | 4.87          | 20.46         | 213      | 195      |
| GHATGHAR        | 0.00          | 1.58          | 0        | 0        |
| <b>Total</b>    | <b>5.40</b>   | <b>24.52</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 9.48          | 41.70         | 0        | 0        |
| <b>Total</b>    | <b>9.48</b>   | <b>41.70</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 53.28         | 222.06        | 0        | 0        |
| JSWEL(Mus)      | 13.80         | 54.88         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 14.28         | 69.86         | 0        | 0        |
| SWPGPL-Mus      | 6.20          | 17.05         | 0        | 0        |
| Other(Mus)      | 24.71         | 93.31         | 0        | 0        |
| <b>Total</b>    | <b>112.27</b> | <b>457.15</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 6.37          | 28.56         | 0        | 0        |
| <b>Total</b>    | <b>6.37</b>   | <b>28.56</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 6.53          | 27.90         | 281      | 268      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 1.64          | 7.54          | 107      | 54       |
| Trombay 7B      | 1.19          | 5.20          | 63       | 44       |
| Trombay 8       | 4.34          | 18.64         | 211      | 156      |
| TATA Hydro      | 3.05          | 16.50         | 340      | 1        |
| <b>Total</b>    | <b>16.75</b>  | <b>75.77</b>  |          |          |
| <b>AEMIL</b>    |               |               |          |          |
| DTPS U-1&2      | 9.24          | 38.30         | 468      | 342      |
| <b>Total</b>    | <b>9.24</b>   | <b>38.30</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 131.64      | 571.06        | MSPGCL Total        | 145.41      | 645.56        |
|                |             |         | MSPGCL Thml+Gas | 136.63      | 594.52        | Koyna 1,2 & 4 Total | 2.64        | 21.92         |
|                |             |         | MSPGCL Hydro    | 8.79        | 51.04         | State Total         | 299.52      | 1287.03       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 04/Nov/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5275        | 263  | 202  | 5740   | 489  | 4531      | 0    | 0     | 5938        | 5818        | -1234                | 15344                 | 0                    | 15344                     | 2301             | 17645           | 49.96         |
| 2                  | 5380        | 384  | 211  | 5975   | 383  | 4557      | 0    | 0     | 5886        | 5886        | -1184                | 15617                 | 0                    | 15617                     | 2144             | 17761           | 49.91         |
| 3                  | 5661        | 285  | 203  | 6149   | 435  | 4530      | 0    | 0     | 5774        | 5470        | -1103                | 15481                 | 0                    | 15481                     | 2019             | 17500           | 49.94         |
| 4                  | 5739        | 285  | 193  | 6217   | 426  | 4506      | 0    | 0     | 5693        | 5779        | -1030                | 15898                 | 0                    | 15898                     | 1935             | 17833           | 50.01         |
| 5                  | 5884        | 500  | 213  | 6597   | 436  | 4713      | 0    | 0     | 5637        | 5832        | -996                 | 16582                 | 0                    | 16582                     | 1901             | 18483           | 49.98         |
| 6                  | 6379        | 615  | 204  | 7198   | 391  | 5180      | 0    | 0     | 5805        | 6020        | -1025                | 17764                 | 0                    | 17764                     | 1973             | 19737           | 49.99         |
| 7                  | 6430        | 756  | 204  | 7390   | 386  | 5238      | 0    | 11    | 6163        | 6029        | -961                 | 18093                 | 0                    | 18093                     | 2035             | 20128           | 50.01         |
| 8                  | 6143        | 515  | 205  | 6863   | 302  | 5279      | 0    | 164   | 6289        | 6193        | -889                 | 17912                 | 0                    | 17912                     | 2061             | 19973           | 50.03         |
| 9                  | 5456        | 389  | 202  | 6047   | 287  | 4866      | 0    | 442   | 6253        | 6161        | -1077                | 16726                 | 0                    | 16726                     | 2130             | 18856           | 50.01         |
| 10                 | 5142        | 640  | 201  | 5983   | 329  | 4599      | 0    | 693   | 6494        | 6549        | -1174                | 16979                 | 0                    | 16979                     | 2205             | 19184           | 50.01         |
| 11                 | 5304        | 541  | 199  | 6044   | 401  | 4599      | 0    | 877   | 6994        | 7054        | -1208                | 17767                 | 0                    | 17767                     | 2291             | 20058           | 50.03         |
| 12                 | 5389        | 341  | 197  | 5927   | 422  | 4543      | 0    | 976   | 7265        | 6979        | -1272                | 17575                 | 0                    | 17575                     | 2323             | 19898           | 50.00         |
| 13                 | 5499        | 262  | 206  | 5967   | 419  | 4491      | 0    | 902   | 6986        | 6945        | -1244                | 17480                 | 0                    | 17480                     | 2323             | 19803           | 50.00         |
| 14                 | 5707        | 265  | 196  | 6168   | 363  | 4799      | 0    | 793   | 6565        | 6649        | -1242                | 17530                 | 0                    | 17530                     | 2297             | 19827           | 50.07         |
| 15                 | 5753        | 260  | 186  | 6199   | 335  | 4904      | 0    | 733   | 6558        | 6642        | -1228                | 17585                 | 0                    | 17585                     | 2286             | 19871           | 50.03         |
| 16                 | 5795        | 263  | 195  | 6253   | 323  | 4929      | 0    | 521   | 6621        | 6224        | -1177                | 17073                 | 0                    | 17073                     | 2275             | 19348           | 49.92         |
| 17                 | 5715        | 241  | 207  | 6163   | 310  | 4778      | 0    | 222   | 6242        | 5668        | -1113                | 16028                 | 0                    | 16028                     | 2237             | 18265           | 50.03         |
| 18                 | 5429        | 246  | 189  | 5864   | 340  | 4648      | 0    | 35    | 5618        | 5327        | -1119                | 15095                 | 0                    | 15095                     | 2258             | 17353           | 50.08         |
| 19                 | 5472        | 296  | 240  | 6008   | 355  | 4641      | 0    | 1     | 5415        | 5265        | -1213                | 15057                 | 0                    | 15057                     | 2482             | 17539           | 50.13         |
| 20                 | 5192        | 297  | 231  | 5720   | 458  | 4540      | 0    | 0     | 5373        | 5024        | -1177                | 14565                 | 0                    | 14565                     | 2482             | 17047           | 50.05         |
| 21                 | 4771        | 322  | 241  | 5334   | 508  | 4395      | 0    | 0     | 5117        | 4803        | -1104                | 13936                 | 0                    | 13936                     | 2416             | 16352           | 49.99         |
| 22                 | 4762        | 328  | 242  | 5332   | 427  | 4413      | 0    | 0     | 4797        | 4791        | -1136                | 13827                 | 0                    | 13827                     | 2371             | 16198           | 49.93         |
| 23                 | 4715        | 242  | 213  | 5170   | 470  | 4342      | 0    | 0     | 4880        | 4872        | -1237                | 13617                 | 0                    | 13617                     | 2355             | 15972           | 50.02         |
| 24                 | 4650        | 250  | 204  | 5104   | 485  | 4253      | 0    | 0     | 4853        | 5046        | -1317                | 13571                 | 0                    | 13571                     | 2346             | 15917           | 50.00         |
| MUs                | 131.64      | 8.79 | 4.98 | 145.41 | 9.48 | 112.27    | 0.00 | 6.37  | 143.22      | 141.03      | -27.46               | 387.10                | 0.00                 | 387.10                    | 53.45            | 440.55          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 04/Nov/2021**

**Position as on 6.30 Hrs of 05/Nov/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                       | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                        |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 04/09/2021   | 23.58        |            | Continued. | Annual Overhaul                                                                        |               |
| MSPGCL                | Chandrapur Unit 6       | 500      | 17/10/2021   | 18.40        |            | Continued. | Boiler Tripped On Total Air Flow less than 30%.(Converted to AOH 00:00 hrs 18.10.2021) |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                        |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                   |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                   |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                 |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                                  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                                          |               |
| MSPGCL                | Nasik Unit 3            | 210      | 30/08/2021   | 22.51        |            | Continued. | Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021            |               |
| IPP                   | JSW (J) U1              | 300      | 02/09/2021   | 08.41        |            | Continued. | Turbine vibrations high.                                                               |               |
| MSPGCL                | Uran Unit A0            | 120      | 10/09/2021   | 01.54        |            | Continued. | Turbine bearing Vabration high                                                         |               |
| IPP                   | RPL(AMT) U-2            | 270      | 29/09/2021   | 01.15        |            | Continued. | Coal Shortage                                                                          |               |
| IPP                   | RPL(AMT) U-1            | 270      | 05/10/2021   | 22.15        |            | Continued. | Coal Shortage                                                                          |               |
| IPP                   | JSW (J) U4              | 300      | 22/10/2021   | 21.45        |            | Continued. | Due to no schedule.                                                                    |               |
| MSPGCL                | Paras Unit 3            | 250      | 27/10/2021   | 19.05        |            | Continued. | Air heater problem                                                                     |               |
| IPP                   | SWPGPL U-4              | 135      | 28/10/2021   | 20.18        | 04/11/2021 | 00.49      | Bearing vibration high                                                                 |               |
| MSPGCL                | Uran Unit 5             | 108      | 02/11/2021   | 00.21        | 05/11/2021 | 08.01      | Gas shortage                                                                           |               |
| MSPGCL                | Nasik Unit 4            | 210      | 03/11/2021   | 21.02        |            | Continued. | Zero Schedule By MSEDCL                                                                |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 04/11/2021   | 06.33        | 04/11/2021 | 18.25      | Turbine Overspeed                                                                      |               |
| MSPGCL                | Parli Unit 6            | 250      | 04/11/2021   | 16.50        |            | Continued. | Zero schedule                                                                          |               |
| MSPGCL                | Uran Unit 6             | 108      | 05/11/2021   | 07.56        |            | Continued. | Gas shortage                                                                           |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 04/Nov/2021**

**Statement-VII**

Position as on 6.30 Hrs of 05/Nov/2021

| Name of Line                            | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                 |
|-----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                  |
| Karad Solapur (PG)                      | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                                         |
| Khadka-Aurangabad (Waluj)               | IntraState                | 11/10/2021   | 12.33        |            | Continued. | PO          | Height raising/shifting work of S/C 400kV Waluj- Bhusawal line for Samruddhi Mahamarg. ie. 1) Dismantling of loc no. 125 (D+6), 126 (D+6).       |
| Karad - Jaigad - II                     | IntraState                | 03/11/2021   | 20.35        |            | Continued. | HT          | Over Voltage                                                                                                                                     |
| Lonikand I - Koyna stage-IV             | IntraState                | 04/11/2021   | 21.31        | 05/11/2021 | 07.23      | HT          | Over Voltage                                                                                                                                     |
| Lonikand I - Koyna stage-IV             | IntraState                | 05/11/2021   | 20.56        |            | Continued. | HT          | Over Voltage                                                                                                                                     |
| <b>220 KV LINE Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                  |
| Mudshingi Chikodi                       | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                                                      |
| Talandage - Chikodi                     | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                                           |
| Solapur(PG)- Jeur                       | InterState                | 03/11/2021   | 19.41        | 04/11/2021 | 06.42      | T           | Distance Protection                                                                                                                              |
| Mahalakshmi Amona                       | InterState                | 05/11/2021   | 15.46        | 05/11/2021 | 18.00      | T           | Distance Protection                                                                                                                              |
| Padegaon-Sawangi                        | IntraState                | 29/10/2021   | 08.23        | 04/11/2021 | 15.30      | PO          | Height raising at 1st crossing form LOC no.38 to LOC no41 & 2nd crossing form LOC no.22 to 23 for samruddhi mahamarg crossing (ORC) packing NME. |
| Oni Kharepatan Line                     | IntraState                | 04/11/2021   | 15.01        | 04/11/2021 | 16.16      | T           | Backup protection operated                                                                                                                       |
| Adlabs - Pedambe                        | IntraState                | 04/11/2021   | 17.53        | 05/11/2021 | 13.15      | T           | Distance Protection                                                                                                                              |
| Dasturi-Kandalgaon Line                 | IntraState                | 04/11/2021   | 17.55        | 05/11/2021 | 15.17      | T           | Distance Protection                                                                                                                              |
| Jejuri (400 Kv)- Baramati li            | IntraState                | 04/11/2021   | 19.57        | 05/11/2021 | 05.41      | T           | Coupling capacitor burst R-ph                                                                                                                    |
| Ranjangaon-Fiat 2                       | IntraState                | 05/11/2021   | 06.46        | 05/11/2021 | 17.55      | PO          | Annual Maintenance Work                                                                                                                          |
| Ranjangaon-Fiat 1                       | IntraState                | 05/11/2021   | 06.46        | 05/11/2021 | 17.55      | PO          | Annual Maintenance Work                                                                                                                          |
| <b>220 KV ICT Outages/Trippings</b>     |                           |              |              |            |            |             |                                                                                                                                                  |
| 220/132 kV 200 Mva ICT-II @Boisar -li   | IntraState                | 04/11/2021   | 09.38        | 04/11/2021 | 12.45      | EO          | Attending Hot Spot                                                                                                                               |
| 220/132 Kv 200 Mva Cgl lct 1 @Boisar-li | IntraState                | 04/11/2021   | 13.58        | 04/11/2021 | 17.47      | EO          | Attending Hot Spot                                                                                                                               |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage