

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 04/Dec/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.101	608.951	1) Gujrat	-5.371	-23.171
2) Hydro	6.920	37.078	2) Madhya Pradesh	-0.579	-3.327
3) Gas	5.588	22.383	3) Chattisgarh	3.910	18.400
Total MSPGCL	163.609	668.412	4) Maharashtra	161.221	647.326
B) 1) APML	72.651	290.177	5) Goa (Amona)	-1.062	-4.866
2) JSWEL	13.666	46.290	Total	158.119	634.362
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.762	105.930
4) RPL(AMT)	31.119	124.611	b) Mumbai Drawl	26.327	125.908
5) SWPGPL	7.453	31.399	c) MSEDCL Bilateral *	57.307	225.204
6) Other IPP	46.030	174.955	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.762	105.930
C) 1) TPCL Thermal	12.770	41.810	Include PX	0.000	0.000
2) TPCL Hydro	2.013	12.710	Standby	0.000	0.000
3) TPCL Gas	1.710	6.772	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.895	39.857	1) MSEDCL	471.096	1871.750
D) STATE			2) Mumbai Discoms	53.714	227.056
1) Thermal	345.685	1358.050	3) Other Discoms	9.157	37.619
(A1+C1+C4+(B1-B6))			TOTAL STATE	533.967	2136.425
2) Hydro	8.933	49.788			
(A2+C2)					
3) Gas	7.298	29.155			
(A3+B7+C3)					
4) Wind	4.573	22.645			
6) SOLAR	9.360	42.426			
TOTAL STATE	375.849	1502.064			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	6925	6860	6491	5439
MSPGCL Hydro	608	519	279	197
MSPGCL Gas	231	229	228	234
MSPGCL Total Generation	7764	7608	6998	5870
Central Sector Receipt	7791	7445	6859	5621
WIND	187	76	183	310
CPP / IPP Thermal	7228	7218	7248	6782
CPP / IPP Gas	0	0	0	0
SOLAR	1370	1522	1	0
Exchange with Mumbai	-1168	-1354	-1256	-1385
MSEDCL DEMAND MET	22754	22116	19624	16816
Load Shedding	0	0	0	0
MSEDCL DEMAND	22754	22116	19624	16816
TPCL GENERATION	735	612	720	550
AEML GENERATION	500	487	432	342
MUMBAI DEMAND	2403	2453	2408	2277
OTHER DISCOM DEMAND	418	399	409	382
STATE DEMAND MET	25575	24968	22441	19475
STATE DEMAND	25575	24968	22441	19475
Frequency (Hz)	50.02	50.03	50.00	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 06:04 Hrs	49.68 Hz at 08:21 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 04/Dec/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.06	20.29	215	195
Unit 7	0.00	0.00	0	0
Unit 8	13.29	52.14	587	458
Unit 9	12.88	54.12	565	435
Unit 10	13.98	52.71	619	496
Total	45.21	179.25		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.66	37.04	460	275
Unit 5	9.63	38.74	470	275
Total	19.30	75.78		
Parli				
Unit 6	4.10	16.57	227	135
Unit 7	4.07	16.40	238	148
Unit 8	3.72	13.64	179	143
Total	11.89	46.61		
Chandrapur				
Unit 3	3.55	13.66	175	127
Unit 4	3.37	12.97	162	120
Unit 5	7.01	27.78	305	280
Unit 6	6.63	26.70	285	255
Unit 7	0.00	0.00	0	0
Unit 8	5.14	31.83	428	0
Unit 9	10.04	39.67	497	311
Total	35.74	152.62		
Paras				
Unit 3	5.07	20.59	221	180
Unit 4	5.22	20.68	236	179
Total	10.30	41.26		
Khaparkheda				
Unit 1	2.88	10.76	135	105
Unit 2	2.80	11.14	130	100
Unit 3	3.76	14.31	178	128
Unit 4	3.04	13.04	137	120
Unit 5	9.86	39.74	450	280
Total	22.33	89.00		
Nasik				
Unit 3	3.23	13.32	160	116
Unit 4	3.10	11.11	156	117
Unit 5	0.00	0.00	0	0
Total	6.33	24.42		
Uran				
All Units	5.59	22.38	241	222
Total	5.59	22.38		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	0.49	19	0
Total	0.03	0.49		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.58	9.89	440	35
Stage 4	0.22	9.00	185	0
Stage 3	0.51	4.02	80	0
Total	3.31	22.90		
Hydro				
KDPH	0.43	1.73	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.52	2.09	58	0
BHIRA T.R.	0.14	0.64	40	0
SMLHY_PTN	2.34	8.14	100	95
GHATGHAR	0.15	1.09	116	0
Total	3.58	13.68		
Wind				
Total	4.57	22.64	0	0
Total	4.57	22.64		
CPP				
APML(Mus)	72.65	290.18	0	0
JSWEL(Mus)	13.67	46.29	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.12	124.61	0	0
SWPGPL-Mus	7.45	31.40	0	0
Other(Mus)	46.03	174.96	0	0
Total	170.92	667.43		
SOLAR				
Total	9.36	42.43	0	0
Total	9.36	42.43		
Tata				
Trombay 5	8.83	27.55	469	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.91	3.61	40	36
Trombay 7B	0.80	3.16	34	32
TATA Hydro	2.01	12.71	282	10
Trombay 8	3.94	14.26	232	129
Total	16.49	61.29		
AEML				
DTPS U-1&2	10.90	39.86	501	342
Total	10.90	39.86		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.10	608.95	MSPGCL Total	163.61	668.41
			MSPGCL Thml+Gas	156.69	631.33	Koyna 1,2 & 4 Total	2.80	18.89
			MSPGCL Hydro	6.92	37.08	State Total	375.85	1502.06

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 04/Dec/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5504	295	237	6036	177	6547	0	0	5923	5820	-826	17400	0	17400	2145	354	19899	49.94
2	5862	196	240	6298	148	6791	0	0	5917	5623	-785	17735	0	17735	2080	340	20155	50.00
3	5987	149	239	6375	149	6961	0	0	5920	5480	-750	17891	0	17891	2040	324	20255	50.04
4	5969	148	240	6357	196	6775	0	0	5931	5748	-709	18063	0	18063	2011	304	20378	50.02
5	6321	151	239	6711	180	7095	0	0	5961	5705	-697	18688	0	18688	1986	306	20980	50.05
6	6426	151	238	6815	208	7241	0	0	6531	6181	-724	19378	0	19378	2019	343	21740	50.04
7	6438	152	241	6831	306	7260	0	8	6767	6450	-741	19746	0	19746	2040	368	22154	50.04
8	6848	153	240	7241	289	7226	0	175	6481	6335	-757	20123	0	20123	2061	386	22570	49.92
9	6715	191	241	7147	294	7290	0	547	6887	6883	-876	20884	0	20884	2103	401	23388	49.85
10	6875	632	234	7741	258	7243	0	1018	6628	7063	-1015	21905	0	21905	2267	403	24575	49.95
11	6925	608	231	7764	187	7228	0	1370	7794	7791	-1168	22754	0	22754	2403	418	25575	50.02
12	6658	397	228	7283	123	7152	0	1508	8048	8171	-1297	22548	0	22548	2462	392	25402	50.04
13	6860	519	229	7608	76	7218	0	1522	7462	7445	-1354	22116	0	22116	2453	399	24968	50.03
14	6722	294	225	7241	67	7235	0	1297	7639	8058	-1523	21991	0	21991	2378	384	24753	50.04
15	6467	453	223	7143	77	7262	0	986	7873	8248	-1494	21823	0	21823	2364	399	24586	50.01
16	6566	434	223	7223	70	7283	0	596	7882	8064	-1414	21414	0	21414	2326	408	24148	50.04
17	6473	236	222	6931	94	7240	0	295	7559	7392	-1335	20208	0	20208	2281	409	22898	49.98
18	6475	323	228	7026	130	7248	0	37	6946	6784	-1194	19622	0	19622	2284	409	22315	50.02
19	6491	279	228	6998	183	7248	0	1	7088	6859	-1256	19624	0	19624	2408	409	22441	50.00
20	6487	428	228	7143	206	7374	0	0	5928	5664	-1197	18777	0	18777	2399	413	21589	49.92
21	5838	150	231	6219	286	7292	0	0	5691	5238	-1204	17421	0	17421	2376	410	20207	50.02
22	5208	226	232	5666	304	6964	0	0	5770	5809	-1288	17060	0	17060	2331	395	19786	50.01
23	5439	197	234	5870	310	6782	0	0	5835	5621	-1385	16816	0	16816	2277	382	19475	50.01
24	5547	158	237	5942	255	6964	0	0	5759	5687	-1338	17108	0	17108	2221	402	19731	50.05
MUs	151.10	6.92	5.59	163.61	4.57	170.92	0.00	9.36	160.22	158.12	-26.33	471.10	0.00	471.10	53.72	9.16	533.97	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 04/Dec/2022

Position as on 6.30 Hrs of 05/Dec/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	Zero Schedule.	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.(unit out due to coal shortage from 15.11.2022)	07/12/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	UNIT IS READY(UNIT UNDER TOLLING from 20.11.2022)	07/12/2022
MSPGCL	Koyna Unit 4	70	28/11/2022	10:20		Continued.	Due to Injector No 1 Coller ring Broken.	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/12/2022
MSPGCL	Chandrapur Unit 8	500	04/12/2022	14:12		Continued.	CONDENSER TUBE LEAKAGE (SILICA ON HIGHER SIDE)	07/12/2022
IPP	RPL(AMT) U-3	270	05/12/2022	12:00		Continued.	Coal Shortage	08/12/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 05/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (412) OF KARJAT CKT - 1 @ LONIKAND 2	IntraState	04/12/2022	09:38	04/12/2022	15:17	PO	Diagnostic testing and Maintenance
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY - 406 OF FUTURE BAY @ AKOLA 2	IntraState	05/12/2022	10:14	05/12/2022	18:39	PO	Annual Maintenance of Bay Equipment
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
KHADKA-AURANGABAD (WALUJ)	IntraState	03/12/2022	21:48	04/12/2022	07:08	HT	Line loading control
KHARGHAR - TALEGAON (PG)	IntraState	03/12/2022	23:54			PO	For Tapping of 400KV Kalwa-Padgha-2 Line on KHARGHAR - TALEGAON (PG) so as to form temporary 400KV Kalwa-Kharghar -Talegaon Line for replacement of existing conductor by HTLS conductor of 400KV Kalwa-Padgha-2 line.
PADGHE - KALWA CKT - 2	IntraState	03/12/2022	23:54	04/12/2022	07:15	PO	For Tapping of 400KV PADGHE - KALWA CKT - 2 line on 400KV Kharghar-Talegaon Line to form Temporary 400KV Kalwa-Kharghar-Talegaon line for carrying out HTLS work on 400KV Kalwa-Padgha-2 line (dead portion after tapping)
JEJURI- KOYNA STAGE-IV	IntraState	04/12/2022	11:35	04/12/2022	18:28	PO	PID Faulty disc insulator replacement work & Cold & Chemical line washing work
KARAD - TALANDGE CKT - 1	IntraState	05/12/2022	10:17	05/12/2022	17:00	PO	PID Faulty disc insulator replacement work & Cold line washing work
NAGOTHANE - DABHOL CKT - 1	IntraState	05/12/2022	12:31	05/12/2022	18:43	PO	Cold washing work
JAIGAD - KARAD CKT - 2	IntraState	05/12/2022	20:03		Continued.	HT	H/T for Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 1 @ NAGOTHANE	IntraState	03/12/2022	09:20			PO	FOR CB replacemnt work
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	03/12/2022	16:08	04/12/2022	05:02	PO	Renovation of cooling system and replacement of Auxiliary protection and oil filtration and chemical washing of equipment Bay maintenance and diagnostic work
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	05/12/2022	09:45		Continued.	PO	(1) C & Tan D measurement of ICT Units. (2) Bay maintenance work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
AAREY - MSETCL BORIVALI CKT - 1	IntraState	24/11/2022	17:39		Continued.	T	Tripped on Differential protection
KALWA SALSETTE - 3	IntraState	01/12/2022	22:23			EO	Interchanging of BUS of 220KV Kalwa-Salshette-3 & 220KV Kalwa-Salshette-4 to free 220 kv TBC. 220 kv Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 04/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 05/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA SALSETTE - 4	IntraState	01/12/2022	22:42			EO	Interchanging of BUS of 220 kV Kalwa-Salsette-3 & 220 kV Kalwa-Salsette-4 to free 220 kV TBC. 220 kV Kalwa Salsette 3 line on TBC from 12.11.2022 due to 29 A Bus damaged isolator.
BIDRI - SAWANTWADI	IntraState	04/12/2022	05:14	04/12/2022	05:35	T	Tripped on Distance protection
PADGHE - JAMBHUL 1	IntraState	04/12/2022	08:32	04/12/2022	10:26	PO	Work of Shifting / Height raising of various EHV (220KV) transmission lines infringing in Samruddhi Highway crossing Stringing - 4 Spans Removal of Tower - 1Nos OPGW shifting - 2 Spans
CHINCHWAD-2 - TELCO	IntraState	04/12/2022	09:26	04/12/2022	16:19	PO	1) Stringing of top 4 conductors on 220 kV Chinchwad-Telco Line, Monopole towers- 19-20 on dtd: 02.12.2022. 2) Stringing of top 4 conductors on 220 kV Chinchwad- Telco Line, Monopole towers- 16A-17 on dtd: 03.12.2022. 3)Stringing of top 4 conductors on 220 kV Chinchwad- Telco Line, Monopole towers- 18-19 on dtd:04.12.2022
KALWA SALSETTE - 4	IntraState	04/12/2022	14:14	04/12/2022	16:24	EO	Attending Hot spot at GIS bushing terminal jumper Bph at Salsette R/S
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	04/12/2022	15:58	04/12/2022	18:49	T	Distance Protection
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	05/12/2022	09:22	05/12/2022	15:58	PO	M 2 maintenance of GIS bay by M/s GE & Biannual relay testing work by Testing team
TALANDGE - ICHALKARANJI 1	IntraState	05/12/2022	09:41	05/12/2022	18:21	PO	1) For cleaning of insulator strings by using high voltage insulator cleaner & protector (Chemical Cleaning) at Multi-circuit Tower Locations 40 to 44 2) Replacement of insulator strings found critical in P.I.D
TALANDGE - ICHALKARANJI 2	IntraState	05/12/2022	09:42	05/12/2022	18:21	PO	1) For cleaning of insulator strings by using high voltage insulator cleaner & protector (Chemical Cleaning) at Multi-circuit Tower Locations 40 to 44 2) Replacement of insulator strings found critical in P.I.D
MAIN BUS @ TILWANI	IntraState	05/12/2022	09:43	05/12/2022	18:20	PO	1) Quarterly maintenance of 220 kV PT and all 220 KV Main Bus isolators of all line & T/F bays. 2)Hot spot attending work 3) Insulator string replacement work
CHINCHWAD-2 - TELCO	IntraState	05/12/2022	10:55	05/12/2022	14:18	PO	Stringing of top 4 conductors on 220 kV Chinchwad-Telco Line, Monopole towers- 19-20
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	05/12/2022	13:37	05/12/2022	15:49	T	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	05/12/2022	13:37	05/12/2022	15:13	T	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 04/Dec/2022

Statement-VII

Position as on 6.30 Hrs of 05/Dec/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
HALKARNI-MAHALAXMI LINE	IntraState	05/12/2022	17:04	05/12/2022	19:40	PO	Protection Relay Testing and Diagnostic Testing work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	04/12/2022	08:42	04/12/2022	17:36	PO	1) 220kV Padghe Line & 220kV Bus Sectionaliser Bay Isolators Gear Box Replacement & Isolators Maintenance works. 2) Diagnostic Testing of 220kV Padghe Bay & 220kV Bus Sectionaliser Bay 3) Attending hotspot on 220 kV Bus Section-1
220/22 KV 50 MVA PTR 2 @ LONIKAND	IntraState	05/12/2022	09:43	05/12/2022	17:43	PO	220/22kV,50MVA PTR No-2, 29A Bus Isolator alignment work by shifting PTR No.2 on 220kV T.B.C. bay.
132 KV LINE Outages/Trippings							
EKL(OCR) -TAKALI	IntraState	05/12/2022	13:42	05/12/2022	14:23	T	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.
EKL(GCR)-SINNAR	IntraState	05/12/2022	13:42	05/12/2022	14:34	HT	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.
132 KV ICT Outages/Trippings							
132/33 KV 50 MVA PTR 3	IntraState	05/12/2022	13:42	05/12/2022	14:16	T	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.
132/33 KV 50 MVA PTR 1	IntraState	05/12/2022	13:42	05/12/2022	14:15	T	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.
132/33 KV 50 MVA PTR 2	IntraState	05/12/2022	13:42	05/12/2022	14:16	T	At 220kV OCR EKLAHARE S/STN,220Kv Busbar Trip relay (Only 96 of all 220kV Busbar feeders)operated.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage