

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Mar/2016 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	98.679	497.714	1) Gujrat	-2.958	-17.858
2) Hydro	6.557	31.635	2) Madhya Pradesh	10.605	52.560
3) Gas	10.910	51.469	3) Chattisgarh	5.650	31.630
Total MSPGCL	116.146	580.818	4) Maharashtra Net	86.082	423.317
B) 1) APML	65.567	312.681	5) Goa (Amona)	-0.920	-3.394
2) JSWEL	22.695	112.576	6) TAPS 1&2 Injection	3.563	17.962
3) VIPL	12.531	56.462	7) RGPPL Injection	11.607	57.622
4) RPL(AMT)	17.125	75.604	8) Pench (MS)	0.027	0.382
5) WPCL	2.529	17.054	9) Pench (Excess)	-0.027	-0.382
6) Other IPP	8.668	42.679	Total	113.602	561.457
C) 1) TPCL Thermal	12.881	53.612	a) Mumbai Schedule	21.075	100.393
2) TPCL Hydro	2.202	18.253	b) Mumbai Drawl	24.849	141.939
3) TPCL Gas	4.099	20.303	c) MSEDCL Bilateral *	19.640	128.788
4) R-INFRA Thermal	11.337	54.560	Include PX	-7.350	-10.672
D) STATE			d) Mumbai Bilateral *	21.075	100.393
1) Thermal	252.012	1222.942	Include PX	2.923	17.428
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	8.759	49.888	H) ENERGY CATERED (MUs)		
3) Gas	15.009	71.772	1) MSEDCL	340.966	1656.924
4) Wind	5.731	33.898	2) Mumbai Discoms	55.368	288.667
6) SOLAR	1.221	5.634	TOTAL STATE	396.334	1945.591
TOTAL STATE	282.732	1384.134			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4372	4255	4076	3842
MSPGCL Hydro	601	414	609	112
MSPGCL Gas	454	427	459	463
MSPGCL Total Generation	5427	5096	5144	4417
Central Sector Receipt	5500	5322	4674	3795
WIND	74	27	449	207
CPP / IPP	5557	5644	5706	4899
SOLAR	165	195	0	0
Exchange with Mumbai	-1163	-1216	-1062	-912
MSEDCL DEMAND MET	15560	15068	14911	12406
Load Shedding	4	4	5	4
MSEDCL DEMAND	15564	15072	14916	12410
TPCL GENERATION	1053	1030	1029	465
R-INFRA GENERATION	516	515	517	403
MUMBAI DEMAND	2732	2761	2608	1780
STATE DEMAND MET	18292	17829	17519	14186
STATE DEMAND	18296	17833	17524	14190
Frequency (Hz)	49.95	49.99	50.01	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.2 Hz at 18:17 Hrs	49.8 Hz at 00:04 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 05/Mar/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	4.01	0	0
Unit 8	8.00	42.20	350	330
Total	8.00	46.22		
Bhusawal				
Unit 2	0.00	1.70	0	0
Unit 3	3.98	19.14	170	160
Unit 4	0.00	0.00	0	0
Unit 5	9.96	45.04	510	345
Total	13.94	65.87		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	4.52	21.55	204	168
Unit 4	4.41	21.24	196	160
Unit 5	9.12	46.61	410	340
Unit 6	3.90	40.63	415	0
Unit 7	9.60	46.84	436	360
Total	31.54	176.87		
Paras				
Unit 3	5.65	15.70	254	192
Unit 4	0.00	5.35	0	0
Total	5.65	21.06		
Khaparkheda				
Unit 1	4.04	19.52	180	160
Unit 2	4.08	19.88	185	160
Unit 3	2.93	15.64	200	0
Unit 4	4.45	20.42	207	159
Unit 5	11.07	51.49	510	365
Total	26.57	126.95		
Nasik				
Unit 3	4.24	20.15	200	160
Unit 4	4.17	19.32	192	162
Unit 5	4.25	19.98	198	158
Total	12.66	59.45		
Uran				
All Units	10.91	51.47	489	427
Total	10.91	51.47		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.03	0.38	20	0
Total	0.03	0.38		
Koyna				
Stage 1-2	3.26	13.38	375	40
Stage 4	0.49	4.36	200	0
Stage 3	1.05	3.54	160	0
Total	4.80	21.28		
Hydro				
KDPH	0.00	2.09	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.19	0.75	62	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.28	1.30	40	0
RNGR+BHTSA	0.21	0.82	11	0
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	1.08	5.39	46	45
GHATGHAR	0.00	0.00	0	0
Total	1.76	10.35		
Wind				
Total	5.73	33.90	0	0
Total	5.73	33.90		
CPP				
APML(Mus)	65.57	312.68	0	0
JSWEL(Mus)	22.70	112.58	0	0
VIPL(Mus)	12.53	56.46	0	0
RPLAMT(Mus)	17.12	75.60	0	0
WPCL(Mus)	2.53	17.05	0	0
Other(Mus)	8.67	42.68	0	0
Total	129.12	617.06		
SOLAR				
Total	1.22	5.63	0	0
Total	1.22	5.63		
Tata				
Trombay 5	9.55	45.95	493	315
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.55	12.59	114	89
Trombay 7B	1.55	7.71	67	59
Trombay 8	3.33	7.67	242	0
TATA Hydro	2.20	18.25	238	0
Total	19.18	92.17		
R-INFRA				
1-2	11.34	54.56	519	402
Total	11.34	54.56		

Infirm Power	Chandrapur 8	0.00	Koradi 9	0.32
---------------------	--------------	------	----------	------

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	98.68	497.71
MSPGCL Thml+Gas	109.59	549.18

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	6.56	31.64
MSPGCL Total	116.15	580.82

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	3.75	17.74
State Total	282.73	1384.13

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Mar/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	3836	222	471	4529	138	4936	0	4520	4598	-1153	13048	5	13053	2065	15118	49.94
2	3881	152	462	4495	145	4963	0	4290	4269	-1024	12848	4	12852	1896	14748	49.95
3	3842	112	463	4417	207	4899	0	4213	3795	-912	12406	4	12410	1780	14190	49.97
4	3821	96	462	4379	243	4765	0	4161	4179	-843	12723	4	12727	1711	14438	49.94
5	3799	96	460	4355	256	4863	0	4283	4108	-823	12759	4	12763	1690	14453	49.96
6	3798	136	466	4400	253	4948	0	4579	4675	-925	13351	4	13355	1792	15147	49.93
7	4072	445	489	5006	224	5125	0	4992	4917	-928	14344	4	14348	1865	16213	49.96
8	4412	206	467	5085	121	5456	14	5116	5099	-802	14973	4	14977	2006	16983	49.99
9	4604	274	459	5337	68	5546	73	5213	5151	-845	15330	4	15334	2143	17477	50.00
10	4652	358	446	5456	71	5559	131	5250	4862	-1039	15040	4	15044	2460	17504	50.00
11	4372	601	454	5427	74	5557	165	5336	5500	-1163	15560	4	15564	2732	18296	49.95
12	4239	765	445	5449	57	5555	175	5384	5387	-1196	15427	4	15431	2764	18195	49.94
13	4255	414	427	5096	27	5644	195	5127	5322	-1216	15068	4	15072	2761	17833	49.99
14	4272	240	427	4939	42	5675	146	5049	5063	-1150	14715	5	14720	2653	17373	50.00
15	4264	164	427	4855	90	5671	146	5066	5202	-1137	14827	5	14832	2691	17523	49.96
16	4277	170	453	4900	181	5666	89	5055	5409	-1109	15136	5	15141	2687	17828	49.97
17	4206	190	450	4846	372	5676	63	4905	4828	-1139	14646	5	14651	2659	17310	49.99
18	4106	110	440	4656	452	5691	24	3929	3939	-985	13777	5	13782	2558	16340	49.99
19	4030	206	438	4674	415	5686	0	3782	3828	-1008	13595	5	13600	2507	16107	50.03
20	4076	609	459	5144	449	5706	0	4618	4674	-1062	14911	5	14916	2608	17524	50.01
21	4105	171	465	4741	546	5562	0	4720	4915	-1066	14698	5	14703	2564	17267	50.04
22	3862	165	455	4482	465	5408	0	4535	4646	-1196	13805	5	13810	2426	16236	50.00
23	3872	420	468	4760	405	5234	0	4390	4711	-1117	13993	5	13998	2238	16236	49.98
24	4026	235	457	4718	430	5325	0	4270	4525	-1011	13987	5	13992	2112	16104	50.02
MUs	98.68	6.56	10.91	116.15	5.73	129.12	1.22	112.78	113.60	-24.85	340.97	0.11	341.07	55.37	396.44	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 05/Mar/2016

Position as on 6.30 Hrs of 06/Mar/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(Converted to AOH for 30 Days from 00.00Hrs 06-03-2016)	
CENT.SECTOR	Tarapur 2	160	10/09/2015	12.55		Continued.	Refuelling work	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Water Shortage	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
MSPGCL	Chandrapur Unit-8	500	10/11/2015	12.10		Continued.	Drum level low	
RGPPL	Dabhol 3B	230	07/01/2016	17:51		Continued.	Change Over.	
MSPGCL	Chandrapur Unit 2	210	12/01/2016	04.47		Continued.	Boiler Tube Leakage	
RGPPL	Dabhol 3X	290	03/02/2016	15:36		Continued.	Change Over	
MSPGCL	Ghatghar Unit-2	125	09/02/2016	18.00		Continued.	oil filtration work.	
MSPGCL	Bhusawal Unit 4	500	14/02/2016	12.10		Continued.	Zero Schedule Given by MSEDCL.	
MSPGCL	Ghatghar Unit-1	125	15/02/2016	00.00		Continued.	Attending Water valve Leakage.	
IPP	RPL(AMT) U-2	270	16/02/2016	01.14		Continued.	Due to Zero Schedule Given by MSEDCL.	
IPP	RPL(AMT) U-3	270	16/02/2016	01.17		Continued.	Due to Zero Schedule Given by MSEDCL.	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	Change Over , No Schedule	
MSPGCL	Koradi Unit 5	200	18/02/2016	11.21		Continued.	MSEDCL Zero Shedule.	
IPP	WPCL U-2	135	29/02/2016	21.46		Continued.	Change over against Unit III	
MSPGCL	Bhusawal Unit 2	210	01/03/2016	10.13	06/03/2016	00.00	Boiler Tube Leakage	
MSPGCL	Koradi Unit 7	210	01/03/2016	23.55		Continued.	Zero Schedule Given by MSEDCL.	
IPP	JSW (J) U3	300	02/03/2016	13.45	05/03/2016	10.11	Cooling Water Leakage.	
MSPGCL	Paras Unit 4	250	02/03/2016	22.50		Continued.	Air heater problem	
CPP	WPCL U-4	135	03/03/2016	00.01		Continued.	ESP BACK FILTER	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Mar/2016

Position as on 6.30 Hrs of 06/Mar/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							MAINTENANCE. WORK.	
TPC_G	Trombay 8	250	03/03/2016	20.25	05/03/2016	07.07	main steam line leakage	
MSPGCL	Khaparkheda Unit 3	210	04/03/2016	05.10	05/03/2016	07.22	Boiler Tube Leakage	
MSPGCL	Uran Unit 8	108	04/03/2016	22.55		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 6	500	05/03/2016	10.15		Continued.	Turbine bearing Vabration high	
MSPGCL	Bhusawal Unit 3	210	06/03/2016	11.11		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 05/Mar/2016

Statement-VII

Position as on 6.30 Hrs of 06/Mar/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	06/03/2016	20.00	06/03/2016	21.00	HT	Sparking on capacitive Bank at Padghe end
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar I	InterState	04/03/2016	16.14	05/03/2016	07.08	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	04/03/2016	17.09	05/03/2016	06.59	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	05/03/2016	10.30	05/03/2016	19.00	PO	Rejoining of Earth Wire
Akola Wardha li	InterState	05/03/2016	13.27	05/03/2016	21.37	T	Distance Protection
Kolhapur Solapur (PG) II	InterState	05/03/2016	17.45	06/03/2016	06.57	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	05/03/2016	19.05		Continued.	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	06/03/2016	16.52		Continued.	HT	Over Voltage
Akola II - Taptitanda ckt-II	IntraState	31/12/2015	18.16		Continued.	HT	Change over(outage taken on 2/3/2016 at 10.34hrs for commissioning of 765KV Ektuni S/Stn)
Babhaleshwar-Taptitanda ckt-II	IntraState	11/02/2016	18.40		Continued.	HT	CHANGE OVER
Bhusawal-Aurangabad	IntraState	26/02/2016	17.08		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	02/03/2016	16.34		Continued.	HT	Over Voltage
N.Koyna-Karad - Ckt I	IntraState	03/03/2016	12.08	05/03/2016	09.59	PO	Attend hot spot(RFC 14.45/3-3-16)
karad -kolhapur-I	IntraState	03/03/2016	16.32	05/03/2016	10.03	HT	Over Voltage
Padghe - Talegaon (PG)	IntraState	04/03/2016	11.50	05/03/2016	10.09	T	Distance Protection
Lonikand I - Koyna stage-IV	IntraState	04/03/2016	18.11	05/03/2016	09.21	HT	Over Voltage
New Koyna -Koyna Stage IV-I	IntraState	05/03/2016	09.44	05/03/2016	14.44	PO	Routine Maintenance Work
Babhaleshwar - Padghe-I	IntraState	05/03/2016	10.56	05/03/2016	21.32	PO	Insulator Replacement Work
karad -kolhapur-II	IntraState	05/03/2016	16.36		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	05/03/2016	21.54	06/03/2016	09.32	HT	Over Voltage
Babhaleshwar - Padghe-II	IntraState	06/03/2016	08.16	06/03/2016	23.00	PO	Insulator Replacement Work
Lonikand I - Koyna stage-IV	IntraState	06/03/2016	17.41		Continued.	HT	Over Voltage
Padghe - Talegaon (PG)	IntraState	06/03/2016	23.07		Continued.	EO	To attend Hot Spot
400 KV ICT Outages/Trippings							
400/220 Kv 500 Mva Ict 1 @Lamboti	IntraState	05/03/2016	16.36	06/03/2016	22.31	PO	Tertiary bushing replacement (upto 06-03-2016)
400/220 KV 500 MVA ICT- II @Warora	IntraState	05/03/2016	18.34	05/03/2016	21.10	T	NDR Operated
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	05/03/2016	10.21	05/03/2016	12.16	EO	Attending Hot Spot
Badnera - Deoli (PG)	InterState	06/03/2016	17.56	06/03/2016	18.29	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Kalwa - Borivali	IntraState	10/01/2016	09:15		Continued.	PO	Tower Erection Work.
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Padghe - Vasai	IntraState	24/01/2016	08.32		Continued.	PO	For Formation of Temp. Padgha-Borivali (Charge upto 51/1).
Bableshevar- Alephata	IntraState	03/02/2016	06.28		Continued.	HT	controlling bblsr ICT Overloading
Bableshevar- Ranjangaon	IntraState	03/02/2016	07.12		Continued.	HT	To Control BBLSR ICT O/L

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Mar/2016

Statement-VII

Position as on 6.30 Hrs of 06/Mar/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Hingoli- Girawali	IntraState	14/02/2016	12.37		Continued.	HT	To Improve Voltage @ Hingoli.
Khadka-Chalisgaon-1	IntraState	29/02/2016	10:08		Continued.	PO	For Diversion of CKT Which Submerges in Waghur Dam.
Khadka-Chalisgaon-2	IntraState	29/02/2016	10:14		Continued.	PO	For Diversion of CKT Which Submerges in Waghur Dam.
Wadkhal - Ipcl 2	IntraState	04/03/2016	16.45	05/03/2016	19.49	PO	conductor stringing work
Nanded - Parli Ext. Ckt II	IntraState	05/03/2016	07.41	05/03/2016	17.17	PO	Re-orientation work
Koradi-Butibori Rly Tss	IntraState	05/03/2016	09.38	05/03/2016	17.30	PO	Tan Delta Measurment of CTs
Vsnl-512 Khadki	IntraState	05/03/2016	10.00	05/03/2016	14.14	PO	Testing Work
512 Khadki- Century Enka	IntraState	05/03/2016	14.24	05/03/2016	17.44	PO	Testing Work
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	05/03/2016	14.55	05/03/2016	15.14	T	Distance Protection
Talandage(kolh'r)- Sawantwadi II	IntraState	05/03/2016	16.24	05/03/2016	16.33	T	Distance Protection
Hinganghat - Bhugaon	IntraState	05/03/2016	18.28	05/03/2016	18.46	T	Distance Protection
Chakan-Chinchwad	IntraState	05/03/2016	21.09	06/03/2016	05.32	PO	Erection of Narrow Base M/C Tower
Telco- Chinchwad	IntraState	05/03/2016	21.10	06/03/2016	05.33	PO	Erection of Narrow Base M/C Tower
Nanded - Parli Ext. Ckt I	IntraState	06/03/2016	08.35	06/03/2016	17.18	PO	Re-orientation work
Dahanu Ghodbunder Line 2	IntraState	06/03/2016	08.47	06/03/2016	17.41	PO	Replacement of CT Junction Box
Chakan (400kv)-Bridgestone	IntraState	06/03/2016	09.19	06/03/2016	16.50	PO	For removing Bunching arrangement
Talegaon (Ambi)-General Motors	IntraState	06/03/2016	09.30	06/03/2016	13.10	PO	Annual Maintenance Work
Salsette Borivli 1	IntraState	06/03/2016	10.25	06/03/2016	19.44	PO	Testing Work
Pophali - Nerale	IntraState	06/03/2016	15.10	06/03/2016	15.30	T	Distance Protection
Hinganghat - Hinganghat Rly TSS-2	IntraState	06/03/2016	19.41		Continued.	T	O/C, E/F(Trial taken 20.29 Hrs but failed)
Chakan-Chinchwad	IntraState	06/03/2016	20.12		Continued.	PO	Erection of Narrow Base M/C Tower
Telco- Chinchwad	IntraState	06/03/2016	20.15		Continued.	PO	Erection of Narrow Base M/C Tower
Nanded-Ghatodi	IntraState	06/03/2016	22.11	06/03/2016	22.27	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/33kv 100 MVA ICT-II @ Boisar	IntraState	20/02/2016	14.51	05/03/2016	00.17	T	Differential Protn.Optd./Internal Fault,Declared Faulty, replaced by 50MVA.
220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2)	IntraState	05/03/2016	10.38	05/03/2016	17.26	PO	Attending Oil Leakage
220/132 kv 200MVA ICT II @ Girwali	IntraState	05/03/2016	11.49	05/03/2016	13.11	PO	Routine Maintenance Work
132 KV LINE Outages/Trippings							
Hinganghat-Ismt-Ckt1	IntraState	06/03/2016	19.41	06/03/2016	20.45	T	Directional O/C E/F operated

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage