

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/May/2015 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.511	560.867	1) Gujrat	-4.118	-21.388
2) Hydro	31.168	99.311	2) Madhya Pradesh	12.935	64.940
3) Gas	5.128	31.635	3) Chattisgarh	5.550	27.470
Total MSPGCL	144.807	691.813	4) Maharashtra Net	104.112	508.473
B) 1) APLM	47.210	267.180	5) Goa	-7.453	-37.523
2) JSWEL	22.373	119.435	6) TAPS 1&2 Injection	3.599	17.526
3) VIPL	12.391	56.136	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	5.700	28.070	8) Pench (MS)	0.059	0.297
5) WPCL	7.206	40.153	9) Pench (Excess)	-0.059	-0.297
6) Other IPP	5.770	31.336	Total	114.566	559.201
C) 1) TPCL Thermal	17.618	79.497	a) Mumbai Schedule	27.586	125.493
2) TPCL Hydro	5.787	13.879	b) Mumbai Drawl	29.055	133.742
3) TPCL Gas	2.397	14.286	c) MSEDCL Bilateral *	26.184	150.249
4) R-INFRA Thermal	11.829	58.598	Include PX	-0.418	4.710
D) STATE			d) Mumbai Bilateral *	27.586	125.493
1) Thermal	238.608	1241.272	Include PX	1.467	6.783
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	36.955	113.190	H) ENERGY CATERED (MUs)		
3) Gas	7.525	45.921	1) MSEDCL	339.575	1738.596
4) Wind	7.435	72.545	2) Mumbai Discoms	66.688	300.002
6) SOLAR	1.172	6.172	TOTAL STATE	406.263	2038.598
TOTAL STATE	291.695	1479.100			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4284	4707	4488	4380
MSPGCL Hydro	1926	2024	381	868
MSPGCL Gas	173	154	275	272
MSPGCL Total Generation	6383	6885	5144	5520
Central Sector Receipt	5253	5053	4596	4799
WIND	30	310	873	117
CPP / IPP	4259	4534	4466	4085
SOLAR	118	85	0	0
Exchange with Mumbai	-1281	-1481	-1287	-739
MSEDCL DEMAND MET	14762	15386	13792	13782
Load Shedding	558	656	100	64
MSEDCL DEMAND	15320	16042	13892	13846
TPCL GENERATION	1138	1363	1207	828
R-INFRA GENERATION	497	506	518	518
MUMBAI DEMAND	2916	3350	3012	2085
STATE DEMAND MET	17678	18736	16804	15867
STATE DEMAND	18236	19392	16904	15931
Frequency (Hz)	49.88	49.88	49.86	49.88

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 06:02 Hrs	49.51 Hz at 14:45 Hrs	49.88	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation, Maximum, Minimum for 05/May/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	3.60	16.40	160	130
Unit 6	0.00	0.00	0	0
Unit 7	3.58	18.21	170	127
Total	7.19	34.60		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	11.10	51.85	510	365
Unit 5	9.09	48.89	500	265
Total	20.20	100.74		
Parli				
Unit 3	0.00	9.15	0	0
Unit 4	0.00	0.00	0	0
Unit 5	3.44	17.46	149	140
Unit 6	5.42	26.21	250	191
Unit 7	5.19	26.51	250	103
Total	14.05	79.33		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.15	3.38	149	76
Unit 3	4.60	22.33	204	168
Unit 4	3.42	20.13	184	0
Unit 5	0.00	1.63	0	0
Unit 6	0.98	14.38	320	0
Unit 7	9.89	46.80	440	367
Total	22.04	108.64		
Paras				
Unit 3	5.50	26.08	237	222
Unit 4	5.20	26.87	235	181
Total	10.70	52.94		
Khaparkheda				
Unit 1	3.66	20.05	185	115
Unit 2	3.58	18.11	160	125
Unit 3	4.14	20.48	190	160
Unit 4	4.05	21.20	182	144
Unit 5	9.55	54.47	500	300
Total	24.98	134.31		
Nasik				
Unit 3	4.33	22.28	200	85
Unit 4	4.24	21.95	194	75
Unit 5	0.79	6.06	172	0
Total	9.37	50.30		
Uran				
All Units	5.13	31.64	282	20
Total	5.13	31.64		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.06	0.30	20	0
Total	0.06	0.30		
Koyna				
Stage 1-2	7.28	25.43	545	40
Stage 4	14.49	37.96	1120	0
Stage 3	4.92	13.88	320	0
Total	26.69	77.27		
Hydro				
KDPH	0.84	2.82	35	34
VTRNA	0.89	4.53	61	0
TILLARI	0.37	1.85	64	0
BHTGR/VEER	0.06	0.34	3	2
BHIRA T.R.	0.20	0.45	40	0
RNGR+BHTSA	0.26	1.07	11	10
BHANDARDRA	0.37	2.02	16	15
ELDARY	0.02	0.02	6	0
SMLHY_PTN	0.72	4.17	37	27
GHATGHAR	0.74	4.78	240	0
Total	4.48	22.04		
Wind				
Total	7.44	72.54	0	0
Total	7.44	72.54		
CPP				
APML(Mus)	47.21	267.18	0	0
JSWEL(Mus)	22.37	119.44	0	0
VIPL(Mus)	12.39	56.14	0	0
RPLAMT(Mus)	5.70	28.07	0	0
WPCL(Mus)	7.21	40.15	0	0
Other(Mus)	5.77	31.34	0	0
Total	100.65	542.31		
SOLAR				
Total	1.17	6.17	0	0
Total	1.17	6.17		
Tata				
Trombay 5	11.65	49.62	493	432
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.60	8.52	114	59
Trombay 7B	0.79	5.77	36	32
Trombay 8	5.97	29.88	250	247
TATA Hydro	5.79	13.88	471	0
Total	25.80	107.66		
R-INFRA				
1-2	11.83	58.60	520	379
Total	11.83	58.60		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	108.51	560.87
MSPGCL Thml+Gas	113.64	592.50

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	31.17	99.31
MSPGCL Total	144.81	691.81

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	21.78	63.39
State Total	291.70	1479.10

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/May/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4232	2227	281	6740	556	3338	0	4580	4664	-1100	14198	73	14271	2631	16902	49.83
2	4139	2150	282	6571	428	3859	0	4635	4777	-1078	14557	68	14625	2432	17057	49.92
3	4238	1722	282	6242	330	4086	0	4555	4664	-966	14356	73	14429	2257	16686	49.90
4	4286	1181	282	5749	253	4028	0	4551	4894	-810	14114	69	14183	2149	16332	49.91
5	4380	868	272	5520	117	4085	0	4540	4799	-739	13782	64	13846	2085	15931	49.88
6	4442	1179	272	5893	54	4161	0	4581	4736	-765	14079	135	14214	2112	16326	49.94
7	4546	1174	272	5992	55	4356	2	4602	4877	-747	14535	276	14811	2095	16906	50.02
8	4459	1359	272	6090	49	4419	37	4663	5099	-860	14834	293	15127	2209	17336	50.00
9	4436	1720	267	6423	47	4398	82	4837	4890	-1186	14654	462	15116	2548	17664	49.89
10	4284	1926	173	6383	30	4259	118	4885	5253	-1281	14762	558	15320	2916	18236	49.88
11	4442	1516	20	5978	37	3666	136	4896	5026	-1493	13350	859	14209	3255	17464	49.96
12	4724	1534	20	6278	34	3773	183	4960	4141	-1530	12879	753	13632	3339	16971	49.93
13	4670	1854	69	6593	37	3894	153	4873	5660	-1523	14814	415	15229	3342	18571	49.80
14	4720	1985	94	6799	71	4313	159	5009	4929	-1468	14803	484	15287	3285	18572	49.84
15	4740	2000	146	6886	136	4450	134	5008	4944	-1514	15036	407	15443	3345	18788	49.74
16	4707	2024	154	6885	310	4534	85	5077	5053	-1481	15386	656	16042	3350	19392	49.88
17	4707	1656	178	6541	484	4513	55	4894	4724	-1472	14845	525	15370	3339	18709	49.89
18	4810	724	190	5724	517	4459	25	4430	4449	-1438	13736	193	13929	3159	17088	49.93
19	4649	452	228	5329	810	4479	3	4064	3967	-1392	13196	99	13295	3013	16308	49.85
20	4488	381	275	5144	873	4466	0	4678	4596	-1287	13792	100	13892	3012	16904	49.86
21	4508	249	276	5033	758	4348	0	4692	4208	-1287	13060	84	13144	2813	15957	49.82
22	4591	201	272	5064	618	4314	0	4404	4571	-1223	13344	58	13402	2667	16069	49.91
23	4655	311	275	5241	419	4259	0	4522	4836	-1199	13556	58	13614	2647	16261	49.75
24	4658	775	276	5709	412	4193	0	4463	4809	-1216	13907	55	13962	2686	16648	49.85
MUs	108.51	31.17	5.13	144.81	7.44	100.65	1.17	112.40	114.57	-29.05	339.58	6.82	346.39	66.69	413.08	49.88

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/May/2015

Position as on 6.30 Hrs of 06/May/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refueling work	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Renovation and Modification work	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	PA Fan Vibration Problem	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
IPP	RPL(AMT) U-1	270	21/03/2015	23.28		Continued.	Turbine vibration high.	
MSPGCL	Chandrapur Unit-8	500	29/03/2015	18.26		Continued.	Withdrawn	
MSPGCL	Koradi Unit-8	660	30/03/2015	20.22		Continued.	BLR Tripped.	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
IPP	RPL(AMT) U-4	270	03/04/2015	11.42		Continued.	Boiler feed Pump problem.	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
IPP	RPL(AMT) U-3	270	05/04/2015	22.01		Continued.	Governor AVR Problem.	
TPC-G	Trombay 6	500	06/04/2015	16.27		Continued.	Economic shut down.	
MSPGCL	Parli Unit 4	210	13/04/2015	11.27		Continued.	Turbine vibration high.	
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem	
MSPGCL	Bhusawal Unit 3	210	20/04/2015	00.00		Continued.	no buyer as per msdcl reqirment	
MSPGCL	Koyna Unit 8	80	30/04/2015	10.25	05/05/2015	12.10	Maintenance work	
MSPGCL	Chandrapur Unit 5	500	01/05/2015	04.30		Continued.	Air heater problem	
MSPGCL	Nasik Unit 5	210	02/05/2015	05.25	05/05/2015	17.05	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 6	500	02/05/2015	11.29	05/05/2015	19.38	Boiler Tube Leakage	
CPP	WPCL U-1	135	03/05/2015	13.00		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 3	210	03/05/2015	20.51		Continued.	Sparking on Slipring.	
MSPGCL	Chandrapur Unit 4	210	04/05/2015	21.50	05/05/2015	03.19	Differential Prot.Optd.	
IPP	Adani U-5	660	04/05/2015	21.50	06/05/2015	04.49	SPS Optd.	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/May/2015

Position as on 6.30 Hrs of 06/May/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	Adani U-3	660	04/05/2015	21.50	05/05/2015	01.08	SPS Optd.	
MSPGCL	Uran Unit 8	108	05/05/2015	09.13	05/05/2015	10.48	Condenser Pump Problem	
MSPGCL	Uran Unit B0	120	05/05/2015	09.13	05/05/2015	13.40	Condenser Pump Problem	
MSPGCL	Uran Unit A0	120	05/05/2015	09.56	05/05/2015	18.22	Rotor Earth Fault	
IPP	JSW (J) U4	300	05/05/2015	09.57	05/05/2015	13.19	Generator Prot.operated	
MSPGCL	Uran Unit 5	108	05/05/2015	10.02	05/05/2015	13.05	Rotor Earth Fault	
IPP	Adani U-2	660	06/05/2015	04.23		Continued.	FRS MOV Bonnet leakage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/May/2015

Statement-VII

Position as on 6.30 Hrs of 06/May/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Wardha PG -Aurangabad PG III	IntraState	21/04/2015	00.07		Continued.	HT	To Control Line Loading of Waluj-A'Bad PG
Wardha PG - Aurangabad PG IV	IntraState	21/04/2015	10.33		Continued.	HT	Line Rectification work
Koradi-III - Akola-II ckt-I	IntraState	05/05/2015	16.07	05/05/2015	19.20	T	Distance Protection
400 KV LINE Outages/Trippings							
Kolhapur Mapusa II	InterState	04/05/2015	18.14	05/05/2015	06.13	HT	Over Voltage
Wardha (PG)-Warora II	InterState	04/05/2015	20.47		Continued.	EO	CB under lockout at Wardha PG end.
Chandrapur-II - Warora - I	InterState	04/05/2015	21.50	05/05/2015	05.03	T	Dist Prot Optrd,Z-I R-Ph to earth.
Talegaon PG-Aurangabad-I	InterState	05/05/2015	09.44	05/05/2015	11.54	T	Tripped at A'Bad end only.Dist.Prot.operated
Talegaon PG - Aurangabad - II	InterState	05/05/2015	09.44		Continued.	T	Distance Protection
Lamboti - Solapur (PG)	InterState	05/05/2015	20.16	05/05/2015	22.12	HT	Sparking on Bus Isolator at Lamboti end
Akola II - RPL(Rattanindia) Ckt I	IntraState	07/04/2015	00.27		Continued.	T	Over Current Protection
Babhaleshwar-Taptitanda ckt-I	IntraState	01/05/2015	12.16		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	04/05/2015	16.34	05/05/2015	06.24	HT	Over Voltage
Karad-Jaigad - I	IntraState	04/05/2015	16.41	05/05/2015	06.27	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	04/05/2015	17.45	05/05/2015	07.16	HT	Over Voltage
Chandrapur II- Warora ckt II	IntraState	04/05/2015	21.50	05/05/2015	00.04	T	Master Trip Optrd,R-Ph auto reclose block.
Dhule- Bableswhar - I	IntraState	05/05/2015	09.33	05/05/2015	10.44	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Babhaleshwar - Padghe-I	IntraState	05/05/2015	09.33	05/05/2015	11.49	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Babhaleshwar-Taptitanda ckt-II	IntraState	05/05/2015	09.33	05/05/2015	11.55	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Khadka - Bableswhar	IntraState	05/05/2015	09.33	05/05/2015	11.39	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Babhaleshwar - Padghe-II	IntraState	05/05/2015	09.33	05/05/2015	11.49	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Bableswhar- Aurangabad (Waluj)	IntraState	05/05/2015	09.33	05/05/2015	10.38	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Dhule - Bableswhar - li	IntraState	05/05/2015	09.33	05/05/2015	10.45	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Taptitanda Waluj	IntraState	05/05/2015	10.27	05/05/2015	12.02	T	Over Voltage
Deepnagar Taptitanda	IntraState	05/05/2015	10.27	05/05/2015	12.10	T	Over Voltage
Karad-Jaigad - I	IntraState	05/05/2015	17.40		Continued.	T	Distance Protection(RFC from 18.55Hrs)
Girwali-Solapur (Lamboti)	IntraState	05/05/2015	19.32	05/05/2015	21.20	T	Distance Protection
karad -kolhapur-I	IntraState	06/05/2015	03.03		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 MVA ICT II @Babhleshwar	IntraState	05/05/2015	09.33	05/05/2015	11.11	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
400/220/33 Kv 315 MVA ICT I @Babhleshwar	IntraState	05/05/2015	09.33	05/05/2015	11.04	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	05/05/2015	09.33	05/05/2015	11.14	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
220 KV LINE Outages/Trippings							

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/May/2015

Statement-VII

Position as on 6.30 Hrs of 06/May/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Talandage - Chikodi	InterState	05/05/2015	18.42	05/05/2015	20.00	T	Tripped at Chikodi end
Hingoli- Girawali	InterState	05/05/2015	21.01		Continued.	T	Distance Protection
Sahara-Urse	IntraState	03/03/2015	11.06		Continued.	PO	Tower erection work (90Days)
Chandrapur Gcr - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chandrapur Gcr - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	27/04/2015	18.21		Continued.	T	Distance Protection
Wada - Kolshet	IntraState	04/05/2015	06.27	05/05/2015	16.25	PO	Construction work.
Wardha-Yeotmal	IntraState	04/05/2015	21.28	05/05/2015	12.28	T	Distance Protection
Bableshwar Ahamadnagar-li	IntraState	05/05/2015	09.33	05/05/2015	11.13	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Aurangabad (Waluj)-Bhenda	IntraState	05/05/2015	09.33	05/05/2015	12.04	T	Backup Prot.operated O/C & E/F
Eklahara(Gcr)(Nasik)- Bableshwar-I	IntraState	05/05/2015	09.33	05/05/2015	12.05	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Eklahara(Gcr)(Nasik)- Bableshwar 2	IntraState	05/05/2015	09.33	05/05/2015	12.05	T	Bus Bar operated(R Phase Bus Reactor CB Burst at 400KV BBLSR)
Chalishgaon -Babhaleshwar	IntraState	05/05/2015	09.33	05/05/2015	11.06	T	Backup Prot.operated O/C & E/F
Eklahara-(Ocr)-Navasari I	IntraState	05/05/2015	09.52	05/05/2015	14.55	T	Distance Protection
Bableshwar- Bableshwar-I	IntraState	05/05/2015	10.53	05/05/2015	11.12	HT	To Control Load
Bableshwar- Bableshwar-II	IntraState	05/05/2015	10.53	05/05/2015	11.05	HT	To Control Load
Kandalgaon - Pirangut	IntraState	05/05/2015	14.06	05/05/2015	15.58	T	Distance Protection
Padghe - Jindal	IntraState	05/05/2015	16.15		Continued.	PO	Breaker O/H work,CKT on TBC
Karad - Vita Ckt- I	IntraState	05/05/2015	16.32	05/05/2015	18.18	EO	To attend Hot Spot
Parli(U-VIII) GCR CKT	IntraState	05/05/2015	20.30	05/05/2015	21.58	T	Distance Protection
Parli 3 (Old Gcr)-Osmanabad	IntraState	05/05/2015	21.05	05/05/2015	21.49	T	Distance Protection
Eklahara-(Ocr)-Navasari I	IntraState	05/05/2015	23.09		Continued.	HT	To control Load on Bus section at Nasik GCR
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Monkey Fault
132 KV LINE Outages/Trippings							
Parli 2(Girwali) - Latur Midc	IntraState	05/05/2015	16.47	05/05/2015	18.31	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage