

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 05/May/2020 TUESDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	73.484	338.997	1) Gujrat	7.218	35.999
2) Hydro	13.889	77.959	2) Madhya Pradesh	15.099	69.543
3) Gas	6.712	33.588	3) Chattisgarh	9.690	42.960
<b>Total MSPGCL</b>	<b>94.085</b>	<b>450.544</b>	4) Maharashtra	148.258	721.920
B) 1) APLM	72.224	348.159	5) Goa (Amona)	-0.638	-1.188
2) JSWEL	14.121	76.522	<b>Total</b>	<b>179.627</b>	<b>869.234</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.163	115.633
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	25.765	124.170
5) WPCL	2.693	13.464	c) MSEDCL Bilateral *	70.098	321.390
6) Other IPP	7.113	35.696	Include PX	48.171	206.343
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.163	115.633
C) 1) TPCL Thermal	6.449	32.151	Include PX	17.603	82.764
2) TPCL Hydro	4.563	22.466	Standby	0.000	0.000
3) TPCL Gas	4.368	21.869	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	8.972	45.041	1) MSEDCL	371.232	1815.024
D) STATE			2) Mumbai Discoms	50.117	245.697
1) Thermal	185.056	890.030	<b>TOTAL STATE</b>	<b>421.349</b>	<b>2060.721</b>
(A1+C1+C4+(B1-B6))					
2) Hydro	18.452	100.425			
(A2+C2)					
3) Gas	11.080	55.457			
(A3+B7+C3)					
4) Wind	19.414	107.145			
6) SOLAR	7.720	38.430			
<b>TOTAL STATE</b>	<b>241.722</b>	<b>1191.487</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 22 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	2563	3199	3172	2828
MSPGCL Hydro	406	1039	1254	424
MSPGCL Gas	276	276	273	288
MSPGCL Total Generation	3245	4514	4699	3540
Central Sector Receipt	8517	8723	6132	6839
WIND	622	481	800	1202
CPP / IPP Thermal	3619	4106	4088	3967
CPP / IPP Gas	0	0	0	0
SOLAR	1015	663	0	0
Exchange with Mumbai	-1171	-1258	-1014	-942
<b>MSEDCL DEMAND MET</b>	<b>15847</b>	<b>17229</b>	<b>14705</b>	<b>14606</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	15847	17229	14705	14606
TPCL GENERATION	501	517	895	685
AEML GENERATION	374	376	373	373
<b>MUMBAI DEMAND</b>	<b>2046</b>	<b>2151</b>	<b>2282</b>	<b>2000</b>
STATE DEMAND MET	17893	19380	16987	16606
<b>STATE DEMAND</b>	<b>17893</b>	<b>19380</b>	<b>16987</b>	<b>16606</b>
Frequency (Hz)	50.02	49.96	50.00	49.94

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.21 Hz at 18.32 Hrs	49.7 Hz at 00.07 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 05/May/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>Bhusawal</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>Parli</b>				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	5.03	12.38	237	135
<b>Total</b>	<b>5.03</b>	<b>12.38</b>		
<b>Chandrapur</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	10.51	52.11	477	360
Unit 7	9.97	21.41	460	360
Unit 8	11.47	57.32	500	365
Unit 9	10.26	50.14	445	370
<b>Total</b>	<b>42.21</b>	<b>180.98</b>		
<b>Paras</b>				
Unit 3	5.46	24.89	250	200
Unit 4	5.85	26.89	250	206
<b>Total</b>	<b>11.31</b>	<b>51.78</b>		
<b>Khaparkheda</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	9.82	0	0
Unit 3	0.00	9.86	0	0
Unit 4	4.33	21.38	191	160
Unit 5	10.61	52.80	490	370
<b>Total</b>	<b>14.93</b>	<b>93.86</b>		
<b>Nasik</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>Uran</b>				
All Units	6.71	33.59	299	263
<b>Total</b>	<b>6.71</b>	<b>33.59</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.07	0.52	30	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Total</b>	<b>0.07</b>	<b>0.52</b>		
<b>Koyna</b>				
Stage 1-2	5.78	24.14	540	40
Stage 4	4.12	29.83	734	0
Stage 3	1.66	11.50	240	0
<b>Total</b>	<b>11.56</b>	<b>65.48</b>		
<b>Hydro</b>				
KDPH	0.86	3.86	36	36
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.29	1.29	80	0
RNGR+BHTSA	0.30	1.47	13	12
BHANDARDRA	0.47	2.34	20	19
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.40	3.53	17	16
GHATGHAR	0.00	0.00	0	0
<b>Total</b>	<b>2.33</b>	<b>12.48</b>		
<b>Wind</b>				
Total	19.41	107.14	0	0
<b>Total</b>	<b>19.41</b>	<b>107.14</b>		
<b>CPP</b>				
APML(Mus)	72.22	348.16	0	0
JSWEL(Mus)	14.12	76.52	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.69	13.46	0	0
Other(Mus)	7.11	35.70	0	0
<b>Total</b>	<b>96.15</b>	<b>473.84</b>		
<b>SOLAR</b>				
Total	7.72	38.43	0	0
<b>Total</b>	<b>7.72</b>	<b>38.43</b>		
<b>Tata</b>				
Trombay 5	6.45	32.15	271	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.80	14.00	118	114
Trombay 7B	1.57	7.87	67	64
Trombay 8	0.00	0.00	0	0
TATA Hydro	4.56	22.47	449	44
<b>Total</b>	<b>15.38</b>	<b>76.49</b>		
<b>AEML</b>				
DTPS U-1&2	8.97	45.04	376	372
<b>Total</b>	<b>8.97</b>	<b>45.04</b>		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	73.48	339.00	MSPGCL Total	94.08	450.54
			MSPGCL Thml+Gas	80.20	372.58	Koyna 1,2 & 4 Total	9.90	53.98
			MSPGCL Hydro	13.89	77.96	State Total	241.72	1191.49

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 05/May/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3221	175	268	3664	1477	3985	0	0	7321	7351	-1150	15327	0	15327	2332	17659	49.95
2	3228	159	286	3673	1325	3975	0	0	7107	6946	-1049	14870	0	14870	2200	17070	49.99
3	2953	124	289	3366	1455	3967	0	0	7007	6855	-1023	14620	0	14620	2087	16707	49.96
4	2828	424	288	3540	1202	3967	0	0	6943	6839	-942	14606	0	14606	2000	16606	49.94
5	3160	194	299	3653	1261	4051	0	0	7171	7031	-917	15079	0	15079	1965	17044	49.96
6	3210	394	279	3883	1010	4061	0	0	7769	7706	-925	15735	0	15735	1999	17734	50.00
7	3211	759	290	4260	800	4099	0	60	8198	8076	-858	16437	0	16437	1947	18384	50.02
8	3220	305	299	3824	633	4092	0	242	8000	7844	-899	15736	0	15736	1861	17597	50.02
9	3191	145	273	3609	765	4067	0	524	7758	7446	-1016	15395	0	15395	1919	17314	50.04
10	2906	126	293	3325	1113	3813	0	752	7968	7479	-1056	15426	0	15426	1970	17396	50.03
11	2590	129	267	2986	909	3642	0	965	8312	8231	-1151	15582	0	15582	2022	17604	50.02
12	2563	406	276	3245	622	3619	0	1015	8579	8517	-1171	15847	0	15847	2046	17893	50.02
13	2773	566	265	3604	488	3803	0	1039	8814	8775	-1180	16529	0	16529	2075	18604	50.00
14	3075	237	263	3575	365	4036	0	941	8898	8650	-1197	16370	0	16370	2087	18457	49.97
15	3169	634	274	4077	534	4059	0	856	8774	8539	-1276	16789	0	16789	2154	18943	49.90
16	3199	1039	276	4514	481	4106	0	663	8673	8723	-1258	17229	0	17229	2151	19380	49.96
17	3158	991	278	4427	499	4088	0	442	8276	8234	-1186	16504	0	16504	2074	18578	50.02
18	3150	1122	267	4539	515	4110	0	180	7196	7282	-1096	15530	0	15530	1972	17502	50.03
19	2873	472	281	3626	488	4046	0	41	6665	6665	-1033	13833	0	13833	1912	15745	50.05
20	3080	760	281	4121	503	4114	0	0	6469	6590	-1014	14314	0	14314	2049	16363	50.01
21	3181	774	281	4236	533	4145	0	0	6242	6143	-997	14060	0	14060	2144	16204	49.97
22	3172	1254	273	4699	800	4088	0	0	5966	6132	-1014	14705	0	14705	2282	16987	50.00
23	3212	1422	293	4927	828	4107	0	0	6450	6629	-1138	15353	0	15353	2412	17765	50.01
24	3161	1278	273	4712	808	4111	0	0	6893	6944	-1219	15356	0	15356	2457	17813	50.02
<b>MUs</b>	<b>73.48</b>	<b>13.89</b>	<b>6.71</b>	<b>94.08</b>	<b>19.41</b>	<b>96.15</b>	<b>0.00</b>	<b>7.72</b>	<b>181.45</b>	<b>179.63</b>	<b>-25.76</b>	<b>371.23</b>	<b>0.00</b>	<b>371.23</b>	<b>50.12</b>	<b>421.35</b>	<b>50.00</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/May/2020**

Position as on 6.30 Hrs of 06/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>FORCED OUTAGE</b>								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	10/04/2020	20.30		Continued.	Zero Schedule By MSEDCL	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/May/2020**

Position as on 6.30 Hrs of 06/May/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koradi Unit-8	660	12/04/2020	00.00		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 9	660	12/04/2020	01.10		Continued.	Zero schedule.	
MSPGCL	Koradi Unit 10	660	12/04/2020	02.01		Continued.	Zero schedule.	
MSPGCL	Khaparkheda Unit 1	210	22/04/2020	20.45		Continued.	Zero Schedule By MSEDCL	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Khaparkheda Unit 2	210	03/05/2020	08.04		Continued.	Zero schedule Given by MSEDCL.	
MSPGCL	Khaparkheda Unit 3	210	03/05/2020	09.34		Continued.	Zero schedule Given by MSEDCL.	
MSPGCL	Paras Unit 3	250	06/05/2020	00.58		Continued.	Boiler Tube Leakage	

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/May/2020**

**Statement-VII**

Position as on 6.30 Hrs of 06/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>400 KV LINE Outages/Trippings</b>							
Karad Solapur (PG)	InterState	03/05/2017	11:49			Continued.	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	30/04/2020	17.40			Continued.	Over Voltage
Dabhol Nagothane II	InterState	05/05/2020	12.14	05/05/2020	13.32	T	Bus Bar A Operated.
Dhule- Bableshtar - I	IntraState	24/03/2020	20.20			Continued.	Over Voltage
Padghe - Nagothane - II	IntraState	07/04/2020	23.58			Continued.	To attend Hot Spot
Chandrapur - Parli	IntraState	19/04/2020	02.20			Continued.	T Distance Protection(Tower collapsed at Loc.No.59.60.61)
Chandrapur-II - Nanded ckt II	IntraState	19/04/2020	02.21			Continued.	T Distance Protection(Tower collapsed at Loc.No.59.60.61)
Karad - Jaigad - II	IntraState	02/05/2020	19.23	06/05/2020	06.27	HT	Over Voltage
Girwali- Lonikand 2	IntraState	03/05/2020	17.48			Continued.	HT Controlling loading of Parli Parli (PG) D/C.
Khadka-Aurangabad (Waluj)	IntraState	03/05/2020	18.09			Continued.	HT Over Voltage
Babhaleshtar - Padghe-I	IntraState	04/05/2020	11.56			Continued.	HT Over Voltage
Taptitanda Waluj	IntraState	04/05/2020	17.09	05/05/2020	13.06	T	Distance Protection
Chandrapur-Warora-II 425 Bay	IntraState	05/05/2020	08.08	05/05/2020	12.31	PO	Routine maintainance and DCRM/CRM/CB Timings Testing works and isolater maintainance work .
Padghe - Nagothane - I	IntraState	05/05/2020	12.14	05/05/2020	13.24	T	Bus Bar 1 Operated.
Main Bus 1 @Nagothane	IntraState	05/05/2020	12.14	05/05/2020	12.41	T	Bus Bar Operated.
<b>400 KV ICT Outages/Trippings</b>							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07			Continued.	T Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57			Continued.	EO Testing work (Bushing Tan Delta problem hence kept out.)
400/220/33 Kv 500 MVA ICT-I @Lonikand 2	IntraState	17/04/2020	13.19			Continued.	PO Attending Hot Spot
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	19/04/2020	11.55			Continued.	HT Over Voltage
400/220/33 Kv 315 MVA ICT- 2 @Nagothane	IntraState	29/04/2020	18.38			Continued.	T tripped on NDR (charge from HV side 29/Apr/2020 23.12).
400/220kv 315 Mva ICT I @Karad	IntraState	05/05/2020	08.03	05/05/2020	14.21	PO	Quarterly & pre-monsoon Maint. of ICT & Bay.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	05/05/2020	09.13	05/05/2020	17.16	PO	Plastic Paper Wrapping work to bucholz relays and 33 KV PT cleaning work to avoid NDR operation.
400/220/33 Kv 500 Mva Ict-3 @Nagothane	IntraState	05/05/2020	10.41	05/05/2020	13.15	PO	Diagnostic Testing Work & Pre Monsoon Maintenance Work.
<b>220 KV LINE Outages/Trippings</b>							
Mudshingi Chikodi	InterState	24/09/2019	17.12			Continued.	PO No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10			Continued.	PO No Schedule.(close at Chikodi end only)
PARLY (PG) - OLD GCR PARLI	InterState	05/05/2020	11.11	05/05/2020	15.28	EO	Attending hot spot on main bus 2 section isolator B-ph both ends.
BOISAR BORIVALI	IntraState	24/07/2018	13.18			Continued.	HT To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05			Continued.	PO Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37			Continued.	PO Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20			Continued.	HT Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20			Continued.	HT Over Voltage
Sawantwadi-Bidri	IntraState	04/05/2020	20.10			Continued.	HT Over Voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/May/2020**

**Statement-VII**

Position as on 6.30 Hrs of 06/May/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Satara (MIDC)-Ajinkyatara	IntraState	05/05/2020	10.25	05/05/2020	16.20	PO	Quarterly Maintainance Work
Parly-Parly Extn-I	IntraState	05/05/2020	11.17	05/05/2020	14.30	PO	Insulator String By Porcelain Long Rod at Various Location.
Karad - Vita Ckt- II	IntraState	05/05/2020	17.50	05/05/2020	19.18	T	Distance Protection Karad End.
Karad - Vita Ckt- I	IntraState	05/05/2020	17.50	05/05/2020	19.18	T	Distance Protection Karad End.
Vita-Hiwarwadi	IntraState	05/05/2020	17.50	05/05/2020	19.19	T	Tripped At Hiwarwadi End.
Vita - Mhaishal	IntraState	05/05/2020	17.50	05/05/2020	19.33	T	Distance Protection
Vita Alkud	IntraState	05/05/2020	17.50	05/05/2020	19.35	T	Distance Protection
<b>220 KV ICT Outages/Trippings</b>							
220/110KV, 200MVA T/F-III at Mudshingi	InterState	27/04/2020	17.15		Continued.	HT	Over Voltage
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00		Continued.	PO	Shifting 220KV Side to New GIS
220/22 Kv 50 Mva Telk Ptr 2 @Mahad	IntraState	05/05/2020	11.17	05/05/2020	18.45	PO	Diagnostic Testing Work & Pre Monsoon Maintenance Work.
220/132 Kv 200 MVA ICT I @Dhule	IntraState	05/05/2020	16.30	05/05/2020	19.46	PO	Pre-monsoon Maintenance & Diagnostic Testing Work.
220/33kv 50mva Transformers & Rect Ptr 2 @Vita	IntraState	05/05/2020	17.50		Continued.	T	Caught fire.
220/33kv 50mva Apex Ptr 1 @Vita	IntraState	05/05/2020	17.50	05/05/2020	19.20	T	Tripped.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage