

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 05/May/2023 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 159.405        | 684.783         | 1) Gujrat                      | -2.644         | -19.446         |
| 2) Hydro            | 16.932         | 99.939          | 2) Madhya Pradesh              | 7.459          | 47.292          |
| 3) Gas              | 6.272          | 31.481          | 3) Chattisgarh                 | 5.340          | 32.010          |
| <b>Total MSPGCL</b> | <b>182.609</b> | <b>816.203</b>  | 4) Maharashtra                 | 202.359        | 992.996         |
| B) 1) APLM          | 39.250         | 195.412         | 5) Goa (Amona)                 | -1.251         | -6.150          |
| 2) JSWEL            | 19.850         | 97.802          | <b>Total</b>                   | <b>211.263</b> | <b>1046.702</b> |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 38.802         | 188.923         |
| 4) RPL(AMT)         | 24.090         | 124.253         | b) Mumbai Drawl                | 42.533         | 206.431         |
| 5) SWPGPL           | 9.399          | 46.257          | c) MSEDCL Bilateral *          | 90.141         | 477.858         |
| 6) Other IPP        | 11.036         | 70.523          | Include PX                     | 0.000          | 0.000           |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 38.802         | 188.923         |
| C) 1) TPCL Thermal  | 10.962         | 52.808          | Include PX                     | 0.000          | 0.000           |
| 2) TPCL Hydro       | 2.618          | 14.495          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 2.018          | 12.321          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.471         | 48.418          | 1) MSEDCL                      | 470.733        | 2267.146        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 68.602         | 334.473         |
| 1) Thermal          | 284.463        | 1320.256        | 3) Other Discoms               | 10.448         | 51.420          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>549.783</b> | <b>2653.039</b> |
| 2) Hydro (A2+C2)    | 19.550         | 114.434         |                                |                |                 |
| 3) Gas (A3+B7+C3)   | 8.290          | 43.802          |                                |                |                 |
| 4) Wind             | 11.978         | 57.835          |                                |                |                 |
| 6) SOLAR            | 14.239         | 70.010          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>338.520</b> | <b>1606.337</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6550                      | 6650                  | 6637                      | 6508                      |
| MSPGCL Hydro               | 613                       | 566                   | 1429                      | 462                       |
| MSPGCL Gas                 | 244                       | 235                   | 256                       | 276                       |
| MSPGCL Total Generation    | 7407                      | 7451                  | 8322                      | 7246                      |
| Central Sector Receipt     | 9629                      | 9675                  | 8397                      | 8279                      |
| WIND                       | 101                       | 103                   | 1029                      | 415                       |
| CPP / IPP Thermal          | 3669                      | 3745                  | 4645                      | 4492                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2025                      | 1796                  | 0                         | 0                         |
| Exchange with Mumbai       | -2147                     | -2120                 | -1535                     | -1395                     |
| <b>MSEDCL DEMAND MET</b>   | <b>20224</b>              | <b>20181</b>          | <b>20378</b>              | <b>18715</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 20224                     | 20181                 | 20378                     | 18715                     |
| TPCL GENERATION            | 666                       | 675                   | 1032                      | 535                       |
| AEML GENERATION            | 474                       | 485                   | 489                       | 390                       |
| <b>MUMBAI DEMAND</b>       | <b>3287</b>               | <b>3280</b>           | <b>3056</b>               | <b>2320</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>460</b>                | <b>469</b>            | <b>480</b>                | <b>322</b>                |
| STATE DEMAND MET           | 23971                     | 23930                 | 23914                     | 21357                     |
| <b>STATE DEMAND</b>        | <b>23971</b>              | <b>23930</b>          | <b>23914</b>              | <b>21357</b>              |
| Frequency (Hz)             | 50.04                     | 50.06                 | 49.93                     | 49.96                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.        | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|----------------------|-----------------------|---------------|---------------------|
| 50.3 Hz at 17.05 Hrs | 49.77 Hz at 19.15 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 05/May/2023

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 4.40         | 21.03         | 195      | 165      |
| Unit 8             | 13.44        | 20.05         | 586      | 510      |
| Unit 9             | 12.45        | 62.94         | 543      | 475      |
| Unit 10            | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>30.29</b> | <b>104.02</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 2.84         | 16.80         | 155      | 0        |
| Unit 4             | 9.73         | 39.08         | 445      | 380      |
| Unit 5             | 10.30        | 51.92         | 465      | 390      |
| <b>Total</b>       | <b>22.88</b> | <b>107.82</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 5.35         | 26.84         | 250      | 145      |
| Unit 7             | 0.00         | 6.52          | 3        | 0        |
| Unit 8             | 4.06         | 23.12         | 190      | 139      |
| <b>Total</b>       | <b>9.42</b>  | <b>56.48</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 3.73         | 17.60         | 165      | 138      |
| Unit 4             | 2.86         | 7.23          | 164      | 10       |
| Unit 5             | 8.61         | 13.92         | 394      | 320      |
| Unit 6             | 8.92         | 43.18         | 397      | 315      |
| Unit 7             | 8.34         | 40.96         | 388      | 315      |
| Unit 8             | 10.18        | 51.45         | 453      | 395      |
| Unit 9             | 9.88         | 51.02         | 441      | 337      |
| <b>Total</b>       | <b>52.52</b> | <b>225.35</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.78         | 22.17         | 211      | 173      |
| Unit 4             | 5.14         | 22.89         | 228      | 197      |
| <b>Total</b>       | <b>9.91</b>  | <b>45.06</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.14         | 15.01         | 135      | 120      |
| Unit 2             | 3.11         | 15.15         | 139      | 114      |
| Unit 3             | 4.31         | 20.37         | 188      | 166      |
| Unit 4             | 4.62         | 21.28         | 197      | 182      |
| Unit 5             | 11.35        | 34.83         | 485      | 460      |
| <b>Total</b>       | <b>26.52</b> | <b>106.65</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 4.00         | 20.19         | 176      | 153      |
| Unit 5             | 3.87         | 19.23         | 172      | 154      |
| <b>Total</b>       | <b>7.87</b>  | <b>39.42</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 6.27         | 31.48         | 283      | 234      |
| <b>Total</b>       | <b>6.27</b>  | <b>31.48</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.01         | 0.04          | 9        | 0        |
| <b>Total</b>       | <b>0.01</b>  | <b>0.04</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |
| Stage 1-2          | 4.10         | 21.92         | 490      | 40       |

| Generating unit | Generation    |               |          |          |
|-----------------|---------------|---------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 4         | 6.67          | 44.31         | 1002     | 0        |
| Stage 3         | 2.44          | 14.60         | 320      | 0        |
| <b>Total</b>    | <b>13.22</b>  | <b>80.83</b>  |          |          |
| <b>Hydro</b>    |               |               |          |          |
| KDPH            | 0.72          | 3.68          | 30       | 30       |
| VTRNA           | 1.17          | 5.79          | 61       | 0        |
| TILLARI         | 0.00          | 0.23          | 0        | 0        |
| BHIRA T.R.      | 0.16          | 0.61          | 40       | 0        |
| SMLHY_PTN       | 1.66          | 8.75          | 88       | 57       |
| GHATGHAR        | 0.00          | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>3.70</b>   | <b>19.07</b>  |          |          |
| <b>Wind</b>     |               |               |          |          |
| Total           | 11.98         | 57.84         | 0        | 0        |
| <b>Total</b>    | <b>11.98</b>  | <b>57.84</b>  |          |          |
| <b>CPP</b>      |               |               |          |          |
| APML(Mus)       | 39.25         | 195.41        | 0        | 0        |
| JSWEL(Mus)      | 19.85         | 97.80         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00          | 0        | 0        |
| RPLAMT-Mus      | 24.09         | 124.25        | 0        | 0        |
| SWPGPL-Mus      | 9.40          | 46.26         | 0        | 0        |
| Dhariwal        | 0.00          | 16.14         | 0        | 0        |
| IEPL            | 4.74          | 23.31         | 199      | 194      |
| Other(Mus)      | 6.30          | 31.07         | 0        | 0        |
| <b>Total</b>    | <b>103.62</b> | <b>534.25</b> |          |          |
| <b>SOLAR</b>    |               |               |          |          |
| Total           | 14.24         | 70.01         | 0        | 0        |
| <b>Total</b>    | <b>14.24</b>  | <b>70.01</b>  |          |          |
| <b>Tata</b>     |               |               |          |          |
| Trombay 5       | 7.09          | 34.56         | 339      | 267      |
| Trombay 6       | 0.00          | 0.00          | 0        | 0        |
| Trombay 7A      | 1.08          | 7.00          | 88       | 41       |
| Trombay 7B      | 0.93          | 5.33          | 57       | 36       |
| TATA Hydro      | 2.62          | 14.50         | 348      | 13       |
| Trombay 8       | 3.87          | 18.25         | 221      | 131      |
| <b>Total</b>    | <b>15.60</b>  | <b>79.62</b>  |          |          |
| <b>AEML</b>     |               |               |          |          |
| DTPS U-1&2      | 10.47         | 48.42         | 492      | 303      |
| <b>Total</b>    | <b>10.47</b>  | <b>48.42</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 159.40      | 684.78        | MSPGCL Total        | 182.61      | 816.20        |
|                |             |         | MSPGCL Thml+Gas | 165.68      | 716.26        | Koyna 1,2 & 4 Total | 10.77       | 66.23         |
|                |             |         | MSPGCL Hydro    | 16.93       | 99.94         | State Total         | 338.52      | 1606.34       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 05/May/2023

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                                    | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|------------------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | Trans<br>mission<br>Constr<br>aint |                               |                  |                           |                 |               |
| 1                  | 6585        | 1161  | 275  | 8021   | 522   | 4452      | 0    | 0     | 8674        | 8584        | -1744                | 19448                  | 0                | 0                                  | 19448                         | 2800             | 387                       | 22635           | 50.00         |
| 2                  | 6567        | 637   | 275  | 7479   | 479   | 4504      | 0    | 0     | 8470        | 8376        | -1636                | 18851                  | 0                | 0                                  | 18851                         | 2619             | 351                       | 21821           | 49.95         |
| 3                  | 6557        | 697   | 275  | 7529   | 445   | 4464      | 0    | 0     | 8307        | 8143        | -1508                | 18746                  | 0                | 0                                  | 18746                         | 2442             | 327                       | 21515           | 49.96         |
| 4                  | 6508        | 462   | 276  | 7246   | 415   | 4492      | 0    | 0     | 8468        | 8279        | -1395                | 18715                  | 0                | 0                                  | 18715                         | 2320             | 322                       | 21357           | 49.96         |
| 5                  | 6583        | 199   | 277  | 7059   | 457   | 4481      | 0    | 0     | 8671        | 8653        | -1380                | 18916                  | 0                | 0                                  | 18916                         | 2274             | 354                       | 21544           | 49.97         |
| 6                  | 6622        | 276   | 277  | 7175   | 427   | 4524      | 0    | 0     | 9133        | 8899        | -1387                | 19247                  | 0                | 0                                  | 19247                         | 2304             | 391                       | 21942           | 49.99         |
| 7                  | 6651        | 761   | 279  | 7691   | 321   | 4604      | 0    | 96    | 8840        | 8659        | -1447                | 19505                  | 0                | 0                                  | 19505                         | 2306             | 419                       | 22230           | 49.96         |
| 8                  | 6674        | 256   | 278  | 7208   | 166   | 4483      | 0    | 459   | 9281        | 9071        | -1615                | 19331                  | 0                | 0                                  | 19331                         | 2423             | 441                       | 22195           | 49.96         |
| 9                  | 6726        | 330   | 283  | 7339   | 122   | 4266      | 0    | 1040  | 9175        | 9117        | -1753                | 19675                  | 0                | 0                                  | 19675                         | 2686             | 456                       | 22817           | 49.94         |
| 10                 | 6734        | 422   | 266  | 7422   | 110   | 3963      | 0    | 1596  | 9288        | 9465        | -1833                | 20242                  | 0                | 0                                  | 20242                         | 2985             | 481                       | 23708           | 49.98         |
| 11                 | 6606        | 549   | 253  | 7408   | 75    | 3714      | 0    | 1873  | 9418        | 9411        | -2060                | 19956                  | 0                | 4                                  | 19956                         | 3199             | 465                       | 23620           | 49.97         |
| 12                 | 6550        | 613   | 244  | 7407   | 101   | 3669      | 0    | 2025  | 9566        | 9629        | -2147                | 20224                  | 0                | 5                                  | 20224                         | 3287             | 460                       | 23971           | 50.04         |
| 13                 | 6650        | 566   | 235  | 7451   | 103   | 3745      | 0    | 1796  | 9534        | 9675        | -2120                | 20181                  | 0                | 15                                 | 20181                         | 3280             | 469                       | 23930           | 50.06         |
| 14                 | 6696        | 333   | 236  | 7265   | 147   | 3761      | 0    | 1638  | 9432        | 9636        | -2014                | 19975                  | 0                | 15                                 | 19975                         | 3137             | 458                       | 23570           | 50.04         |
| 15                 | 6709        | 265   | 235  | 7209   | 196   | 4147      | 0    | 1414  | 9769        | 9709        | -2083                | 20130                  | 0                | 17                                 | 20130                         | 3213             | 462                       | 23805           | 49.91         |
| 16                 | 6706        | 142   | 234  | 7082   | 450   | 4256      | 0    | 1277  | 9779        | 9538        | -2128                | 20000                  | 0                | 13                                 | 20000                         | 3275             | 475                       | 23750           | 49.99         |
| 17                 | 6496        | 220   | 235  | 6951   | 627   | 4005      | 0    | 684   | 9734        | 9756        | -2171                | 19363                  | 0                | 5                                  | 19363                         | 3234             | 489                       | 23086           | 50.03         |
| 18                 | 6571        | 418   | 246  | 7235   | 875   | 4378      | 0    | 298   | 9245        | 8993        | -2094                | 19202                  | 0                | 1                                  | 19202                         | 3140             | 483                       | 22825           | 50.05         |
| 19                 | 6605        | 1071  | 251  | 7927   | 991   | 4578      | 0    | 43    | 8416        | 8343        | -1876                | 19527                  | 0                | 5                                  | 19527                         | 3049             | 479                       | 23055           | 50.02         |
| 20                 | 6637        | 1429  | 256  | 8322   | 1029  | 4645      | 0    | 0     | 8479        | 8397        | -1535                | 20378                  | 0                | 4                                  | 20378                         | 3056             | 480                       | 23914           | 49.93         |
| 21                 | 6730        | 1272  | 265  | 8267   | 1150  | 4632      | 0    | 0     | 7937        | 7956        | -1667                | 19872                  | 0                | 0                                  | 19872                         | 2967             | 466                       | 23305           | 50.02         |
| 22                 | 6771        | 1323  | 271  | 8365   | 1068  | 4572      | 0    | 0     | 7650        | 7614        | -1634                | 19513                  | 0                | 0                                  | 19513                         | 2885             | 472                       | 22870           | 49.95         |
| 23                 | 6722        | 1641  | 275  | 8638   | 958   | 4637      | 0    | 0     | 7651        | 7725        | -1635                | 19878                  | 0                | 16                                 | 19878                         | 2850             | 445                       | 23173           | 49.98         |
| 24                 | 6749        | 1889  | 275  | 8913   | 744   | 4653      | 0    | 0     | 7758        | 7635        | -1671                | 19858                  | 0                | 7                                  | 19858                         | 2871             | 416                       | 23145           | 49.91         |
| MUs                | 159.41      | 16.93 | 6.27 | 182.61 | 11.98 | 103.62    | 0.00 | 14.24 | 212.68      | 211.26      | -42.53               | 470.73                 | 0.00             | 0.11                               | 470.73                        | 68.60            | 10.45                     | 549.78          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

1)ELR done at 132KV Akole S/S & Rajur S/S due to 132 KV BBLR- SANGAMNER OVER LOAD 2)LTS stage 1 operated due to overloading of 220 KV Jejuri Lonand line 3)FLS at 132KV Shirwal s/stn for load management after LTS operated

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/May/2023**

**Position as on 6.30 Hrs of 06/May/2023**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                   | Adani U-3               | 660      | 27/04/2023   | 22:35        |            | Continued. | ZERO SCHEDULE                                                                                                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                                                                                                    |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                                                                                                    |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                                                                                                 |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                                                                                                  |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 01/04/2024    |
| CENT.SECTOR           | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 01/05/2024    |
| MSPGCL                | Ghatghar Unit-1         | 125      | 20/04/2022   | 00:35        |            | Continued. | Stator Earth Fault                                                                                                                                      | 31/07/2023    |
| MSPGCL                | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 30/05/2023    |
| MSPGCL                | Uran Unit 5             | 108      | 12/11/2022   | 13:23        |            | Continued. | Material replacement work.                                                                                                                              | 01/03/2024    |
| MSPGCL                | Ghatghar Unit-2         | 125      | 08/02/2023   | 07:02        |            | Continued. | Stator Earth Fault                                                                                                                                      | 01/06/2023    |
| MSPGCL                | Nasik Unit 3            | 210      | 17/04/2023   | 21:27        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 20/05/2023    |
| MSPGCL                | Uran Unit 6             | 108      | 20/04/2023   | 19:15        |            | Continued. | No Schedule.                                                                                                                                            |               |
| MSPGCL                | Koradi Unit-10          | 660      | 28/04/2023   | 17:02        | 06/05/2023 | 20:26      | Boiler Tube Leakage                                                                                                                                     | 03/05/2023    |
| IPP                   | Adani U-2               | 660      | 29/04/2023   | 08:21        |            | Continued. | Zero Schedule.                                                                                                                                          |               |
| IPP                   | JSW (J) U4              | 300      | 01/05/2023   | 09:29        |            | Continued. | NO SCHEDULE                                                                                                                                             |               |
| IPP                   | RPL(AMT) U-4            | 270      | 01/05/2023   | 15:30        |            | Continued. | Coal Shortage                                                                                                                                           |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 02/05/2023   | 05:17        | 05/05/2023 | 00:41      | Boiler Tube Leakage                                                                                                                                     |               |
| MSPGCL                | Parli Unit 7            | 250      | 02/05/2023   | 09:22        | 05/05/2023 | 23:51      | heavy steam leakage at PRDS level                                                                                                                       |               |
| MSPGCL                | Uran Unit 7             | 108      | 06/05/2023   | 16:30        |            | Continued. | Low gas pressure.                                                                                                                                       |               |
| MSPGCL                | Bhusawal Unit 4         | 500      | 06/05/2023   | 22:37        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 09/05/2023    |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/May/2023**

**Statement-VII**

**Position as on 6.30 Hrs of 06/May/2023**

| Name of Line                                                       | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                      |
|--------------------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV LINE Outages/Trippings</b>                               |                           |              |              |            |            |             |                                                                                                                                                                                                       |
| CHANDRAPUR - PADGHE HVDC POLE 2                                    | IntraState                | 05/05/2023   | 20:10        | 05/05/2023 | 21:24      | HT          | Emergency outage of 500 kV Chandrapur-Padghe HVDC Pole-2 line for the work of :- 1.The Polethene Hanging is observed during ground patrolling at loc no 987 on Pole 2 of 500KV Chandrapur Padghe Line |
| <b>400 KV MAINBAY Outages/Trippings</b>                            |                           |              |              |            |            |             |                                                                                                                                                                                                       |
| Main Bay- 400/20 kV GT-2 and 400 kV Bus-1 at 400 kV Dhariwal (STU) | IntraState                | 04/05/2023   | 13:10        | 05/05/2023 | 20:53      | PO          | GT-2 (TRASFORMER) TRANSFER ON TBC BAY for for interconnection of CTU & STU buses on MAIN BUS-II for implementation of close bus connection & operation                                                |
| 408 MAIN BAY OF 400KV WALUJ CKT @ 400KV DEEPNAGAR SS               | IntraState                | 05/05/2023   | 11:22        |            | Continued. | PO          | For servicing & overhauling of 400kV AREVA make WALUJ/AURANGABAD CKT Main C.B. Mechanism                                                                                                              |
| <b>400 KV LINE Outages/Trippings</b>                               |                           |              |              |            |            |             |                                                                                                                                                                                                       |
| TALANDGE - KOLHAPUR (PG) CKT - 2                                   | InterState                | 20/03/2023   | 07:49        |            |            | PO          | For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1                                                 |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1                                | IntraState                | 03/04/2023   | 11:30        |            |            | HT          | H/T TO CONTROL LINE LOADING OF PUNE PG                                                                                                                                                                |
| KORADI II - IEPL                                                   | IntraState                | 05/05/2023   | 08:09        | 05/05/2023 | 17:24      | PO          | Jumper nut bolt and hardware tightening work at various locations                                                                                                                                     |
| DEEPNAGAR - AURANGABAD (WALUJ)                                     | IntraState                | 06/05/2023   | 06:32        | 06/05/2023 | 14:48      | PO          | For string replacement work                                                                                                                                                                           |
| JEJURI - KARAD                                                     | IntraState                | 06/05/2023   | 16:42        | 06/05/2023 | 18:54      |             | Cold line washing work and PID faulty disc replacement work.                                                                                                                                          |
| DEEPNAGAR - AURANGABAD (WALUJ)                                     | IntraState                | 06/05/2023   | 22:37        |            | Continued. | T           | Deepnagar Unit-4 tripped through 409 Tie and 410 Main Bay and 408 Bay was already under planned outage for CB overhauling.                                                                            |
| <b>400 KV ICT Outages/Trippings</b>                                |                           |              |              |            |            |             |                                                                                                                                                                                                       |
| STATION TF No 3 @ CHANDRAPUR GCR                                   | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                        |
| 400/220KV 500MVA ICT 3 @ AKOLA                                     | IntraState                | 25/04/2023   | 10:41        |            |            | PO          | For termination of power cable                                                                                                                                                                        |
| 400/6.6 KV 60 MVA STATION TRANSFORMER-1 @ DHARIWAL (STU)           | IntraState                | 04/05/2023   | 11:30        | 05/05/2023 | 13:37      | PO          | Outage proposal on 400/6.6 KV Station Transformer (ST-1, Bay no.3) for interconnection of CTU & STU buses on MAIN BUS-II for implementation of close bus connection & operation                       |
| 400/220KV 315 MVA ICT - 2 @ NEW KOYNA                              | IntraState                | 05/05/2023   | 17:33        | 05/05/2023 | 20:44      | EO          | Y ph LA LCM is 446 micro ohm also in thermovision camera shows hot and bright                                                                                                                         |
| 400/220/33 KV 315MVA ICT - 3 @ KHADKA                              | IntraState                | 06/05/2023   | 10:15        | 06/05/2023 | 17:25      | PO          | For premonsoon maintenance work                                                                                                                                                                       |
| <b>400 KV BUSBAR Outages/Trippings</b>                             |                           |              |              |            |            |             |                                                                                                                                                                                                       |
| MAIN BUS - 2 @ DHARIWAL                                            | IntraState                | 04/05/2023   | 11:45        | 05/05/2023 | 12:06      | PO          | Outage on MAIN BUS-II for interconnection of CTU & STU on MAIN BUS-II for implementation of close bus                                                                                                 |
| <b>220 KV TBC Outages/Trippings</b>                                |                           |              |              |            |            |             |                                                                                                                                                                                                       |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Tripping for 05/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 06/May/2023

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                           |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BUS COUPLER @ MULUND                   | IntraState                | 04/05/2023   | 12:39        |            |            | EO          | 1) CB Dew Point test of 220 KV Bus Coupler which is found very Low.<br>2) The 220 KV Bus Coupler is already in OFF condition. Permission is required to open Both isolators.<br>3) Due to Low value of dew point values, the breaker pole may burst, hence CB kept out of service and now same is proposed to be attended. |
| <b>220 KV MAINBAY Outages/Tripping</b> |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                            |
| BUS SECTION @ KALWA                    | IntraState                | 06/05/2023   | 05:57        | 06/05/2023 | 08:21      | EO          | (135Degree) Hot spot attending work by Hot line unit. (220kV Bus section road side Bph isolator palm nut bolt replacement work )                                                                                                                                                                                           |
| <b>220 KV LINE Outages/Tripping</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                            |
| EKLAHARE (OCR) - NAVASARI CKT - 1      | IntraState                | 10/02/2023   | 09:45        |            |            | PO          | Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)                                                                                                                                                                                                                             |
| EKLAHARE (OCR) - PADGHE                | IntraState                | 05/03/2023   | 08:55        |            |            | HT          | For load management                                                                                                                                                                                                                                                                                                        |
| PAL DOMBIVALI - PALAVA                 | IntraState                | 05/05/2023   | 09:06        | 05/05/2023 | 17:13      | PO          | For attending closing problem of 29A isolator of 220kV Pal-Padghe Line and separation of 220kV Bus PT & Padghe Line jumpers on bus by Hot line Unit.                                                                                                                                                                       |
| MAIN BUS SECTION - 2 @ PAL-DOMBIVALI   | IntraState                | 05/05/2023   | 09:13        | 05/05/2023 | 17:05      | PO          | For attending closing problem of 29A isolator of 220kV Pal-Padghe Line and separation of 220kV Bus PT & Padghe Line jumpers on bus by Hot line Unit.                                                                                                                                                                       |
| SADAWAGHAPUR KARAD CKT 1               | IntraState                | 05/05/2023   | 10:47        | 05/05/2023 | 17:03      | PO          | Cold line washing of insulator strings from Loc No.75 to 111                                                                                                                                                                                                                                                               |
| FLAGSHIP-CHINCHWAD                     | IntraState                | 05/05/2023   | 11:10        | 05/05/2023 | 18:35      | PO          | i) Chinchwad line bay Relay testing.<br>ii) 220kV Main Bus section I & III isolator alignment work.                                                                                                                                                                                                                        |
| CHIKHALI-JALNA I                       | IntraState                | 05/05/2023   | 11:47        | 05/05/2023 | 14:59      | HT          | Outage On Chikhli-Paras Ckt-2.                                                                                                                                                                                                                                                                                             |
| KALWA - AIROLI KNOWLEDGE PARK          | IntraState                | 05/05/2023   | 12:30        | 05/05/2023 | 16:57      | PO          | "1) Auxiliary Isolator (29C) servicing and isolator alignment at 220KV AKP S/stn<br>2) Routine Maintenance at 220KV RS Kalwa"                                                                                                                                                                                              |
| ADLABS - PEDAMBE                       | IntraState                | 05/05/2023   | 12:40        | 05/05/2023 | 18:21      | PO          | For Chemical and cold washing of insulator strings and other maintenance work.                                                                                                                                                                                                                                             |
| TROMBAY (M) - CHEMBUR CKT - 3          | IntraState                | 05/05/2023   | 13:04        | 05/05/2023 | 19:21      | PO          | For anti rust painting of cross arm at highly prohibited area of BARC, HPCL                                                                                                                                                                                                                                                |
| PARAS-CHIKHALI CKT NO-II               | IntraState                | 05/05/2023   | 15:00        | 05/05/2023 | 16:11      | HT          | Emergency Hand Tripped From Paras End Due To Heavy Sparking Observed On Line Isolator.                                                                                                                                                                                                                                     |
| AAREY - MSETCL BORIVALI CKT - 2        | IntraState                | 05/05/2023   | 21:34        |            | Continued. | PO          | Interconnection of OLD GIS Bus 2 with NEW GIS Bus 2.                                                                                                                                                                                                                                                                       |
| PALGHAR - NALASOPARA                   | IntraState                | 05/05/2023   | 23:07        | 06/05/2023 | 05:00      | HT          | For replacement of heavily rusted old Disc insulator string with porcelain long rod insulator at location no. 197,199 & 201.                                                                                                                                                                                               |
| ANTOP HILL - DHARAVI-2                 | IntraState                | 05/05/2023   | 23:30        | 06/05/2023 | 01:20      | PO          | Testing and trial tripping                                                                                                                                                                                                                                                                                                 |
| KHAPARKHEDA-AMBAZARI-I                 | IntraState                | 06/05/2023   | 10:13        | 06/05/2023 | 13:35      | PO          | Diagnostic Testing Work.                                                                                                                                                                                                                                                                                                   |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 06/May/2023

| Name of Line                                | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                        |
|---------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 220 KV BALAPUR - MALKAPUR LINE              | IntraState                | 06/05/2023   | 10:50        | 06/05/2023 | 17:43      | PO          | Replacement Of Flash over Disc At Loc No. 14R-Ph.                                                                                                                                                                                                                                                       |
| KALWA - PANCHANAND                          | IntraState                | 06/05/2023   | 10:52        | 06/05/2023 | 20:18      | PO          | 1) For erection of 3 nos tower and stringing work for NHSRL by EHV Project dn, Kalwa.                                                                                                                                                                                                                   |
| 220KV KARJAT-AHMEDNAGAR-CKT-1               | IntraState                | 06/05/2023   | 10:56        | 06/05/2023 | 15:54      | EO          | As per local farmer information sparking observed loc no47. To attend the same                                                                                                                                                                                                                          |
| PETH- MUDSHINGI 1 LINE                      | IntraState                | 06/05/2023   | 12:01        | 06/05/2023 | 16:50      | EO          | For Attending hot spot in R phase blade contact of Line isolator                                                                                                                                                                                                                                        |
| KALWA - MULUND 1                            | IntraState                | 06/05/2023   | 12:40        | 06/05/2023 | 17:31      | T           | WAVETRIP JUMPER BOKEN AT MULUND S/STN.                                                                                                                                                                                                                                                                  |
| NAGOTHANE - IPCL                            | IntraState                | 06/05/2023   | 12:52        | 06/05/2023 | 14:53      | EO          | for emergency tree cutting work                                                                                                                                                                                                                                                                         |
| BOMBAY DYEING - SAHARA                      | IntraState                | 06/05/2023   | 13:09        | 06/05/2023 | 20:00      | PO          | 1) 220kV CB overhauling work on 220kV Sahara-Bombay dying Line at 220kV Sahara SS.<br>2) Line Signature test.                                                                                                                                                                                           |
| BHUGAON - WARDHA (PG)                       | IntraState                | 06/05/2023   | 19:29        | 06/05/2023 | 19:56      | HT          | Hand Tripped to control OD, 1000MW, F 49.89HZ.                                                                                                                                                                                                                                                          |
| TROMBAY DHARAVI - 6                         | IntraState                | 06/05/2023   | 23:40        |            | Continued. | PO          | Shifting of Conductors of 220kV Trombay Dharavi 6 to new Tower No 26A & 26B for Line diversion at Sejal Shakti                                                                                                                                                                                          |
| <b>220 KV ICT Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                         |
| 220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE   | IntraState                | 12/10/2020   | 11:35        |            |            | T           | Tripped due to Grid disturbance.                                                                                                                                                                                                                                                                        |
| 220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE   | IntraState                | 10/11/2022   | 10:35        |            |            | EO          | For attending to abnormal Nosie from ICT                                                                                                                                                                                                                                                                |
| 220/100 KV 200 MVA ICT 1 @ KOLSHET          | IntraState                | 05/05/2023   | 07:40        | 05/05/2023 | 11:40      | EO          | Outage required on 100 KV Bus1 along with 100kV Kolshet -Padghe line, 50MVA PTR No.1, 100kV Bus section CB and 200MVA, 220/100kV ICT no.1 (only LV CB) to:<br>1] To Attend Major Red hotspot on 100KV Main Bus to PTR no-1 Bus Rph palm -150 Deg. sel<br>2] Also Isolator servicing and alignment work. |
| 220/132 KV 100 MVA ICT 2                    | IntraState                | 06/05/2023   | 09:00        | 06/05/2023 | 19:30      | PO          | Diagnostic Testing Work.                                                                                                                                                                                                                                                                                |
| 220/132 KV 200 MVA PTR NO 5 @ PARVATI       | IntraState                | 06/05/2023   | 09:02        | 06/05/2023 | 14:22      | PO          | Half Yearly Maint.                                                                                                                                                                                                                                                                                      |
| 220/110kV 100MVA ICT - 3 @ PETH             | IntraState                | 06/05/2023   | 09:03        | 06/05/2023 | 17:10      | PO          | Premonsoon maintenance work                                                                                                                                                                                                                                                                             |
| 220/110 KV 250 MVA ICT - 2 @ VERSOVA (TATA) | IntraState                | 06/05/2023   | 10:37        | 06/05/2023 | 13:57      | PO          | R/M & Testing                                                                                                                                                                                                                                                                                           |
| <b>220 KV BUSBAR Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                         |
| BUS SECTION - 1 @ BHAVEGHAR                 | IntraState                | 05/05/2023   | 10:48        | 05/05/2023 | 17:50      | PO          | HV Breaker Overhauling and Maintenance Work.                                                                                                                                                                                                                                                            |
| BUS SECTION 3 @ FLAGSHIP                    | IntraState                | 05/05/2023   | 11:22        | 05/05/2023 | 15:17      | PO          | i) Chinchwad line bay Relay testing.<br>ii) 220kV Main Bus section I & III isolator alignment work.                                                                                                                                                                                                     |
| BUS SECTION 1 @ FLAGSHIP                    | IntraState                | 05/05/2023   | 11:24        | 05/05/2023 | 15:15      | PO          | i) Chinchwad line bay Relay testing.<br>ii) 220kV Main Bus section I & III isolator alignment work                                                                                                                                                                                                      |
| <b>132 KV LINE Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                         |
| RISOD-YELDARI                               | IntraState                | 20/04/2023   | 17:57        |            |            | HT          | TO CONTROL LOADING ON RISOD - MALEGAON CKT                                                                                                                                                                                                                                                              |
| <b>110 KV LINE Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                         |
| SALSETTE POWAI                              | IntraState                | 27/03/2023   | 11:04        |            |            | PO          | Replacement of tower number 77 & 78 for TDS project work.                                                                                                                                                                                                                                               |
| KALWA KALYAN                                | IntraState                | 05/05/2023   | 09:12        | 05/05/2023 | 17:06      | PO          | TBR installation at loc. 135 to 142                                                                                                                                                                                                                                                                     |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 05/May/2023**

**Statement-VII**

Position as on 6.30 Hrs of 06/May/2023

| Name of Line            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                         |
|-------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------------------|
| KALYAN KALWA SALSETTE 1 | IntraState                   | 06/05/2023      | 17:06           | 06/05/2023 | 19:29         | PO             | REMOVAL OF BIRD NEST AT<br>FIVE LOCATION |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage