

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Jun/2020 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	76.301	447.568	1) Gujrat	4.296	15.213
2) Hydro	6.853	31.737	2) Madhya Pradesh	5.274	22.531
3) Gas	3.013	8.704	3) Chattisgarh	5.340	23.890
Total MSPGCL	86.167	488.009	4) Maharashtra	103.563	456.099
B) 1) APML	40.995	254.979	5) Goa (Amona)	-0.220	-0.242
2) JSWEL	17.137	76.985	Total	118.253	517.491
3) VIPL	0.000	0.000	a) Mumbai Schedule	19.116	105.267
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	16.349	98.908
5) WPCL	2.610	11.959	c) MSEDCL Bilateral *	23.396	141.144
6) Other IPP	8.859	38.936	Include PX	0.212	22.830
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	19.116	105.267
C) 1) TPCL Thermal	7.340	37.014	Include PX	11.372	70.257
2) TPCL Hydro	3.330	17.733	Standby	0.000	0.000
3) TPCL Gas	4.412	22.014	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.447	45.660	1) MSEDCL	294.332	1448.228
D) STATE			2) Mumbai Discoms	40.878	221.329
1) Thermal	162.689	913.101	TOTAL STATE	335.210	1669.557
(A1+C1+C4+(B1-B6))					
2) Hydro	10.183	49.470			
(A2+C2)					
3) Gas	7.425	30.718			
(A3+B7+C3)					
4) Wind	29.966	133.563			
6) SOLAR	6.694	25.214			
TOTAL STATE	216.957	1152.066			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3470	3378	3134	2834
MSPGCL Hydro	225	145	811	230
MSPGCL Gas	146	130	133	86
MSPGCL Total Generation	3841	3653	4078	3150
Central Sector Receipt	5281	5498	5231	4326
WIND	961	1292	1592	1016
CPP / IPP Thermal	3171	3051	2906	2416
CPP / IPP Gas	0	0	0	0
SOLAR	705	505	0	0
Exchange with Mumbai	-673	-650	-886	-468
MSEDCL DEMAND MET	13286	13349	12921	10440
Load Shedding	0	0	0	0
MSEDCL DEMAND	13286	13349	12921	10440
TPCL GENERATION	538	795	555	566
AEML GENERATION	479	372	373	373
MUMBAI DEMAND	1690	1817	1814	1407
STATE DEMAND MET	14976	15166	14735	11847
STATE DEMAND	14976	15166	14735	11847
Frequency (Hz)	49.98	49.99	50.00	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.26 Hz at 13.01 Hrs	49.81 Hz at 21.10 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 05/Jun/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	18.14	0	0
Unit 10	0.00	18.21	0	0
Total	0.00	36.35		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	2.50	0	0
Unit 5	0.00	4.40	0	0
Total	0.00	6.91		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	2.61	0	0
Total	0.00	2.61		
Chandrapur				
Unit 3	0.09	10.04	56	0
Unit 4	0.04	9.43	22	0
Unit 5	0.00	23.58	0	0
Unit 6	9.19	44.58	440	350
Unit 7	9.13	44.11	455	335
Unit 8	10.24	46.74	485	360
Unit 9	9.86	46.10	455	355
Total	38.55	224.58		
Paras				
Unit 3	5.10	23.75	256	130
Unit 4	5.42	25.26	253	195
Total	10.52	49.01		
Khaparkheda				
Unit 1	3.95	19.51	175	150
Unit 2	4.11	20.04	185	160
Unit 3	4.32	20.32	195	159
Unit 4	4.28	20.18	190	162
Unit 5	10.57	48.05	500	370
Total	27.23	128.11		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Uran				
All Units	3.01	8.70	150	52
Total	3.01	8.70		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.16	0.67	21	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.16	0.67		
Koyna				
Stage 1-2	2.88	13.14	405	30
Stage 4	1.60	4.40	294	0
Stage 3	0.72	4.06	80	0
Total	5.19	21.60		
Hydro				
KDPH	0.24	2.78	14	0
VTRNA	0.00	0.00	0	0
TILLARI	0.67	2.72	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.00	0.53	0	0
RNGR+BHTSA	0.25	1.16	11	10
BHANDARDRA	0.43	2.15	18	17
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.07	0.79	3	2
GHATGHAR	0.00	0.00	0	0
Total	1.66	10.13		
Wind				
Total	29.97	133.56	0	0
Total	29.97	133.56		
CPP				
APML(Mus)	41.00	254.98	0	0
JSWEL(Mus)	17.14	76.98	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	2.61	11.96	0	0
Other(Mus)	8.86	38.94	0	0
Total	69.60	382.86		
SOLAR				
Total	6.69	25.21	0	0
Total	6.69	25.21		
Tata				
Trombay 5	7.34	37.01	309	301
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.81	14.04	118	116
Trombay 7B	1.60	7.97	68	66
Trombay 8	0.00	0.00	0	0
TATA Hydro	3.33	17.73	411	44
Total	15.08	76.76		
AEML				
DTPS U-1&2	9.45	45.66	502	371
Total	9.45	45.66		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	76.30	447.57	MSPGCL Total	86.17	488.01
			MSPGCL Thml+Gas	79.31	456.27	Koyna 1,2 & 4 Total	4.47	17.54
			MSPGCL Hydro	6.85	31.74	State Total	216.96	1152.07

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Jun/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	2851	114	52	3017	1217	2462	0	0	4422	4562	-572	10686	0	10686	1630	12316	50.05
2	2850	240	72	3162	1275	2430	0	0	4037	4361	-461	10767	0	10767	1531	12298	50.03
3	2838	90	85	3013	1104	2421	0	0	3939	4448	-458	10528	0	10528	1453	11981	50.02
4	2834	230	86	3150	1016	2416	0	0	3917	4326	-468	10440	0	10440	1407	11847	50.04
5	2851	180	104	3135	1096	2581	0	0	4151	4435	-464	10783	0	10783	1394	12177	50.04
6	3058	311	129	3498	1206	2927	0	0	4393	4714	-477	11868	0	11868	1404	13272	50.02
7	3353	477	150	3980	1120	3004	0	56	4525	4921	-412	12669	0	12669	1404	14073	50.02
8	3381	676	140	4197	988	3012	0	217	4779	5042	-422	13034	0	13034	1473	14507	50.02
9	3422	338	147	3907	851	3041	0	477	5117	5137	-544	12869	0	12869	1581	14450	49.99
10	3470	225	146	3841	961	3171	0	705	5348	5281	-673	13286	0	13286	1690	14976	49.98
11	3445	215	134	3794	1017	3082	0	845	5372	5166	-895	13009	0	13009	1803	14812	50.04
12	3063	173	143	3379	1112	3030	0	988	5463	5301	-958	12852	0	12852	1859	14711	50.02
13	2950	145	131	3226	1449	3035	0	918	5241	5148	-999	12777	0	12777	1921	14698	50.04
14	3020	225	130	3375	1319	2963	0	786	5174	5351	-985	12809	0	12809	1928	14737	50.05
15	3347	135	140	3622	1401	3052	0	665	5359	5108	-776	13072	0	13072	1884	14956	49.93
16	3378	145	130	3653	1292	3051	0	505	5408	5498	-650	13349	0	13349	1817	15166	49.99
17	3433	140	130	3703	1607	3015	0	322	5289	5083	-783	12947	0	12947	1771	14718	50.01
18	3048	133	142	3323	1610	2986	0	171	5094	4901	-805	12186	0	12186	1739	13925	50.04
19	2873	173	132	3178	1581	2857	0	39	4731	4952	-770	11837	0	11837	1705	13542	50.02
20	3134	811	133	4078	1592	2906	0	0	4667	5231	-886	12921	0	12921	1814	14735	50.00
21	3450	524	144	4118	1533	2996	0	0	4784	4566	-823	12390	0	12390	1886	14276	49.98
22	3455	392	133	3980	1278	2998	0	0	4772	4836	-640	12452	0	12452	1911	14363	49.98
23	3419	477	135	4031	1219	3040	0	0	4708	5075	-739	12626	0	12626	1934	14560	50.04
24	3378	284	145	3807	1122	3125	0	0	4723	4810	-689	12175	0	12175	1939	14114	50.03
MUs	76.30	6.85	3.01	86.17	29.97	69.60	0.00	6.69	115.41	118.25	-16.35	294.33	0.00	294.33	40.88	335.21	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jun/2020

Position as on 6.30 Hrs of 06/Jun/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Uran Unit 5	108	06/04/2020	13.23		Continued.	Gas shortage	
TPC_G	Trombay 8	250	11/04/2020	16.55		Continued.	Zero Schedule.	
CPP	SWPGL U-3	135	25/04/2020	00.08		Continued.	No Schedule	
IPP	JSW (J) U3	300	30/04/2020	15.13		Continued.	No Schedule	
MSPGCL	Parli Unit 7	250	12/05/2020	19.34		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Shaft Position	
MSPGCL	Uran Unit B0	120	25/05/2020	12.51		Continued.	Shaft position	
MSPGCL	Koradi Unit-8	660	31/05/2020	22.56		Continued.	Heavy steam Leakage in super heater.(Converted in To Zero schedule w.e.f	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jun/2020

Position as on 6.30 Hrs of 06/Jun/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
							03.06.2020 01.28)	
MSPGCL	Bhusawal Unit 4	500	01/06/2020	07.16		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Bhusawal Unit 5	500	01/06/2020	12.21		Continued.	Zero schedule By MSEDCL	
MSPGCL	Parli Unit 8	250	01/06/2020	13.13		Continued.	Zero schedule By MSEDCL	
MSPGCL	Koradi Unit 9	660	02/06/2020	15.42		Continued.	Flame Failure	
MSPGCL	Uran Unit A0	120	02/06/2020	17.07	05/06/2020	04.27	Jerk In the Grid.	
MSPGCL	Koradi Unit 10	660	03/06/2020	02.20		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Chandrapur Unit 3	210	03/06/2020	13.07	05/06/2020	21.47	RSD	
MSPGCL	Chandrapur Unit 4	210	03/06/2020	13.15	05/06/2020	22.12	RSD	
MSPGCL	Chandrapur Unit 5	500	03/06/2020	15.00	06/06/2020	15.35	RSD	
IPP	Adani U-1	660	03/06/2020	15.02		Continued.	RSD	
IPP	Adani U-5	660	04/06/2020	12.29		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 6	500	06/06/2020	09.00		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	02/06/2020	12.39	05/06/2020	07.52	PO	REPLACEMENT OF PID SUSPICIOUS DISC INSULATOR AND MAINTENANCE WORK RFC AT 18:40.
Chandrapur Bhadravati I	InterState	02/06/2020	20.53		Continued.	HT	Over Voltage
Chandrapur Bhadravati II	InterState	02/06/2020	20.53		Continued.	HT	Over Voltage
Dhule Khandwa II	InterState	02/06/2020	21.23		Continued.	HT	Over Voltage
Dabhol Nagothane I	InterState	03/06/2020	11.03	05/06/2020	11.16	T	Distance Protection
Dhule Sar'Sarovar II	InterState	05/06/2020	09.35	06/06/2020	09.18	PO	Suspicious disc insulator and maintenance work.
Dhule Sar'Sarovar I	InterState	06/06/2020	09.37		Continued.	PO	Work at Sardar Sarovar end.
Parli(MS)-Parli (PG) I	InterState	06/06/2020	11.58	06/06/2020	18.40	EO	Attending loose suspension clam at lon.no.12.
Khadka-Aurangabad (Waluj)	IntraState	31/05/2020	17.29		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	02/06/2020	18.39		Continued.	HT	Over Voltage
Dhule- Bableshwar - I	IntraState	02/06/2020	18.42		Continued.	HT	Over Voltage
Padghe - Kalwa- I	IntraState	03/06/2020	02.40		Continued.	T	Over Voltage
Babhaleshwar - Padghe-I	IntraState	03/06/2020	15.23	05/06/2020	11.27	T	Distance Protection
Babhaleshwar - Bhusawal II	IntraState	04/06/2020	06.27	06/06/2020	12.01	T	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	05/06/2020	00.04	05/06/2020	10.00	HT	Over Voltage
Padghe - Nagothane - I	IntraState	05/06/2020	00.25		Continued.	HT	Over Voltage
Karad - Talandge Ckt 2	IntraState	05/06/2020	10.38	05/06/2020	16.27	T	Pilot string replacement.
Babhaleshwar - Padghe-II	IntraState	05/06/2020	10.40		Continued.	T	Distance protection(RFC at 12.30Hrs DT. 6-6-2020)
Chandrapur - Parli	IntraState	05/06/2020	12.06	06/06/2020	08.24	PO	29B y phase isolator scissor replacement.
Main Bus II @ Parly	IntraState	05/06/2020	14.42	05/06/2020	20.45	PO	Attend jumper of corona ring at switchyard gantry end dislocated and in hanging condition.
karad -kolhapur-II	IntraState	06/06/2020	18.15		Continued.	HT	Over Voltage
Babhaleshwar - Bhusawal II	IntraState	06/06/2020	19.17		Continued.	HT	Over Voltage
Chandrapur - Parli	IntraState	06/06/2020	23.36		Continued.	HT	Breaker got Lockout at Chandrapur End.at 20.32HRS.
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57	06/06/2020	13.51	EO	Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	03/06/2020	08.28		Continued.	HT	Over Voltage
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	03/06/2020	15.30		Continued.	T	Oil Level low(Kept on Humming from 16.38Hrs DT.07-06-2020)
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	03/06/2020	17.37		Continued.	HT	Over Voltage
400/220KV 500MVA ICT 2@koradi 2	IntraState	05/06/2020	07.30		Continued.	PO	1) Tan delta measurement of bushing of ICT- 2.
400/220/33kv, 500 MVA ICT-I @Khaparkheda	IntraState	05/06/2020	14.31	05/06/2020	19.29	T	33 KV PT oil leakage attending work.
400/132 KV 200MVA ICT II @Bhusawal	IntraState	05/06/2020	21.00	05/06/2020	21.42	T	Due to HV pole discrepancy.
400/220/33kv 315MVA ICT2 @Lonikand	IntraState	06/06/2020	08.46	06/06/2020	22.36	EO	OLTC Overhauling By External agency On urgent basis as per instructions from higher

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 Kv 315 Mva Ict 2 @Parali (Girwali)	IntraState	06/06/2020	17.14	06/06/2020	21.16	PO	authorities. HV Backup relay testing work Bay.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05		Continued.	PO	Isolation of 220KV Cables on MSETCL Tower NO.240
Pusad-Ghatodi	IntraState	02/06/2020	08.35		Continued.	HT	In view Of outage On 220Kv Pusad wardha PG CKT.
Ongc Uran - Jnpt	IntraState	03/06/2020	06.30		Continued.	T	Distance Protection
Bombay Dyeing - Sahara	IntraState	03/06/2020	12.00	05/06/2020	17.50	T	Backup Protection
Nagothane - Posco	IntraState	03/06/2020	13.18		Continued.	T	Distance Protection
Apta - Hoc	IntraState	03/06/2020	15.14	05/06/2020	17.00	T	Distance Protection
Butibori-Abhijeet	IntraState	04/06/2020	13.40	05/06/2020	00.18	EO	Relay Replacement work.
Wardha-Yeotmal	IntraState	04/06/2020	16.06	06/06/2020	16.31	PO	Construction Work.
Pedambe-Nerle	IntraState	05/06/2020	04.42	05/06/2020	14.35	T	Distance Protection
MAHAPE - RELIANCE GIS	IntraState	05/06/2020	09.16	05/06/2020	12.24	PO	Pre-monsoon and diagnostic testing work.
Chandrapur GCR - Wani	IntraState	05/06/2020	09.52	05/06/2020	18.19	PO	Replacement/fixing of arcing horn betn loc no. 01 to 56 and providing repair sleeve betn loc no. 12 to 15 & 26.
Talandge-Mudshingi Ckt-I	IntraState	05/06/2020	11.22	05/06/2020	15.10	PO	Tightening/Replacement of jump nut bolts at M/C Loc No 1 Y Phase Loc No 293 R phase & M/C 21 Y phase.
Boisar Versova Line	IntraState	05/06/2020	14.24	05/06/2020	16.33	PO	Replacement of abnormal hot insulators on tower no. SS 191.
Dahanu Versova	IntraState	05/06/2020	14.24	05/06/2020	12.56	PO	220kv Isolator maintenance work at Dahanu switchyard.
Sawantwadi-Bidri	IntraState	05/06/2020	23.50	06/06/2020	09.30	HT	Over Voltage
Trombay Salsette 1 Backbay	IntraState	06/06/2020	06.38	06/06/2020	09.07	T	Distance Protection
Koradi-Ambazari-I	IntraState	06/06/2020	09.29	06/06/2020	16.39	PO	Fixing OF Vibration Dampers at various locations & Tightening of nut bolts at cut-points.
Ghodbunder - Versova	IntraState	06/06/2020	10.00	06/06/2020	14.05	PO	Replacement of abnormal hot insulator on towers no.LS 284 & 297.
BHUGAON WARORA CKT-II	IntraState	06/06/2020	10.00	06/06/2020	13.37	EO	Disc Replacement Work.
Talandge(400kv)- Sawantwadi(Insuli)	IntraState	06/06/2020	10.28	06/06/2020	12.59	EO	Replacement of Flashover String at loc.no.254 R PH.
New Koyana - Loteparshuram	IntraState	06/06/2020	10.35	06/06/2020	14.19	EO	Attending Hot Spot
Eklahara(Gcr)(Nasik)- Bableshwar 2	IntraState	06/06/2020	12.32	06/06/2020	17.53	PO	Attending red hot at loc no.4, B phase, 159 Deg cels. temperature.
Ghodbunder - Gorai	IntraState	06/06/2020	14.13	06/06/2020	17.53	PO	Replacement of abnormal hot insulators on tower no. LS 280 & 282.
V Warora - Waroralytss1	IntraState	06/06/2020	14.36	06/06/2020	16.15	EO	Replacement Of Broken Earth Wire.
Pusad-WardhaPG(Deoli)	IntraState	06/06/2020	17.14		Continued.	PO	Routine Maintenance work. and Shifting/Diversion work of 220 KV Deoli Pusad Line at loc no 167-168 due to proposed Wardha Yavatmal Nanded Railway Line.
220 KV ICT Outages/Trippings							

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2020

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 kv 100 MVA ICT II@Malegaon	IntraState	05/06/2020	10.27	05/06/2020	16.53	PO	Bushing tan delta & ct tan delta.
220/132kv 200 Mva Aditya Vidyut Ict 2 @Kanhan	IntraState	05/06/2020	10.31	05/06/2020	14.08	PO	Diagnostic testing, premonsoon maint.and routine relay testing work.
220/100 Kv 200 MVA ICT I @Pal-Dombivali	IntraState	05/06/2020	14.24	05/06/2020	17.36	PO	Plastic paper wrapping on buchholz, PRV, OSR, FD & terminal boxes.
220/132kv 100mva Ptr 1 @Kharepatan	IntraState	06/06/2020	08.31	06/06/2020	10.34	PO	For annual maintenance ICT and its associated equipment.
200MVA ICT VI @ Nasik GCR	IntraState	06/06/2020	09.26	06/06/2020	17.30	PO	For LA replacement work & premonsoon maintenance work.
220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	IntraState	06/06/2020	10.52	06/06/2020	18.29	EO	for replacement of Cables of NIFPS(for attending DC leakage), Tan delta of Wdg, oil leakage attending.
220/132 Kv 200 Mva Cgl Ict @Satana	IntraState	06/06/2020	11.10	06/06/2020	12.20	PO	pre-monsoon & quarterly maint. work.
220/132 KV ICT III @ Nasik OCR	IntraState	06/06/2020	11.31	06/06/2020	12.25	PO	Attending DC Leakage.
220/132 Kv 200 Mva Cgl Ict 1 @Raymond (Nasik 2)	IntraState	06/06/2020	13.50	06/06/2020	14.46	PO	Pre-monsoon maintenance Work.
220/132 Kv 200 Mva Emco Ict 2 @Raymond (Nasik 2)	IntraState	06/06/2020	14.50	06/06/2020	16.08	PO	Premonsoon maintenance Work.
220/132 Kv 100 Mva Ict 1 @Tuljapur	IntraState	06/06/2020	17.51	06/06/2020	19.57	PO	Attending DC Leakage.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage