

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Jun/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	173.519	852.663	1) Gujrat	-7.477	-26.960
2) Hydro	18.359	78.048	2) Madhya Pradesh	3.847	20.961
3) Gas	3.149	15.725	3) Chattisgarh	1.020	9.590
Total MSPGCL	195.027	946.436	4) Maharashtra	168.277	859.913
B) 1) APML	72.439	361.935	5) Goa (Amona)	-0.528	-4.970
2) JSWEL	17.630	87.712	Total	165.139	858.534
3) VIPL	0.000	0.000	a) Mumbai Schedule	28.075	169.977
4) RPL(AMT)	25.736	120.568	b) Mumbai Drawl	31.469	185.705
5) SWPGPL	6.335	40.261	c) MSEDCL Bilateral *	72.376	380.734
6) Other IPP	16.156	80.714	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	28.049	169.820
C) 1) TPCL Thermal	15.603	76.822	Include PX	0.000	0.000
2) TPCL Hydro	4.089	27.392	Standby	0.026	0.157
3) TPCL Gas	0.714	4.258	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.490	57.105	1) MSEDCL	492.304	2451.293
D) STATE			2) Mumbai Discoms	63.365	351.283
1) Thermal	338.908	1677.780	3) Other Discoms	8.935	47.227
(A1+C1+C4+(B1-B6))			TOTAL STATE	564.604	2849.803
2) Hydro (A2+C2)	22.448	105.440			
3) Gas (A3+B7+C3)	3.863	19.983			
4) Wind	24.149	138.704			
6) SOLAR	10.097	49.361			
TOTAL STATE	399.465	1991.268			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7347	7243	7261	7397
MSPGCL Hydro	392	384	386	624
MSPGCL Gas	134	124	125	126
MSPGCL Total Generation	7874	7750	7772	8148
Central Sector Receipt	7942	8522	5511	6217
WIND	565	680	1437	867
CPP / IPP Thermal	5645	5794	5987	5964
CPP / IPP Gas	0	0	0	0
SOLAR	1347	1075	0	0
Exchange with Mumbai	-1491	-1563	-1180	-1273
MSEDCL DEMAND MET	21483	21878	19151	19530
Load Shedding	0	0	0	0
MSEDCL DEMAND	21483	21878	19151	19530
TPCL GENERATION	662	679	1064	1120
AEML GENERATION	485	490	496	493
MUMBAI DEMAND	2638	2732	2740	2886
OTHER DISCOM DEMAND	399	380	377	393
STATE DEMAND MET	24520	24990	22268	22809
STATE DEMAND	24520	24990	22268	22809
Frequency (Hz)	49.93	49.97	50.01	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 16:32 Hrs	49.72 Hz at 00:10 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Jun/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.40	21.60	190	175
Unit 7	0.00	0.00	0	0
Unit 8	12.49	65.78	602	399
Unit 9	12.71	62.96	557	514
Unit 10	12.63	63.43	585	475
Total	42.22	213.77		
Bhusawal				
Unit 3	3.56	17.30	165	125
Unit 4	10.81	52.04	465	405
Unit 5	10.23	35.12	455	365
Total	24.60	104.46		
Parli				
Unit 6	4.70	25.11	234	153
Unit 7	4.35	21.09	205	140
Unit 8	3.08	15.55	138	119
Total	12.14	61.75		
Chandrapur				
Unit 3	3.05	12.98	131	115
Unit 4	3.03	15.74	133	123
Unit 5	8.67	43.37	375	310
Unit 6	9.42	45.39	422	350
Unit 7	7.59	42.33	365	291
Unit 8	10.43	53.67	458	410
Unit 9	10.27	51.34	439	402
Total	52.45	264.84		
Paras				
Unit 3	5.15	25.32	242	150
Unit 4	4.87	20.13	222	145
Total	10.01	45.45		
Khaparkheda				
Unit 1	3.12	15.54	150	105
Unit 2	3.64	18.14	155	145
Unit 3	3.53	20.51	180	0
Unit 4	0.02	13.16	15	0
Unit 5	10.64	54.19	470	425
Total	20.95	121.55		
Nasik				
Unit 3	3.92	19.24	181	125
Unit 4	3.84	5.42	182	123
Unit 5	3.38	16.18	162	109
Total	11.15	40.84		
Uran				
All Units	3.15	15.72	138	124
Total	3.15	15.72		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.40	1.73	30	0
Total	0.40	1.73		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.34	18.72	530	40
Stage 4	5.23	18.47	750	0
Stage 3	2.41	9.26	240	0
Total	11.98	46.44		
Hydro				
KDPH	0.52	2.64	22	22
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.54	0	0
BHIRA T.R.	0.34	1.66	80	0
SMLHY_PTN	5.13	24.67	222	199
GHATGHAR	0.00	0.36	0	0
Total	5.98	29.87		
Wind				
Total	24.15	138.70	0	0
Total	24.15	138.70		
CPP				
APML(Mus)	72.44	361.94	0	0
JSWEL(Mus)	17.63	87.71	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.74	120.57	0	0
SWPGPL-Mus	6.34	40.26	0	0
Other(Mus)	16.16	80.71	0	0
Total	138.30	691.19		
SOLAR				
Total	10.10	49.36	0	0
Total	10.10	49.36		
Tata				
Trombay 5	10.17	50.21	451	299
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.64	4.18	114	0
Trombay 7B	0.08	0.08	61	0
TATA Hydro	4.09	27.39	433	0
Trombay 8	5.44	26.61	237	199
Total	20.41	108.47		
AEML				
DTPS U-1&2	11.49	57.10	501	359
Total	11.49	57.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	173.52	852.66	MSPGCL Total	195.03	946.44
			MSPGCL Thml+Gas	176.67	868.39	Koyna 1,2 & 4 Total	9.57	37.19
			MSPGCL Hydro	18.36	78.05	State Total	399.46	1991.27

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 05/Jun/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7349	1418	137	8904	1118	6092	0	0	6921	6777	-1367	21185	0	21185	2981	340	24505	49.89
2	7154	1570	128	8852	1182	6079	0	0	6628	6544	-1241	21090	0	21090	2826	326	24241	49.90
3	7129	1766	138	9032	1170	6080	0	0	6516	6391	-1135	21242	0	21242	2660	297	24199	49.89
4	7194	1524	128	8846	1080	6071	0	0	6544	6116	-1053	20765	0	20765	2539	295	23599	50.00
5	7425	1396	138	8958	1057	6117	0	0	6526	6529	-1045	21301	0	21301	2452	315	24068	49.91
6	7435	1474	137	9046	1106	6090	0	0	6485	6170	-995	21083	0	21083	2423	334	23840	49.91
7	7407	1342	128	8876	1032	6083	0	79	6644	6564	-1091	21177	0	21177	2346	367	23889	49.98
8	7395	448	138	7982	837	5927	0	306	7181	6860	-1405	20123	0	20123	2317	384	22824	50.02
9	6996	478	126	7600	610	5239	0	719	7286	7380	-1503	19655	0	19655	2360	390	22405	50.00
10	7057	506	135	7698	541	5056	0	932	7442	7525	-1319	20046	0	20046	2455	387	22888	50.02
11	7141	428	124	7694	486	5161	0	1289	7694	7719	-1403	20552	0	20552	2551	393	23496	49.97
12	7347	392	134	7874	565	5645	0	1347	8042	7942	-1491	21483	0	21483	2638	399	24520	49.93
13	7195	314	124	7632	596	5772	0	1367	8243	7993	-1503	21475	0	21475	2676	382	24533	50.00
14	7268	302	134	7704	630	5774	0	1303	8221	7992	-1498	21527	0	21527	2667	378	24572	50.02
15	7243	384	124	7750	680	5794	0	1075	8644	8522	-1563	21878	0	21878	2732	380	24990	49.97
16	7288	562	134	7984	973	5775	0	841	8538	8147	-1583	21746	0	21746	2776	391	24913	49.98
17	7237	298	124	7658	1632	5685	0	530	8055	7394	-1495	21000	0	21000	2711	404	24115	50.00
18	6909	302	135	7346	1369	5444	0	240	7355	6768	-1286	19484	0	19484	2605	398	22487	50.06
19	6728	714	125	7568	1579	5089	0	69	6228	6026	-1211	18706	0	18706	2546	413	21666	50.02
20	7338	432	135	7906	1471	5621	0	0	5773	5606	-1198	18987	0	18987	2663	418	22068	49.96
21	7261	386	125	7772	1437	5987	0	0	5704	5511	-1180	19151	0	19151	2740	377	22268	50.01
22	7267	426	135	7828	1240	5688	0	0	5903	5923	-1217	19062	0	19062	2797	401	22259	49.96
23	7397	624	126	8148	867	5964	0	0	6032	6217	-1273	19530	0	19530	2886	393	22809	49.97
24	7359	872	137	8368	891	6062	0	0	6320	6523	-1414	20060	0	20060	3018	370	23448	49.98
MUs	173.52	18.36	3.15	195.03	24.15	138.30	0.00	10.10	168.92	165.14	-31.47	492.30	0.00	492.30	63.37	8.94	564.60	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jun/2022

Position as on 6.30 Hrs of 06/Jun/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 6	108	29/05/2022	00:32		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	29/05/2022	04:57	05/06/2022	22:22	Gas shortage	
IPP	RPL(AMT) U-4	270	31/05/2022	01:15		Continued.	Ash Conveyer problem	06/06/2022
IPP	SWPGPL U-3	135	04/06/2022	01:00	06/06/2022	02:36	Boiler Bottom Ash System problem	
TPC-G	Trombay 7A	120	04/06/2022	03:15	05/06/2022	17:48	Gas shortage	05/06/2022
MSPGCL	Khaparkheda Unit 3	210	05/06/2022	01:07	05/06/2022	03:57	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
Main bay 713 of 1500MVA ICT 2 @ 765kv Ektuni	IntraState	06/06/2022	10:35	06/06/2022	19:00	PO	"Diagnostic Testing of CB & Routine Maintenance "
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	05/06/2022	03:21	05/06/2022	06:46	EO	Premonsoon Work
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	06/06/2022	02:00	06/06/2022	06:44	EO	A] HVDC TL O&M Sub-Division, Junnar:- 1. Cleaning of dust contaminated insulator string from location no.1790 to 1802 in Naneghat Area.
400 KV LR Outages/Trippings							
400KV KORADI-BHILAI (Koradi end)	IntraState	05/06/2022	08:51	05/06/2022	19:40	HT	work at PG end
400 KV LINE Outages/Trippings							
KORADI - BHILAI	InterState	06/06/2022	09:39	06/06/2022	13:44	EO	Outage required for Emergency work of attending isolator problem of B ph 29 A due to heavy sparking observed.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	30/05/2022	15:15			HT	H/T for Load Management ie. to avoid the dumping of power in 400 kV Kharghar and Kalwa Lines.
KHARGHAR - TALEGAON (PG)	IntraState	04/06/2022	22:26	05/06/2022	02:21	EO	Cold washing of insulator string rom loc no 10 to 33 (DC portion)
LONIKAND I -JEJURI	IntraState	05/06/2022	17:41	05/06/2022	21:17	EO	Replacement of R phase L.A due to high LCM value (280 microamps) of 400kV Lonikand-Jejuri line bay at 400kV Lonikand-I.
PADGHE - KALWA CKT - 2	IntraState	05/06/2022	19:57	05/06/2022	22:16	EO	Hot Spot Attending work at loc. no. 1012 Y-Phase (145 Degree)
KARAD - LONIKAND I	IntraState	05/06/2022	22:56	06/06/2022	06:56	HT	For Load Management
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2022	12:33			PO	For CB replacement work
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	IntraState	06/06/2022	18:17	06/06/2022	21:25	PO	For cleaning of Tertiary to avoid tripping of ICT on NDR
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
CHAKAN-BHOSARI 1	IntraState	04/06/2022	21:59	05/06/2022	00:41	HT	R-ph CC abnormal sound & hotspot at Bhosari end
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	05/06/2022	01:21	05/06/2022	02:17	T	Distance Protection
LOTEPARSHURAM- DASTURI LINE	IntraState	05/06/2022	06:10	05/06/2022	11:50	PO	For replacement of damaged tower at loc no. 95&99 of 220kV Lote-Dasturi line & 220kV Pophali-Kandalgaon line.
KALWA - TFIPL	IntraState	05/06/2022	07:00	05/06/2022	12:38	PO	Outage required for safety purpose for removing of jumpers of 220KV Kharghar-Borivali-1 for CTRLS at Loc no.47.
KHARGHAR - BORIVALI CKT - 1	IntraState	05/06/2022	07:08	05/06/2022	14:56	PO	The work of removing of jumpers for making LILO at 220KV CTRLS S/stn at Loc no.47
TROMBAY - ANTOP HILL CKT - 1	IntraState	05/06/2022	09:41	05/06/2022	20:05	PO	For CVT testing

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 05/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHAKAN-BHOSARI 1	IntraState	05/06/2022	10:47	05/06/2022	18:36	PO	Double Jumpering Work at location no 25 to 27 (M/C) 68,59,57,52,51, tap 1, Z1,Z3, 4A, 4,3,2,1. and cold washing of insulators at loc no, 1,2,34,Z1, Z3, loc no 31, to 22 (M/c) from Chakan end.
AAREY - AEML SAKI CKT - 2	IntraState	05/06/2022	14:22	05/06/2022	17:50	EO	Covering of damaged Sheath of 220 kV Cable with heat shrink sleeves to prevent ingress of moisture.
BABLESHWAR-BABLESHWAR(400KV)-II	IntraState	05/06/2022	17:16	05/06/2022	20:35	T	TRIPPED ON DISTANCE PROTECTION
MAIN BUS @ ONI	IntraState	06/06/2022	08:43	06/06/2022	18:30	PO	220kV all bus isolator maintenance and 220kV PT Maintenance and plastic paper binding to all T/F Aux protection relay CB, CT MB box etc.
CHALISGAON -BABHALESHWAR	IntraState	06/06/2022	08:44	06/06/2022	16:10	PO	Replacement of damaged earthwire at T.L.No.301 to 306 on dated 06.06.2022
MUDSHINGI - CHIKODI	IntraState	06/06/2022	09:18			PO	Line reorientation work from D/C towers (Loc. 320 to 312 to M/C-9)) to M/C towers (Guide-D/C- M/C 3 to M/C 9) .
MUDSHINGI- BELEWADI LINE	IntraState	06/06/2022	10:00			PO	For Line diversion from D/C towers (Loc. 2 to 11) to D/C towers (L.no. 320 to 312) & (M/C 9 to M/C-22 to D/C-12)
TALANDGE - MUDSHINGI CKT - 2	IntraState	06/06/2022	10:07			PO	For Line diversion from D/C towers (Loc. 2 to 11) to D/C towers (L.no. 320 to 312) & (M/C 9 to M/C-22 to D/C-12)
TALANDGE - MUDSHINGI CKT - 1	IntraState	06/06/2022	10:07	06/06/2022	20:52	PO	Line reorientation work from D/C towers (Loc. 320 to 312 to M/C-9)) to M/C towers (Guide-D/C- M/C 3 to M/C 9) .
VERSOVA - GHODBUNDER	IntraState	06/06/2022	10:10	06/06/2022	14:50	PO	Checking and Refilling of CB compressor oil and premonsoon maintenance of CB
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	06/06/2022	13:19	06/06/2022	18:22	PO	Replacement of faulty insulator found in PID testing, other routine maintenance work. Cold line cleaning & jumper nut bolt tightening work
LAMBOTI - KARKAMB	IntraState	06/06/2022	16:09	06/06/2022	21:17	PO	Outage is required for 1) For changing / replacement of faulty string at loc no. 19, 44, 45, 47, 52, 85, 86, 87, 88, 89, 90, 91, 92, 94, 96, 97, 99. 2) Disc cleaning work from loc 24 to 75 (Pandharpur - Karkamb section)
BORIVALI - BOISAR (PG)	IntraState	06/06/2022	21:16	06/06/2022	23:05	EO	Replacement of damaged R-Ph jumper (Twin) between Bus Isolator and C.B.
220 KV ICT Outages/Tripping							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2022

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22-22 KV 50 MVA PTR 2 @ COLOURCHEM	IntraState	05/06/2022	07:15	05/06/2022	13:30	PO	For premonsoon maintenance work including transformer buccholz , PRV relay ,MB plastic paper wrapping work .
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	05/06/2022	09:25	05/06/2022	11:26	PO	Plastic wrapping of auxiliaries of ICT-1 & 2 alternately
220/110/33KV 250 MVA ICT-4 @ MAHALAXMI GIS (T)	IntraState	05/06/2022	10:02	05/06/2022	16:59	PO	R/M AND PROTECTION TESTING
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	05/06/2022	11:38	05/06/2022	12:44	PO	Plastic wrapping of auxiliaries of ICT-1 & 2 alternately
220/22 KV 80 MVA PTR 2 @ NALASOPARA	IntraState	05/06/2022	13:30	05/06/2022	20:09	PO	Pre monsoon maintenance and LV Bushing oil leakage attending work by M/s Mahati Industries.
220/22 KV 50 MVA PTR 1 @ VASAI	IntraState	06/06/2022	06:25	05/06/2022	08:58	PO	Polythene Wrapping of PTR-1 auxiliaries.
220/33kv 125 MVA TF 2 @ GOREGAON	IntraState	06/06/2022	09:58	06/06/2022	17:53	PO	Annual Maintenance & Premonsoon Maintenance of Transformer
220/22 KV 50 MVA PTR 1 @ KALWA	IntraState	06/06/2022	10:27	06/06/2022	16:10	PO	Safety precaution for firewall construction work.
220/33kv 125 MVA TF 2 @ CHEMBUR	IntraState	06/06/2022	10:31	06/06/2022	16:18	PO	Annual and Premonsoon maintenance of Transformer.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 2	IntraState	06/06/2022	10:32	06/06/2022	14:00	PO	For attending line GOD

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage