

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Jun/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	134.261	707.359	1) Gujrat	-3.886	-15.575
2) Hydro	18.113	132.907	2) Madhya Pradesh	4.864	40.611
3) Gas	5.118	26.114	3) Chattisgarh	3.760	14.290
Total MSPGCL	157.492	866.380	4) Maharashtra	212.316	1093.347
B) 1) APLM	66.875	304.301	5) Goa (Amona)	-1.558	-7.310
2) JSWEL	22.622	121.994	Total	215.496	1125.363
3) VIPL	0.000	0.000	a) Mumbai Schedule	44.911	216.939
4) RPL(AMT)	31.311	153.486	b) Mumbai Drawl	49.584	240.889
5) SWPGPL	10.391	50.879	c) MSEDCL Bilateral *	106.124	556.262
6) Other IPP	2.191	12.596	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.911	216.939
C) 1) TPCL Thermal	12.827	62.662	Include PX	0.000	0.000
2) TPCL Hydro	5.673	25.948	Standby	0.000	0.000
3) TPCL Gas	2.161	10.722	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.483	37.577	1) MSEDCL	490.275	2546.376
D) STATE			2) Mumbai Discoms	78.728	377.798
1) Thermal	288.961	1450.854	3) Other Discoms	10.737	52.883
(A1+C1+C4+(B1-B6))			TOTAL STATE	579.740	2977.057
2) Hydro (A2+C2)	23.786	158.855			
3) Gas (A3+B7+C3)	7.279	36.836			
4) Wind	27.349	125.667			
6) SOLAR	16.869	79.482			
TOTAL STATE	364.244	1851.694			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5471	5575	5645	5496
MSPGCL Hydro	165	862	1759	281
MSPGCL Gas	202	193	209	229
MSPGCL Total Generation	5838	6630	7613	6006
Central Sector Receipt	9880	10248	8053	8790
WIND	983	1027	1594	995
CPP / IPP Thermal	4528	5817	6306	4888
CPP / IPP Gas	0	0	0	0
SOLAR	2262	1295	0	669
Exchange with Mumbai	-2556	-2499	-1703	-1824
MSEDCL DEMAND MET	20433	22038	21386	19081
Load Shedding	0	0	0	0
MSEDCL DEMAND	20433	22038	21386	19081
TPCL GENERATION	762	931	1259	576
AEML GENERATION	436	497	328	303
MUMBAI DEMAND	3754	3927	3290	2703
OTHER DISCOM DEMAND	502	480	477	443
STATE DEMAND MET	24689	26446	25153	22227
STATE DEMAND	24689	26446	25153	22227
Frequency (Hz)	50.06	50.02	49.99	50.06

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 16.03 Hrs	49.79 Hz at 13.46 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.91	23.39	210	195
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	12.99	64.88	570	495
Total	17.90	88.27		
Bhusawal				
Unit 3	2.21	15.51	160	0
Unit 4	10.44	49.26	450	410
Unit 5	10.68	52.00	470	420
Total	23.33	116.77		
Parli				
Unit 6	4.80	26.06	250	148
Unit 7	4.64	23.44	239	147
Unit 8	4.14	21.26	201	136
Total	13.58	70.76		
Chandrapur				
Unit 3	0.37	8.36	131	0
Unit 4	3.66	18.25	155	145
Unit 5	0.00	0.00	0	0
Unit 6	0.62	36.56	393	0
Unit 7	9.46	45.83	427	341
Unit 8	11.21	55.50	496	404
Unit 9	11.38	56.66	494	428
Total	36.72	221.16		
Paras				
Unit 3	4.61	25.03	212	176
Unit 4	5.14	26.41	221	204
Total	9.76	51.44		
Khaparkheda				
Unit 1	2.78	15.30	130	100
Unit 2	3.08	15.26	138	120
Unit 3	4.33	11.26	185	171
Unit 4	3.73	21.18	187	0
Unit 5	11.15	55.02	480	445
Total	25.07	118.03		
Nasik				
Unit 3	0.00	0.88	0	0
Unit 4	3.98	20.21	179	128
Unit 5	3.94	19.84	173	150
Total	7.91	40.93		
Uran				
All Units	5.12	26.11	229	193
Total	5.12	26.11		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	0.57	23	0
Total	0.13	0.57		
Koyna				
Stage 1-2	5.08	28.10	515	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	7.13	64.58	750	0
Stage 3	2.42	21.03	320	0
Total	14.63	113.72		
Hydro				
KDPH	0.42	2.29	18	17
VTRNA	1.14	5.68	60	0
TILLARI	0.00	1.04	0	0
BHIRA T.R.	0.30	1.75	80	0
SMLHY_PTN	1.49	7.85	67	56
GHATGHAR	0.00	0.00	0	0
Total	3.36	18.62		
Wind				
Total	27.35	125.67	0	0
Total	27.35	125.67		
CPP				
APML(Mus)	66.88	304.30	0	0
JSWEL(Mus)	22.62	121.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.31	153.49	0	0
SWPGPL-Mus	10.39	50.88	0	0
Dhariwal	0.00	0.00	0	0
IEPL	0.00	0.00	0	0
Other(Mus)	2.19	12.60	0	0
Total	133.39	643.26		
SOLAR				
Total	16.87	79.48	0	0
Total	16.87	79.48		
Tata				
Trombay 5	8.44	41.21	428	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.19	5.90	108	37
Trombay 7B	0.97	4.82	64	34
TATA Hydro	5.67	25.95	442	83
Trombay 8	4.39	21.46	229	131
Total	20.66	99.33		
AEML				
DTPS U-1&2	8.48	37.58	500	290
Total	8.48	37.58		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	134.26	707.36	MSPGCL Total	157.49	866.38
			MSPGCL Thml+Gas	139.38	733.47	Koyna 1,2 & 4 Total	12.21	92.68
			MSPGCL Hydro	18.11	132.91	State Total	364.24	1851.69

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6170	766	224	7160	470	6238	0	0	8358	7906	-1742	19648	0	0	19648	3208	384	23240	49.94
2	6022	722	227	6971	477	6238	0	0	8013	7952	-1624	19656	0	0	19656	3017	358	23031	50.00
3	5791	631	227	6649	591	6164	0	0	8566	8179	-1683	19567	0	0	19567	2813	333	22713	50.02
4	5764	279	228	6271	850	5936	0	0	8885	8136	-1629	19229	0	0	19229	2681	335	22245	50.03
5	5583	182	227	5992	1189	5391	0	0	9215	8866	-1617	19459	0	0	19459	2606	362	22427	49.98
6	5629	187	229	6045	1275	5194	0	5	9376	9026	-1674	19478	0	0	19478	2608	393	22479	49.99
7	5563	194	229	5986	1245	5131	0	166	8957	8952	-1718	19343	0	0	19343	2582	419	22344	50.03
8	5496	281	229	6006	995	4888	0	669	8655	8790	-1824	19081	0	0	19081	2703	443	22227	50.06
9	5418	284	216	5918	1204	4889	0	1235	8799	8792	-2112	19450	0	0	19450	3038	476	22964	50.08
10	5379	252	208	5839	1082	4538	0	1751	9306	9290	-2370	19667	0	0	19667	3364	463	23494	49.94
11	5447	196	203	5846	1087	4390	0	2114	9773	9541	-2623	19870	0	0	19870	3635	485	23990	49.97
12	5471	165	202	5838	983	4528	0	2262	9812	9880	-2556	20433	0	0	20433	3754	502	24689	50.06
13	5458	120	203	5781	977	4593	0	2183	9883	10101	-2579	20567	0	0	20567	3755	489	24811	50.04
14	5554	460	197	6211	1112	4670	0	2121	9663	9944	-2521	21077	0	0	21077	3692	460	25229	49.97
15	5498	435	199	6132	1074	5582	0	1718	10136	10206	-2531	21726	0	16	21726	3833	455	26014	49.96
16	5575	862	193	6630	1027	5817	0	1295	10021	10248	-2499	22038	0	45	22038	3927	480	26446	50.02
17	5451	1363	198	7012	1059	5955	0	889	9385	9877	-2421	21872	0	40	21872	3848	499	26219	50.08
18	5337	1264	201	6802	1361	5851	0	414	9731	9587	-2544	20968	0	7	20968	3635	503	25106	50.01
19	5344	1144	203	6691	1533	5896	0	47	9230	8874	-2264	20283	0	4	20283	3397	494	24174	50.04
20	5537	1729	204	7470	1566	6303	0	0	8029	8238	-1885	21204	0	0	21204	3336	488	25028	49.99
21	5645	1759	209	7613	1594	6306	0	0	7803	8053	-1703	21386	0	0	21386	3290	477	25153	49.99
22	5739	1478	218	7435	1518	6310	0	0	7796	7885	-1741	20922	0	0	20922	3264	485	24671	50.03
23	5678	1702	220	7600	1495	6317	0	0	7815	8664	-1811	21816	168	0	21984	3325	449	25758	50.04
24	5712	1658	224	7594	1585	6265	0	0	8038	8509	-1913	21534	343	0	21877	3417	506	25800	50.05
MUs	134.26	18.11	5.12	157.49	27.35	133.39	0.00	16.87	215.24	215.50	-49.58	490.28	0.51	0.11	490.79	78.73	10.74	580.25	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR done at 220KV GCR S/S due to overloading of 220KV BBLR-I & II 2) 22KV feeders at Shirwal s/stn through PLCC command received from Kamthadi ss. FLS for load management after LTS is operated

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jun/2023

Position as on 6.30 Hrs of 06/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	07/06/2023
MSPGCL	Koradi Unit 8	660	29/05/2023	05:36	06/06/2023	09:11	Boiler Tube Leakage	06/06/2023
MSPGCL	Koradi Unit 9	660	30/05/2023	00:08		Continued.	Boiler Tube Leakage	05/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Chandrapur Unit 3	210	03/06/2023	07:48	05/06/2023	18:50	Boiler Tube Leakage	05/06/2023
MSPGCL	Nasik Unit 3	210	04/06/2023	02:10	06/06/2023	03:05	Boiler Tube Leakage	07/06/2023
MSPGCL	Chandrapur Unit 6	500	05/06/2023	01:55		Continued.	Boiler Tube Leakage	08/06/2023
MSPGCL	Bhusawal Unit 3	210	05/06/2023	15:40		Continued.	Boiler Tube Leakage	
MSPGCL	Koyana STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	
MSPGCL	Khaparkheda Unit 4	210	05/06/2023	16:40	05/06/2023	18:54	Low furnace pressure	
MSPGCL	Parli Unit 6	250	06/06/2023	03:45	06/06/2023	07:26	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
400KV TIE BAY 402 STN TF 1 AND AKOLA2 CKT 1 @ NANDGAONPETH	InterState	06/06/2023	06:18			HT	Hand tripped for breaker trials of STN TF-1
TIE BAY - 405 OF SOLAPUR PG @ ALKUD	IntraState	06/06/2023	11:19	06/06/2023	12:42	PO	Diagnostic testing & Maintenance work
400 KV MAINBAY Outages/Trippings							
400/6.9KV 63MVA STN T/F 1 @ NANDGAONPETH	InterState	01/06/2023	06:09			PO	ST-1 transformer oil leakage arresting, maintenance , diagnostic testing, Metering CT and CVT testing and ST1 transformer protection relay testing work. ST-1transformer painting work
MAIN BAY 401 OF STN T/F 1 @ NANDGAONPETH	InterState	06/06/2023	06:18			HT	Hand tripped for breaker trials of STN TF-1
MAIN BAY (406) OF STG-4 @ JEJURI	IntraState	05/06/2023	09:48	05/06/2023	14:51	EO	For attending hot spot at 406 bay Rph CT Stud clamp
MAIN BAY (404) OF SOLAPUR PG @ ALKUD	IntraState	06/06/2023	12:49			PO	Diagnostic testing & Maintenance work
400 KV LR Outages/Trippings							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	05/06/2023	10:58			PO	Overhauling of 400 kV CGL make SF CB by M/s Ajaydeep Power Corporation,Aurangabad
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
DHULE - SSNNL CKT - 1	InterState	04/06/2023	10:11	05/06/2023	02:42	T	Distance Protection
LONIKAND I - TALEGAON (PGCIL)	InterState	04/06/2023	14:32	05/06/2023	02:32	T	Y-Phase wave trap burst at Lonikand, heavy storm.
DHULE - SSNNL CKT - 2	InterState	04/06/2023	22:36	05/06/2023	02:18	EO	While ground patrolling carried out, at loc no. 278 to 280 Snapping of earth wire observed so please give permission for emergency outage on 400 KV Dhule-SSNNL-2 line & 400kV Dhule SSNL 1 line is already in Breakdown & work s already progressed on 400kV Dhule SSNL 1 line for stringing of earth wire (LOC No.267 to 268).
DHULE - SSNNL CKT - 1	InterState	06/06/2023	08:54			PO	Under MTAMC Project work, Main -II Dist Protn relay replacement work
PADGHE (GIS) PG - KUDUS CKT - 2	InterState	06/06/2023	10:51			PO	CVT replacement in 400 kV Padghe-Kudus ckt-2 at MSETCL Kudus.
DABHOL - NEW KOYNA CKT - 2	IntraState	22/05/2023	13:26			PO	Dismantling of exisging tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/06/2023	23:37			HT	HT for load management
PARLI - KARJAT CKT - 1	IntraState	05/06/2023	02:56	05/06/2023	06:33	EO	For replacement of PID faulty insulator string at loc no 221 Yph

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LONIKAND I - KOYNA STAGE-IV	IntraState	05/06/2023	03:09	05/06/2023	04:45	EO	Emergency outage is required on 400kV Lonikand 1 -Stage 4 Line to attend CVT clamp broken jump work
LONIKAND - JEJURI CKT - 1	IntraState	05/06/2023	05:02	05/06/2023	06:49	EO	Emergency outage is required on 400kV Lonikand 1 -Jejuri Ckt 1 Line to attend CVT clamp broken jump work at Lonikand 1 end.
LONIKAND - JEJURI CKT - 2	IntraState	05/06/2023	07:01	05/06/2023	08:23	EO	Emergency outage is required on 400kV Lonikand 1 -Jejuri Ckt 1 Line to attend CVT clamp broken jump work at Lonikand 1 end.
CHANDRAPUR - KHAPERKHEDA	IntraState	05/06/2023	13:24	05/06/2023	17:51	EO	To attend the problem of low air pressure alarm of 400kV CGL make Circuit Breaker.
LONIKAND I - KOYNA STAGE-IV	IntraState	05/06/2023	15:12	05/06/2023	23:28	EO	Hot Spot Attending work at Loc No 01 & PID Faulty String Replacment work at Loc No 186
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	05/06/2023	19:04	05/06/2023	22:08	T	Tripped on Distance Protection.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	05/06/2023	16:30	06/06/2023	21:49	EO	for attending hot-spot observed at Y ph,D isolator jaw & B-ph,A-bus isolator ,T-jump side jaw at 400 kV Talandge
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	06/06/2023	09:32			PO	HV ISOLATOR OVERHAULING WORK BY SHIFTING HV CB ON 400 KV TBC
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	IntraState	06/06/2023	11:59			PO	Premonsoon Maintenance Work
400 KV BR Outages/Trippings							
BUS REACTOR (125 MVar) @ LAMBOTI	IntraState	05/06/2023	09:48	05/06/2023	18:01	PO	Routine Testing and Pre-monsoon activities.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV WANI - PANDHARKAWDA CKT II BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
MAIN BUS @ NIWALI	IntraState	05/06/2023	10:45	05/06/2023	18:58	PO	Routine maintenance work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
SAHARA-URSE	IntraState	04/06/2023	21:12	05/06/2023	06:19	EO	CB overhauling work of 220kV Sahara-Urse line bay.
VERSOVA - GHODBUNDER	IntraState	05/06/2023	00:30	05/06/2023	06:06	PO	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
GHODBUNDER - GORAI	IntraState	05/06/2023	00:39	05/06/2023	06:11	PO	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
ALEPHATA-PARGAON(KATHAPUR)	IntraState	05/06/2023	08:10	05/06/2023	19:34	HT	H/T for load Management.
KALMESHWAR-PANDHURNA	IntraState	05/06/2023	09:01	05/06/2023	22:36	PO	Work at Pandhurna end.
WARORA - WARORA RLY TSS 1	IntraState	05/06/2023	09:13	05/06/2023	12:13	PO	Replacement of broken disc insulators on pilot string at loc no.4A.
TALANDAGE - FIVE STAR MIDC 2	IntraState	05/06/2023	10:33	05/06/2023	15:04	PO	for dignostic testing and quarterly maintenance work
220 KV CHALISGAON - KHADKA CKT -1	IntraState	05/06/2023	11:22	05/06/2023	12:56	PO	Removing of broken earth wire at loc no.26 which is observed during drone patrolling.
NERUL - SEAWOOD CABLE CKT - 2	IntraState	05/06/2023	11:24	05/06/2023	14:29	PO	Maintenance work by Railways
TALANDAGE - FIVE STAR MIDC 1	IntraState	05/06/2023	15:20	05/06/2023	19:19	PO	Distance and Back up relay testing work
MUMEWADI -HALKARNI 2 LINE	IntraState	06/06/2023	09:01			PO	Insulator cleaning work
DAHANU - GHODBUNDER CKT - 1	IntraState	06/06/2023	10:00	06/06/2023	11:30	PO	Premonsoon maintenance of Circuit Breaker.
KHARGHAR - KHANDESHWAR CKT - 1	IntraState	06/06/2023	10:06			PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
KHARGHAR - KHANDESHWAR CKT - 2	IntraState	06/06/2023	10:18			PO	Crossing of 220kV Uran-Kharghar line Conductor at Loc. No. 85 & 86 above 220kV Kandalgaon - Kharghar line conductor.
DAHANU - GHODBUNDER CKT - 2	IntraState	06/06/2023	11:52			PO	Premonsoon maintenance of Circuit Breaker
VERSOVA - GHODBUNDER	IntraState	06/06/2023	23:38	06/06/2023	06:17	PO	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
GHODBUNDER - GORAI	IntraState	06/06/2023	23:51	06/06/2023	06:26	PO	Erection of U-Girder at LOC P154-155 LHS along metro line 9 near silver park - Mira Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	05/06/2023	09:40	05/06/2023	16:17	PO	Quarterly maint work
220/132 KV 100 MVA ICT 1 @ PHALTAN MIDC	IntraState	05/06/2023	11:45	05/06/2023	18:15	PO	HV R & B Ph bushing replacement work
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	06/06/2023	08:23			PO	Faulty jumper replacement work by agency & Hot spot attending work.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
NERAL - AMBERNATH	IntraState	05/06/2023	07:36	05/06/2023	09:33	PO	BIRD NEST REMOVAL
KALWA KALYAN	IntraState	05/06/2023	21:26	06/06/2023	06:35	PO	Tower errection & conductor shifting at loc 165

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage