

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Jun/2024 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	157.097	806.336	1) Gujrat	6.392	16.020
2) Hydro	9.201	68.099	2) Madhya Pradesh	5.093	23.557
3) Gas	8.219	37.607	3) Chattisgarh	2.410	14.370
Total MSPGCL	174.517	912.042	4) Maharashtra	211.103	1043.199
B) 1) APLM	60.132	338.632	5) Goa (Amona)	-2.257	-11.530
2) JSWEL	26.976	138.534	Total	222.741	1085.616
3) VIPL	0.000	0.000	a) Mumbai Schedule	51.055	227.687
4) RPL(AMT)	31.731	135.568	b) Mumbai Drawl	54.064	238.959
5) SWPGPL	12.508	61.007	c) MSEDCL Bilateral *	100.191	499.615
6) Other IPP	13.961	77.383	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	51.015	227.647
C) 1) TPCL Thermal	12.677	66.917	Include PX	0.000	0.000
2) TPCL Hydro	8.181	31.768	Standby	0.040	0.040
3) TPCL Gas	4.130	20.641	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.727	49.310	1) MSEDCL	505.752	2628.258
D) STATE			2) Mumbai Discoms	84.779	407.595
1) Thermal	320.809	1673.687	3) Other Discoms	11.820	57.764
(A1+C1+C4+(B1-B6))			TOTAL STATE	602.351	3093.617
2) Hydro (A2+C2)	17.382	99.867			
3) Gas (A3+B7+C3)	12.349	58.248			
4) Wind	13.749	96.025			
6) SOLAR	15.321	80.174			
TOTAL STATE	379.610	2008.001			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6140	6240	6801	6859
MSPGCL Hydro	240	298	858	160
MSPGCL Gas	456	458	286	290
MSPGCL Total Generation	6836	6996	7946	7310
Central Sector Receipt	10355	10806	8696	8135
WIND	291	855	747	627
CPP / IPP Thermal	5186	5314	6412	6383
CPP / IPP Gas	0	0	0	0
SOLAR	2088	1247	0	0
Exchange with Mumbai	-2600	-2896	-2053	-1870
MSEDCL DEMAND MET	21636	21798	21215	20208
Load Shedding	0	0	0	0
MSEDCL DEMAND	21636	21798	21215	20208
TPCL GENERATION	1075	1030	1284	859
AEML GENERATION	247	245	251	238
MUMBAI DEMAND	3922	4171	3588	2967
OTHER DISCOM DEMAND	520	524	532	377
STATE DEMAND MET	26078	26492	25336	23552
STATE DEMAND	26078	26492	25336	23552
Frequency (Hz)	49.95	50.03	50.05	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 08.52 Hrs	49.8 Hz at 04.18 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.40	21.11	190	162
Unit 8	14.00	69.86	613	531
Unit 9	13.23	44.22	610	485
Unit 10	12.73	65.05	565	482
Total	44.35	200.24		
Bhusawal				
Unit 3	0.00	2.34	0	0
Unit 4	9.84	53.32	480	290
Unit 5	8.92	50.89	470	0
Total	18.76	106.55		
Parli				
Unit 6	4.19	23.21	247	134
Unit 7	1.20	14.93	205	0
Unit 8	4.06	22.85	231	143
Total	9.46	61.00		
Chandrapur				
Unit 3	3.60	18.76	166	130
Unit 4	3.63	19.00	169	123
Unit 5	8.07	40.28	380	280
Unit 6	5.29	32.52	230	205
Unit 7	8.48	45.77	400	289
Unit 8	10.00	51.68	448	315
Unit 9	1.65	23.35	372	0
Total	40.71	231.36		
Paras				
Unit 3	5.16	20.80	234	171
Unit 4	0.92	7.43	243	0
Total	6.08	28.23		
Khaparkheda				
Unit 1	3.58	18.35	160	115
Unit 2	4.50	22.45	205	151
Unit 3	3.91	11.13	173	139
Unit 4	4.40	21.80	193	164
Unit 5	11.08	55.10	470	425
Total	27.47	128.82		
Nasik				
Unit 3	3.68	16.79	172	133
Unit 4	3.19	16.55	146	66
Unit 5	3.40	16.79	158	119
Total	10.26	50.14		
Uran				
All Units	8.22	37.61	458	282
Total	8.22	37.61		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	2.28	19.64	345	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	3.27	24.81	501	0
Stage 3	0.87	9.93	160	0
Total	6.43	54.38		
Hydro				
KDPH	0.44	2.34	19	19
VTRNA	0.51	2.20	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.62	7.93	71	62
GHATGHAR	0.20	1.25	125	0
Total	2.78	13.72		
Wind				
Total	13.75	96.02	0	0
Total	13.75	96.02		
CPP				
APML(Mus)	60.13	338.63	0	0
JSWEL(Mus)	26.98	138.53	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.73	135.57	0	0
SWPGPL-Mus	12.51	61.01	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.46	28.79	266	0
Other(Mus)	4.36	25.05	0	0
JPL	5.14	23.55	271	129
Total	145.31	751.12		
SOLAR				
Total	15.32	80.17	0	0
Total	15.32	80.17		
Tata				
Trombay 5	9.51	45.19	461	276
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	12.96	108	108
Trombay 7B	1.54	7.68	65	63
TATA Hydro	8.18	31.77	446	74
Trombay 8	3.17	21.73	227	0
Total	24.99	119.33		
AEML				
DTPS U-1&2	5.73	49.31	252	160
Total	5.73	49.31		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	157.10	806.34	MSPGCL Total	174.52	912.04
			MSPGCL Thml+Gas	165.32	843.94	Koyna 1,2 & 4 Total	5.55	44.45
			MSPGCL Hydro	9.20	68.10	State Total	379.61	2008.00

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7144	388	372	7904	386	7072	0	0	8756	8704	-2067	21559	0	0	21559	3584	440	25584	50.02
2	7157	126	374	7658	447	7068	0	0	8848	8224	-1909	21076	0	0	21076	3329	411	24816	50.03
3	7187	118	288	7592	680	7057	0	0	8396	7688	-1848	20762	0	0	20762	3133	408	24302	49.99
4	6859	160	290	7310	627	6383	0	0	8681	8135	-1870	20208	0	0	20208	2967	377	23552	49.96
5	6686	426	290	7402	506	6347	0	0	8411	8224	-1694	20388	0	0	20388	2881	398	23666	49.94
6	6801	126	290	7218	416	6965	0	0	8548	8319	-1730	20763	0	0	20763	2860	425	24048	50.01
7	6673	142	290	7106	305	6679	0	109	9060	8814	-1862	20689	0	0	20689	2800	462	23950	50.02
8	6555	252	291	7098	255	6249	0	496	8986	8749	-2022	20334	0	0	20334	2892	491	23716	50.05
9	6217	134	289	6640	337	5521	0	938	9979	9904	-2364	20451	0	0	20451	3148	525	24124	50.13
10	6373	148	287	6808	358	5334	0	1463	10522	9938	-2442	20932	0	0	20932	3525	528	24984	49.98
11	5685	244	423	6352	297	5151	0	1880	10910	10639	-2549	21244	0	0	21244	3815	527	25586	49.93
12	6140	240	456	6836	291	5186	0	2088	10463	10355	-2600	21636	0	17	21636	3922	520	26078	49.95
13	6242	134	457	6832	431	5156	0	2132	10564	10069	-2628	21461	0	38	21461	3952	531	25944	49.96
14	6109	132	455	6696	513	5157	0	2042	10760	10120	-2640	21367	0	0	21367	3913	522	25802	50.02
15	5990	128	455	6572	624	5226	0	1824	10961	10502	-2790	21442	0	159	21442	4060	517	26018	50.06
16	6240	298	458	6996	855	5314	0	1247	11063	10806	-2896	21798	0	179	21798	4171	524	26492	50.03
17	6429	266	449	7144	713	5844	0	747	10651	10433	-2752	21585	0	84	21585	4099	545	26228	50.01
18	6495	398	293	7186	880	5515	0	306	10277	9776	-2544	20572	0	3	20572	3909	548	25028	50.06
19	6358	708	282	7348	1216	5368	0	49	9403	9158	-2190	20395	0	0	20395	3667	554	24616	50.04
20	6685	912	285	7882	1010	6129	0	0	8803	8797	-2092	21195	0	0	21195	3604	531	25330	50.01
21	6801	858	286	7946	747	6412	0	0	8605	8696	-2053	21215	0	0	21215	3588	532	25336	50.05
22	6933	858	284	8076	603	6659	0	0	8546	8460	-2062	21231	0	0	21231	3576	505	25312	50.05
23	6635	1064	287	7986	612	6753	0	0	9236	8931	-2172	21594	0	0	21594	3656	515	25766	50.00
24	6703	938	288	7930	640	6763	0	0	9879	9300	-2288	21858	0	0	21858	3728	486	26072	50.01
MUs	157.10	9.20	8.22	174.52	13.75	145.31	0.00	15.32	230.31	222.74	-54.06	505.75	0.00	0.48	505.75	84.78	11.82	602.35	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)DLS implement 400KV Jejuri due to under voltage. 2) Power cut due to transmission constraints in Palghar circle & solapur circle.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jun/2024

Position as on 6.30 Hrs of 06/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Chandrapur Unit 9	500	02/06/2024	22:52	05/06/2024	17:17	Condenser Vacuum low	06/06/2024
MSPGCL	Bhusawal Unit 3	210	03/06/2024	00:30		Continued.	Boiler tube leakage (On tolling).	07/06/2024
MSPGCL	Parli Unit 7	250	03/06/2024	22:36	05/06/2024	16:28	Boiler Tube Leakage	06/06/2024
MSPGCL	Paras Unit 4	250	05/06/2024	03:59		Continued.	Fire in GT	
MSPGCL	Bhusawal Unit 5	500	05/06/2024	22:05		Continued.	Air heater problem	08/06/2024
Total Capacity MSPGCL		1955						
TPC-G								
TPC-G	Trombay 8	250	05/06/2024	08:36	05/06/2024	15:39	Tripped on Class A Protection due to GT8 -Y Phase Tower string Insulator shattering.	
Total Capacity TPC-G		250						
AEML								
AEML	AEML Unit 2	250	04/06/2024	16:58		Continued.	Boiler Tube Leakage	07/06/2024
Total Capacity AEML		250						
IPP								
IPP	IEPL Unit 1	270	05/06/2024	17:46	05/06/2024	20:21	ID Fan Problem	
IPP	IEPL Unit 1	270	05/06/2024	20:25	06/06/2024	22:37	ID Fan Problem	
IPP	IEPL Unit 1	270	05/06/2024	23:25	06/06/2024	01:20	Protection MS temperature malfunction	
Total Capacity IPP		810						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3585						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00	05/06/2024	10:15	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	05/06/2024	02:00	05/06/2024	09:55	As per MSEDCL requirement	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jun/2024

Position as on 6.30 Hrs of 06/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	05/06/2024	17:00		Continued.	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	05/06/2024	17:15		Continued.	Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		432						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		432						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV TIEBAY Outages/Trippings							
TIE BAY - 402 OF BUS REACTOR @ ALKUD	IntraState	05/06/2024	12:28	05/06/2024	19:25	PO	Diagnostic testing & Maintenance work
TIE BAY - 415 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	06/06/2024	05:57			PO	Diagnostic testing and Pre Mansoon Maintenance
400 KV MAINBAY Outages/Trippings							
MAIN BAY (401) OF BUS REACTOR @ ALKUD	IntraState	05/06/2024	12:28	05/06/2024	19:25	PO	Diagnostic testing & Maintenance work
MAIN BAY - 416 OF 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	06/06/2024	05:57			PO	Diagnostic testing and Pre Monsoon Maintenance
400 KV LINE Outages/Trippings							
PUNE(GIS) - TALEGAON(PG) CKT - 4	InterState	05/06/2024	17:13	06/06/2024	00:15	T	Tripped on distance protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
220 KV PARLI (400 KV)- GIRWALI I/C -2	IntraState	26/05/2024	15:40	05/06/2024	00:26	T	6 Nos. Tower collapsed (Loc no 36- 41) .
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	05/06/2024	06:50	05/06/2024	11:50	PO	for repairing of conductor strand at loc .9-10,51-52, 3-4
KORADI - KHAPERKHEDA CKT - 1	IntraState	05/06/2024	09:14	05/06/2024	16:47	PO	DCRM,CB Timing &CRM of Main & Tie CB
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	05/06/2024	09:24	05/06/2024	23:13	PO	DISTANCE PROTECTION RELAY RETROFITTING WORK.
BUS REACTOR (125 MVAR) @ ALKUD	IntraState	05/06/2024	12:28	05/06/2024	19:25	PO	Diagnostic testing & Maintenance work
JEJURI- KOYNA STAGE-IV	IntraState	05/06/2024	12:53	05/06/2024	13:42	T	Tripped from Koyna stage IV only with no indication
LONIKAND I - KOYNA STAGE-IV	IntraState	05/06/2024	12:53	06/06/2024	01:59	T	Tripped on distance protection
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	06/06/2024	06:32			PO	DCRM of 410 CB and Routine maintenance & Relay Testing work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/11.5KV STATION TRANSFORMER - 1 @ TIRORA	IntraState	05/06/2024	11:23	05/06/2024	19:51	PO	MCT Testing work
400/220/33 KV 315MVA ICT - 3 @ KARAD	IntraState	05/06/2024	16:35	06/06/2024	01:59	T	Tripped on differential protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220KV 500MVA ICT - 1 @ KARJAT	IntraState	06/06/2024	09:34			PO	All Isolator Alignment work (related to ICT-1 bay) to be done by Agency, Diagnostic Testing Pre Monsoon Maintenance and relay testing work.
400 KV BR Outages/Trippings							
50 MVAr BUS REACTOR - 1 @ JAIGAD	IntraState	04/06/2024	10:29			PO	CSD RELAY INTALLATION AND COMMISSIONING AT JAIGAD END
220 KV TBC Outages/Trippings							
BUS COUPLER @ PHURSUNGI	IntraState	05/06/2024	10:00	05/06/2024	13:05	PO	Replacement of Aux. switch (RPH) of CB
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220/7 KV 50 MVA STATION T/F II	IntraState	05/06/2024	04:27	05/06/2024	17:30	HT	HOT SPOT NEAR BUSHING R-Y PH
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:40	05/06/2024	00:26	T	6 Nos. Tower collapsed (Loc no 36- 41) .
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25	06/06/2024	00:45	T	TOWER COLLAPSED AT LOC.414-419.
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25	06/06/2024	00:44	T	TOWER COLLAPSED AT LOC.414-419.
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	05/06/2024	00:16	05/06/2024	06:09	PO	1) Making bunching of 220kv AKP -Nashik & 220kv NTT-Bapgaon line at Loc no. 398 for the work of 220kv GIS Substation of M/s Gigaplex (PDG)
NTT - BAPGAON	IntraState	05/06/2024	00:18	05/06/2024	06:18	PO	1) Making bunching of 220kv AKP -Nashik & 220kv NTT-Bapgaon line at Loc no. 398 for the work of 220kv GIS Substation of M/s Gigaplex (PDG).
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kv GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
WAGHIVALI - DHARAVI 7	IntraState	05/06/2024	01:42	05/06/2024	05:21	PO	¿Resagging of conductor at S G Barve Metro - 2B crossing
WAGHIVALI - DHARAVI 8	IntraState	05/06/2024	01:42	05/06/2024	05:21	PO	Project work----Resagging of conductor in span 38-39 at S G Barve Metro - 2B crossing
132 KV TSS CKT - I	IntraState	05/06/2024	02:50	05/06/2024	03:26	T	Y PH, Z1, 4.42KM
PALGHAR - NALASOPARA	IntraState	05/06/2024	04:46	05/06/2024	09:17	PO	Replacement of Insulator String Identified in PID.
AMALNER(220KV)-CHOPDA CKT - 1	IntraState	05/06/2024	06:15	05/06/2024	14:10	T	DIST PROT Z1 B PH D= 22 KM IF=3.46 KA
AMBAZARI-KALMESHWAR	IntraState	05/06/2024	07:57	05/06/2024	14:42	PO	STRINGING OF EARTHWIRE FROM LOC NO 148 - 152
BUTIBORI-BUTIBORI 3	IntraState	05/06/2024	08:12	05/06/2024	14:42	PO	FOR DIAGNOSTIC TESTING WORK.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
POPHLI PEDHMBE LINE- 1	IntraState	05/06/2024	11:00	05/06/2024	17:30	PO	For emergency tree cutting work nut bolt tightening and other line maintenance work.
POPHLI PEDHMBE LINE- 1	IntraState	05/06/2024	11:00	05/06/2024	17:30	PO	For emergency tree cutting work nut bolt tightening and other line maintenance work.
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT II	IntraState	05/06/2024	12:40	05/06/2024	14:10	PO	DAMPER REPLACEMENT AT LOC. NO. 105 R-PH & 109 R & B-PH
GIS BHANDUP - BORIVALI	IntraState	06/06/2024	00:42	06/06/2024	06:38	PO	For the installation of saver assembly sets at TL no. 23 & 26. (Total 12 sets are to be installed) Total Completed 24 sets out of 48 sets.
KHARGHAR - BORIVALI CKT - 2	IntraState	06/06/2024	00:44	06/06/2024	06:41	PO	For the installation of saver assembly sets at TL no. 23 & 26. (Total 12 sets are to be installed) Total Completed 24 sets out of 48 sets
WAGHIVALI - DHARAVI 8	IntraState	06/06/2024	01:19	06/06/2024	07:30	PO	METRO PROJECT WORK
TROMBAY - VIKHROLI (GIS) CKT - 3	IntraState	06/06/2024	01:35	06/06/2024	07:40	PO	Project Work for - Resagging of conductor in span 38-39 at S G Barve Metro - 2B crossing
PALGHAR - PANCHALI TSS	IntraState	06/06/2024	04:20	06/06/2024	08:59	PO	Replacement of Rusted Insulator strings at Loc No.06, 21 &18.
PALGHAR - NALASOPARA	IntraState	06/06/2024	04:44	06/06/2024	09:02	PO	Replacement of Insulator String Identified in PID.
TALOJA II - OCIL 1	IntraState	06/06/2024	08:08			PO	Preventive Maintenance & Testing of switchgear at OCIL end
DAHANU - VIRAJ	IntraState	06/06/2024	09:02			PO	Pre Monsoon Maintenance.
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132 KV 100 MVA ICT 2 @ BALAPUR	IntraState	05/06/2024	08:40	05/06/2024	19:39	PO	FOR RELAY TESTING AND ICT PAINTING ALONG WITH PRE-MONSOON MAINTENANCE AT 220 KV BALAPUR SUBSTATION.
220/132kV 100 MVA ICT- 2 @ PALGHAR-220 KV	IntraState	05/06/2024	09:40	05/06/2024	11:53	PO	Pre monsoon maintenance work. Covering polythene to buchholz, PRV &OSR relay.
200 MVA 220/132 KV ICT 3 @ GIRWALI	IntraState	05/06/2024	09:44	05/06/2024	10:54	PO	PREMANSOON MAINTENANCE WORK
220/100 KV 200 MVA ICT 2 @ PAL- DOMBIVALI	IntraState	05/06/2024	10:02	05/06/2024	12:32	PO	Pre-Monsoon maintenance work.
220/132 KV 200 MVA ICT 2 @ KAULEWADA	IntraState	05/06/2024	10:27	05/06/2024	16:27	PO	RELAY REPLACEMENT
220/132 KV 100 MVA ICT 2 @ PARANDA	IntraState	05/06/2024	12:19	05/06/2024	15:05	PO	FOR PRE MONSOON WORK OF ICT AND FOR PROTECTION TRAILS OF AUX RELAYS
220/100 KV 100 MVA ICT 1 @ JAMBHUL	IntraState	06/06/2024	09:13			PO	Premonsoon Maintenance Work, Plastic paper wrapping to TF Auxiliaries
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS-2 @ HINJEWADI 3(GIS)	IntraState	04/06/2024	13:02	05/06/2024	18:44	PO	Bus Extension for Bay 208 of 220kV Nextra2 Ss for project work
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
KANHAN-PENCH	IntraState	05/06/2024	10:30	05/06/2024	16:17	PO	For routine maintenance work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage