

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 05/Jul/2018 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                 |
|---------------------|----------------|-----------------|--------------------------------|----------------|-----------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly         |
| 1) Thermal          | 112.877        | 555.936         | 1) Gujrat                      | -4.875         | -14.264         |
| 2) Hydro            | 5.221          | 19.096          | 2) Madhya Pradesh              | 12.186         | 74.052          |
| 3) Gas              | 8.694          | 44.447          | 3) Chattisgarh                 | 5.510          | 29.500          |
| <b>Total MSPGCL</b> | <b>126.792</b> | <b>619.479</b>  | 4) Maharashtra                 | 98.429         | 484.519         |
| B) 1) APLM          | 55.524         | 296.455         | 5) Goa (Amona)                 | -0.418         | -2.134          |
| 2) JSWEL            | 14.643         | 82.567          | <b>Total</b>                   | <b>110.832</b> | <b>571.673</b>  |
| 3) VIPL             | 6.363          | 31.137          | a) Mumbai Schedule             | 24.991         | 109.181         |
| 4) RPL(AMT)         | 10.225         | 52.381          | b) Mumbai Drawl                | 33.021         | 145.687         |
| 5) SWPGPL           | 2.610          | 12.472          | c) MSEDCL Bilateral *          | 12.235         | 120.177         |
| 6) Other IPP        | 5.965          | 29.427          | Include PX                     | -10.105        | -12.178         |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 24.991         | 109.181         |
| C) 1) TPCL Thermal  | 5.267          | 36.527          | Include PX                     | 7.737          | 34.638          |
| 2) TPCL Hydro       | 6.792          | 29.323          | Standby                        | 0.000          | 0.000           |
| 3) TPCL Gas         | 4.074          | 19.210          | <b>H) ENERGY CATERED (MUs)</b> |                |                 |
| 4) AEML Thermal     | 10.937         | 53.947          | 1) MSEDCL                      | 351.418        | 1792.248        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 60.091         | 284.693         |
| 1) Thermal          | 224.411        | 1150.849        | 3) Other Discoms               |                |                 |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>411.509</b> | <b>2076.941</b> |
| 2) Hydro            | 12.013         | 48.419          |                                |                |                 |
| (A2+C2)             |                |                 |                                |                |                 |
| 3) Gas              | 12.768         | 63.657          |                                |                |                 |
| (A3+B7+C3)          |                |                 |                                |                |                 |
| 4) Wind             | 48.060         | 219.079         |                                |                |                 |
| 6) SOLAR            | 3.425          | 23.265          |                                |                |                 |
| <b>TOTAL STATE</b>  | <b>300.677</b> | <b>1505.269</b> |                                |                |                 |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 4931                      | 4771                  | 5136                      | 4298                      |
| MSPGCL Hydro               | 256                       | 82                    | 354                       | 79                        |
| MSPGCL Gas                 | 365                       | 353                   | 363                       | 360                       |
| MSPGCL Total Generation    | 5552                      | 5206                  | 5853                      | 4737                      |
| Central Sector Receipt     | 4811                      | 4716                  | 4302                      | 4154                      |
| WIND                       | 2168                      | 2428                  | 1740                      | 1816                      |
| CPP / IPP Thermal          | 4295                      | 4182                  | 4314                      | 3621                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 447                       | 513                   | 1                         | 0                         |
| Exchange with Mumbai       | -1784                     | -1765                 | -1478                     | -946                      |
| <b>MSEDCL DEMAND MET</b>   | <b>15489</b>              | <b>15280</b>          | <b>14732</b>              | <b>13382</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 15489                     | 15280                 | 14732                     | 13382                     |
| TPCL GENERATION            | 847                       | 829                   | 820                       | 406                       |
| AEML GENERATION            | 502                       | 501                   | 502                       | 376                       |
| <b>MUMBAI DEMAND</b>       | <b>3133</b>               | <b>3095</b>           | <b>2800</b>               | <b>1728</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>0</b>                  | <b>0</b>              | <b>0</b>                  | <b>0</b>                  |
| STATE DEMAND MET           | 18622                     | 18375                 | 17532                     | 15110                     |
| <b>STATE DEMAND</b>        | <b>18622</b>              | <b>18375</b>          | <b>17532</b>              | <b>15110</b>              |
| Frequency (Hz)             | 50.03                     | 49.97                 | 49.92                     | 49.98                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.16 Hz at 16.00 Hrs | 49.76 Hz at 20.19 Hrs | 49.96         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 05/Jul/2018

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 0.00         | 0.00          | 0        | 0        |
| Unit 9             | 9.61         | 44.44         | 468      | 332      |
| Unit 10            | 9.72         | 43.38         | 451      | 322      |
| <b>Total</b>       | <b>19.34</b> | <b>87.82</b>  |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 9.52         | 46.90         | 475      | 355      |
| Unit 5             | 9.43         | 46.36         | 485      | 350      |
| <b>Total</b>       | <b>18.95</b> | <b>93.26</b>  |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 3.13         | 21.07         | 196      | 0        |
| <b>Total</b>       | <b>3.13</b>  | <b>21.07</b>  |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 10.08        | 46.82         | 450      | 365      |
| Unit 6             | 9.71         | 50.34         | 430      | 370      |
| Unit 7             | 9.68         | 49.15         | 446      | 358      |
| Unit 8             | 10.79        | 52.01         | 490      | 360      |
| Unit 9             | 0.00         | 4.95          | 0        | 0        |
| <b>Total</b>       | <b>40.26</b> | <b>203.27</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 4.51         | 21.59         | 210      | 161      |
| Unit 4             | 4.53         | 19.38         | 213      | 170      |
| <b>Total</b>       | <b>9.03</b>  | <b>40.97</b>  |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 3.36         | 16.20         | 150      | 110      |
| Unit 2             | 3.60         | 17.88         | 150      | 150      |
| Unit 3             | 3.83         | 18.81         | 165      | 155      |
| Unit 4             | 3.71         | 18.37         | 160      | 148      |
| Unit 5             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>14.50</b> | <b>71.25</b>  |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 3.81         | 19.19         | 168      | 152      |
| Unit 4             | 0.00         | 0.00          | 0        | 0        |
| Unit 5             | 3.86         | 19.10         | 166      | 154      |
| <b>Total</b>       | <b>7.67</b>  | <b>38.29</b>  |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 8.69         | 44.45         | 387      | 350      |
| <b>Total</b>       | <b>8.69</b>  | <b>44.45</b>  |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.04         | 0.35          | 21       | 0        |
| <b>Total</b>       | <b>0.04</b>  | <b>0.35</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation   |               |          |          |
|-----------------|--------------|---------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| Stage 1-2       | 2.14         | 8.49          | 370      | 40       |
| Stage 4         | 0.08         | 0.08          | 58       | 0        |
| Stage 3         | 1.35         | 4.79          | 210      | 0        |
| <b>Total</b>    | <b>3.58</b>  | <b>13.36</b>  |          |          |
| <b>Hydro</b>    |              |               |          |          |
| KDPH            | 0.00         | 0.00          | 0        | 0        |
| VTRNA           | 0.32         | 0.32          | 59       | 0        |
| TILLARI         | 0.00         | 0.00          | 0        | 0        |
| BHIRA T.R.      | 0.48         | 1.86          | 80       | 0        |
| SMLHY_PTN       | 0.11         | 0.42          | 13       | 2        |
| GHATGHAR        | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>    | <b>0.92</b>  | <b>2.61</b>   |          |          |
| <b>Wind</b>     |              |               |          |          |
| Total           | 48.06        | 219.08        | 0        | 0        |
| <b>Total</b>    | <b>48.06</b> | <b>219.08</b> |          |          |
| <b>CPP</b>      |              |               |          |          |
| APML(Mus)       | 55.52        | 296.46        | 0        | 0        |
| JSWEL(Mus)      | 14.64        | 82.57         | 0        | 0        |
| VIPL(Mus)       | 6.36         | 31.14         | 0        | 0        |
| RPLAMT(Mus)     | 10.22        | 52.38         | 0        | 0        |
| WPCL(Mus)       | 2.61         | 12.47         | 0        | 0        |
| Other(Mus)      | 5.96         | 29.43         | 0        | 0        |
| <b>Total</b>    | <b>95.33</b> | <b>504.44</b> |          |          |
| <b>SOLAR</b>    |              |               |          |          |
| Total           | 3.42         | 23.26         | 0        | 0        |
| <b>Total</b>    | <b>3.42</b>  | <b>23.26</b>  |          |          |
| <b>Tata</b>     |              |               |          |          |
| Trombay 5       | 0.00         | 9.51          | 0        | 0        |
| Trombay 6       | 0.00         | 0.00          | 0        | 0        |
| Trombay 7A      | 2.55         | 11.93         | 114      | 102      |
| Trombay 7B      | 1.52         | 7.28          | 66       | 62       |
| TATA Hydro      | 6.79         | 29.32         | 459      | 10       |
| Trombay 8       | 5.27         | 27.02         | 229      | 215      |
| <b>Total</b>    | <b>16.13</b> | <b>85.06</b>  |          |          |
| <b>R-INFRA</b>  |              |               |          |          |
| DTPS U-1&2      | 10.94        | 53.95         | 504      | 375      |
| <b>Total</b>    | <b>10.94</b> | <b>53.95</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 112.88      | 555.94        | MSPGCL Total        | 126.79      | 619.48        |
|                |             |         | MSPGCL Thml+Gas | 121.57      | 600.38        | Koyna 1,2 & 4 Total | 2.22        | 8.57          |
|                |             |         | MSPGCL Hydro    | 5.22        | 19.10         | State Total         | 300.68      | 1505.27       |

# State Load Despatch Center,Airoli (MSETCL)

## Hourly Load Data As on 05/Jul/2018

### Annexure-2

| TIME SR. NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS SHARE | CS RECPT | Mum. NET EXCH. | MSEDC L DEM. MET | LOAD SHED DING | MSEDC L DEM. WITH LS | MUMBAI DEMAN D | OTHER DISCOM DEMAN D | STATE DEMAND | FREQ. (Hz) |
|--------------|-------------|------|------|--------|-------|-----------|------|-------|----------|----------|----------------|------------------|----------------|----------------------|----------------|----------------------|--------------|------------|
|              | THM         | HY   | GAS  |        |       | THM       | GAS  |       |          |          |                |                  |                |                      |                |                      |              |            |
| 1            | 4466        | 92   | 366  | 4924   | 2130  | 3808      | 0    | 0     | 3660     | 3737     | -1040          | 13559            | 0              | 13559                | 2003           |                      | 15562        | 49.97      |
| 2            | 4379        | 79   | 387  | 4845   | 2078  | 3731      | 0    | 0     | 3639     | 4022     | -1016          | 13660            | 0              | 13660                | 1822           |                      | 15482        | 49.98      |
| 3            | 4341        | 74   | 362  | 4777   | 1946  | 3644      | 0    | 0     | 4157     | 4069     | -953           | 13483            | 0              | 13483                | 1749           |                      | 15232        | 49.96      |
| 4            | 4298        | 79   | 360  | 4737   | 1816  | 3621      | 0    | 0     | 4024     | 4154     | -946           | 13382            | 0              | 13382                | 1728           |                      | 15110        | 49.98      |
| 5            | 4326        | 94   | 368  | 4788   | 1708  | 3640      | 0    | 0     | 4375     | 4455     | -946           | 13645            | 0              | 13645                | 1727           |                      | 15372        | 49.93      |
| 6            | 4592        | 109  | 369  | 5070   | 1748  | 3831      | 0    | 0     | 4807     | 5106     | -1007          | 14748            | 0              | 14748                | 1788           |                      | 16536        | 49.92      |
| 7            | 4761        | 484  | 356  | 5601   | 1597  | 4083      | 0    | 20    | 5239     | 5834     | -1088          | 16047            | 0              | 16047                | 1895           |                      | 17942        | 49.93      |
| 8            | 4749        | 409  | 369  | 5527   | 1562  | 4162      | 0    | 103   | 5548     | 5682     | -1203          | 15833            | 0              | 15833                | 2185           |                      | 18018        | 50.01      |
| 9            | 4751        | 282  | 360  | 5393   | 1719  | 4137      | 0    | 208   | 5718     | 5814     | -1502          | 15769            | 0              | 15769                | 2504           |                      | 18273        | 49.99      |
| 10           | 4682        | 248  | 365  | 5295   | 1724  | 4078      | 0    | 282   | 5109     | 5669     | -1629          | 15419            | 0              | 15419                | 2836           |                      | 18255        | 49.93      |
| 11           | 4905        | 482  | 357  | 5744   | 1951  | 4138      | 0    | 340   | 4793     | 5070     | -1737          | 15506            | 0              | 15506                | 3076           |                      | 18582        | 50.02      |
| 12           | 4931        | 256  | 365  | 5552   | 2168  | 4295      | 0    | 447   | 5193     | 4811     | -1784          | 15489            | 0              | 15489                | 3133           |                      | 18622        | 50.03      |
| 13           | 4771        | 82   | 353  | 5206   | 2428  | 4182      | 0    | 513   | 5090     | 4716     | -1765          | 15280            | 0              | 15280                | 3095           |                      | 18375        | 49.97      |
| 14           | 4680        | 88   | 362  | 5130   | 2534  | 3885      | 0    | 472   | 4869     | 4699     | -1652          | 15068            | 0              | 15068                | 2978           |                      | 18046        | 50.04      |
| 15           | 4482        | 91   | 351  | 4924   | 2605  | 3855      | 0    | 402   | 4714     | 4843     | -1683          | 14946            | 0              | 14946                | 2990           |                      | 17936        | 49.96      |
| 16           | 4678        | 130  | 362  | 5170   | 2671  | 3771      | 0    | 284   | 4693     | 4589     | -1706          | 14779            | 0              | 14779                | 2998           |                      | 17777        | 49.99      |
| 17           | 4531        | 150  | 350  | 5031   | 2843  | 3757      | 0    | 200   | 4315     | 4276     | -1659          | 14448            | 0              | 14448                | 2965           |                      | 17413        | 49.91      |
| 18           | 4558        | 276  | 361  | 5195   | 2593  | 3745      | 0    | 125   | 4127     | 4204     | -1588          | 14274            | 0              | 14274                | 2917           |                      | 17191        | 49.93      |
| 19           | 4877        | 291  | 358  | 5526   | 2253  | 3986      | 0    | 28    | 4177     | 4130     | -1542          | 14381            | 0              | 14381                | 2835           |                      | 17216        | 50.02      |
| 20           | 5136        | 354  | 363  | 5853   | 1740  | 4314      | 0    | 1     | 4503     | 4302     | -1478          | 14732            | 0              | 14732                | 2800           |                      | 17532        | 49.92      |
| 21           | 5137        | 272  | 364  | 5773   | 1796  | 4279      | 0    | 0     | 4447     | 4272     | -1355          | 14765            | 0              | 14765                | 2691           |                      | 17456        | 49.87      |
| 22           | 5120        | 180  | 355  | 5655   | 1680  | 4205      | 0    | 0     | 3846     | 4157     | -1312          | 14385            | 0              | 14385                | 2648           |                      | 17033        | 49.91      |
| 23           | 4885        | 292  | 354  | 5531   | 1361  | 4114      | 0    | 0     | 3690     | 4189     | -1259          | 13936            | 0              | 13936                | 2455           |                      | 16391        | 49.88      |
| 24           | 4841        | 327  | 377  | 5545   | 1409  | 4069      | 0    | 0     | 3740     | 4032     | -1171          | 13884            | 0              | 13884                | 2273           |                      | 16157        | 49.90      |
| MUs          | 112.88      | 5.22 | 8.69 | 126.79 | 48.06 | 95.33     | 0.00 | 3.42  | 108.47   | 110.83   | -33.02         | 351.42           | 0.00           | 351.42               | 60.09          |                      | 411.51       | 49.96      |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/Jul/2018**

**Position as on 6.30 Hrs of 06/Jul/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                           | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                            |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |            | Continued. | EE R&M LE Work                                                             |               |
| MSPGCL                | Koyna STG-IV Unit-4     | 250      | 12/06/2018   | 09.40        |            | Continued. | Annual Overhaul                                                            |               |
| MSPGCL                | Khaparkhedha Unit 5     | 500      | 20/06/2018   | 05.14        |            | Continued. | Annual Overhaul                                                            |               |
| MSPGCL                | Parli Unit 6            | 250      | 24/06/2018   | 18.02        |            | Continued. | Zero Schedule(Converted for Capital overhaul from 00.00Hrs Dt. 23/07/2018) |               |
| MSPGCL                | Koradi Unit 8           | 660      | 29/06/2018   | 13.27        |            | Continued. | Converted to APH from 19/07/2018                                           |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 01/07/2018   | 11.35        |            | Continued. | Annual Overhaul                                                            |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                            |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                                                          |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                    | 25/06/2022    |
| IPP                   | SWPGPL U-2              | 135      | 29/02/2016   | 21.46        |            | Continued. | No PPA                                                                     |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                          |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                                                          |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                       |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                       |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 03/12/2017   | 01.35        |            | Continued. | Water Shortage                                                             |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 03/12/2017   | 14.17        |            | Continued. | Water Shortage                                                             |               |
| MSPGCL                | Ghatghar Unit-1         | 125      | 14/04/2018   | 23.45        |            | Continued. | Stator Earth Fault                                                         |               |
| IPP                   | RPL(AMT) U-1            | 270      | 01/05/2018   | 00.00        |            | Continued. | Coal Shortage( Zero schedule on 30.06.2018)                                |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/05/2018   | 18.46        |            | Continued. | Coal Swapping IEPL                                                         |               |
| MSPGCL                | Nasik Unit 4            | 210      | 01/06/2018   | 00.53        |            | Continued. | Dhariwal Inter Change                                                      |               |
| MSPGCL                | Uran Unit 6             | 108      | 09/06/2018   | 11.50        |            | Continued. | GT winding short.                                                          |               |
| IPP                   | SWPGPL U-4              | 135      | 10/06/2018   | 00.01        |            | Continued. | Maintenance work                                                           |               |
| IPP                   | VIPL U-1                | 300      | 11/06/2018   | 00.30        |            | Continued. | Coal Shortage                                                              |               |
| MSPGCL                | Koradi Unit 7           | 210      | 11/06/2018   | 22.10        |            | Continued. | Coal Shortage                                                              |               |
| MSPGCL                | Parli Unit 7            | 250      | 17/06/2018   | 08.32        |            | Continued. | ZERO SCHEDULE                                                              |               |
| IPP                   | RPL(AMT) U-4            | 270      | 22/06/2018   | 17.31        |            | Continued. | Bottom Ash Problem.                                                        |               |
| IPP                   | RPL(AMT) U-3            | 270      | 26/06/2018   | 00.01        |            | Continued. | Zero Schedule                                                              |               |
| IPP                   | IEPL Unit 1             | 270      | 26/06/2018   | 13.00        |            | Continued. | Poor Coal Receipt                                                          |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01.12        |            | Continued. | Stator Earth Fault                                                         |               |
| MSPGCL                | Ghatghar Unit-2         | 125      | 29/06/2018   | 01:12        |            | Continued. | Stator Earth Fault                                                         |               |
| IPP                   | Dhariwal                | 300      | 03/07/2018   | 00.00        | 05/07/2018 | 10.45      | to attend defect of turbine governing & seal oil system.                   |               |
| TPC-G                 | Trombay 5               | 500      | 03/07/2018   | 00.31        |            | Continued. | to attend east side bunker gallery junction tower 5 cross bracing.         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 05/Jul/2018**

**Position as on 6.30 Hrs of 06/Jul/2018**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage               | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|--------------------------------|---------------|
| IPP                | JSW (J) U4              | 300      | 03/07/2018   | 18.23        | 05/07/2018 | 19.37      | Condenser cleaning work.       |               |
| IPP                | Adani U-5               | 660      | 04/07/2018   | 14:52        |            | Continued. | Turbine side MS Drain leakage. |               |
| IPP                | JSW (J) U2              | 300      | 05/07/2018   | 06.44        |            | Continued. | Generator Elect. Fault         |               |
| MSPGCL             | Parli Unit 8            | 250      | 05/07/2018   | 15.37        | 05/07/2018 | 17.52      | HAND TRIPPED FOR TESTING WORK. |               |
| IPP                | RPL(AMT) U-5            | 270      | 06/07/2018   | 07.18        | 06/07/2018 | 09.10      | Auxiliary Problem              |               |

