

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 05/Jul/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	139.251	644.790	1) Gujrat	1.575	16.142
2) Hydro	4.870	35.348	2) Madhya Pradesh	5.154	15.871
3) Gas	6.543	33.210	3) Chattisgarh	1.520	9.000
Total MSPGCL	150.664	713.348	4) Maharashtra	152.955	745.172
B) 1) APLM	58.031	283.143	5) Goa (Amona)	-2.006	-10.188
2) JSWEL	19.190	97.398	Total	159.198	775.997
3) VIPL	0.000	0.000	a) Mumbai Schedule	41.993	210.209
4) RPL(AMT)	24.128	123.303	b) Mumbai Drawl	44.688	222.230
5) SWPGPL	11.896	58.803	c) MSEDCL Bilateral *	98.443	500.943
6) Other IPP	11.802	60.077	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	41.993	210.209
C) 1) TPCL Thermal	11.635	60.854	Include PX	0.000	0.000
2) TPCL Hydro	5.327	24.756	Standby	0.000	0.000
3) TPCL Gas	3.576	19.264	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.940	49.416	1) MSEDCL	446.510	2187.165
D) STATE			2) Mumbai Discoms	75.166	376.518
1) Thermal	285.873	1377.784	3) Other Discoms	11.419	56.642
(A1+C1+C4+(B1-B6))			TOTAL STATE	533.095	2620.325
2) Hydro	10.197	60.104			
(A2+C2)					
3) Gas	10.119	52.474			
(A3+B7+C3)					
4) Wind	52.484	281.634			
6) SOLAR	15.224	72.334			
TOTAL STATE	373.897	1844.330			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5255	4796	6328	6090
MSPGCL Hydro	171	104	490	144
MSPGCL Gas	274	271	273	273
MSPGCL Total Generation	5700	5171	7091	6507
Central Sector Receipt	7848	7417	6711	5949
WIND	2491	2648	2244	1845
CPP / IPP Thermal	4622	4603	6062	4843
CPP / IPP Gas	0	0	0	0
SOLAR	1681	1455	0	0
Exchange with Mumbai	-2518	-2456	-1820	-1293
MSEDCL DEMAND MET	19326	18342	19770	17466
Load Shedding	0	0	0	0
MSEDCL DEMAND	19326	18342	19770	17466
TPCL GENERATION	753	776	1080	705
AEML GENERATION	364	301	413	454
MUMBAI DEMAND	3635	3533	3313	2452
OTHER DISCOM DEMAND	498	496	518	385
STATE DEMAND MET	23459	22371	23601	20303
STATE DEMAND	23459	22371	23601	20303
Frequency (Hz)	49.99	49.88	50.01	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13.06 Hrs	49.69 Hz at 05.24 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 05/Jul/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.09	18.87	185	134
Unit 8	12.18	58.66	585	367
Unit 9	12.33	58.46	588	371
Unit 10	11.51	11.69	560	233
Total	40.11	147.68		
Bhusawal				
Unit 3	3.36	16.44	175	130
Unit 4	0.00	0.00	0	0
Unit 5	10.31	48.45	495	301
Total	13.68	64.89		
Parli				
Unit 6	3.89	19.63	231	142
Unit 7	3.87	19.50	227	140
Unit 8	3.70	19.20	192	143
Total	11.46	58.33		
Chandrapur				
Unit 3	3.32	7.59	156	125
Unit 4	3.40	16.46	158	130
Unit 5	6.85	38.52	405	0
Unit 6	7.92	37.90	403	275
Unit 7	0.00	22.01	0	0
Unit 8	8.50	43.41	410	280
Unit 9	10.14	46.87	500	278
Total	40.12	212.77		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	5.07	24.10	250	147
Total	5.07	24.10		
Khaparkheda				
Unit 1	2.96	13.38	150	100
Unit 2	4.09	18.06	202	118
Unit 3	3.78	17.75	176	129
Unit 4	0.50	2.78	147	0
Unit 5	10.39	50.90	490	290
Total	21.72	102.86		
Nasik				
Unit 3	3.46	14.81	174	125
Unit 4	3.64	17.28	183	127
Unit 5	0.00	2.06	0	0
Total	7.09	34.16		
Uran				
All Units	6.54	33.21	276	267
Total	6.54	33.21		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	1.19	7.82	230	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	6.96	0	0
Stage 3	0.56	4.61	160	0
Total	1.75	19.38		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.76	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.38	1.72	67	0
SMLHY_PTN	2.49	12.22	107	98
GHATGHAR	0.24	1.27	125	0
Total	3.12	15.97		
Wind				
Total	52.48	281.63	0	0
Total	52.48	281.63		
CPP				
APML(Mus)	58.03	283.14	0	0
JSWEL(Mus)	19.19	97.40	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.13	123.30	0	0
SWPGPL-Mus	11.90	58.80	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.02	26.07	265	104
Other(Mus)	2.13	9.93	0	0
JPL	4.65	24.08	270	170
Total	125.05	622.72		
SOLAR				
Total	15.22	72.33	0	0
Total	15.22	72.33		
Tata				
Trombay 5	7.72	39.58	422	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.18	11.93	108	56
Trombay 7B	1.40	7.33	64	47
TATA Hydro	5.33	24.76	418	75
Trombay 8	3.92	21.27	230	132
Total	20.54	104.87		
AEML				
DTPS U-1&2	9.94	49.42	499	301
Total	9.94	49.42		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	139.25	644.79	MSPGCL Total	150.66	713.35
			MSPGCL Thml+Gas	145.79	678.00	Koyna 1,2 & 4 Total	1.19	14.77
			MSPGCL Hydro	4.87	35.35	State Total	373.90	1844.33

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 05/Jul/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5898	148	272	6318	1780	6070	0	0	6237	5785	-1409	18103	0	0	18103	3057	441	21601	49.99
2	6023	145	272	6440	1801	5591	0	0	6217	5604	-1317	17705	0	0	17705	2768	414	20887	50.02
3	6079	160	273	6512	1852	5158	0	0	6197	5524	-1226	17443	0	0	17443	2513	377	20333	49.98
4	6090	144	273	6507	1845	4843	0	0	6095	5949	-1293	17466	0	0	17466	2452	385	20303	49.97
5	6234	142	275	6651	1885	5002	0	0	5975	5792	-1248	17695	0	0	17695	2423	387	20505	49.94
6	6516	335	273	7124	1937	5644	0	0	6162	5882	-1254	18898	0	0	18898	2465	435	21798	49.85
7	6585	332	275	7192	1858	6031	0	138	6465	6268	-1324	19696	0	0	19696	2569	467	22732	49.91
8	6244	189	276	6709	1918	5873	0	534	6858	6911	-1608	19849	0	0	19849	2773	488	23110	49.98
9	6120	145	267	6532	2062	5557	0	991	7173	6839	-1967	19512	0	0	19512	3099	502	23113	50.02
10	5734	160	274	6168	2279	4963	0	1476	7594	7429	-2322	19471	0	0	19471	3413	522	23406	49.97
11	5255	171	274	5700	2491	4622	0	1681	8000	7848	-2518	19326	0	0	19326	3635	498	23459	49.99
12	4756	106	268	5130	2450	4329	0	1859	8182	7972	-2604	18640	0	0	18640	3702	496	22838	49.96
13	4652	102	271	5025	2634	4061	0	1890	8062	7461	-2617	17975	0	0	17975	3637	479	22091	50.02
14	4590	103	272	4965	2619	4025	0	1898	7424	7098	-2445	17685	0	0	17685	3504	475	21664	50.05
15	4646	98	270	5014	2355	4165	0	1850	7940	7545	-2471	17985	0	0	17985	3525	473	21983	49.93
16	4796	104	271	5171	2648	4603	0	1455	7695	7417	-2456	18342	0	0	18342	3533	496	22371	49.88
17	5653	104	270	6027	2704	4689	0	920	7206	6728	-2290	18279	0	0	18279	3513	499	22291	50.02
18	5847	148	273	6268	2569	4711	0	466	7338	6743	-2095	18136	0	0	18136	3456	526	22118	50.06
19	6078	284	274	6636	2541	5039	0	66	7115	7145	-1969	18916	0	0	18916	3373	542	22831	50.05
20	6328	490	273	7091	2244	6062	0	0	6836	6711	-1820	19770	0	0	19770	3313	518	23601	50.01
21	6442	538	272	7252	2060	6245	0	0	6700	6051	-1615	19478	0	0	19478	3199	515	23192	49.92
22	6261	282	274	6817	2075	5908	0	0	6473	6143	-1605	18831	0	0	18831	3122	507	22460	50.02
23	6255	269	275	6799	1939	6076	0	0	6386	6025	-1581	18763	0	0	18763	3077	495	22335	50.05
24	6169	171	276	6616	1938	5780	0	0	6416	6328	-1634	18546	0	0	18546	3045	482	22073	50.06
MUs	139.25	4.87	6.54	150.66	52.48	125.05	0.00	15.22	166.75	159.20	-44.69	446.51	0.00	0.00	446.51	75.17	11.42	533.09	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jul/2024

Position as on 6.30 Hrs of 06/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 2	70	15/06/2024	07:10		Continued.	Govrner renovation	10/07/2024
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	06/07/2024
MSPGCL	Paras Unit 3	250	30/06/2024	22:35		Continued.	Annual Overhaul	14/08/2024
MSPGCL	Khaparkheda Unit 4	210	01/07/2024	17:16	05/07/2024	18:53	Boiler Steaming Validity Extension.	05/07/2024
MSPGCL	Koyna Unit 5	80	02/07/2024	11:00		Continued.	Governer Replacement.	27/07/2024
Total Capacity MSPGCL		1110						
IPP								
IPP	RPL(AMT) U-1	270	01/07/2024	07:00		Continued.	Annual Overhaul	01/08/2024
Total Capacity IPP		270						
Total Capacity PLANNED OUTAGE		1380						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Chandrapur Unit 7	500	03/07/2024	20:35	06/07/2024	02:05	GTR Y PHASE OIL FILTRATION WORK	06/07/2024
MSPGCL	Chandrapur Unit 5	500	05/07/2024	15:34	05/07/2024	18:03	Derrator Level Low	05/07/2024
MSPGCL	Chandrapur Unit 7	500	06/07/2024	02:09	06/07/2024	04:26	Turbine control valve hunting	
Total Capacity MSPGCL		1745						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2065						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	17/06/2024	21:44		Continued.	Zero Schedule given by MSEDCL	
MSPGCL	Uran Unit 6	108	04/07/2024	23:59		Continued.	No Schedule by MSEDCL.	
Total Capacity MSPGCL		216						
IPP								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 05/Jul/2024

Position as on 6.30 Hrs of 06/Jul/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JSW (J) U2	300	01/07/2024	01:12		Continued.	Non availability of load schedule	
Total Capacity IPP		300						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		516						
UNIT OUT ON TOLLING *								
MSPGCL								
MSPGCL	Nasik Unit 5	210	01/07/2024	16:56		Continued.	In Case IV Tolling.	
Total Capacity MSPGCL		210						
Total Capacity UNIT OUT ON TOLLING *		210						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Trippings							
TIE BAY (702) OF 765/21KV GT-4 and 765/400KV ICT (HV Side) @ TIRORA	IntraState	05/07/2024	09:44	05/07/2024	18:31	PO	Bay equipment maintenance work
765 KV LINE Outages/Trippings							
SOLAPUR (PG) - PUNE (GIS)	InterState	05/07/2024	08:10	05/07/2024	22:16	PO	due to Sant Tukaram Palkhi (Procession)-2024
400 KV EKTUNI - BABHLESHWAR CKT- 2	InterState	05/07/2024	13:01	05/07/2024	19:16	PO	Routine Maintenance work and diagnostic testing work.
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	05/07/2024	09:10	05/07/2024	21:06	T	Tripped on Y ph to earth fault
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	23/06/2024	19:11			HT	H/T For load Management.
KALWA - KHARGHAR	IntraState	04/07/2024	23:52	05/07/2024	01:21	EO	(1)To attend hotspot at Y phase Wavetrap of 400 KV Kharghar Klawe line at Kharghar end.
NAGOTHANE - DABHOL CKT - 2	IntraState	05/07/2024	16:07	05/07/2024	23:25	HT	Line handtripped for isolatator alignment work at dabhol end.
LONIKAND - JEJURI CKT - 1	IntraState	05/07/2024	21:02	05/07/2024	23:07	PO	Important work of making preparation for retrofitting of distance protection relay which is scheduled on 18.07.2024
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/06/2024	00:07			HT	H/T LV side only.
400/11kv STN-4A @ DEEPNAGAR	IntraState	26/06/2024	11:13			PO	For E/M for checking, cleaning and oil filtration work at MSPGCL End.
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	05/07/2024	08:37	05/07/2024	19:27	PO	Retrofitting of old Sifang CSC 211 HV & LV Backup protection relay by New Siemens make 7SJ6621
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	05/07/2024	16:32	05/07/2024	19:10	EO	For replacement of B Ph CT Jumper P1 Side due to broken conductor strand
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	06/07/2024	07:28			PO	Normalcy Restoration of RRS Scheme for ICT I
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	06/07/2024	07:28			PO	Normalcy Restoration of RRS Scheme for ICT I & Test Charge of RRS Scheme of ICT 2
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
TOPWORTH - KHANDESHWAR	IntraState	15/06/2024	14:24			PO	Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel
PANVEL TSS - KHANDESHWAR	IntraState	15/06/2024	14:30			PO	Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
KARAD - KADEGAON	IntraState	02/07/2024	09:09	05/07/2024	17:08	PO	For Relay Retrofitting & Relay rewring work.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	02/07/2024	14:56			HT	For controlling loading of Kharghar - Talegaon PG.
GHATGHAR - BAPGAON	IntraState	04/07/2024	06:36			PO	For height raising & shifting of line on 05 nos. Monopoles in b/w existing loc. No. 330-333 due to infringement of Vadodara-Mumbai Expressway SPUR.
MAHAPE - TFIPL	IntraState	04/07/2024	10:07			PO	Retrofitting of relays at both location TFIPL & Mahape and charging for the work of newly proposed 220kV GIS S/stn of M/s STT Data Centre.
CENTURI ENKA- BHOSARI	IntraState	04/07/2024	10:57	05/07/2024	16:05	EO	220kV Cenka bay old Auxillary isolator RCC structure dismetalled on dtd 27.06.2024 . Line Bay not having Aux Isoaltor since 27.6.2024. now outage is required for new Auxillary Bus Isolator Erection Work by BNC power .
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	05/07/2024	02:06	05/07/2024	04:19	T	Tripped on distance protection.
220 KV KHADKA (400 KV) -BHADLI TSS CKT-2	IntraState	05/07/2024	09:05	05/07/2024	11:51	PO	FOR REPLACEMENT OF FLASHOVER STRING OF R-PH AT LOC NO. 21

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 05/Jul/2024

Statement-VII

Position as on 6.30 Hrs of 06/Jul/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 KV JALNA - THAPTITANDA CKT - I	IntraState	05/07/2024	10:18	05/07/2024	16:20	PO	FLASHOVER STRINGS REPLACEMENT FOUND IN MONKEY PATROLLING LOC 192R-PHASE,197R-PHASE
NEW KOYNA - NIWALI	IntraState	05/07/2024	11:12	05/07/2024	18:15	PO	Backup relay replacement & CT ratio changing work at 220kV Niwali s/s.
BHUGAON - WARDHA (PG)	IntraState	05/07/2024	11:35	05/07/2024	17:02	EO	FOR CHECKING & TESTING OF B-PH LMU & ITS COUPLING CAPACITOR,
BHUGAON - WARDHA (PG)	IntraState	05/07/2024	11:35	05/07/2024	17:02	EO	For checking & testing of B-ph LMU & its coupling capacitor, as LA inside the LMU is observed to be burnt & melted condition
ADLABS - PEDAMBE	IntraState	05/07/2024	23:24			T	Distance Protection
URAN - ULWE GIS CKT - 2	IntraState	06/07/2024	08:10			EO	"Attending Hot Spot(114 deg C) at B-ph Cable Bushing
POPHLI PEDHMBE LINE- 1	IntraState	06/07/2024	08:20			PO	R Phase CT to transfer bus isolator & CT to line side isolator conductor strand broken. same conductor needs to be replace.
SALSETTE - VIKHROLI (GIS) CKT - 3	IntraState	06/07/2024	09:07			PO	Defective polymer insulator replacement at Loc.72 and 73
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	21/06/2024	12:50			PO	Augmentation of 100 MVA ICT-02 with 200 MVA ICT
220/100 KV 100 MVA ICT 2 @ TAMBATI	IntraState	05/07/2024	11:01	05/07/2024	20:00	PO	1) Retrofitting of Num. Differential protection relay by PAC Dn. Panvel. 2) Diagnostic testing woks. 3) Bay maintenance works.
220/132 KV 200 MVA ICT 1	IntraState	05/07/2024	21:15			T	DIFF OPTD B PH
132 KV LINE Outages/Trippings							
NARAYANGAON-VIGHANHAR	IntraState	02/07/2024	16:17			HT	For controlling loading of Kharghar - Talegaon PG.
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 1	IntraState	08/04/2024	12:31		Continued.	EO	Bird nest removal AT LOC 63 and 64
WAGHIVALI - MANKHURD	IntraState	05/07/2024	10:26	05/07/2024	11:27	PO	BIRD NEST REMOVAL
KARANJADE - BHOKARPADA	IntraState	05/07/2024	15:37	05/07/2024	16:14	PO	BIRD NEST REMOVAL
KHOPOLI - KARANJADE	IntraState	05/07/2024	16:23	05/07/2024	16:53	PO	BIRD NEST REMOVAL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage